



ROTOR CONTACT	LIMIT SWITCH CONTACT DEVELOPMENT				FUNCTION	REFERENCE
	VALVE POSITION					
	FULLY OPEN	A	B	FULLY CLOSED		
1					BYPASS	
2					SPARE	
3					GREEN LT	THIS DWG
4					OPEN LIMIT	
5					BYPASS	
6					SPARE	
7					SIGNAL ISOLATE	E-11GE SH 4
8					SPARE	
9					SPARE	
10					SPARE	
11					SPARE	
12					SPARE	
13					SPARE	
14					SPARE	
15					RED LT	THIS CKT
16					SPARE	

- NOTES
1. ALL EQUIPMENT LOCATED AT RESPECTIVE MCC EXCEPT AS NOTED
 2. APPLICABLE LOGIC DIAGRAM LSK-26-4
 3. CIRCUIT NO. TO PRECEDE WIRE NO.
 4. TORQUE SWITCHES TQS-O & TQS-C STOP MOTOR IF MECHANICAL OVERLOAD OCCURS DURING OPENING OR CLOSING CYCLE.
 5. FOR LOCATION REFERENCE SEE E-23
 6. THIS CIRCUIT WAS PREVIOUSLY ON E-692

NUCLEAR SAFETY RELATED

CS	CONT DET	DWG	SPARES
1-515BS	"R"	E-3B	L2, R2

ELEMENTARY DIAGRAM-480V MCC CKTS
 CHARGING PP TO HOT LEG ISOL VALVE
 BEAVER VALLEY POWER STATION-UNIT 2
 DUQUESNE LIGHT COMPANY
 STONE & WEDSTER ENGINEERING CORPORATION
 12241-E-G UW

7	6	5/24/84	4	2/22/84	3	7/20/83	2	8/26/81	1	3-9-79
---	---	---------	---	---------	---	---------	---	---------	---	--------

84092/0320

TI
 APERTURE
 CARD

PDR RIDS

8409210320

