



- NOTES**
1. PORTION OF PIPING IS ELIMINATED RELEASE POINT NOT IN CONTRACT E-46-4, SEE DWG. 3102 & 3104.
 2. UNLESS OTHERWISE INDICATED ALL PIPING AND/OR FLARE INSTRUMENTED ROOF LISTS SHALL BE 304L. ROOF VALVES SHALL BE 304L. LINE UP TO AND EXHAUST ROOF VALVE SH-1. SEE PARAGRAPH 3 INSTALLED UNDER CONTRACT E-68-4.
 3. ALL TEMPERATURE TEST & PROTECTING WELD PENETRATIONS SHALL BE 100% O.A. UNLESS OTHERWISE NOTED.
 4. ALL "1/2" PIPING BETWEEN SHOWN HEREON SHALL BE CLASS 300 - P FORMER CLASSIFICATION.
 5. UNLESS NOTED OTHERWISE, ALL PIPING & EQUIPMENT FORMED BY SUBPROCESSOR (WITH THROUGH CODE 9-11) IS INSTALLED BY TURBINE ERECTION COMPANY/CYCOR.
 6. "CP" INDICATES LOCATION OF CATHODE PROTECTIVE LEADS TO BE INSTALLED IN ACCORDANCE WITH PARAGRAPH 1-1-10.2, CONTRACT E-08-6.
 7. ALL VALVE HANGERS IN PARAGRAPH 1-1-10 ARE REQUIRED TO BE USED IN CONSULTING PROCEDURES. THESE HANGERS ARE ADVISED OR NOTIFIED SHALL NOT BE SHOWN ON PIPING DWG.
 8. ALL ITEMS MARKED DWG 11 AND TAG BUILT 11 ARE AS SHOWN IN PIPING DWG.

DRAWING SUBJECT TO REVISION
 PER DC 95-33
 DRAWING BEING REVISED PER
 DC#

INFORMATION ONLY

ANSTEC APERTURE CARD

NON-CONTROLLED PRINT:
 JUL 18 1995
 NPPD P.A.S.
 THIS DRAWING GENERATED BY N.P.D.

BURNS AND ROE, INC.
 ENGINEERS AND CONTRACTORS
 CHICAGO, ILL. • HOUSTON, TEX. • LOS ANGELES, CALIF.
**FLOW DIAGRAM
 MISC. DRAINS, VENTS,
 AND SEAL SYSTEMS**
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION

AS BUILT

454208909

AUG 23, 1993 NPPD



* 9511280261

PDR

9512040077

