



- NOTE:
1. DGCS, FD-23.7 & FD-28.0 BY BLACK & VEATCH FOR CRYSTAL RIVER UNIT #1
 2. ALL PIPING IN THIS SYSTEM TO BE LINE SPEC 125-B, SEISMIC CLASS III, PER ANSI B31.1, EXCEPT WHERE NOTED.
 3. PIPING SHALL BE ASME SA 312 TP 316L, SCH. 40, SEAMLESS. FITTINGS SHALL BE ASME SA 182 F316L, 3000#, SW END, FLANGES SHALL BE ASME SA 182 F316L, 150#, RF, SW END.

MAR IN PROGRESS
 78-2-1
 78-6-20
 85-05-01

TI APERTURE CARD

INFORMATION ONLY

NO.	REVISIONS	BY	CHECKED	APPROVED	DATE
49	REVISED PER DCN 87-229	SWM	DAW	EMM	7/4/87
48	REVISED PER DCN 87-189	SWM	DAW/ABT	EMM	11-12-86
47	AS-BUILT PER MAR 86-11-08-01	SWM	DAW	EMM	9-18-87
46	AS-BUILT PER MAR 86-10-03-01	SWM	ABT	EMM	9-18-87
45	AS-BUILT PER MAR 83-06-28-02	SWM	BG	EMM	5-4-87
44	REVISED PER DCN 86-274 & RESCALED	SWM	LBT	JRM	3-23-87
43	AS-BUILT PER MAR 82-10-19-31, FCA-2	SWM	EWM	JRM	1-23-87
42	AS-BUILT PER MAR 83-05-30-01	SWM	RK	JRM	12-18-86
41	AS-BUILT PER MAR 86-10-03-01	SWM	JEE	JRM	12-17-86
40	REVISED PER DCN 86-142	CLW	DAW	JRM	7-2-86
39	AS-BUILT PER MAR (A) 84-03-09-01 & (B) DCN 86-077	CLW	RWK	JRM	5-13-86
38	AS-BUILT PER MAR 82-10-19-31	SWM	RK	JRM	3-27-86
37	AS-BUILT PER MAR 85-11-07-01	SWM	GJC	JEC	3-11-86
36	AS-BUILT PER MAR 82-05-17-01	SWM	GJC	JEC	1-22-86
35	AS-BUILT PER MAR 83-06-28-02	CLW	LBT	PRT	1-18-86

FLORIDA POWER CORPORATION
 ST. PETERSBURG, FLORIDA

CRYSTAL RIVER PLANT
 855,000 KW

UNIT NO. 3
 TURBINE PLANT PIPING
 DOMESTIC WATER

D.O. SYSTEM FLOW DIAGRAM

IS1 AND ORIGINAL DESIGN BASIS CODE CLASSES
 REDRAWN ON CAD SYSTEM
 DRAWN BY: E.L.W. DATE: 02-27-83
 CHECKED BY: B.F.K. DATE: 04-14-83
 APPROVED BY: J.H.B. DATE: 04-14-83

BAYMONT ENGINEERING COMPANY

FD-302-211
 SHEET 01 OF 01 49

PDR RIDS

Q801070473

