



CABLE BLOCK DIAGRAM 3

SCHEME C1HE02C3
EAB HVAC CONTROL ROOM SMOKE
PURGE EXHAUST AND
RETURN AIR DRIVERS
C1HEFY9688 & C1HEFY9693

- 4. FOR LEGEND AND SYMBOLS REFER TO -
DRAWINGS 9-E-N201-01 & 9-E-N201-02.
- 5. Q - DENOTES LOCATION NUMBER. FOR COMPLETE LOCATION NUMBER REFER TO CABLE BLOCK DIAGRAMS SHOWN ON THIS DRAWING.
- 6. ELEMENTARY DIAGRAM SHOWN IS FOR FV-9672 AND FV-9695. FV-9699, 9694 & FV-9666, 9693 ARE SIMILAR EXCEPT AS NOTED ON CABLE BLOCK DIAGRAM AND IN BRACKETS []
- 7. LIM SW USED ONLY FOR FV-9695, 9694 & 9693.
- 8. LIM SW USED ONLY FOR FV-9672, 9669 & 9666.
- 9. ENERGIZED TO OPEN DAMPER.
- 10. ENERGIZED TO CLOSE DAMPER.
- 11. FOR CABLE PULL AND WIRE NOS BETWEEN AUX RELAY PNL AND ISOLATION RELAY PANEL SEE DWG 9-E-FN10-01.

[illegible]

BECHTEL ENERGY CORPORATION
HOUSTON, TEXAS

HOUSTON LIGHTING & POWER CO.
SOUTH TEXAS PROJECT

NUCLEAR SAFETY RELATED			
ELEMENTARY DIAGRAM E.A.B. HVAC CONTROL ROOM SMOKE PURGE EXHAUST AND RETURN AIR DAMPERS			
SCALE	JOB NO.	DRAWING NO.	REV
NONE	14926	9-E-HE02-01	4

PDR RIDS

8701230052

