



- NOTES:**
1. BUTTERFLY VALVE SIZ. BY C.A.D. OCCASIONALLY FOR THE INITIAL DESIGN. IN ALL OTHERS, THE SIZING IS TO BE CHECKED BY THE DESIGNER.
 2. ISOLATION VALVES SUPPLIED WITH INSTRUMENTS.
 3. UNLESS OTHERWISE INDICATED ALL PIPING IS SAFETY CLASSIFICATION I PIPING DESIGN TABLE 100 OR.
 4. RADIOGRAPH WELDS IN CLASS 1C PIPING IN ACCORDANCE WITH "ASME" SECTION III REQUIREMENTS. PERFORM MAGNETIC PARTICLE EXAMINATION ON "RSPC" COIL NOZZLE JOINT AT WATER HOT HEADS, AND RADIOGRAPHIC EXAMINATION OF THE WELD AT THE PLACE CONNECTED TO THE NOZZLE.
 5. VALVES ABOVE NOTED LTP ARE LOCKED-IN POSITION FOR SYSTEM FLOW PERFORMANCE.

NOTE 2 NUCLEAR SAFETY RELATED
 THIS DRAWING IS THE PROPERTY OF THE UNITED STATES GOVERNMENT AND IS LOANED TO YOU. IT AND ITS CONTENTS ARE NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM.

NO.	REV.	DATE	BY	CHKD.	DESCRIPTION
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					

DIAGRAM OF ESSENTIAL SER. WATER (PRIMARY CONTAINMENT VENT SYSTEM)

BYRON STATION UNIT-1
 COMMONWEALTH EDISON CO.
 CHICAGO, ILLINOIS

CRITICAL CONTROL ROOM DRAWING

DATE: 11-15-68
 DRAWN BY: [Name]
 CHECKED BY: [Name]

MC

PDR RIDS

9603250443

