



NOTE:  
1. MV-PC-161B & MV-PC-165B ARE PART OF ANDERSON - GREENWOOD INSTRUMENT MANFOLD INSTALLED ON LT-0105.  
2. CHANNEL B INPUT TO 2/4 LOGIC IS DISABLED PER TN-95-076. LOGIC IS NOW 2/3.

42	4-7	93	ADDED NOTE 2 PER TN-95-076 & OCR-95-088. (1/22/93)	JCD	REV	DATE
REV	DATE	BY	CHK	APP	DATE	
0950	M-201 SH.2	42	PALISADES PLANT CONSUMERS POWER COMPANY PIPING & INSTRUMENT DIAGRAM PRIMARY COOLANT SYSTEM			
M201-2.DGN						

91003280053

PDR RID®

