



- NOTES:
- REFER TO Dwg H-209 FOR SAFEGUARDS PUMPS COOLING.
 - REFER TO Dwg H-211 FOR SAFEGUARDS ROOMS SUMPS.
 - REFER TO Dwg HSSS-696-1 ICE Dwg 2966-D-3284 FOR L.P. SAFETY INJECTION PUMPS VENT AND DRAIN PIPING.
 - REFER TO Dwg HSSS-696-1 ICE Dwg 2966-D-3282 FOR H.P. SAFETY INJECTION PUMPS VENT AND DRAIN PIPING.
 - REFER TO P&ID DIAGRAM H-225 FOR CONTROL AIR SYSTEM DETAILS.
 - HCC-101-2" & HCC-102-2" SHALL BE TIED INTO EXISTING PIPING AT EL. 635' -8" LOCATE ROOT VALVES ADJACENT TO THE TIE IN FOR "NET TAP" IF REQUIRED.
 - ALL VALVE PREFIXES ARE "ES" AND TAGGED AS BUILT UNLESS OTHERWISE NOTED.

ANSTEC APERTURE CARD

CHANGED BY: 44-15220, SCL, SWP & SD TO NORMALLY CLOSED PER CIP-001-05-001A & CIP-001-05-002.	DATE: 10/2/68
DESCRIPTION:	BY: CR
CONSUMERS POWER COMPANY PULASKI NUCLEAR PLANT CONWAY, MISSISSIPPI	
PIPING & INSTRUMENT DIAGRAM	
SAFETY INJECTION CONTAINMENT SPRAY AND SHUTDOWN COOLING SYSTEM	
DWG. NO. H284	SHEET NO. 1A
DATE: 10/2/68	REV. NO. 22

060 3280090

