



NOTES:  
 A. FOR LIST OF NOTES AND SYMBOLS SEE 458807-19-1.  
 B. DRAP CONDUIT RUN WITH A 1 HOUR RATED FIRE RAMP FOR 15' ON THE LENGTH BUILT IN UNIT 2.  
 C. DRAP CONDUITS SHALL BE 2" MINIMUM RATED FIRE DRAP OVER PENETRATION WITH 1 HOUR RATED FIRE DRAP OVER THROUGH THE 565 FT ELEVATION.

**TI APERTURE CARD**

NO.	DATE	BY	CHKD	APPD	ISSD
1	5-23-67	JMB	JMB	JMB	JMB
DRAWN BY: J. D. BRADY ** CHECKED BY: J. C. BRADY ** SCALE: 3/16" = 1'-0" EXCEPT AS NOTED NO ISSUING ERM REQUIRED. STUDY DRAWING ONLY. NOT TO BE USED FOR CONSTRUCTION.					
<b>ROCKHOUSE REACTOR BUILDING UNIT 2</b> <b>C &amp; G APPENDIX R</b> <b>SEPARATIONS</b> <b>FLOOR EL 565.0 COL N-R</b> <b>CEILING PLAN</b>					
BROWNS FERRY NUCLEAR PLANT TENNESSEE VALLEY AUTHORITY DIVISION OF ENGINEERING DESIGN					
COMMITTED	RECOMMENDED	APPROVED			
JAMES B. BLACK **	H. C. SUTHERLAND **				
KNOXVILLE 1-7-66 67 E 458807-19-6 R2 FILE 458807-19-6					

30Y 1 3 3 9 8

PDR RIDS

86091080385

