



ENCLOSURE BUILDING FILTRATION ROOM
 00024-
 P-0550-0026-5-2-
 25203-26028-5-15

ANSTEC APERTURE CARD

NOTES
 1. FOR NOTES, SYMBOLS AND UNIT #2 OBSERVATIONS SEE DRAWING SHEETS 2 & 3 FOR ALL OTHER UNIT #2 NOTES SEE SHEET 04-0111
 2. THE SAMPLE COIL AND ISOLATION VALVES SHOWN MUST BE ACCESSIBLE AND APPROXIMATELY 3 FEET ABOVE THE FLOOR WITH 1 FOOT SEPARATION.

OPERATIONS CRITICAL

NO.	DATE	DESCRIPTION	BY	CHKD.

Northeast Utilities System
 FOR
 NORTHEAST NUCLEAR ENERGY CO.

NO.	DATE	DESCRIPTION	BY	CHKD.

180022116

25203-26028 SH 5 OF 6
 9712220081

9712220081

PDR RIDS

9712220081

