



- LEGEND**
- 1. THE FLOOR SLAB AT EL. 12'-0" FOR ROOM NO. 241, HAS BEEN CONSIDERED TO MEET APPENDIX B SEPARATION REQUIREMENTS FOR SAFE SHUTDOWN EQUIPMENT AND RACENWAY SEPARATED BY THIS SLAB.
 - 2. THE NORMALLY LOCKED OR UNLOCKED STATUS OF A DOOR IS ADMINISTRATIVELY CONTROLLED.
 - 3. THE AUTO-LOCKING FUNCTION OF STAIRDOOR TYPE LOCKERS MAY BE DEFEATED, SUCH ACTION BEING ADMINISTRATIVELY CONTROLLED.

ANGLED APERTURE CARD

CAD: [Signature] DATE: [Date]	
ALABAMA POWER COMPANY ALABAMA POWER PLANT - UNIT NO. 1 THE PROJECT - [Project Name]	
DRAWN BY: [Name] CHECKED BY: [Name]	DATE: [Date] SCALE: [Scale]
PROJECT NO.: [Number]	SHEET NO.: [Number]

9801070101

PDR RIDS

9801070101

