



2) EXTERNAL WIRING REVISIONS TO THIS DWG. ARE NON NUCLEAR SAFETY RELATED. WHERE ROUTING AND SEPERATION ARE REQUIRED NOTATION IS NNSR/SG-R OR NNSR/SG-G FOR SAFEGUARD RED OR GREEN ROUTING. SWITCHES AND RELAYS IN RPSA OR 3B PSA PANEL ARE NUCLEAR SAFETY RELATED.

CHANGE IN PROGRESS
DUE TO WAR/REV/SP
* 80-09-13-01
FCN FCN FCN
FCN FCN FCN

RS-13

22A (74)		TI APERTURE CARD		MUP-2A (MU-05)	
ENGINEERING INTERFACES					
1	2	3	4	5	6
FLORIDA POWER CORPORATION ST. PETERSBURG, FLORIDA CRYSTAL RIVER PLANT					
UNIT NO. 3		853,000 KW			
ELEMENTARY DIAGRAM REMOTE SHUTDOWN PANEL "A-1" RELAY ACTUATION					
AS BUILT PER MARS 77-10-66-10, 77-7-1-14, 77-7-1-4 & 77-7-1-6					
ISSUED FOR MARS 77-7-1-4					
NO REVISIONS					
5011		B-208-082		1	
TOTAL ORDER		SIZE		REV	
GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.					
DRAWINGS		ENGINEER APP'D.			
MADE		CR		APP	
REV		CHK		DATE	
DATE		DATE		DATE	

8703190375

PDR RIDS

