



SYSTEM #12

STREAM	LENGTH	PERMEATION	ELEVATION
A	450 FT	X-50	258'-0"
B	500 FT	X-49	254'-0"
C	470 FT	X-48	252'-0"
D	410 FT	X-37	237'-0"
RETURN	420 FT	X-30	237'-0"

FOR INFORMATION ONLY

ALL SYSTEMS SUPPLIED BY BECKMAN INSTRUMENTS, DREEM & FINE ADT'D.
 PURCHASE ACQUISITION: 8/15/72
 PURCHASE C-57 VERIFICATION: 8/14
 PURCHASE GROSS: (LATER)

(1) TO TIDE-14 SELECTOR
 (2) FOR PUMP SAMPLES SEE DWG. C-66001-C
 (3) SUPPLIED BY M.M.P.
 (4) TO AUTOMATIC CALIBRATION UNIT IN PANEL
 (5) LOCATED IN MAIN CONTROL ROOM ("L" PANEL)

M.O. 317-30-4244-18-0000

NIAGARA MOHAWK
 NIAGARA MOHAWK POWER CORPORATION

NINE MILE POINT NUCLEAR STATION
 PRIMARY CONTAINMENT ATMOSPHERE
 H₂-O₂ MONITOR SYSTEM #12
 P&I DIAGRAM

REVISED PER AS-BUILT ON 10/10/74 INC. 4244

REVISED FOR AS-BUILT

GENERAL MISC. REV. #100
 ED. CABINET COOLER NO. 4244

REV. VOLVING & SIGN. SHEETS DATED:
 CHG. 2 2/15/76 FROM 11/9/75
 CHG. 10 10/10/74 FROM 11/9/75
 CHG. 11 10/10/74 FROM 11/9/75

DATE: 11/9/75

3-N21-5109
 C-26939-C

Roll # 715

TI
 APERTURE
 CARD

8610090362

PDR RIDS

8610090362

