

From: Garcia, Carlos A <cgarci1@entergy.com>
Sent: Friday, October 16, 2020 7:40 AM
To: Chris Sweeney; EndangeredSpecies Resource; incidental.take@noaa.gov; msanza@gw.dec.state.ny.us
Cc: Garcia, Carlos A
Subject: [External_Sender] DRAFT September 2020 - IPEC Monthly Sturgeon Monitoring Report
Attachments: September 2020 Sturgeon Monthly Report.pdf

Good afternoon,

This report is being submitted in accordance with Term & Condition 12 in the 2013 Entergy Indian Point Biological Opinion and Incidental Take Statement, as amended February 9, 2018. Since no sturgeon were collected during the month of September 2020, attached you will find a summary of cooling and service water pump operation for Unit 3 only during the month.

If you have any questions, please contact me at 646.355.8972, or Chris Sweeney of Normandeau at 631.410.3164.

Carlos A. Garcia
Environmental Staff Specialist

Chemistry|Environmental
Indian Point Energy Center
450 Broadway|Buchanan, NY 10511
e: cgarci1@entergy.com | p: 914.254.8468 | c: 646.355.8972

This message is intended for the exclusive use of the intended addressee. If you have received this message in error or are not the intended addressee or his or her authorized agent, please notify me immediately by e-mail, discard any paper copies and delete all electronic files of this message.

Hearing Identifier: NRR_DRMA
Email Number: 836

Mail Envelope Properties (BLAPR09MB742701DA855D767A21533AB7EF030)

Subject: [External_Sender] DRAFT September 2020 - IPEC Monthly Sturgeon Monitoring Report
Sent Date: 10/16/2020 7:40:25 AM
Received Date: 10/16/2020 7:40:30 AM
From: Garcia, Carlos A
Created By: cgarc1@entergy.com

Recipients:

"Garcia, Carlos A" <cgarc1@entergy.com>
Tracking Status: None
"Chris Sweeney" <CSweeney@normandeau.com>
Tracking Status: None
"EndangeredSpecies Resource" <EndangeredSpecies.Resource@nrc.gov>
Tracking Status: None
"incidental.take@noaa.gov" <incidental.take@noaa.gov>
Tracking Status: None
"msanza@gw.dec.state.ny.us" <msanza@gw.dec.state.ny.us>
Tracking Status: None

Post Office: BLAPR09MB7427.namprd09.prod.outlook.com

Files	Size	Date & Time
MESSAGE	1033	10/16/2020 7:40:30 AM
September 2020 Sturgeon Monthly Report.pdf		7154

Options

Priority: Normal
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:

MONTHLY REPORTING - SEPTEMBER 2020			
DATE	UNIT 3		UNIT 2
	CIRC WATER PUMPS @ 140,000 GPM	SERVICE WATER PUMPS @ 5000 GPM	
9/2/2020	6	6	UNIT 2 IS PERMANENTLY SHUTDOWN. NO STURGEON MONITORING CONDUCTED
9/4/2020	6	6	
9/9/2020	6	6	
9/11/2020	6	6	
9/14/2020	6	6	
9/16/2020	6	6	
9/18/2020	6	6	
9/21/2020	6	6	
9/23/2020	6	6	
9/25/2020	6	5 (1)	
9/28/2020	6	5 (1)	
9/30/2020	6	5 (1)	

NOTES

- For Circulating Water Pumps (CWP), speeds may vary for operations or maintenance.
U3 Speeds = 84,000-140,000 gpm
- Based on river and plant operational conditions, operating Service Water Pumps (SWP) may vary.
- (1) 31 SWP secured from 9/25/19 for operations/maintenance.