

List of New CoC 1042 Amendment 2, Revision 6 Technical Specifications
Changes and Justifications

Changed Technical Specifications (TS) Area and Page Number	Justification
Table of Contents, List of Tables, and List of Figures	Updated
2.3 (<i>RECONSTITUTED FUEL ASSEMBLIES</i>) (Page 2-6)	As described in the revised response to Shielding RAI 6-4, the maximum number of irradiated stainless steel rods per DSC has been added.
4.0 (Design Features) (Page 4-11)	As described in Enclosure 11, Item 5, the alternative to the ACI code section for concrete temperatures has been revised for clarity.