

Facility: Cooper Nuclear Station		Exam Date: September 21 – 24, 2020												
Admin	JPMs	1 ADMIN Topic and K/A	2 LOD (1-5)	3 Attributes						4 Job Content		5 U/E/S	6 Explanation	
				I/C Focus	Cues	Critical Steps	Scope (N/B)	Overlap	Perf. Std.	Key	Minutia			Job Link
	A1	1 2.1.25	2	X							X			<ul style="list-style-type: none"> JPM cannot be completed as written because the cue does not include the time since shutdown. Without this information, the graph cannot be utilized. Added 24 hours for time after shutdown to the IC to allow 8 hours to be the time to 200 F Need to provide a marked up copy of Figure 4 as a key to show the intersection of the graph. Inserted a snip it in the answer key with intersection on graph they examinee would use. JPM now SAT
	A2	1 2.1.37	2	X							X			<ul style="list-style-type: none"> It doesn't look like there is enough information to answer the question. Where did 10-15 start? Was this the 04-08 rod pull? Where did 02-31 come from? Need all the handouts. Why doesn't step 2.10 apply to move 10-15 to its correct position? Sent the wrong handout. I had one filled out so they could see the problems. The 2.10 is if it is not for the Approach to criticality which is stated in the step only 2.9 applies. JPM now SAT
	A3	2 2.2.15	2											<ul style="list-style-type: none"> Hard to review without the handout. The Cue tells you to include annunciators and the annunciator is a critical step. Recommend removing because it should be obvious with the handout. Also, an evaluator should be able to ask an appropriate follow-up question if they left the annunciator off. Forgot to include handouts of drawings. I added the handouts and marked up the different locations to identify the annunciator and also the trip. Change validation time to 20 minutes. Changed validation time to 20 minutes. JPM now SAT
	A4	3 2.3.11	2											S
	A5	1 2.1.20	1											<ul style="list-style-type: none"> LOD is probably a 1, and I fail to see how this is SRO level of knowledge. Added loss of DC bus, requiring the examinee to also determine the effect of loss of power on level instruments. JPM now SAT
	A6	1 2.1.3	3											<ul style="list-style-type: none"> Seems like CS-7B is open and CS-7A is closed. I think A core spray is inoperable. I didn't see HPCI test light. Seems buried. Could be trouble. This could take an hour based on number of pages given.

Instructions for Completing This Table:

Check or mark any item(s) requiring a comment and explain the issue in the space provided using the guide below.

1. Check each JPM for appropriate administrative topic requirements (COO, EC, Rad, and EP) or safety function requirements and corresponding K/A. Mark in column 1. (ES-301, D.3 and D.4)
2. Determine the level of difficulty (LOD) using an established 1–5 rating scale. Levels 1 and 5 represent an inappropriate (low or high) discriminatory level for the license that is being tested. Mark in column 2 (Appendix D, C.1.f)
3. In column 3, “Attributes,” check the appropriate box when an attribute is **not met**:
 - The initial conditions and/or initiating cue is clear to ensure the operator understands the task and how to begin. (Appendix C, B.4)
 - The JPM contains appropriate cues that clearly indicate when they should be provided to the examinee. Cues are objective and not leading. (Appendix C, D.1)
 - All critical steps (elements) are properly identified.
 - The scope of the task is not too narrow (N) or too broad (B).
 - Excessive overlap does not occur with other parts of the operating test or written examination. (ES-301, D.1.a, and ES-301, D.2.a)
 - The task performance standard clearly describes the expected outcome (i.e., end state). Each performance step identifies a standard for successful completion of the step.
 - A valid marked up key was provided (e.g., graph interpretation, initialed steps for handouts).
4. For column 4, “Job Content,” check the appropriate box if the job content flaw **does not meet** the following elements:
 - Topics are linked to the job content (e.g., not a disguised task, task required in real job).
 - The JPM has meaningful performance requirements that will provide a legitimate basis for evaluating the applicant's understanding and ability to safely operate the plant. (ES-301, D.2.c)
5. Based on the reviewer's judgment, is the JPM as written (U)nacceptable (requiring repair or replacement), in need of (E)nhancement, or (S)atisfactory? Mark the answer in column 5.
6. In column 6, provide a brief description of any (U)nacceptable or (E)nhancement rating from column 5.

Save initial review comments and detail subsequent comment resolution so that each exam-bound JPM is marked by a (S)atisfactory resolution on this form.

Facility: Cooper Nuclear Station		Scenario: 1				Exam Date: September 21 – 24, 2020			
1	2	3	4	5	6	7	8	9	10
Event	Realism/Cred.	Required Actions	Verifiable actions	LOD	TS	CTs	Scen. Overlap	U/E/S	Explanation
								E	Need to add a failure for RO to respond to prior to the major. Currently, only has a reactivity manipulation. Added RRMG A speed control failure as event 2.
1					1			U S	This is a pre-briefed Tech spec, so it does not count as a tech spec call. Change to a REC pump trip. Changed to REC pump trip. This is now event 3.
2								S	Moved to event 1
3					1			S	Now event 4
4								S	Now Event 5
5							2020 exam 1	S	Now event 6, Different success path than the previous major.
6						2		S	Now event 7
7								S	Now event 9
8								S	Initial event 8 now event 10. Added failure of scram discharge volume vent and drain valves to automatically close
9								S	Old event 7
10								E S	Old event 8. Change to RCIC pump trip, otherwise RCIC will not allow level to go low enough to require emergency depressurization. RCIC fails to start and will trip after crew manually starts it, and it is unrecoverable.
					2	2	9	E S	

Facility: Cooper Nuclear Station		Scenario: 2					Exam Date: September 21 – 25, 2020			
1	2	3	4	5	6	7	8	9	10	
Event	Realism/Cred.	Required Actions	Verifiable actions	LOD	TS	CTs	Scen. Overlap	U/E/S	Explanation	
									The list of objectives on page 1 have RCIC initiation after APRM spike, but the table on page 2 has the RCIC initiation after the APRM spike. Corrected order of events, RCIC initiation is before APRM failure.	
1								S		
2					1	1		IMS	Change spurious RCIC initiation to an instrument failure due to logic actuation instead of a component failure. Changed designation of RCIC malfunction from "C" (component) to "I" (instrument) per CE comment. ATC should get credit for verifiable action. Gave ATC credit Add cues if asked to open the starter for MO-14 and add roll play if asked to investigate RCIC initiation (page 22). Added cues. Add step 2.2.4 for BOP (page 22). Added step 2.2.4	
3					1			IMS	Now event 4. How could APRM A read ~82% and be considered operable?. Should this be changed to reading consistently with other APRM at whatever power level RCIC drove the crew to? If it is reading much lower than the rest then there's a possibility of not meeting step 2.3 of the alarm card because 2 APRM would be inop. Changed to only APRM C failure high to ensure operator has to perform a verifiable action (bypass APRM C) per discussion with CE. Due to changing to only one APRM inoperable, no LCO entry would be required. Therefore, added MSL Rad Monitor D downscale event after RCIC initiation event and before APRM C event to replace APRM Tech Spec call per discussion with CE. Add TLCO 3.3.3 (page 25). Added TLCO 3.3.3. Added main steam line radiation detector failure as Tech Spec only call as event 3.	
4								S	Now event 5.	
5								S	Now events 6 and 7	
6						2		S	Now event 8.	
7								S	Now event 9.	
8								S	Now event 10.	
9								S		
10								S		
				2		3	9 10	IMS S		

Facility: Cooper Nuclear Station		Scenario: 3			Exam Date: September 21 – 24, 2020				
1	2	3	4	5	6	7	8	9	10
Event	Realism/Cred.	Required Actions	Verifiable actions	LOD	TS	CTs	Scen. Overlap	U/E/S	Explanation
									For CT2, add which areas reach max safe first and second. Added areas.
1							2020 exam 1	S	
2								E S	Change to upscale failure. Changed to upscale. Add booth cue that if crew does not proceed to placing HPCI in standby because of the failure, booth calls as SM directing moving to placing HPCI in standby. Added cue.
3									Imbed placing HPCI in standby into event 4. Combined events 3 and 4
4					1			S	Now event 3
5								S	Now event 4
6					1			S	Now event 5
7						1		E	Now event 6 On the D-1, the critical task is listed as CT#2, when it is CT#1. Corrected typo on D-1 page 2; CT is now listed as CT#1.
8								S	Now event 7
9						1		S	Now event 8 Corrected typo on page 36; CT is now listed as CT#2.
10								S	Now event 9
					2	2	9 8	E	

Facility: Cooper Nuclear Station		Scenario: 4				Exam Date: September 21 – 24, 2020			
1	2	3	4	5	6	7	8	9	10
Event	Realism/Cred.	Required Actions	Verifiable actions	LOD	TS	CTs	Scen. Overlap	U/E/S	Explanation
									Additional comments may follow validation
1					1			S	
2							2018 exam	S	
3					1			S	Page 24, one value is in "wc and another in "wg; is this correct or should they both be "wg Changed "wc to "wg to match units used in procedure.
4						2		S	
5								S	
6								S	
7						1	2018 exam	E S	Critical task #3 is not identified anywhere in the D-2. Critical task #3 is questionable as a critical task since it is satisfied by the booth. In order to qualify as a critical task, there needs to be some kind of documented evidence that 5 minutes is the time it takes to vent the scram header once direction is given, then there has to be very tight control on the booth waiting that specific amount of time. The task cannot be satisfied "if they make the call to vent prior to exceeding BIIT and exiting the EOP." Removed Critical task #3
8								S	
					2	3	6	E	

Instructions for Completing This Table:

- 1 Use this table for each scenario for evaluation.
- 2 Check this box if the events are not related (e.g., seismic event followed by a pipe rupture) **OR** if the events do not obey the laws of physics and thermodynamics.
- 3, 4 In columns 3 and 4, check the box if there is **no** verifiable or required action, as applicable. Examples of required actions are as follows: (ES-301, D.5f)
 - opening, closing, and throttling valves
 - starting and stopping equipment
 - raising and lowering level, flow, and pressure
 - making decisions and giving directions
 - acknowledging or verifying key alarms and automatic actions (Uncomplicated events that require no operator action beyond this should **not** be included on the operating test unless they are necessary to set the stage for subsequent events. (Appendix D, B.3).)
- 5 Check this box if the level of difficulty is **not** appropriate.
- 6 Check this box if the event has a TS.
- 7 Check this box if the event has a critical task (CT). If the same CT covers more than one event, check the event where the CT started **only**.
- 8 Check this box if the event overlaps with another event on any of the last two NRC examinations. (Appendix D, C.1.f)
- 9 Based on the reviewer's judgment, is the event as written (U)nacceptable (requiring repair or replacement), in need of (E)nhancement, or (S)atisfactory? Mark the answer in column 9.
- 10 Record any explanations of the events here.

In the shaded boxes, sum the number of check marks in each column.

- In column 1, sum the number of events.
- In columns 2–4, record the total number of check marks for each column.
- In column 5, based on the reviewer's judgement, place a checkmark only if the scenario's LOD is not appropriate.
- In column 6, TS are required to be ≥ 2 for each scenario. (ES-301, D.5.d)
- In column 7, preidentified CTs should be ≥ 2 for each scenario. (Appendix D; ES-301, D.5.d; ES-301-4)
- In column 8, record the number of events not used on the two previous NRC initial licensing exams. A scenario is considered unsatisfactory if there is < 2 new events. (ES-301, D.5.b; Appendix D, C.1.f)
- In column 9, record whether the scenario as written (U)nacceptable, in need of (E)nhancement, or (S)atisfactory from column 11 of the simulator scenario table.

Facility: Cooper Nuclear Station								Exam Date: September 21 – 24, 2020		
Scenario	1 Event Totals	2 Events Unsat.	3 TS Total	4 TS Unsat.	5 CT Total	6 CT Unsat.	7 % Unsat. Scenario Elements	8 U/E/S	11 Explanation	
1	10	0	2	1	2	0	7.1	E S	Event 1 is a pre-briefed Tech spec, so it does not count as a tech spec call.	
2	10	0	2	0	3	0	0	E S		
3	9	0	2	0	2	0	0	E S		
4	8	0	2	0	3	1	7.7	E S	Critical task #3 is questionable as a critical task since it is satisfied by the booth.	

Instructions for Completing This Table:

Check or mark any item(s) requiring comment and explain the issue in the space provided.

1, 3, 5 For each simulator scenario, enter the **total** number of events (column 1), TS entries/actions (column 3), and CTs (column 5).

This number should match the respective scenario from the event-based scenario tables (the sum from columns 1, 6, and 7, respectively).

2, 4, 6 For each simulator scenario, evaluate each event, TS, and CT as (S)atisfactory, (E)nhance, or (U)nsatisfactory based on the following criteria:

- a. Events. Each event is described on a Form ES-D-2, including all switch manipulations, pertinent alarms, and verifiable actions. Event actions are balanced between at-the-controls and balance-of-plant applicants during the scenario. All event-related attributes on Form ES-301-4 are met. Enter the total number of unsatisfactory events in column 2.
- b. TS. A scenario includes at least two TS entries/actions across at least two different events. TS entries and actions are detailed on Form ES-D-2. Enter the total number of unsatisfactory TS entries/actions in column 4. (ES-301, D.5d)
- c. CT. Check that a scenario includes at least two preidentified CTs. This criterion is a target quantitative attribute, not an absolute minimum requirement. Check that each CT is explicitly bounded on Form ES-D-2 with measurable performance standards (see Appendix D). Enter the total number of unsatisfactory CTs in column 6.

7 In column 7, calculate the percentage of unsatisfactory scenario elements: $\left(\frac{2 + 4 + 6}{1 + 3 + 5}\right) 100\%$

8 If the value in column 7 is > 20%, mark the scenario as (U)nsatisfactory in column 8. If column 7 is ≤ 20%, annotate with (E)nhancement or (S)atisfactory.

9 In column 9, explain each unsatisfactory event, TS, and CT. Editorial comments can also be added here.

Save initial review comments and detail subsequent comment resolution so that each exam-bound scenario is marked by a (S)atisfactory resolution on this form.

Site name: Cooper Nuclear Station			Exam Date: September 21 – 24, 2020			
OPERATING TEST TOTALS						
	Total	Total Unsatisf.	Total Edits	Total Satisf.	% Unsatisf.	Explanation
Admin. JPMs	9	2	3	4		
Sim./In-Plant JPMs	11	1	6	4		
Scenarios	4	0	4	0		
Op. Test Totals:	24	3	13	8	12.5%	

Instructions for Completing This Table:

Update data for this table from quality reviews and totals in the previous tables and then calculate the percentage of total items that are unsatisfactory and give an explanation in the space provided.

- Enter the total number of items submitted for the operating test in the "Total" column. For example, if nine administrative JPMs were submitted, enter "9" in the "Total" items column for administrative JPMs. For scenarios, enter the total number of simulator scenarios.
- Enter the total number of (U)nsatisfactory JPMs and scenarios from the two JPMs column 5 and simulator scenarios column 8 in the previous tables. Provide an explanation in the space provided.
- Enter totals for (E)nhancements needed and (S)atisfactory JPMs and scenarios from the previous tables. This task is for tracking only.
- Total each column and enter the amounts in the "Op. Test Totals" row.
- Calculate the percentage of the operating test that is (U)nsatisfactory ($\text{Op. Test Total Unsatisf.} / \text{Op. Test Total}$) and place this value in the bolded "% Unsatisf." cell.

Refer to ES-501, E.3.a, to rate the overall operating test as follows:

 - satisfactory, if the "Op. Test Total" "% Unsatisf." is $\leq 20\%$
 - unsatisfactory, if "Op. Test Total" "% Unsatisf." is $> 20\%$
- Update this table and the tables above with post-exam changes if the "as-administered" operating test required content changes, including the following:
 - The JPM performance standards were incorrect.
 - The administrative JPM tasks/keys were incorrect.
 - CTs were incorrect in the scenarios (not including post scenario critical tasks defined in Appendix D).
 - The EOP strategy was incorrect in a scenario(s).
 - TS entries/actions were determined to be incorrect in a scenario(s).