

SPACE AND ACCESS TABULATION OF RADIATION ZONES																														LEGEND			
BLDG.	FLOOR EL.	ROOM NO.	SPACE	PLANT CONDITION						REMARKS	BLDG.	FLOOR EL.	ROOM NO.	SPACE	PLANT CONDITION						REMARKS	N	LOCAL	HS	R	M	ST						
				N	LOCAL	HS	R	M	ST						N	LOCAL	HS	R	M	ST													
A	83'-0"	2101	WASTE GAS DECAY TANK ROOM	V	V	V	V	V	V	SEE NOTE 1	100'-0"	2161	CORRIDOR	II	III	II	II	II	II	SEE NOTE 1	121'-0"	2201	COMPUTER ROOM	I	II	I	I	I	I	SEE NOTE 1	N - NORMAL PLANT OPERATION + POWER LOCAL - LOSS OF COOLANT ACCIDENT HS - HOT STANDBY R - REFUELING M - MAINTENANCE OR COMPONENT TESTING ST - SYSTEMS TESTING		
		2102	VALVE COMPARTMENT ROOM	IV	IV	IV	IV	IV	IV			2162	HALLWAY	II	IV	II	II	II	II				2202	COMMUNICATION ROOM	I	II	I	I	I			I	
		2103	CORRIDOR	III	III	III	III	III	III			2163	WDS CONTROL PANEL ROOM	II	III	II	II	II	II				2203	WASTE EVAP. COND. TANKS & PUMP ROOM	III	III	III	III	III			III	
		2104	PASSAGEWAY TO UNIT - 2	III	III	III	III	III	III			2164	STORAGE ROOM	V-A	V-A	V-A	V-A	V-A	V-A				2204	WASTE EVAP. PACKAGE ROOM	V	V	V	V	IV			V	
		2105	RECOMBINER ROOM	V	V	V	V	V	V	SEE NOTE 1		2165	WASTE GAS DECAY TANK ROOM	V-A	V-A	V-A	V-A	V-A	V-A				2205	PASSAGEWAY TO UNIT 2	II	III	II	II	II			II	
		2106	RECOMBINER ROOM	V	V	V	V	V	V	SEE NOTE 1		2166	WASTE GAS DECAY TANK ROOM	V-A	V-A	V-A	V-A	V-A	V-A				2206	HEAT EXCH. ROOM	V-A	V-A	V-A	V-A	V-A			V-A	
		2107	STORAGE ROOM	III	III	III	III	III	III			2167	STORAGE ROOM	II	III	II	II	II	II				2207	HATCH AREA	II	III	II	II	II			II	
		2108	WASTE MONITOR TANK ROOM	V	V	V	V	V	V	SEE NOTE 1		2168	CHEMICAL & LAUNDRY DRAIN TANK ROOM	III	IV	III	III	III	III				2208	CORRIDOR	II	III	II	II	II			II	
		2109	WASTE MONITOR TANK PUMP ROOM	III	III	III	III	III	III	SEE NOTE 1												2209	HALLWAY	II	IV	II	II	II	II				
		2110	MONITORING CONTROL PANEL RM.	II	III	II	II	II	II			100'-0"	2170	LETDOWN HEAT EXCHANGER ROOM	V-A	V-A	V-A	V-A	V-A			V-A		2210	CORRIDOR	I	II	I	I			I	I
B	77'-0"	2111	CTWT SPRAY PUMP ROOM	II	V	II	II	II	II		100'-0"	2171	STORAGE ROOM	III	IV	III	III	III	III		2211	CORRIDOR	I	II	I	I	I	I					
		2112	GALLERY ACCESS ROOM	II	IV	II	II	II	II			2172	HALLWAY	III	V	III	III	III	III		2212	BATTERY 1B ROOM	I	II	I	I	I	I					
										2173		CHARGING/SAFETY INJECTION PUMP ROOM	V	V	V	V	V	V		2213	BATTERY SERVICE ROOM	I	II	I	I	I	I						
										2174		CHARGING/SAFETY INJECTION PUMP ROOM	V	V	V	V	V	V		2214	BATTERY 1A ROOM	I	II	I	I	I	I						
		2115	HALLWAY	II	V	II	II	II	II			2175	HALLWAY	III	V	III	III	III	III														
										2176		SPENT RESIN STORAGE TANK ROOM	V-A	V-A	V-A	V-A	V-A	V-A		2216	VALVE COMPARTMENT AREA	V	V	V	V	IV	V						
										2177		SLUICE PUMP	V	V	V	V	V	V		2217	VOLUME CONTROL TANK ROOM	V-A	V-A	V-A	V-A	V-A	V-A						
										2178		SLUICE FILTER	V	V	V	V	V	V		2218	CHILLER UNIT ROOM	II	II	II	II	II	II						
		2118	FLOOR DRAIN TANK ROOM	V	V	V	V	V	V	SEE NOTE 1		2179	SPENT RESIN VALVE ROOM	III	III	III	III	III	III														
		2119	WASTE HOLD-UP TANK ROOM	V	V	V	V	V	V	SEE NOTE 1		2180	AUX. BOILER ROOM NO. 2	III	III	III	III	III	III		2220	VALVE COMPARTMENT RM.	V-A	V-A	V-A	V-A	V-A	V-A					
C	85'-0"	2120	CORRIDOR	III	III	III	III	III	III		100'-0"	2181	CHARGING/SAFETY INJECTION PUMP ROOM	V	V	V	V	V	V		2221	SPENT RESIN STORAGE TANK ROOM	V-A	V-A	V-A	V-A	V-A	V-A					
		2121	FLOOR DRAIN TANK PUMP RM.	III	III	III	III	III	III	SEE NOTE 1		2182	CONTAMINATED STORAGE ROOM	III	V	III	IV	III	III		2222	CORRIDOR	II	V	II	II	II	II					
		2122	WASTE EVAP. FEED PUMP RM.	IV	IV	IV	IV	IV	IV	SEE NOTE 1		2183	TENDON ACCESS GALLERY	II	V	II	II	II	II		2223	PIPING PENETRATION ROOM	V	V	V	V	IV	V					
										2184		PIPING PENETRATION ROOM	V	V	V	V	IV	V		2224	DC SWITCHGEAR ROOM	I	II	I	I	I	I						
		2125	CTWT SPRAY PUMP ROOM	II	V	II	II	II	II			2185	COMPONENT COOLING WATER HEAT EXCHANGER ROOM	I	III	I	II	II	II		2225	BATTERY CHARGER ROOM	I	II	I	I	I	I					
										2186		BORIC ACID AREA	III	V	III	III	III	III		2226	DC SWITCHGEAR ROOM	I	II	I	I	I	I						
										2187		HYDRO TEST PUMP ROOM	III	IV	III	III	III	III															
		2128	RHR HEAT EXCHANGER	V	V	V	V	V	V	SEE NOTE 1		2188	BORIC ACID TANKS AREA	III	IV	III	III	III	III		121'-0"	2228	CORRIDOR	I	II	I	I	I	I				
		2129	RHR LOW HEAD PUMP ROOM	V	V	V	V	V	V	SEE NOTE 1		2189	PLANT HEATING EQUIPMENT ROOM	I	V	I	I	I	I		2229	SWITCHGEAR ROOM	I	II	I	I	I	I					
		2131	RHR LOW HEAD PUMP ROOM	V	V	V	V	V	V	SEE NOTE 1		2190	AUX. F.W. CONTROL PANEL ROOM	I	II	I	I	I	I		2230	RECYCLE EVAP. PACKAGE ROOM	V	V	V	V	III	V					
D	83'-0"	2131	RHR LOW HEAD PUMP ROOM	V	V	V	V	V	V	SEE NOTE 1	2191	AUX. F.W. PUMP ROOM	I	II	I	I	I	I		2231	SPENT RESIN SLUICE PUMP ROOM	V-A	V-A	V-A	V-A	V-A	V-A						
		2132	STAIR NO. 2	II	III	II	II	II	II		2192	AUX. F.W. PUMP ROOM	I	II	I	I	I	I		2232	SPENT RESIN SLUICE FILTER ROOM	V-A	V-A	V-A	V-A	V-A	V-A						
		2133	ELEVATOR NO. 2	II	III	II	II	II	II		2193	AUX. F.W. PUMP ROOM	I	II	I	I	I	I		2233	SWITCHGEAR ROOM	I	II	I	I	I	I						
										2194	LOWER EQUIPMENT ROOM	I	V	I	I	I	I		2234	HALLWAY	I	II	I	I	I	I							
										2195	ACCESS HATCH ROOM	I	II	I	I	I	I		2235	CROW CONTROL SYS. CABINET ROOM	I	II	I	I	I	I							
										2196	ACCESS AREA TO TENDON GALLERY	I	V	I	I	I	I																
		2154A	VALVE COMPARTMENT	IV	V	IV	IV	IV	IV	SEE NOTE 1									2237	CORRIDOR	II	V	II	II	II	II							
		2151	WASTE GAS DECAY TANKS ROOMS	V-A	V-A	V-A	V-A	V-A	V-A	SEE NOTE 1	2199	PHOSPHATE TANK AND PUMP AREA	I	II	I	I	I	I		114'-5"	2238	CASK STORAGE ROOM	V	V	V	V	V	V					
		2152	VALVE COMPARTMENT ROOM	IV	IV	IV	IV	IV	IV			STAIR NO. 1	I	III	I	I	I	I		113'-10"	2239	TRANSFER CANAL	V-A	V-A	V-A	V-A	V-A	V-A					
		2153	WASTE GAS COMPRESSORS ROOMS	V-A	V-A	V-A	V-A	V-A	V-A	SEE NOTE 1		ELEVATOR NO. 4	I	III	I	I	I	I		114'-5"	2240	SPENT FUEL POOL	V	V	V	V	V	V					
E	83'-0"	2154	AUX. BOILER ROOM NO. 1	II	III	II	II	II	II		112'-0"								2241	MAIN STEAM & FEED WATER VALVE ROOM	I	V	I	I	I	I							
		2155	PASSAGEWAY TO UNIT 2	II	III	II	II	II	II																								
		2156	HOLD-UP TANK ROOM	V	V	V	V	V	V	SEE NOTE 1		100'-0"																					
		2157	HOLD-UP TANK ROOM	V	V	V	V	V	V	SEE NOTE 1		85'-10"																					
		2158	HOLD-UP TANK ROOM	V	V	V	V	V	V	SEE NOTE 1		65'-10"																					
		2159	RECYCLE EVAP. FEED PUMP ROOMS	IV	IV	IV	IV	IV	IV	SEE NOTE 1																							
		2160	HATCH AREA	II	III	II	II	II	II																								
F	77'-0"	2154A	VALVE COMPARTMENT	IV	V	IV	IV	IV	IV	SEE NOTE 1	100'-0"	2199	PHOSPHATE TANK AND PUMP AREA	I	II	I	I	I	I		CTMT	121'-0"	2254	WALKWAY	I	II	I	I	I	I			
		2151	WASTE GAS DECAY TANKS ROOMS	V-A	V-A	V-A	V-A	V-A	V-A	SEE NOTE 1			STAIR NO. 1	I	III	I	I	I	I														
		2152	VALVE COMPARTMENT ROOM	IV	IV	IV	IV	IV	IV				ELEVATOR NO. 4	I	III	I	I	I	I														
		2153	WASTE GAS COMPRESSORS ROOMS	V-A	V-A	V-A	V-A	V-A	V-A	SEE NOTE 1																							
		2154	AUX. BOILER ROOM NO. 1	II	III	II	II	II	II				CTWT BUILDING	V-A	V-A	V-A	V-A	V-A	V-A														
		2155	PASSAGEWAY TO UNIT 2	II	III	II	II	II	II																								
		2156	HOLD-UP TANK ROOM	V	V	V	V	V	V	SEE NOTE 1			112'-0"	ELEVATOR NO. 6	V-A	V-A	V-A	V-A	V-A	V-A													
		2157	HOLD-UP TANK ROOM	V	V	V	V	V	V	SEE NOTE 1			100'-0"	STAIR NO. 8	II	III	II	II	II	II													
		2158	HOLD-UP TANK ROOM	V	V	V	V	V	V	SEE NOTE 1			85'-10"	STAIR NO. 3	V-A	V-A	V-A	V-A	V-A	V-A													
		2159	RECYCLE EVAP. FEED PUMP ROOMS	IV	IV	IV	IV	IV	IV	SEE NOTE 1			65'-10"	STAIR NO. 4	V-A	V-A	V-A	V-A	V-A	V-A													
G	83'-0"	2154A	VALVE COMPARTMENT	IV	V	IV	IV	IV	IV	SEE NOTE 1	100'-0"	2199	PHOSPHATE TANK AND PUMP AREA	I	II	I	I	I	I		CTMT	121'-0"	2254	WALKWAY	I	II	I	I	I	I			
		2151	WASTE GAS DECAY TANKS ROOMS	V-A	V-A	V-A	V-A	V-A	V-A	SEE NOTE 1			STAIR NO. 1	I	III	I	I	I	I														
		2152	VALVE COMPARTMENT ROOM	IV	IV	IV	IV	IV	IV				ELEVATOR NO. 4	I	III	I	I	I	I														
		2153	WASTE GAS COMPRESSORS ROOMS	V-A	V-A	V-A	V-A	V-A	V-A	SEE NOTE 1																							
		2154	AUX. BOILER ROOM NO. 1	II	III	II	II	II	II				CTWT BUILDING	V-A	V-A	V-A	V-A	V-A	V-A														
		2155	PASSAGEWAY TO UNIT 2	II	III	II	II	II	II																								
		2156	HOLD-UP TANK ROOM	V	V	V	V	V	V	SEE NOTE 1			112'-0"	ELEVATOR NO. 6	V-A	V-A	V-A	V-A	V-A	V-A													
		2157	HOLD-UP TANK ROOM	V	V	V	V	V	V	SEE NOTE 1			100'-0"	STAIR NO. 8	II	III	II	II	II	II													
		2158	HOLD-UP TANK ROOM	V	V	V	V	V	V	SEE NOTE 1			85'-10"	STAIR NO. 3	V-A	V-A	V-A	V-A	V-A	V-A													
		2159	RECYCLE EVAP. FEED PUMP ROOMS	IV	IV	IV	IV	IV	IV	SEE NOTE 1			65'-10"	STAIR NO. 4	V-A	V-A	V-A	V-A	V-A	V-A													
H	83'-0"	2154A	VALVE COMPARTMENT	IV	V	IV	IV	IV	IV	SEE NOTE 1	100'-0"	2199	PHOSPHATE TANK AND PUMP AREA	I	II	I	I	I	I		CTMT	121'-0"	2254	WALKWAY	I	II	I	I	I	I			
		2151	WASTE GAS DECAY TANKS ROOMS	V-A	V-A	V-A	V-A	V-A	V-A	SEE NOTE 1			STAIR NO. 1	I	III	I	I	I	I														

LEGEND

N - NORMAL PLANT OPERATION @ POWER
LOCA - LOSS OF COOLANT ACCIDENT
HS - HOT STANDBY
R - REFUELING
M - MAINTENANCE OR COMPONENT TESTING
ST - SYSTEMS TESTING

NOTES

1. SYSTEMS (ALL NORMALLY) BE DRAINED AND PURGED TO REDUCE DOSE RATES FOR MAINTENANCE.
2. ZONE DEPENDS ON EQUIPMENT INSTALLED.
3. HIGH DOSE RATE DURING MAINTENANCE FROM SPENT RESIN STORAGE TANK ON EL. 129'-0".
4. HIGH DOSE RATE DURING MAINTENANCE FROM SPENT RESIN STORAGE TANK ON EL. 100'-0".
5. DOSE RATES WILL BE H

9909300085

PDR RIDS

9909300085

