



TABLE 1			
TRAIN	EQUIPMENT TAG NOS.		SAFETY SIG.
A	1-HS-1806	1-HV-1806	SI-A
B	-1807	-1807	SI-B
A	-1808	-1808	SI-A
B	-1809	-1809	SI-B
A	-1822	-1822	SI-A
B	-1823	-1823	SI-B
A	-1830	-1830	SI-A
B	-1831	-1831	SI-B

NOTE:

1. VALVES LISTED IN TABLE 1 ARE BUTTERFLY TYPE VALVES
OPEN - LIMIT STOPPED
CLOSE - LIMIT STOPPED

NUCLEAR SAFETY RELATED

CONTAINMENT COOLER ISOLATION VALVE

SOUTHERN COMPANY SERVICES, INC.
BIRMINGHAM, ALABAMA

GEORGIA POWER COMPANY
ALVIN W. VOGTLE NUCLEAR PLANT

CONTROL LOGIC DIAGRAM
NUCLEAR SERVICE
COOLING WATER SYSTEM
AUXILIARIES AND ALARMS

3. REFER TO SPECIAL NOTE 2 ON DWG 1X5DN002-2.

REF. DWGS
P&ID 1X4DB135-1, -2
E.D. 1X3D-BD-K04J, K, N, P, S, T, U, V, W & X

NO.	REVISIONS	DATE	DR	CHK	APPV	DTL	SCALE: NONE	DRAWING NO.	REV
1	INCORPORATED PER DCP 95-V1N0035	12/5/97	CD	GLB	WFP			1X5DN090-1	5
2	ISSUED FOR CONSTRUCTION								

THIS DOCUMENT CONTAINS PROPRIETARY, CONFIDENTIAL, AND/OR TRADE SECRET INFORMATION OF THE SUBSIDIARIES OF THE SOUTHERN COMPANY OR OF THIRD PARTIES. IT IS INTENDED FOR USE ONLY BY EMPLOYEES OF, OR AUTHORIZED CONTRACTORS OF, THE SUBSIDIARIES OF THE SOUTHERN COMPANY. UNAUTHORIZED POSSESSION, USE, DISTRIBUTION, COPYING, DISSEMINATION, OR DISCLOSURE OF ANY PORTION HEREOF IS PROHIBITED.

CAD NAME SIZE B 11x17
15DN0901

PDR RID 9910150035

9910150035

