

EQUIPMENT LIST

REV	ITEM NO	INSTR. OR DEV NO	QTY	PROV BY	DESCRIPTION	SERVICE	REMARKS
	30	32	3	E	Reverse power relay, Westinghouse type CRN-1 in type MT21 case for semirush mounting	Emer. generator AOB trip	ESK-8A
	31*	62	3	M	Agastat time delay relay, TDFU, 125 v d-c, 2.5-50 sec range, type 2412PD	HP safety injection pumps	ESK-6C
	32*	27	3	M	Aux. front connected relay, G.E. type HGALLJ, with cover, 120 v a-c	480 V bus tie ACE close interlock	ESK-6B
2	33		As Req'd	M	Terminal block, 12 point, Stanwick sliding link		
	34		2	M	Pushbutton Westinghouse type OT or equal.	Annunciator, Reset and Lamp Test	
3	35		1		Westinghouse type OT211 Selector Switch. Standard handle with lock.	CS-2 for MOV-1	ESK-6AD

8

7

6

5

4

3

3/8-77
E.S.G.
2

6-2-78
4/25
2

4-10-70
18
130

STONE & WEBSTER ENGINEERING CORPORATION

J.O. No. 41386

9699-ESK-4AA

SH. 4 CONT. ON SH.

9699-

ESK-4AA

3SAFETY

INJECTION CNTL PNL

4

4

DDA INT

NRCA ANPGF IØ ~~ØØØ~~

8104130237

