



- NOTES:
1. PROVIDE 0.375" ID RESTRICTION AS SHOWN ON DPC DWG NO. C460001.
 2. FOR TYPICAL MAKE-UP PIPING ARRANGEMENT TO RCP STAND-PIPE SEE DWG. 1X40814 (D-0).
 3. ALL EQUIPMENT AND VALVES TO BE FURNISHED BY WESTINGHOUSE EXCEPT THE FOLLOWING:
 - A. ALL PIPING AND MANUAL VALVES 2" AND UNDER (SURGE LINE, PRESSURIZER RELIEF AND LOOP SEAL PIPING FURNISHED BY WESTINGHOUSE).
 - B. SAMPLE VESSEL AND ATTACHED PIPING FITTINGS.
 - C. REACTOR COOLANT PUMP OIL DRAIN TANK TOGETHER WITH ASSOCIATED PIPING, VALVES, AND INSTRUMENTATION.
 4. FOR DRAIN HEADER INFORMATION SEE DWG. 1X40814-2.
 5. PLACE DETECTORS AT BOTTOM OF PIPE, SURFACE MOUNTED.
 6. DIGITAL PRESSURE INDICATOR TO BE CONNECTED TO THIS LINE DOWNSTREAM OF THE SAMPLE HV.
 7. TYPON HOSE TO BE CONNECTED DURING START-UP VENTING. FG-8099 HAS A PROJECT CLASS OF 424 INSTALLED IN A PROJECT CLASS PIPE OF 415.
 8. ROOT VALVES PROCURED AS CLASS 111 AND INSTALLED FOR CLASS 212.
 9. LINE BETWEEN PRESSURIZER AND VALVE, INCLUDING THE VALVE IS PROJECT CLASS 212.
 10. DELETED.
- NOTES CONTINUED AT B-8.

THIS DOCUMENT CONTAINS PROPRIETARY, CONFIDENTIAL, AND/OR TRADE SECRET INFORMATION OF THE SUBSIDIARIES OF THE SOUTHERN COMPANY OR OF THIRD PARTIES. IT IS INTENDED FOR USE ONLY BY EMPLOYEES OF, OR AUTHORIZED CONTRACTORS OF, THE SUBSIDIARIES OF THE SOUTHERN COMPANY. UNAUTHORIZED POSSESSION, USE, DISTRIBUTION, COPYING, DISSEMINATION, OR DISCLOSURE OF ANY PORTION HEREOF IS PROHIBITED.

INCORP. PER DCP 94-VIN0002 AND	11/3/87	CS	SM	WFP
ASN'S-42653, 42671				
ISSUED FOR CONSTRUCTION	SEE WORK ORDER FOR SIGNATURES			
NO. 1	DATE	BY	CHK	APPV

SCALE: NONE	DRAWING NO. 1X408112	REV. 35
JOB NO. 10604		
CAD NAME 1X408112		

REFER TO WESTINGHOUSE FLOW DIAGRAM
DWG NO. 1054669.

SOUTHERN COMPANY SERVICES, INC.
BIRMINGHAM, ALABAMA

GEORGIA POWER COMPANY
ALVIN W. VOGTLE NUCLEAR PLANT

P & I DIAGRAM
REACTOR COOLANT SYSTEM
SYSTEM NO. 1201

INSTRUMENT IDENTIFICATION NUMBERS

1-1201-T4-002	LSH 10455	LG 10451
1-1201-T4-003	LSH 10456	LG 10452
1-1201-T4-004	LSH 10457	LG 10453
1-1201-T4-005	LSH 10458	LG 10454

230	(4)
228	(3)
226	(2)
224	(1)

211-2	(1)
216-2	(2)
221-2	(3)
226-2	(4)

REACTOR COOLANT PUMP OIL SPILL PROTECTION SYSTEM

9910190006

9910190006

PDR RIDS

