



- NOTES:
1. INSTALL AT ACCESSIBLE AND CONVENIENT LOCATION.
 2. EQUIPMENT AND VALVES FURNISHED BY WESTINGHOUSE EXCEPT ALL PIPING AND ALL MANUAL VALVES 2 INCH AND SMALLER.
 3. FOR PUMP COOLING WATER PIPING DETAILS SEE DWG. 13409B-34.
 4. INSTALL 150 # R.F. FLANGE ON INLET OF 12" DIAM. PIPE FOR PERIODIC TESTING. PROVIDE ONE MATING BLIND FLANGE TO BE DRILLED AND TAPPED FOR TEST CONNECTION. MATING FLANGE MUST BE REMOVED FOR NORMAL OPERATION.
 5. VESSEL IS CONSTRUCTED TO SEISMIC CATEGORY 1 AND ASME III CLASS MC.
 6. PORTION OF THE SYSTEM IS SUSPECTED TO CAUSE STRESS CORROSION CRACKING. REFER TO THE APPLICABLE DESIGN DRAWING FOR MATERIAL AND HEAT TREATMENT REQUIREMENTS.
 7. THE DESCRIPTOR "PX" PERTAINS TO A SEPARABLE COMPONENT OF THE TRANSMITTER.
 8. 4" VIEW PORT TO BE USED TO VERIFY MOTOR OPERATED VALVE STROKE TEST WITHOUT REMOVING THE VESSEL HEAD.
 9. TE-958 & TE-959 HAVE BEEN "ABANDONED IN PLACE".
 10. VENT HOLE IS DRILLED ON CONTAINMENT SIDE OF DISC.
 11. THE SPRAY ADDITIVE TANK AND ASSOCIATED COMPONENTS HAVE BEEN RETIRED IN PLACE.
 12. BLIND ORIFICE PLATE.

APERTURE CARD

REFERENCE: WESTINGHOUSE DRAWING #1095E13
"CONTAINMENT SPRAY SYSTEM"

SOUTHERN COMPANY SERVICES, INC.
BIRMINGHAM, ALABAMA

GEORGIA POWER COMPANY
ALVIN W. VOGTLE NUCLEAR PLANT

P & I DIAGRAM
CONTAINMENT SPRAY SYSTEM
SYSTEM NO. 1206

THIS DOCUMENT CONTAINS PROPRIETARY, CONFIDENTIAL, AND/OR TRADE SECRET INFORMATION OF THE SUBSIDIARIES OF THE SOUTHERN COMPANY OR OF THIRD PARTIES. IT IS INTENDED FOR USE ONLY BY EMPLOYEES OF, OR AUTHORIZED CONTRACTORS OF, THE SUBSIDIARIES OF THE SOUTHERN COMPANY. UNAUTHORIZED POSSESSION, USE, DISTRIBUTION, COPYING, DISSEMINATION, OR DISCLOSURE OF ANY PORTION HEREOF IS PROHIBITED.				INCORP. PER OCP 94-VIN0002 AND ADN'S 42655, 42660, 42661, 42676 ISSUED FOR CONSTRUCTION				DATE	DR	CHK	APPV	DTL
NO.				NO.								
SCALE: NONE				DRAWING NO.				REV.				
JOB NO. 10604				1X40B131				30				
SIZE E 34x44				CAD NAME				1X40B131				

9910190045

9910190045

PDR RIDS

