



OPEN - LIMIT STOPPED
CLOSE - LIMIT STOPPED
5. VALVE 1-HV-5113 HAS A D.C. MOTOR
OTHERS ARE A.C. MOTORS.

E. J. 1X3D-BC-F02C, D, B

APERTURE
CARD

C

GEORGIA POWER COMPANY
ALVIN W. VOGTLE NUCLEAR PLANT

ONLY BY EMPLOYEES OF, HEREOF IS PROHIBITED.	CAD NAME 15DN1201	SIZE B 11x1
--	----------------------	-------------

SERVICE	TRAIN	VALVE	SWITCHES				PANEL
AUX. FW PUMP TURB. DRIVEN	C	1-HV-5113	1-HS-5113A	1-HS-5113B	1-HS-5113C	PAFP	
AUX. FW PUMP MOTOR DRIVEN	B	5118	5118A	5118B	5118C	PSDB	
AUX. FW PUMP MOTOR DRIVEN	A	5119	5119A	5119B	5119C	PSDA	

△						
△						
6	INCORPORATED PER DCP 95-V1N0035	12-5-97	CD	GLB	WFP	
0	ISSUED FOR CONSTRUCTION	SEE MICROFILM FOR SIGNATURES				
NO.	REVISIONS	DATE	DR	CHK	APPV	DTL

THIS DOCUMENT CONTAINS PROPRIETARY, CONFIDENTIAL, AND/OR TRADE SECRET INFORMATION OF THE SUBSIDIARIES OF THE SOUTHERN COMPANY OR OF THIRD PARTIES. IT IS INTENDED FOR USE ONLY BY EMPLOYEES OF, OR AUTHORIZED CONTRACTORS OF, THE SUBSIDIARIES OF THE SOUTHERN COMPANY. UNAUTHORIZED POSSESSION, USE, DISTRIBUTION, COPYING, DISSEMINATION, OR DISCLOSURE OF ANY PORTION HEREOF IS PROHIBITED.

CAD NAME SIZE B 11x17
15DN1201

9910190206

[REDACTED] S

PDR RIDS

9910190206

