



- NOTES
1. FOR FIRE HOSE STATION LOCATIONS SEE ARCHITECTURAL DRAWINGS OF EACH FLOOR.
 2. SPRINKLER LOCATIONS BY ARCHITECTURAL ROOM NUMBERS, UNIT 1 SHOWN.
 3. TROUBLE SIGNAL TO FIRE SUPPRESSION LOCAL PANEL, SEE SPEC. 344003, ATTACHMENT 3, TABLE A.
 4. VENDOR TO SUPPLY SPRINKLER VALVES & HEADS.
 5. VENDOR TO CONNECT TO HEADERS INSTALLED BY PURCHASER. PURCHASER TO PROVIDE PIPE PENETRATION SLEEVES & HANGER ENDS.
 6. FOR HOSE CABINET & SPRINKLER SYSTEM INFORMATION SEE DRAWING 1X408174-5.
 7. SPRINKLER SYSTEM INSPECTORS TEST CONNECTIONS TO BE SUPPLIED BY VENDOR. DETAIL DRAWINGS, TEST CONNECTIONS TO DRAIN DIRECTLY INTO FLOOR DRAINS.
 8. THREADED BRANCH CONNECTIONS ARE REQUIRED ON HEADERS UPSTREAM FROM INDICATED VALVES FOR DELUGE VALVE TEST PIPING. FOR SIZE OF PIPING LINE SEE V.P. 344003-5001.

SOUTHERN COMPANY SERVICES, INC.
BIRMINGHAM, ALABAMA

GEORGIA POWER COMPANY
ALVIN W. VOGTLE NUCLEAR PLANT

P & I DIAGRAM
FIRE PROTECTION WATER SYSTEM
SYSTEM NO. 2301

SCALE:	DRAWING NO.	REV.
NONE	1X408174-2	22

DATE DR CHK APPV DTL
JOB NO. 10604
SIZE E 34x44
CAD NAME
14081742

9910190211

PDR RIDS

9910190211

