



- NOTES:
1. THE BACKGROUND USED ON THIS DRAWING IS PROVIDED FOR ORIENTATION PURPOSES ONLY.
 2. THE PORTABLE EXTINGUISHERS IN ARB ROOMS 102 AND 103 ARE HALON 1211.
 3. "RETIRED IN PLACE".

LEGEND

[Symbol]	3 HR RATED FIRE AREA BOUNDARY
[Symbol]	UNRATED FIRE AREA BOUNDARY
[Symbol]	3 HR RATED BOUNDARY
[Symbol]	2 HR RATED BOUNDARY
[Symbol]	PRE-ACTION SPRINKLER SYSTEM
[Symbol]	HALON SYSTEM
[Symbol]	FIRE HOSE CABINET
[Symbol]	FIRE HOSE REEL
[Symbol]	PORTABLE EXTINGUISHER (DRY CHEMICAL) SEE NOTE 2
[Symbol]	EXIT SIGN LOCATION
[Symbol]	FIRE ALARM PULL BOX
[Symbol]	KNOCK OUT PANEL
[Symbol]	FIRE ZONE BOUNDARY
[Symbol]	FIRE ZONE DESIGNATOR

ELECTRICAL CABLE LOCATION CROSS REFERENCE

FIRE ZONE	UNIT 1 E4 CODE	UNIT 2 E4 CODE
300B	X3	-
301	X3	-
302	X3	-
330	X4	-

INCORP. PER ABN-32033	7-19-97	CD	MWD	EOG
ISSUED FOR CONSTRUCTION	SEE MICROFILM FOR SIGNATURES	DATE	DR	CHK
NO.	REVISIONS	APPV	DTL	

SOUTHERN COMPANY SERVICES, INC.
BIRMINGHAM, ALABAMA

GEORGIA POWER COMPANY
ALVIN W. VOGTLE NUCLEAR PLANT

FIRE AREAS
RADWASTE TRANSFER BUILDING AND
ALTERNATE RADWASTE BUILDING
LEVEL 1, FLOOR PLAN EL. 220'-0"

SCALE: NONE

DRAWING NO. AX4DJ8004

REV. 5

JOB NO. 10604

SIZE C 17X22

CAD NAME A4DJ8004

THIS DOCUMENT CONTAINS PROPRIETARY, CONFIDENTIAL, AND/OR TRADE SECRET INFORMATION OF THE SUBSIDIARIES OF THE SOUTHERN COMPANY OR OF THIRD PARTIES. IT IS INTENDED FOR USE ONLY BY EMPLOYEES OF, OR AUTHORIZED CONTRACTORS OF, THE SUBSIDIARIES OF THE SOUTHERN COMPANY. UNAUTHORIZED POSSESSION, USE, DISTRIBUTION, COPYING, DISSEMINATION, OR DISCLOSURE OF ANY PORTION HEREOF IS PROHIBITED.

PDR RDS 9910200134

9910200134

