

MANUFACTURER: GENERAL ELECTRIC CO. REMARKS: NEW OVERhaul - 201
 MODEL NO.: 50
 MFG. DWG. NO.: B317K22 / SEE 2140K > 1 #1
 CASE SIZE: 2 1/4" X 2 1/4" COLOR: BLACK
 MOUNTING: ST-154 SPEC NO. _____
 MOVEMENT TYPE: 0-400 PSI ACC: _____
 COLOR-SCALE: WHITE POINTER: WHITE
 GRADUATIONS: 5000

INSTRUMENT NUMBER	SERVICE LEGEND	INPUT SIGNAL		SCALE RANGE AND UNITS	REMARKS
		RANGE	FROM INSTR. NO. OR CT/PT RATIO		
CS-112	CORE SPRAY PUMP 1A DSCH.	10-50 MA	CS-109	0-400 PSIG	CS-132 WILL BE LOCALLY MOUNTED IN PUMP ROOM
CS-113	CORE SPRAY PUMP 1B DSCH.	10-50 MA	CS-110	0-400 PSIG	
CS-114	CORE SPRAY PUMP 1C DSCH.	10-50 MA	CS-111	0-400 PSIG	
CS-118	CORE SPRAY FLOW To Rx	10-50 MA (✓)	CS-117	0-4000 GPM (✓)	
CS-122	CORE SPRAY FLOW To Rx	10-50 MA (✓)	CS-121	0-4000 GPM (✓)	
CS-132	CONTAINMENT LVL	10-50 MA	CS-131	0-40 FT	

TERA
APERTURE
CARD

ELECTRICAL INDICATOR DATA SHEET		REVISIONS		REVISIONS		DATA SHEET	
DATE	FOR	DATE	FOR	DATE	FOR	DATE	BY
4/14/71	W-2044 REE 017					DATE: 7/1/71	BY: 1/1/71
						DWG. NO. M-600	SHEET NO. E101

SARGENT & LUNDY STATION: DRESDEN UNIT 1
COMMONWEALTH EDISON CO
700 N. 40TH
 FORM EF-65

8105150201

8105150201

DOCKET
NUMBER

ACCESSION
NUMBER

DRAWING NUMBER

SHEET REV.

