

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
Open Session

Docket Number: (n/a)

Location: teleconference

Date: Tuesday, December 1, 2020

Work Order No.: NRC-1258

Pages 1-59

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

+ + + + +

681ST MEETING

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

OPEN SESSION

+ + + + +

TUESDAY

DECEMBER 1, 2020

+ + + + +

The Advisory Committee met via Video-
Teleconference, at 2:00 p.m. EST, Matthew W. Sunseri,
Chairman, presiding.

COMMITTEE MEMBERS:

- MATTHEW W. SUNSERI, Chairman
- JOY L. REMPE, Vice Chairman
- WALTER L. KIRCHNER, Member-at-large
- RONALD G. BALLINGER, Member
- DENNIS BLEY, Member
- CHARLES H. BROWN, JR. Member
- VESNA B. DIMITRIJEVIC, Member
- JOSE MARCH-LEUBA, Member

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

DAVID A. PETTI, Member

PETER RICCARDELLA, Member

ACRS CONSULTANT:

MICHAEL CORRADINI

STEVE SCHULTZ

DESIGNATED FEDERAL OFFICIAL:

ZENA ABDULLAHI

ALSO PRESENT:

MICHAEL DUDEK, NRR

DAVID H. HINDS, GE-Hitachi

MARIELIZ JOHNSON, NRR

SCOTT MOORE, Executive Director, ACRS

NOLAN RYAN, NRR

GEORGE WADKINS, GE-Hitachi

AGENDA

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

<u>Item</u>	<u>Page</u>
Opening Remarks by the ACRS Chairman	5
<u>BWRX-300 Topical Report NEDC-33912,</u>	
<u>Reactivity Control</u>	
Remarks from the Subcommittee Chairman	7
Presentation and discussion	
NRC staff, Michael Dudek	8
GE-Hitachi, George Wadkins and David Hinds	9

P R O C E E D I N G S

2:01 p.m.

CHAIR SUNSERI: Meeting will now come to order. This is the first day of the 681st meeting of the Advisory Committee on Reactor Safeguards.

I'm Matthew Sunseri, Chair of the ACRS. And I now call the roll to confirm communications and that a quorum exists. I'll start with Ron Ballinger. Dennis Bley.

MEMBER BLEY: Here.

CHAIR SUNSERI: Charles Brown.

MEMBER BROWN: Here.

CHAIR SUNSERI: Vesna Dimitrijevic.

MEMBER DIMITRIJEVIC: Here.

CHAIR SUNSERI: Walt Kirchner.

MEMBER KIRCHNER: Here.

CHAIR SUNSERI: Jose March-Leuba.

MEMBER MARCH-LEUBA: Present.

CHAIR SUNSERI: Dave Petti.

MEMBER PETTI: Here.

CHAIR SUNSERI: Joy Rempe.

VICE CHAIR REMPE: Here.

CHAIR SUNSERI: Pete Riccardella.

MEMBER RICCARDELLA: I'm here.

CHAIR SUNSERI: And myself. We'll go

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 back. Ron Ballinger, have you joined us yet? Okay.
2 He was just on another line with us. I guess he'll
3 join shortly. But we do have a quorum. So we will
4 proceed on.

5 The ACRS was established by the Atomic
6 Energy Act and is governed by the Federal Advisory
7 Committee Act. The ACRS section of the U.S. NRC
8 public website provides information about the history
9 of the ACRS and provides documents such as our
10 charter, bylaws, Federal Register notices for
11 meetings, letter reports, and transcripts of all full
12 and subcommittee meetings, including slides presented
13 at the meetings.

14 The Committee provides its advice on
15 safety matters to the Commission through its publicly
16 available letter reports.

17 The Federal Register notice announcing
18 this meeting was published on November 20, 2020 and
19 provides an agenda and instructions for interested
20 parties to provide written documents or request
21 opportunities to address the Committee.

22 The Designated Federal Officer for this
23 meeting is Ms. Zena Abdullahi.

24 During today's meeting, the Committee will
25 consider the following, a BWRX-300 topical report on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reactivity control, and we will proceed into report
2 preparation if time permits.

3 A phone bridge line has been opened to
4 allow members of the public to listen in on the
5 presentation and Committee discussions. We have
6 received no written comments or requests to make oral
7 statements from members of the public regarding
8 today's session.

9 There will be an opportunity for public
10 comment. And we have set aside time in the agenda for
11 comments from members of the public attending or
12 listening to our meetings. Written comments may be
13 forwarded to Ms. Zena Abdullahi, the Designated
14 Federal Officer.

15 A transcript of the open portion of the
16 meeting is being kept. And it is requested that
17 speakers identify themselves and speak with sufficient
18 clarity and volume so that they may readily be heard.
19 Additionally, participants should mute themselves when
20 not speaking. And that's all.

21 So, as far as opening remarks, I really
22 don't have anything else to add. Our agenda is fairly
23 abbreviated for this session. Over the course of the
24 entire meeting, we will be looking at two letter
25 reports in preparation for our Commission briefing,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 along with a planning and procedure session.

2 So that's all I have for my opening
3 remarks. Any members care to make any statements
4 before we get into the agenda? All right. I'm not
5 hearing anything.

6 So our first topic is BWRX-300 topical
7 report. This session is characterized as open and
8 closed. And Dr. March-Leuba is our lead member on
9 this. And so I will turn it over to Jose at this
10 point.

11 MEMBER MARCH-LEUBA: Thanks, Mr. Chairman.
12 We are going to be listening about the reactivity
13 control design requirements in the topical report for
14 the BWRX-300 from GEH.

15 And before we start, I'd like to remind
16 the members that GEH has chosen to protect our
17 intellectual property. And there are many proprietary
18 issues on this topical report.

19 So, if the questions -- we have a closed
20 phone line that we can jump to if there are questions
21 that get into the proprietary nature. So, if I feel
22 that we are going that direction, I will use the magic
23 words of let's table this for the proprietary session,
24 the closed session, and please don't -- at that
25 moment, let's move to the closed session.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 That said, I want to thank both the staff
2 and GEH for making the extra work to make all the
3 presentations open so the public can learn about this
4 novel design.

5 And we, the Commission, or not the
6 Commission, the Committee heard about all the
7 proprietary and detailed information in the
8 subcommittee meeting just last month.

9 So, with that said, I believe the staff is
10 going to make the introductory remarks. So, Mike, are
11 you ready?

12 MR. DUDEK: I am. Thank you, Lead Person
13 March-Leuba and Chairman Sunseri and the rest of the
14 full Committee. Thank you for your time today.

15 On behalf of the staff, I'm just going to
16 give brief opening remarks on this third topical
17 report from GEH on reactivity control that requested
18 us to review their design requirements, analytical
19 methodology, acceptance criteria, and regulatory basis
20 associated with these reactivity control functions for
21 their small modular reactor design. As you stated, a
22 lot of this is proprietary and information that we
23 should protect.

24 This meeting comes off the heels of a very
25 successful subcommittee meeting. And I think that we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 are prepared to discuss anything that you have or
2 answer any questions that you have.

3 So, without any further ado, I turn it
4 back over to you. And thank you guys, thank you,
5 Committee, for your time today.

6 MEMBER MARCH-LEUBA: Thanks, Mike. So
7 it's time for GEH to start their presentation.

8 MR. WADKINS: Thank you. This is George
9 Wadkins. I am the Vice President, New Power Plants
10 and Products Licensing for GE-Hitachi.

11 Today we will be presenting an overview of
12 the BWRX-300 small modular reactor design features for
13 reactivity control, including a brief description of
14 the content for licensing topical report NEDC-33912P,
15 BWRX-300 Reactivity Control.

16 As noted in our previous discussions with
17 the ACRS members, the BWRX-300 built upon our
18 extensive experience in boiling water reactor
19 technology, including our most recent experiences in
20 development and certification of the Economic
21 Simplified Boiling Water Reactor or ESBWR.

22 The BWRX-300 is the tenth generation of GE
23 boiling water reactors. And the BWRX-300 design
24 leverages the use of proven technology to the greatest
25 extent possible while incorporating advances in design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 requirements and features to further enhance nuclear
2 safety and to provide for the protection of the public
3 in the unlikely event of an accident. Many of these
4 advances will be discussed today.

5 I first want to thank the NRC staff for
6 their in-depth review of this licensing topical
7 report. It is obvious to GE-Hitachi that the safety
8 review completed by the NRC staff was thorough and
9 focused on ensuring that the content of the licensing
10 topical report was complete, understandable, accurate,
11 and met the applicable regulatory requirements and
12 guidance.

13 As previously requested by the ACRS, we
14 are providing for an extensive open discussion of the
15 content of this licensing topical report. During our
16 presentation, we will pause at the end of each slide
17 to allow for questions from the ACRS members. But
18 please feel free to raise questions at any time.

19 If the discussions involve proprietary
20 information, then we will request tabling the question
21 until the latter closed session.

22 So, proceeding on to slide 2, the purpose
23 of today's presentation includes an overview of the
24 BWRX-300 design features involved in the mitigation of
25 licensing basis reactivity events.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 This includes how the BWRX-300 design
2 complies with the applicable regulatory requirements
3 and guidance and how the BWRX-300 design provides for
4 defense-in-depth shutdown capability and reactivity
5 control.

6 The licensing topical report addresses
7 design requirements, acceptance criteria, and
8 regulatory basis for the BWRX-300 reactor protection
9 system, or RPS for short, and other design features
10 for reactivity control and mitigation of anticipated
11 transients without scram, or ATWS for short.

12 I will now turn over the presentation to
13 David Hinds, principal design engineer for the BWRX-
14 300, to discuss defense-in-depth design features for
15 BWRX-300.

16 MR. HINDS: Hello. This is David Hinds.
17 I will first check to ensure you can hear me.

18 MEMBER MARCH-LEUBA: We can hear you.

19 MR. HINDS: Okay. Thank you. All right.
20 So this is a very brief summary of our licensing
21 topical report. I'm trying to touch on technical and
22 the associated licensing input information.

23 And again, if there's detailed questions,
24 we'd be glad to take them. Some of them we may take
25 for the next session.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, in BWRX-300, we apply a very detailed
2 defense-in-depth approach to the design across the
3 board. And we base that upon the fundamentals of the
4 IAEA approach for defense-in-depth. We think it's
5 quite rigorous and easy for our engineering team to
6 follow and align to.

7 So we have applied that approach, which
8 uses a defense line approach such that it's very clear
9 as to where the layers of defense-in-depth are.

10 And for this discussion today and this
11 licensing topical report, we are focused on the
12 defense-in-depth approach associated with the
13 fundamental safety function of reactivity control.

14 Of course, we have defense-in-depth for
15 the other fundamental safety functions. But, again,
16 this is focused only on reactivity control today,
17 which is to ensure defense-in-depth for shutdown
18 capability and reactivity control. If you could, move
19 to the next slide, please.

20 So, in keeping with what I just stated
21 about our defense-in-depth approach, I'll walk briefly
22 through our defense lines.

23 We begin with defense line 1. And defense
24 line 1 is the fundamental design approach where we do,
25 we apply a high level of quality and reliability and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 conservatism into the design.

2 And some of those design approaches that
3 we use for defense line 1 help to reduce challenges to
4 the plant from a trip perspective, reduces the trips
5 per year, reduces the numbers of AOOs. We use a very
6 rigorous operating experience review approach.

7 And as George stated, since this is the
8 tenth generation of our boiling water reactors, we
9 have a long lineage of operating experience to draw
10 from to build upon and continuous improvement. Next
11 slide, please.

12 Just to highlight a few of the associated
13 design features in the plant associated with
14 reactivity control, we'll start right at the basics of
15 control rods.

16 So our control rods -- and, of course,
17 this is not to scale. Our control rods that we're
18 using have a long period of operating experience.
19 We're using control rods that are already receiving
20 operating experience in the current fleet of boiling
21 water reactors.

22 And this is just showing a visual for
23 anyone that's not used to looking at the figures, and
24 on the right, just shows a visual of how the control
25 rod fits in a control cell or fuel cell with four fuel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 bundles surrounding the control rod blade.

2 So it is a proven design, a high level of
3 reliability. And we have even, in addition to the
4 high reliability that we're currently achieving with
5 our control rods, we have done some additional things
6 (audio interference) for the blades, the control rod
7 blades.

8 We've applied a, what we call an in-
9 lattice core such that we have a slightly larger water
10 gap there for the control rod blades to travel between
11 fuel assemblies, helping to minimize any potential for
12 binding or prevention of movement of the rods upon
13 demand. So we've slightly increased the pitch from
14 fuel bundle to fuel bundle, gives plenty of margin for
15 control rod movement.

16 We're also using advancements in the fuel
17 channels that helps to minimize any chance of
18 deformation of fuel channels. We are collecting
19 operating experience on those channels today. We have
20 no evidence of shadow corrosion on those NSF type
21 channels that we're using.

22 And these, this type of design, it also
23 helps ensure we have a very high degree of shutdown
24 margin as well. Can you move to the next slide,
25 please?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, just touching on some of the
2 associated regulations, and then I'll continue through
3 the defense lines as well. So 50.62, 10 CFR 50.62 was
4 one of the regulations that was addressed in the
5 licensing topical report.

6 In that regulation, one of the explicit
7 requirements is for alternate rod insertion system.
8 And we do have the ARI system, which we have
9 experience with on our current operating fleet.

10 And in the slide here, I have the brief
11 summary of the hydraulic scram function or hydraulic
12 ability to insert the control rods.

13 So our control rods are driven on the
14 BWRX-300 by fine motion control rod drives. Our older
15 plants have hydraulic only or locking piston control
16 rod drives.

17 The BWRX-300, just like the ABWR and
18 ESBWR, apply a newer design, which also has operating
19 experience of fine motion control rod drives. They
20 have motors to, electric motors to provide the normal
21 control rod movement in both directions, insert and
22 withdraw, for very small and fine motion. That's for
23 normal power control and also serves as a backup to
24 hydraulics for quick shutdown.

25 The hydraulics are there on this design,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 unlike the current operating fleet of only hydraulic,
2 the hydraulics on this design, as water hydraulics,
3 are only there for the purpose of fast shutdown, i.e.,
4 scram.

5 So we use pressurized water in
6 accumulators, stored energy. Many of you, if not all
7 of you, are probably quite familiar with the operating
8 fleet of the HCU's.

9 So we have redundancy by providing
10 hydraulic control units. Two control rods are aligned
11 to each HCU. We have, the HCU's are actuated by a
12 reactor protection system. And in the BWRX-300, we
13 also have a diverse means.

14 Then, we additionally have a ARI function
15 that will depressurize the scram air header if
16 necessary to provide further backup for insertion or
17 reactor scram if needed.

18 So this is somewhat of a busy slide. But
19 it's somewhat busy because we have many ways to get to
20 the control rods. And so I'll run back through again,
21 because I maybe jumped around a little.

22 Control rods normally inserted and
23 withdrawn by electric motors through the fine motion
24 control rod drives. They're inserted with hydraulics
25 for fast shutdown in a scram. The hydraulics are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 actuated by our reactor protection system. And
2 there's also a diverse means to actuate them.

3 In addition to those two means to actuate
4 the hydraulic control units, if there's a common cause
5 failure of hydraulic control unit actuation, there's
6 a diverse ARI, depressurization to cause the scram as
7 well.

8 So that's basically three ways to get the
9 hydraulics and the electric motors, also in addition
10 to their normal power control, can provide a backup to
11 insertion during the case of a failed scram. So
12 that's a little, brief summary of a little complicated
13 discussion.

14 But in addition, at the very bottom of
15 this slide, for those who are quite familiar with the
16 operating fleet hydraulics, one of the possible, not
17 likely but possible, failure modes was hydraulic lock
18 of the scram discharge volume.

19 I'll note that on this design we've
20 additionally incorporated a way to remove the scram
21 discharge volume. And it's just a one-way insertion
22 of hydraulics. Okay. If we could, move to the next
23 slide, please.

24 MEMBER MARCH-LEUBA: Jose. By that, you
25 mean instead of discharging into, a dedicated volume

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 will discharge into the vessel, correct?

2 MR. HINDS: That is correct. Okay. I'll
3 keep on moving. And I'll be glad to take questions
4 any time.

5 So defense line 2 is -- so defense line 1
6 is more programmatic and fundamental features and
7 design decisions, such as the in-lattice.

8 Once we get into defense line 2, 3, and 4,
9 we have systems and features that may actuate or
10 control to improve safety of the plant or to respond
11 to an event.

12 And defense line 2, that includes
13 functions that normally control the plant, such as
14 pressure control, water level control, things, rod
15 control, normal control features of the plant.

16 And we have a high level of quality
17 applied to defense line 2 than just plain non-safety
18 equipment, but not to the pedigree of the full safety-
19 related or safety class 1 equipment. However, it does
20 have enhanced quality and reliability features applied
21 to the design and the procurement.

22 The defense line 2 is, includes functions
23 to control or stop postulated initiating events. You
24 know, I mentioned pressure control and level control,
25 key features in control of the plant.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So the quality that we place and the
2 redundancy that we place into these systems minimizes
3 postulated initiating events that could challenge the
4 safety class 1 or safety-related systems that will be
5 in defense line 3 as I get to that.

6 Defense line 2 is independent from defense
7 line 3 all the way through, provides a high
8 reliability and, again, reduces the challenges to the
9 plant from a trip perspective. If you could, go to
10 the next slide, please.

11 Here's another design feature just
12 highlighting, of course, the reactor pressure vessel.
13 Just to, there are many things to talk about on the
14 reactor pressure vessel, but I'll only highlight a
15 couple of them.

16 One is, this is a natural circulating
17 boiling water reactor similar to the ESBWR but smaller
18 in size. So we took ESBWR concept, and we scaled it
19 to a nominal 300-megawatt electric power plant.

20 However, many of the features that come
21 with natural circulation are quite helpful in
22 mitigating events.

23 So the part I'll highlight here is large
24 steam volume. It's a higher volume to power ratio as
25 compared to, for example, the ESBWR. So the high

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 volume to power ratio minimizes any pressurization
2 transients.

3 However, in part of our defense line 1
4 design decisions, we added conservatism in. Even
5 though we have that larger volume to power ratio, we
6 have chosen to raise the design pressure from our
7 historical values such that we have additional margin
8 in the design pressure of the reactor vessel, and we
9 have a higher volume to power ratio. So, therefore,
10 the pressurization transients are not a challenge for
11 this plant.

12 And we've already gone through a previous
13 LTR, as listed here, for the reactor pressure vessel
14 isolation and overpressure protection. However, that
15 overpressure or that volume to power ratio and the
16 minimization of pressurization helps also in
17 reactivity abnormal events such as a slow or failed
18 scram. Okay. If you could, go to the next slide,
19 please.

20 Defense line 3 is the heart of safety.
21 That's our highest safety class right in the middle of
22 our defense-in-depth and posture. So safety class 1
23 or safety-related systems reside in defense line 3.

24 And it includes the functions to mitigate
25 a postulated initiating event, assures the plant is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 placed in a safe condition, assigned the highest
2 safety class. And we ensure that we have independence
3 from defense line 2, and for that matter, independence
4 from defense line 4 as well.

5 MEMBER MARCH-LEUBA: Dave, this
6 independence from DL 2, is there going to, do you --
7 obviously, you have the final design. But you won't
8 have any detailed communications between the control
9 system and the protection system, DL 2 and DL 3?

10 MR. HINDS: They are separate digital
11 control systems. The only potential would be for
12 protected communication, for example, one-way
13 information sharing, but not -- there will be
14 protected communications, if any. They are completely
15 separate systems.

16 MEMBER MARCH-LEUBA: Most likely, I would
17 imagine, the communication will go from DL 3, if a
18 scram happens, and you pass it to the control system.

19 MR. HINDS: Yes.

20 MEMBER MARCH-LEUBA: And those should be
21 unidirectional.

22 MR. HINDS: Yes.

23 MEMBER MARCH-LEUBA: And when we review
24 the details, we are going to be very interested on the
25 architecture and make sure that those unidirectional

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 communications are really unidirectional.

2 MR. HINDS: I understand.

3 MEMBER MARCH-LEUBA: Okay.

4 MEMBER BROWN: By that he means not
5 software configured. This is Charlie.

6 MR. HINDS: Okay. I understand.

7 MEMBER BROWN: Hardware, data diode type,
8 one way, not configured by software.

9 MR. HINDS: Okay. I understand. And
10 we'll have, for any license submittal, we would go
11 into, of course, great detail on the I&C architecture
12 and address those features. But I understand your
13 comments. Thank you.

14 MEMBER BROWN: And I presume that will be
15 covered in the, when we finally get to a reactor
16 protection system topical report or whatever you're
17 going to issue for that, will provide that as well as
18 the information of how you intend to achieve, not the
19 detailed parts, obviously, but the architecture
20 approach --

21 MR. HINDS: Yes, for future licensing
22 submittals, yes. Now, there's further decisions to be
23 made as to whether they would be under a licensing
24 topical report or under an actual application. But,
25 yes, I agree with your statement.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Okay. That's fine. I just
2 wondered where it's going to be, because, I mean, when
3 I went through the other, these other documents, so
4 far there's -- you talk about the RPS as an RPS and
5 you say what it's going to do, but there's no other
6 details. That's all.

7 MR. HINDS: That is correct. Your review
8 is correct. So I agree with your statements.

9 MEMBER BROWN: Okay. Thank you.

10 MR. HINDS: Okay. If you could, move to
11 the next slide, please.

12 Okay. One of the key systems within the
13 highest of safety classes, in addition to the reactor
14 protection system, is the isolation condenser system.

15 So I mentioned that the RPV itself has
16 certain pressure mitigating features by its volume to
17 power ratio. However, the pressure control is
18 primarily at least in the safety class 1. In an event
19 where we have an isolation, we use an isolation
20 condenser system.

21 We inherited the design from ESBWR as far
22 as the condensers themselves. We are applying three
23 trains of the same size of condensers that we applied
24 on ESBWR.

25 So, by doing that, with this smaller power

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 plant, we have a very large margin and significant
2 capacity for minimizing any pressurization transients
3 and controlling any challenge to pressurization by use
4 of the isolation condenser system.

5 It primarily operates in a passive mode.
6 This is a very simplified figure that doesn't show the
7 valves. There are valves in here.

8 But all it takes to actuate the system is
9 the opening of one valve in the return line, the
10 condensate return line to the vessel. And there are
11 parallel, diverse means in that condensate return line
12 to actuate. And in the worst case, if we were to lose
13 all power and signal, it fails in the in-service
14 condition.

15 And again, there's redundancy here as well
16 with a very simple actuating system. Once placed in
17 service, it stays in service and requires no support
18 features once placed in service.

19 Again, there's three trains. We have them
20 as a staggered operating points for the automatic
21 initiations on pressure such that they don't all come
22 into service at the same time. But in a severe event
23 where, such as a complete failure to scram, we would
24 expect to hit all three and use them to mitigate the
25 event.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Again, failsafe, simple system. And
2 again, we drew upon the program from ESBWR, which
3 included a full-scale test of these isolation
4 condensers. And we also covered this design feature
5 in our previous LTR for overpressure protection as
6 well.

7 MEMBER MARCH-LEUBA: Dave, this is Jose
8 again. Typically when we do these things, we have
9 competing requirements. From the thermal-hydraulic
10 point of view, it's super exciting to have extra
11 capacity because you can cool down better. You can
12 cool down more and you can cool down with failures.

13 From the criticality safety point of view,
14 you can bring the core to cold. And I'm going to ask
15 you to remind us that no matter how cold the core
16 gets, even with two blades stuck out, you are not
17 going to return to power. That's your requirement, is
18 that correct?

19 MR. HINDS: That's correct. We, as I've
20 mentioned before when I was talking about the
21 hydraulic control units, we have one hydraulic control
22 unit aligned to two control rod drives. And we assume
23 a failure of one of those hydraulic control units and
24 still have adequate shutdown margin.

25 We have ample shutdown margin. In fact,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I think we'll be fine with more than that. However,
2 that's what our analyzed state is, is two stuck-out
3 control rods with ample shutdown margin.

4 MEMBER MARCH-LEUBA: And you plan to do
5 this with all three ICS running at full blast and
6 making the core as cold as it can possibly get?

7 MR. HINDS: Yes, within reason, yes. So
8 yes, agree with your statement.

9 MEMBER MARCH-LEUBA: Thank you.

10 MR. HINDS: So we do have, you know,
11 temperature extremes on our analysis. I think that's
12 permanently addressing your point. And I'll note that
13 we do include some design enhancements from the ESBWR.
14 To get into details on those, if you're interested in
15 getting that level of detail, we'd prefer to discuss
16 that in the closed session.

17 But it does help with, I'll just simply
18 state that those design enhancements improve the
19 pressure control while helping with the reactivity
20 control. So this system helps with pressure control
21 while at the same time assisting with reactivity
22 control. Okay, if we could go to the next slide,
23 please.

24 MEMBER KIRCHNER: David, this is Walt
25 Kirchner. So going back to your statement, you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 mentioned there's defense line 3 is the highest
2 quality class, I'm -- or safety class. I just assume
3 that the reaction coolant pressure boundary as
4 illustrated in this diagram then would also be of the
5 highest quality.

6 MR. HINDS: That's correct.

7 MEMBER KIRCHNER: Safety-related if you're
8 using 10 CFR 50 or 52 definitions.

9 MR. HINDS: Yes, that is correct. And
10 we've applied --

11 MEMBER KIRCHNER: Thank you.

12 MR. HINDS: We've applied the IAEA
13 approach, we've been using terminology of safety class
14 I, II, and III. But I agree with your statement. And
15 so this system is a safety class I or safety-related
16 system highest safety class, that's correct.

17 MEMBER BLEY: David, this is Dennis Bley.
18 I want to go back to what Jose was talking about. And
19 I don't think it's for this current report, but later
20 when we get to this design cert review, you mentioned
21 that the intent is to have maximum ICS occur.

22 You know, in the past, at least in some
23 places, people have worried that that was too much and
24 developed thoughts about how to cut it back, which can
25 lead to significant problems. We'll be interested in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 discussing that when we get into details, that system.

2 MR. HINDS: Okay, thank you. And the part
3 when I mentioned, alluded to some design enhancements,
4 and I'll be glad to discuss a little further in a
5 closed session, will help with your question as well.
6 So I understand your question. And that staggered set
7 point that I mentioned earlier, that also helps with
8 your question as well. But I understand it.

9 So we have evaluated inadvertent IC
10 actuation as part of our standard suite of analysis,
11 and so I understand. Okay.

12 MR. SCHULTZ: Dave, Steve Schultz. In the
13 system that you've described, the return valves fail
14 open, and also they're -- the system is failsafe.
15 With regard to operator action, any operator actions
16 that are proposed or could take place that would close
17 those valves?

18 MR. HINDS: No, the operator is not --
19 okay so I think you asked that, I'll address your
20 question in two ways, and hopefully one way will
21 answer you. It is one is that the system completely
22 actuates without operator action. I think the other
23 side of your question is could the operator cause a
24 problem by disabling the safety function.

25 We have that as a design requirement to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 ensure that the proper human factors, of course there
2 will be operators and the operators will be expected
3 to be aware of this situation and monitor. Part of
4 our human factors design will take into account the
5 human reliability analysis and potential that an
6 operator could disable a safety function.

7 And our intent that we're still working
8 through is that that would not occur. It is an
9 automated system and so I do not think that's
10 difficult to achieve.

11 MR. SCHULTZ: Good, thank you.

12 MR. HINDS: Okay, thank you. If we could
13 move to the next slide, please. Okay, so now we're up
14 to the backup defense behind the safety-related
15 systems, which should hopefully never be called upon.
16 So, defense line 4-alpha, and we've take the IAEA
17 defense lines 4 and split to 4-alpha and -bravo.
18 Won't talk much about 4-bravo, it's more like the flex
19 or deep defense-in-depth.

20 But in the defense line 4-alpha, we have
21 functions to mitigate the postulated initiating event,
22 similar to the goals of defense line 3, but it's in a
23 backup way. And this is there to mitigate times when
24 defense line 3 or the safety-related systems are
25 called upon and experience a common cause failure.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 They're ensured -- they also ensure that the plant is
2 placed in a safe state.

3 If you go to the next slide, please.

4 MEMBER MARCH-LEUBA: Dave, go back to this
5 slide.

6 MR. HINDS: Sure.

7 MEMBER MARCH-LEUBA: And have you ever
8 seen a non-proprietary setting, an example so we can
9 think what you're --

10 MR. HINDS: Yes.

11 MEMBER MARCH-LEUBA: We can focus on what
12 you're talking about?

13 MR. HINDS: Certainly, ARI. So I touched
14 on, because I talked about many features of the
15 control rod movement in an earlier slide, I hit may
16 defense lines. So I hope I didn't confuse things
17 there, I was worried about that slide.

18 So with the control rod insertion, I hit
19 many defense lines there. If you remember, there's
20 many ways to insert the control rods. So an example
21 of the defense line 4-alpha method to insert the
22 control rods is the ARI. And then there's some others
23 where we would get a little further into proprietary.
24 But, and I'll be glad to discuss further. But that's
25 an example, ARI, alternate rod insertion.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER MARCH-LEUBA: Okay, I'll make a
2 note to ask you in the closed session, because I'm
3 interested. Is this defense-in-depth actions going to
4 be performed by a non-safety-grade computer?

5 MR. HINDS: They are a lower safety class
6 than what in the US we'd call safety-related.
7 However, we are applying the IAEA approach, so it's
8 not just taken all the way back to what you would
9 think of non-safety as a graded approach to quality.
10 So we've applied a safety class II, which a not all
11 the way to the level of safety-related, but not all
12 the way down to the level of non-safety-related and
13 augmented quality.

14 MEMBER MARCH-LEUBA: So in I&C lingo, it
15 will be redundant but not diverse?

16 MR. HINDS: This platform in defense line
17 4 is diverse from defense line 3.

18 MEMBER MARCH-LEUBA: All right, but within
19 itself, it will be more than one channel, hopefully
20 three. But they will all be the same type of
21 computer.

22 MR. HINDS: Correct, this is appropriate
23 level of redundancy, but it could be all the same, it
24 could be all the same technology within the
25 redundancy.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER MARCH-LEUBA: Okay, thank you.
2 We'll look at those details with the next --

3 MR. HINDS: Okay.

4 MEMBER MARCH-LEUBA: Yes, I'm sure.

5 MR. HINDS: Okay, thank you. All right,
6 next slide please. Okay, just a little bit into --
7 further into the ATWS rule, 50.62. These are -- this
8 is really a restatement of ATWS rule, which I'm sure
9 you're well aware of. So, but only pulling out the
10 portions of the ATWS rule 50.62 which apply to boiling
11 water reactors specifically, ARI, SLC, and automatic
12 recirc pump trip. Can you go to the next slide
13 please.

14 Okay, as far as going through those
15 features. So automatic recirc pump trip. As I stated
16 earlier, this is a natural circulating power plant, so
17 therefore the automatic recirc pump trip is deemed to
18 be not technical relevant in that we do not have
19 recirc pumps to trip, so therefore we do not include
20 a recirc pump trip feature.

21 However, the purpose of the recirc pump
22 trip is to minimize a reactivity in the case of a
23 failure to scram, and we do have other features to
24 minimize reactivity in a similar fashion.

25 So basically we can control water level

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 within the reactor, and the enhancements that I
2 mentioned for the isolation condenser system that I
3 can discuss further in the closed session help in this
4 respect as well. We, the feedwater system is
5 controlled as well to minimize reactivity effects.
6 Okay, if we could go to the next slide, please.

7 So the SRP, we just stayed a little bit
8 out of the SRP, and I'm sure the NRC will cover this
9 further, so I'll go over it very quickly, is the SRP
10 related to 15.8, related to the ATWS rule. And there
11 is a statement in there, in the SRP, that talking
12 about evolutionary plants, which we think the BWRX-300
13 is an evolutionary plant.

14 And it says that you could have a diverse
15 scram system and satisfying design and quality
16 assurance criteria. And/or you could demonstrate the
17 consequences of the ATWS event or within acceptable
18 values.

19 In keeping with our defense-in-depth
20 approach, we've addressed both of these so we do have
21 a diverse means of shutdown, the details of which I've
22 kind of alluded to at a very high level, but I can
23 talk a little further in the closed session. But we
24 do have a diverse means to shut down. I talked about
25 it a little bit in a very high level in the prior

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 slides. We do have ARI and we do have electric motors
2 to move the control rods that are in addition to the
3 normal hydraulic scram.

4 I've listed there, a little bit to the
5 question a minute ago, where ARI and electric motor
6 run-in are included in defense line 4-alpha. And
7 there's multiple defense lines that are ensuring the
8 hydraulic insertion occurs as well in defense line 2,
9 3, and 4-alpha.

10 MEMBER BROWN: Does the next -- this is
11 Charlie Brown.

12 MR. HINDS: Yes.

13 MEMBER BROWN: Does the fine motor control
14 drive, is that able to insert rods at a fast enough
15 speed to handle the reactivity transience? Is that --
16 it's intended to do that as well?

17 MR. HINDS: Yes. So it's -- great
18 question. It's, during normal operation, we want the
19 fine movement to minimize the reactivity effects at
20 high power, for example. However, the speed is
21 calibrated such that we have an insertion capability
22 that is fast enough to handle the complete failure of
23 all of the other means to get the control rods in.

24 So if all of those other means that I
25 discussed on the hydraulic actuation, as well as the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 ARI, all of them fail, the control rod insertion by
2 motors is fast enough. And that's coupling that with
3 the pressure control features of the isolation
4 condenser system that I just talked about earlier. So
5 short answer is yes, it is fast enough.

6 MEMBER BROWN: Is, does that -- based on
7 your comments, does that mean it has more than one
8 speed? In other words, for insertion it can go faster
9 than you would -- than you would necessarily for your
10 fine motion control during normal operations?

11 MR. HINDS: We're actually still working
12 on whether we're going to adjust the speed any during
13 normal operation, but we do have this setting for the
14 rapid insertion, as we discussed here. We're planning
15 to use servomotors, which have a capability to move at
16 variable speeds. So it's likely that we will have a
17 slower speed during high power operation, but we're
18 still working through making that decision. But it's
19 an excellent question.

20 MEMBER BROWN: Okay, thank you.

21 MR. HINDS: Okay, if we can move to the
22 next slide please, I'll try to wrap up.

23 MEMBER MARCH-LEUBA: While we're on the
24 open session, let me just say that we, ACRS, are going
25 to be terribly interested. I know you, the design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 team, has spent a lot of time thinking about ATWS and
2 during the review, both the staff and ACRS are going
3 to be very interested in this topic when you have the
4 final design and the final calculations to ensure that
5 nothing can go wrong. Just putting it on the record,
6 and we'll talk more about this in the closed session.

7 MR. HINDS: Okay, all right, understand.
8 So just a brief summary here, don't -- hopefully don't
9 need to go into much detail. But here's the listing
10 of regulatory acceptance criteria, all pulled from
11 regulations. So I don't think any, should be any
12 surprises here. So we have pressure requirements,
13 fuel integrity, containment integrity, rad release,
14 and ensuring that shutdown and long-term cooling are
15 all evaluated and analyzed.

16 Okay, if no questions there, I'll keep on
17 moving and trying to keep the time moving. Okay, and
18 so I think this is the last slide in this --

19 MEMBER BROWN: Sir, can I ask one other
20 question? I kind of forgot.

21 MR. HINDS: Sure.

22 MEMBER BROWN: You mentioned this as back
23 on the speed of the time motion motor controls.

24 MR. HINDS: Yes.

25 MEMBER BROWN: You mentioned that that was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 going to be servos.

2 MR. HINDS: That's our intent, yes.

3 MEMBER BROWN: Okay. And --

4 MR. HINDS: We do have some options there
5 where we have some motors that we've used previously
6 that are stepper motors and we have some motors we've
7 used previously that are induction. But our current
8 preference is servos. We've not procured them yet, so
9 there is a chance that that would change, but our
10 current intent is servomotors.

11 MEMBER BROWN: The reason I ask is that
12 servomotors don't always have the same torque
13 characteristics that an induction motor or even a step
14 motor. I'm familiar with both the step motors, I had
15 rod control systems that were step motors in my old
16 plants in the Navy, in one of the design plants. And
17 the motor control were basically reluctance motors,
18 which you could control and make sure they had enough
19 torque.

20 But servomotors don't always have a lot of
21 torque since they're pretty fine control type devices.
22 That was my only question is are those really
23 satisfactory for a higher speed type insertion where
24 you might need to generate some additional torque.
25 That's the only thought process I had.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HINDS: Yes, we have applied torque
2 specifications to our motor supplier and not had any
3 problem to date with aligning to get a supplier for
4 that. But I agree with your focus on that topic. We
5 do not think we'll have a problem meeting it.

6 MEMBER BROWN: Okay.

7 MR. HINDS: But again, we do have further
8 work to be done and through the procurement cycle, but
9 we do have a supplier that we think can meet our
10 requirements there on torque.

11 MEMBER BROWN: Okay, thank you.

12 MR. HINDS: Okay.

13 MEMBER MARCH-LEUBA: The rules of the game
14 -- this is Jose -- the rules of the game is, we don't
15 design the reactor for you, but in my opinion, I would
16 go for the highest torque, the biggest force you can
17 have on that FMC, I mean, the fine motion control rod
18 drive, the electric motors. So that even if there is
19 some binding, you can push the rod in. And I can
20 control the velocity by stepping it slowly with a step
21 motor.

22 Just think about it. I mean, the safest
23 thing is to have the high -- the biggest motor you can
24 find that will push the rod in no matter what. And --
25 okay, that's it. I'm not helping you design your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reactor, but just giving you some hints.

2 MR. HINDS: Okay. Okay, thank you for the
3 comment, I understand the nature of it. Thank you.

4 So the final slide here in this segment is
5 we did highlight another one of the regulations, the
6 GDC 27, and we just highlight it here because we go
7 through in the LTR and evaluate all the appropriate
8 GDCs and regulatory documents associated with
9 reactivity control. And I'll highlight this one in
10 addition to the ATWS rule, just because we had an
11 alternate means of compliance or actually an
12 exception.

13 And it's primarily just the wording of the
14 GDC and that the GDC is, so you can see above, the
15 reactivity control system shall be designed to have a
16 combined capability in conjunction with poise and
17 addition by ECCS of reliability, the reliability
18 controlling reactivity changes to assure under
19 postulated access. Anyway, you can read it.

20 We changed the words but meet the intent,
21 just because the words didn't explicitly align with
22 our design since we are, as stated in our prior
23 submitted LTR and reviewed LTR on the RPV isolation
24 and overpressure protection. We do not rely upon ECCS
25 injection systems and associated borated coolant.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And therefore the wording of this did not
2 explicitly apply, so we've reworded it but still meet
3 the intent such that core coolability is maintained
4 for a locus. Because we have sufficient water
5 inventory, and we're assuring that through the RPV
6 isolation. So we preserve the coolant and we do not
7 have a borated solution and there's no concern with
8 ECCS injection diluting a borated system and causing
9 a reactivity excursion.

10 So this -- I think, we feel like was
11 written for different type designs, and so we've
12 applied a PDC to substitute for the GDC, and that's an
13 exception stated in the LTR.

14 MEMBER BROWN: Presume when you do your
15 submittals in whatever form they are, they will
16 somehow address the fact whether the plant will be
17 able to be shut down under all temperature conditions,
18 the sub-critical as opposed to perking along at low
19 power for weeks?

20 MR. HINDS: Yes, and as I stated before,
21 as we do our shutdown margin calculations with the two
22 highest worth control rods associated with an HCU
23 fully withdrawn and we have ample shutdown margin.
24 And we also have a temperature range which we apply to
25 that, and so I think we will not have a problem

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 meeting the point that you're alluding to.

2 MEMBER BROWN: Okay, thank you.

3 MR. HINDS: Okay. That's it for the slide
4 presentation, and I think I've exceeded my time, I'm
5 sorry.

6 MEMBER MARCH-LEUBA: Well, you did good.
7 Just as a reminder to the members, we are going to
8 have an open presentation by the staff, and then we
9 are going to go to the closed session to see some
10 details of calculations by GEH. And we have plenty of
11 time.

12 Our plan is to read the letter, the ACRS
13 letter in the open session, so we will have the staff
14 present open session here. We will all, that are
15 allowed to, move to the closed session to see those
16 calculations, and then we'll come back to the open
17 session to read the letter.

18 And on that line, GE, Zena is going to
19 send you the final copy of the letter, because we've
20 made some modifications based on members' inputs. And
21 if you could give it a quick read to make sure the
22 modifications did not put any proprietary information
23 on it, we would appreciate it. And we have to do it
24 real fast.

25 So staff, can you start your presentation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 please.

2 MR. NOLAN: Okay, thank you. This is Ryan
3 Nolan. I'm in the Nuclear Methods and Systems and New
4 Reactors Branch in NRR, and I'll be presenting the
5 staff's presentation for our review of the BWRX-300
6 reactivity control topical report. And I will be
7 assisted by Marieliz Johnson, who is helping me with
8 the slides today. Marieliz, you can go to the next
9 slide.

10 So here's an outline of the presentation
11 today. We'll quickly go through the review team, a
12 little bit of background on the BWRX-300. The bulk of
13 the presentation will focus on the staff's review of
14 specific regulatory requirements, and we'll wrap up
15 with the conclusion.

16 These slides are very similar to what you
17 saw in the subcommittee meeting. However, I plan on
18 just touching the highlights and not going into the
19 full detail that we did in the subcommittee meeting.
20 However, if there are questions we can certainly go
21 into more details. Next slide, Marieliz.

22 So this is just to present the review
23 team, many of which are here to support, answer any
24 questions that I cannot. So with that, you can move
25 to the next slide, Marieliz.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So a quick background. BWRX-300, it's a
2 300-megawatt electric SMR. It's natural circulation,
3 uses a passive cooling isolation condenser. The
4 control rods are typical BWR control rods that we're
5 all familiar with.

6 This design does include some defense-in-
7 depth and diverse features with respect to reactivity
8 control for ensuring the reactor is properly
9 controlled and shut down. And this topical report
10 goes through specific requirements, design
11 requirements, as well as assesses regulatory
12 requirements specific to reactivity control functions.
13 Next slide, Marieliz.

14 So here's a short list of the specific
15 design features that are included, or and systems that
16 are included in the BWRX-300 design. I'll just
17 briefly step through each one. The control rod system
18 is made up of control rods, we've already talked about
19 them, GE provided a good overview, as well as control
20 rod drives.

21 The drives are split up into the safety-
22 related rapid insertion function that's performed
23 hydraulically, as well as a non-safety-related fine
24 motion control function that uses electric motors and
25 is used for normal operation as well as a scram

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 follow-up function as a backup means.

2 Also, there's an alternate rod insertion
3 system. This provides a diverse means of a hydraulic
4 scram in the event of an HCU failure. And it uses
5 energized to actuate pilot valves. And so it's an
6 alternate means to vent the control air. Next slide,
7 Marieliz.

8 This is a list of the regulations that we
9 addressed in the safety evaluation. I'm going to go
10 through each. I'll go through the ATWS rule first,
11 and then I will go through each of the GDCs that's
12 underlined. I do not have specific slides on the GDCs
13 which are not underlined. This is mainly due to the
14 means for the requirements or design requirements on
15 certain systems for meeting these requirements are
16 fairly traditional and straightforward.

17 And so just at a high level, the GDCs
18 which are not underlined, the staff found that the
19 approaches described in the topical report were
20 consistent with the associated GDCs, and we found
21 those to be acceptable. So with that, we'll talk
22 about 50.62 on the next slide. Marieliz.

23 So the topical report defines the
24 acceptance criteria for evaluating the effectiveness
25 of the reactivity control systems and functions. It's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 listed here on this slide. These are consistent with
2 the SRP, as well as it's consistent with the
3 acceptance criteria that the operating fleet has used
4 to evaluate the ATWS transients. Next slide,
5 Marieliz.

6 So first, specific requirement for 50.62
7 related to BWRs is C3. This requires all BWRs to have
8 an alternate rod insertion system that's diverse from
9 the reactor trip system. This is fairly
10 straightforward because the BWRX-300 uses a fairly
11 traditional ARI system. They commit to having one,
12 and so the staff found that that approach is
13 acceptable and consistent with the requirement. Next
14 slide.

15 50.62(c)(4) requires BWRs to have a
16 standby liquid control for injection into the vessel.
17 The topical report specifies that the design will meet
18 the risk goals for 50.62, which is a probability of an
19 ATWS is less than one times ten to the minus five per
20 reactor year. This is achieved through diverse scram
21 actuation logic, diverse rod motor force, as well as
22 a couple other things that is proprietary.

23 The staff found that this risk goal is
24 consistent with the intent of 50.62, and this could be
25 used as -- to support a future exemption if so

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 desired. We did write a limitation and condition on
2 this, next slide. We wrote several limitations and
3 conditions in certain areas where the topical report
4 maybe didn't go into a lot of detail as what type of
5 analysis will be performed in the future.

6 And so we just wanted to clarify some of
7 the staff's expectations or what we would expect to
8 demonstrate some of the statements that were included
9 in the topical report. So specific to ATWS, we have
10 a limitation and condition to provide a reliability
11 analysis that takes into account operating experience
12 in order to demonstrate that the probability of an
13 ATWS is less than one times ten to the minus five per
14 reactor year, demonstrating the intent of the rule is
15 satisfied.

16 50.62(c)(5) requires BWRs to automatically
17 trip the recirculation pumps under ATWS conditions.
18 This one as well is fairly straightforward. It's not
19 applicable to the BWRX-300 because it is a natural
20 circulation -- a plant does not have recirc pumps.
21 And so this regulation is not applicable to the BWRX-
22 300. However, the design does have compensating
23 measures, which is proprietary, and we did discuss at
24 the subcommittee meeting. Next slide.

25 So now we're going to step through some of

1 the general design criteria. The first one is GDC 12,
2 which requires control and protection systems to
3 ensure that oscillations that could exceed the SAFDLs
4 are prevented or they're detected and suppressed.

5 The topical report specifies that the
6 BWRX-300 will meet GDC 12 through several design
7 features, some of which are included here, which is a
8 small core, sort of a newer of form of orifice design,
9 a coupled power to flow response, as well as the
10 design of the RPB chimney. We wrote a limitation
11 condition on this as well. Next slide.

12 And this is really just to ensure that the
13 analysis which demonstrates some of the statements
14 made in the topical report is performed using an
15 approved method. And that's really the intent of this
16 limitation condition, is to make sure that there is an
17 appropriate analysis to demonstrate GDC 12 is met.

18 MEMBER MARCH-LEUBA: Ryan, this is Jose.
19 We talked about some of this in the subcommittee.
20 When we say approved method, do we need to have a
21 topical report that says NRC approves it for use in
22 the BWRX-300? Or an approved method for ESBWR is
23 acceptable? Or does it need to be extended? Can you
24 talk a little bit about approved methods?

25 MR. NOLAN: Yeah, yeah, we did talk about

1 it a little internally as well, just briefly. And
2 there needs to be demonstration that the topical
3 report is applicable to the BWRX-300. I think there's
4 some flexibility in how that's done. Traditionally
5 that is done through topical reports.

6 But I think the staff is open and is
7 flexible to how that is documented. So I think at a
8 minimum it needs to be documented somewhere.
9 Traditionally it's the topical report, but it probably
10 doesn't have to be.

11 MEMBER MARCH-LEUBA: Okay, so we'll
12 revisit this in the future, and it's for GEH and the
13 staff to negotiate what will be acceptable. Clearly,
14 I think we all agree, even GEH, that the
15 recommendation needs to be performed. And the
16 question is how we do it with minimal pain. Okay,
17 thank you.

18 MR. NOLAN: Certainly. Next slide. So
19 GDC 26, it requires two independent reactivity control
20 systems based on different design principles. The
21 topical report specifies that the BWRX-300 will meet
22 the GDC by providing control rods, which is used for
23 normal operations including AOs and addresses
24 malfunctions, as well as holding the reactor
25 subcritical under cold conditions.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And then the feedwater level control
2 system is used to satisfy bravo above, which, you
3 know, is used to adjust the reactivity control during
4 planned and normal power outages. And this of course
5 is something that we will review obviously in more
6 detail once we get an application. But as described
7 in the topical report, it is consistent, the approach
8 is consistent with GDC 26.

9 So GDC 27, the intent of the GDC is to
10 require reactor designs to achieve and maintain
11 subcriticality, and this is using only safety-related
12 equipment following accidents, as well as addressing,
13 taking into account single failures. And as was
14 discussed by GEH in their presentation, they proposed
15 a PDC.

16 It maintains fundamentally all of the same
17 information that is in the GDC, with a focus of just
18 satisfying the intent of that regulation. And as was
19 discussed already, the BWRX-300 will use the control
20 rods to ensure that the reactor remains subcritical
21 under cold conditions.

22 We do expect to see an analysis in the
23 future which would demonstrate this. That analysis
24 would look at both, you know, instantaneous shutdown
25 margin, as well as, you know, a long-term shutdown

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 margin, which would account for, you know, any
2 cooldown from the isolation condensers.

3 MEMBER KIRCHNER: So Ryan, this is Walt
4 Kirchner. Just a process question. So they are
5 proposing a PDC in lieu of the GDC, and then in the
6 actual review of an application, then this would
7 require a formal exemption.

8 MR. NOLAN: That's correct. I think, you
9 know, as we, you know, we've been reviewing some
10 interesting designs recently and some exemptions are
11 maybe more administrative in nature and less
12 technical, and perhaps this would fall into that
13 category.

14 So technically from a legal perspective,
15 yes, it would require an exemption. However, I don't
16 think it raises any substantial technical issues or
17 concerns at this point. It's more just a matter of
18 documenting it.

19 MEMBER KIRCHNER: Yeah, and analysis will
20 demonstrate that they have the rod work necessary to
21 keep it shut down as in subcritical through a range of
22 conditions. And it's been brought up earlier, you
23 know, obviously it's the temperature, it's the
24 cooldown that would be something to look at in the
25 future.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Okay, I'm just checking how you're doing
2 this now. And then this would be consistent with the
3 requirements also of 10 CFR 50 or 52 then in terms of
4 a safe shutdown condition.

5 MR. NOLAN: That's correct.

6 MEMBER KIRCHNER: Yeah. I noticed that
7 the GE used the, I think it's the IAEA language, they
8 talked about a safe state. But I suspect for the
9 staff, you would be looking for what's required as for
10 10 CFR 50 or 52.

11 MR. NOLAN: That's correct. And we
12 documented in our safety evaluation specifically the
13 interpretation that the staff has on GDC 27. And that
14 was pulled from the recent SECY paper that we wrote
15 where we specifically state the intent is, and it's a
16 first bullet here, you know, the intent is to maintain
17 long-term subcriticality using only safety-related
18 equipment.

19 MEMBER KIRCHNER: Excellent, thank you.

20 MR. NOLAN: Yup. Next slide. So GDC 28
21 requires that reactivity control systems be designed
22 with appropriate limits on the amount and rate of
23 reactivity increase to ensure that reactivity
24 accidents can neither damage the reactor pressure
25 boundary or disrupt the core or the internal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 structures to a point where it impairs significantly
2 the capability to cool the core.

3 These types of events are called out
4 specifically in GDC 28. Some of them include, you
5 know, rod ejection, rod dropout, things of that
6 nature. The topical report states that the BWRX-300
7 will meet GDC 28, and this is through a series of
8 design features of the control rod drive system in its
9 ability to limit the rate and amount of reactivity
10 increase, as well as a safety analysis which
11 demonstrates compliance with the requirement.

12 And so this analysis would look at control
13 rod drop accidents, and in the topical report GE has
14 committed to using, you know, existing approved
15 methodologies to perform that analysis. It's a
16 similar analysis which was performed for the ESBWR.
17 And so the staff found this approach to be consistent
18 with the GDC.

19 This is the final limitation and condition
20 specific to a control rod drop accident. Again, this
21 is really to document the staff's expectation that
22 this analysis be performed using design-basis
23 assumptions, as well as using approved methods. And
24 we tried to write some flexibility into this condition
25 as well.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And so we provided also another option if
2 GE wants to go a different route that they could
3 demonstrate perhaps that the control rod accident is
4 a beyond-design-basis event and do a sort of a
5 different type of analysis and include that into
6 Chapter 19. Versus a, you know, more of a traditional
7 transient accident analysis, what we typically would
8 refer to as a Chapter 15 analysis.

9 And so that was just to establish sort of
10 expectations and provide some flexibility for the
11 future.

12 MEMBER MARCH-LEUBA: Is there a real need
13 to do that? I mean, we have all the methodology and
14 GEH knows how to do the rod drop calculations on a
15 cycle-specific basis. It doesn't save any money, it
16 doesn't make anything easier to try to change what
17 we're doing. In my opinion, yes, continue to do what
18 you're doing for operating reactors, which is every
19 cycle, just analyze the rod drop and do it.

20 MEMBER KIRCHNER: Yeah, just to add to
21 what Jose's saying, I would expect they're all -- that
22 the applicant, or GEH in particular here, I mean,
23 they're well experienced and must be totally up to
24 date on DG 1327, I don't remember what it now is as a
25 final reg guide, as Jose suggests. So it would seem

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to me that the path forward for expediting one's way
2 through the licensing review would be to stick with
3 the current rod drop analyses.

4 MR. NOLAN: Yes, I think the staff would
5 find that acceptable. The reason this is here is
6 really rooted in the way the original topical report
7 described this analysis, as well as some of the RAI
8 responses. And so we wanted to just be very clear of
9 what our expectation was that it be a design-basis
10 safety analysis, as well as I think GE proposes a one-
11 time analysis to bound cycle-by-cycle variations.

12 But we wanted to clarify that it doesn't
13 have to do that. And I think we felt that this
14 condition provided that flexibility and clarification
15 that we needed to make the finding from a compliance
16 perspective.

17 MEMBER MARCH-LEUBA: I agree with you,
18 Ryan, that either way it satisfies regulations. But
19 the path of least resistance is do the calculation and
20 recycle. You know how to do it. It doesn't -- maybe
21 we'll GE in the closed session, but I don't think it
22 adds that much cost to the -- I would keep doing what
23 has worked for 60 years, and that's my personal
24 opinion. Thank you.

25 MR. NOLAN: Yup, and that's what we're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 trying to communicate here. We would certainly find
2 the traditional approach acceptable. Next slide,
3 Marieliz. Yeah.

4 So to conclude here, taking into account
5 the limitations in conditions, the topical report
6 provides an acceptable description of the
7 requirements, the acceptance criteria, and the
8 regulatory basis for the design feature specific to
9 the reactivity control functions for the BWRX-300.

10 And just as a disclaimer, we don't have
11 the application in front of us at this time, we don't
12 have the detailed design in front of us. And we will
13 evaluate full regulatory compliance at the time that
14 that application or other future licensing activities
15 are submitted to the staff. If an applicant can't
16 demonstrate compliance, you know, we do expect them to
17 justify an exemption to a regulation.

18 And with that, that concludes my
19 presentation.

20 MEMBER MARCH-LEUBA: Great. Do we have
21 any questions for the staff in the open session? And
22 just a reminder, there's going to a GEH closed session
23 presentation, and there will not be a staff closed
24 session presentation, but they will be able to answer
25 questions if necessary.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So any questions?

2 MEMBER KIRCHNER: Jose, this is Walt
3 again. This is not a question, maybe a statement.
4 I'm just thinking about the fine motion control rod
5 drives and the discussion we had. If indeed they wind
6 up down the road designing that system such that it
7 has one speed for normal rod withdrawal during normal
8 operation and a different speed for insertion, then
9 one -- just I'm thinking aloud a little bit here --
10 then one worries that there's the potential for the
11 system to not operate, function correctly and run the
12 rods out at the higher motor speed or however they
13 design it.

14 I'm, just an observation, something to
15 look at down the road when there's an actual design,
16 a detailed design.

17 MEMBER MARCH-LEUBA: We would be very
18 interested on that. But my suspicion is that the rod
19 ejection would be faster than the speed the motor can
20 move at. But and I will bound it.

21 MEMBER KIRCHNER: I agree, that would
22 likely bound it, you know, the traditional ejection or
23 drop in this case.

24 MEMBER MARCH-LEUBA: Yes. Okay, can we
25 open the public line please? For comments? Is the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 public phone line open for comments? Is anybody on
2 the public phone there, can you please say hello? I
3 don't hear anybody. So if there is anybody in the
4 public line that wants to make a comment, please state
5 your name and do the comment.

6 We'll leave the public line open for a
7 moment longer, and I'm going to ask the members if
8 anybody wants to make a statement around the table.
9 Remember that we will come back to the open line this
10 session to read the letter. But if you want to make
11 a comment on the record right now, that will be the
12 time.

13 Seeing no feedback, we are going to
14 temporarily recess this meeting, and we are going to
15 move to the closed team meeting, the closed phone line
16 to get the proprietary information. Everybody knows
17 that? Yes, sir.

18 CHAIR SUNSERI: No, I'm sorry, when you're
19 done, I had a question. I wanted to ask you about
20 timing and things.

21 MEMBER MARCH-LEUBA: Comment, go ahead,
22 I'm done.

23 CHAIR SUNSERI: Okay, so we're going to
24 recess here and go to closed session. I'm going to
25 suggest we take a 20-minute break and reconvene the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 closed session at 20 minutes before the hour, so
2 that'd be 3:40. How long do you think that closed
3 session is going to last? And I know it's just a
4 slag, but do you have an idea? Because we should give
5 the public an ideal of when we would return to the
6 open session approximately, so.

7 MEMBER MARCH-LEUBA: I believe, let me
8 make sure, --

9 CHAIR SUNSERI: Why don't we just say
10 4:30?

11 MEMBER MARCH-LEUBA: GE has provided 20
12 slides, but if we -- and I assume Charlie Hicks is
13 going to be doing it, okay, he likes to talk even more
14 than I do. But we can do -- let me make an executive
15 decision. We'll be back in the open line no earlier
16 than 4:30.

17 CHAIR SUNSERI: Okay.

18 MEMBER MARCH-LEUBA: That will give us --

19 CHAIR SUNSERI: Yeah, that's fine. That's
20 fine. That's good enough. And then we can have staff
21 monitor the 4:30 open line and let people --

22 (Simultaneous speaking.)

23 CHAIR SUNSERI: Yeah, okay, thank you.

24 MEMBER MARCH-LEUBA: So we are on recess,
25 and we will see everybody on the -- everybody that is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 allowed to be in the closed line at 3:40, that's 20
2 minutes from now.

3 CHAIR SUNSERI: Thank you.

4 MEMBER MARCH-LEUBA: So we are off the
5 open line record. We will still have a transcription
6 of the closed session at 3:40. We are on recess.

7 (Whereupon, the above-entitled matter went
8 off the record at 3:19 p.m.)

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25



HITACHI

GE-Hitachi Nuclear Energy

Michelle P. Catts

GE-Hitachi Nuclear Energy Americas, LLC
Senior Vice President, Nuclear Programs
P.O. Box 780, M/C A-18
Wilmington, NC 28402 USA

T 910.200.9836
Michelle.catts@ge.com

M200153
November 24, 2020

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555-0001

Subject: Submittal of ACRS Full Committee Presentation Slides for NEDC-33912P,
BWRX-300 Reactivity Control Licensing Topical Report

Enclosed are the final presentation slides for use during the upcoming Advisory Committee on Reactor Safeguards (ACRS) GE-Hitachi Nuclear Energy Americas, LLC (GEH) Full Committee Meeting on December 1, 2020. This supports the ACRS review involving NEDC-33912P, BWRX-300 Reactivity Control, Revision 0, Supplement 1, and the corresponding NRC Advanced Safety Evaluation Report (SER) with No Open Items.

Enclosure 1 contains non-proprietary information and may be made available to the public.

If you have any questions, please contact me at 910-200-9836.

Sincerely,

Michelle P. Catts

Michelle P. Catts
Senior Vice President, Nuclear Programs
GE-Hitachi Nuclear Energy Americas, LLC

Enclosure:

1. ACRS Full Committee Presentation Slides for NEDC-33912P, BWRX-300 Reactivity Control Licensing Topical Report – Non-Proprietary Information

cc: R Franovich, US NRC

<p>Document Components: 001 M200153 Cover Letter.pdf 002 M200153 Enclosure 1 Non-Proprietary.pdf</p>

ENCLOSURE 1

M200153

ACRS Full Committee Presentation Slides for NEDC-33912P,
BWRX-300 Reactivity Control Licensing Topical Report

Non-Proprietary Information



HITACHI

ACRS Full Committee Presentation

GE-Hitachi (GEH)

Licensing Topical Report (LTR) NEDC-33912P

BWRX-300 Reactivity Control

(Open Session)

December 1, 2020

Purpose of ACRS Full Committee Presentation

- Describe Design Features to Meet Regulatory Requirements and Provide Defense-in-Depth for Licensing Basis Reactivity Events
- Address design requirements, acceptance criteria, and regulatory basis for the BWRX-300 Reactor Protection System (RPS) and other associated means for:
 - Reactivity Control
 - Anticipated Transients Without Scram (ATWS)
- Provide the design requirements, acceptance criteria, and regulatory basis for the BWRX-300 mitigating systems associated with an ATWS

Defense-in-Depth Design Features for BWRX-300 Reactivity Control

Defense-in-Depth Design for BWRX-300

BWRX-300 applies a defense-in-depth approach aligned with IAEA guidance

- Address Fundamental Safety Functions to ensure overall plant safety
- Assigns BWRX-300 functions to Defense Lines associated with Fundamental Safety Functions
- This LTR is focused on the Fundamental Safety Function of Reactivity Control that ensures defense-in-depth shutdown capability and reactivity control

Defense-in-Depth – Defense Line 1

IAEA
Level 1


Defense Line 1 (DL1)

Defense Line 1:

- Reduce challenges to the Reactor Protection System (RPS) from all occurrences
 - Fewer trips per year
 - Reduces number of Anticipated Operational Occurrences (AOOs)
 - Reduced challenges to RPS
 - Some transients become Infrequent Events defined as < 1 per 100 Reactor-years
- Strengthen subsequent Defense Lines
 - Quality
 - Reliability
 - Conservatism

BWRX-300 Reactor Pressure Vessel (RPV)

- Large RPV steam volume results in lower pressurization rate for isolation events (compared to ABWR and existing BWRs) resulting in less reactivity effect
- Refer to NEDC-33910P, BWRX-300 Reactor Pressure Vessel Isolation and Overpressure Protection



Defense-in-Depth – Defense Line 2

IAEA
Level 2



Defense Line 2 (DL2)

Defense Line 2:

- Includes functions which normally control the plant
 - Rod control and control of power generation systems
- Plant functions designed to control or stop a Postulated Initiating Event (PIE)
- Minimizes PIEs that reach DL3 setpoints thereby reducing challenges to DL3 systems
- Independent from DL3
 - Includes diverse means of shutdown
- Provides high reliability of plant control

BWRX-300 Control Rod with Fuel Assemblies

Proven BWR operating fleet
Control Rod design
Increased clearance for
control blades
Positioned by Fine Motion
Control Rod Drives (FMCRDs)



Defense-in-Depth – Defense Line 3

IAEA
Level 3


Defense Line 3 (DL3)

Defense Line 3:

- Includes functions which act to mitigate a PIE
 - Isolation Condenser System (ICS)
- Ensure plant is placed in a safe state
 - Reactor Protection System (RPS) Scram
- Assigned to highest safety class
- Independent of DL2

Isolation Condenser System (ICS)

- Heat exchanger design and capacity of each ICS train is the same as ESBWR
- Total % heat removal capacity from ICS larger than ESBWR
- Fail-safe, simple system
- Limits reactor pressure and temperature and maintains reactor water inventory
- Condensate return valves (not shown) fail open on loss of power to the valves
- Condensate return well above the core
- ICS design enhancements provides pressure control and assists in power reduction



Defense-in-Depth – Defense Line 4a

IAEA
Level 4

Defense Line 4a (DL4a)

Defense Line 4a:

- Includes functions to mitigate a PIE along with failure of DL3
- Mitigates CCFs in DL3
 - Alternate Rod Insertion (ARI) – provides hydraulic scram in event of Hydraulic Control Unit (HCU) actuation failure
 - FMCRD insertion with motors
- Ensures plant is placed in a safe state

Design Features Required by ATWS Rule

10 CFR 50.62 mandates reduction of risk from an ATWS

10 CFR 50.62(c)(3), (4) and(5) require the following design features for BWRs:

- ARI System
- Automatic Standby Liquid Control System (SLCS)
- Automatic Recirculation Pump Trip

10 CFR 50.62(c)(3) – Alternate Rod Insertion (ARI) System

- Each control rod can be inserted hydraulically using stored high-pressure water from hydraulic control unit (HCU) accumulators by either:
 - RPS and diverse actuated scram solenoid valves removing control air to each HCU
 - Diverse ARI pilot valves removing control air to scram solenoid valves for all HCUs
- Fine Motion Control Rod Drives (FMCRDs) have electric-motor-driven positioning used for both insertion and withdrawal of control rods
- Electric-motor-driven positioning diverse from hydraulic scram
 - Allows rod movement, even with failure of ARI System
 - Utilize sensors and logic that are diverse and independent of RPS
- Common cause failure (CCF) of hydraulic scram caused by scram discharge volume used in older designs is eliminated
 - Scram discharge fluid goes into Reactor Pressure Vessel



10 CFR 50.62(c)(5) – Automatic Recirculation Pump Trip

Forced circulation BWRs trip recirculation pumps to reduce core flow and power:

BWRX-300 utilizes natural circulation and has no recirculation pumps

BWRX-300 design incorporates:

- Control of power generation systems to assist in mitigation
- Reduction of water level, core flow and reactor power in a similar manner as recirculation pump trip in a forced circulation plant

Design Features Described in Standard Review Plan (SRP)

NUREG-0800, SRP 15.8, states:

A. For evolutionary plants where the ATWS rule does not explicitly require a diverse scram system, the applicant may provide either of the following:

i. A diverse scram system satisfying the design and quality assurance criteria specified in SRP Section 7.2

ii. Demonstrate that the consequences of an ATWS event are within acceptable values

BWRX-300 meets both requirements for an AOO with failure to scram

- Alternate means for shutdown
- ARI and electric motor run-in included in DL4a
- Successful shutdown ensured by DL2, DL3, DL4a
- Consequences of failure to scram from normal and diverse means mitigated by use of DL4a

Regulatory Acceptance Criteria

- **Primary System** - Maximum primary stress within Reactor Coolant Pressure Boundary (RCPB) does not exceed the emergency limits as defined in the ASME B&PV Code, Section III
- **Fuel Integrity** - Cladding temperature and oxidation criteria of 10 CFR 50.46 met
- **Containment Integrity** - Maximum containment pressure does not exceed the design pressure
- **Radiological Releases** - Maintained within 10 CFR 100 allowable limit
- **Shutdown and Cooling** - Reactor is brought to long-term shutdown with continued effective core cooling

10 CFR Part 50, Appendix A, GDC 27

- 10 CFR Part 50, Appendix A, GDC 27, Combined Reactivity Control Systems Capability - The reactivity control systems shall be designed to have a combined capability, in conjunction with poison addition by the emergency core cooling system, of reliably controlling reactivity changes to assure that under postulated accident conditions and with appropriate margin for stuck rods, the capability to cool the core is maintained
 - Exception - Core coolability is maintained for loss-of-coolant accidents because loss of water inventory in the RPV is minimized by the assured function of RPV isolation valves to mitigate large line breaks

Refer to NEDC-33910P, BWRX-300 Reactor Pressure Vessel Isolation and Overpressure Protection



United States Nuclear Regulatory Commission

Protecting People and the Environment

**NRC Staff Presentation-
GEH Topical Report NEDC-33912P,
Revision 0, Supplement 1,
“BWRX-300 Reactivity Control”**

**BWRX-300 Small Modular Reactor
ACRS Full Committee Meeting
December 1, 2020**

Presentation Outline

- NRC Staff Review Team
- BWRX-300 Background
- NRC Staff Review of NEDC-33912P
- Conclusion

NRC Staff Review Team

- NRR Nuclear Methods, Systems, and New Reactors Branch (SNRB)
 - Ryan Nolan
 - Andrew Proffitt
 - Alex Siwy
- NRR PRA Licensing Branch C (APLC)
 - Anne-Marie Grady
 - Alissa Neuhausen
- NRR Instrumentation and Controls Branch A (EICA)
 - Dinesh Taneja
- NRR New Reactor Licensing Branch (NRLB)
 - Rani Franovich

BWRX-300 Background

- 300 megawatt electric small modular reactor
- Uses natural circulation and passive cooling isolation condenser system
 - Based on ESBWR design
- Uses typical boiling-water reactor bottom-entry, cruciform-shaped control rods
- Includes defense-in-depth and diverse features to ensure the capability to shut down and control the reactor
- NEDC-33912P specifies design requirements and assesses regulatory requirements related to reactivity control

BWRX-300 Reactivity Control Systems and Functions

NEDC-33912P specifies design requirements for:

- Rod control system
- Reactor protection system
- [[]]
- Alternate rod insertion
- [[]]

Evaluation of Applicable Regulations

- 10 CFR 50.62, Requirements for reduction of risk from ATWS events
- 10 CFR 50, Appendix A, General Design Criteria
 - GDC 12, *Suppression of reactor power oscillations*
 - GDC 20, *Protection system functions*
 - GDC 21, *Protection system reliability and testability*
 - GDC 22, *Protection system independence*
 - GDC 23, *Protection system failure modes*
 - GDC 24, *Separation of protection and control systems*
 - GDC 25, *Protection system requirements for reactivity control malfunctions*
 - GDC 26, *Reactivity control system redundancy and capability*
 - GDC 27, *Combined reactivity control systems capability*
 - GDC 28, *Reactivity limits*
 - GDC 29, *Protection against anticipated operational occurrences*

Evaluation of Applicable Regulations: 10 CFR 50.62

- NEDC-33912P, Section 3.7.1 defines the ATWS acceptance criteria for evaluating the effectiveness of the reactivity control diverse shutdown means:
 - RCS and main steam pressure below 120% design
 - Peak cladding temp. and oxidation within 10 CFR 50.46 limits
 - Peak containment pressure/temp. below design
 - Coolable geometry
 - Radiological doses are maintained within 10 CFR 100 limits
- Consistent with SRP Section 15.8, “Anticipated Transients Without Scram.”

Evaluation of Applicable Regulations: 10 CFR 50.62(c)(3)

- Requires BWRs to have an ARI system diverse from the reactor trip system.
- The BWRX-300 includes an ARI system for diverse depressurization of the scram air header and will meet the requirement of 50.62(c)(3).

Evaluation of Applicable Regulations: 10 CFR 50.62(c)(4)

- Requires BWRs to have a standby liquid control system (SLCS) for injection into the vessel.
- NEDC-33912P specifies the BWRX-300 will meet the risk goals of 10 CFR 50.62 for P(ATWS) less than 1×10^{-5} per reactor year [[]].
 - Diverse scram actuation logic
 - Diverse rod motive force
 - [[]]
- This risk goal is consistent with the intent of 10 CFR 50.62 [[]]
- Limitation and Condition 5.1

Evaluation of Applicable Regulations: 10 CFR 50.62(c)(4)

Limitation and Condition 5.1:

Any applicant referencing NEDC-33912P must perform and document:

- Reliability analysis or testing, considering applicable operating experience and expected load follow conditions, of the BWRX-300 diverse scram features to demonstrate the probability of an ATWS is less than 1×10^{-5} per reactor year [[]].

Evaluation of Applicable Regulations

10 CFR 50.62(c)(5)

- Requires BWRs to automatically trip the recirculation pumps under ATWS conditions.
- This requirement is not applicable to the natural circulation BWRX-300.

Evaluation of Applicable Regulations: General Design Criterion 12

- Requires control and protection systems to ensure power oscillations that could exceed the SAFDLs are prevented or detected and suppressed.
- NEDC-33912P states the BWRX-300 will meet GDC 12 and maintains margin to instability through:
 - small core and orifice design
 - coupled power-flow response
 - RPV chimney
- Limitation and Condition 5.3

Evaluation of Applicable Regulations: General Design Criterion 12

Limitation and Condition 5.3:

Any applicant referencing NEDC-33912P must perform and document:

- A stability analysis in accordance with an approved methodology to demonstrate that the BWRX-300 maintains a coupled power-flow response such that any operational perturbation, maneuver, or AOO that does not cause an immediate scram is naturally damped and decays quickly to steady state for all modes of operation; prevents SAFDLs from being exceeded; is not susceptible to regional or radial modes of oscillation; and includes necessary provisions to address cycle-specific conditions.

Evaluation of Applicable Regulations: General Design Criterion 26

- Requires two independent reactivity control systems of different design principles
 - a) The first must use control rods and is used for normal operation, including AOOs, with margin for malfunctions
 - b) The second must reliably control reactivity changes resulting from planned, normal power changes
 - c) One system must be capable of holding the reactor subcritical under cold conditions
- NEDC-33912P states that the BWRX-300 will meet GDC 26 by providing:
 - Control rods (satisfy a and c above)
 - Feedwater level control system at power, other means to adjust level in other modes (satisfies b above)
- NRC staff finds this approach consistent with GDC 26

Evaluation of Applicable Regulations: General Design Criterion 27

- The intent of GDC 27 is to require reactor designs to achieve and maintain long-term subcriticality using only safety-related equipment following a postulated accident with margin for stuck control rods.
- NEDC-33912 proposes the following principal design criterion (PDC) in lieu of GDC 27:

The BWRX-300 reactivity control system shall be designed to have the capability of reliably controlling reactivity changes to assure that under postulated accident conditions and with appropriate margin for stuck rods the capability to cool the core is maintained.
- BWRX-300 control blades will be capable of holding the reactor subcritical under cold conditions assuming failure of the highest worth control rod pair.
- Analysis that demonstrates the control rod system is sufficient for achieving and maintaining shutdown margin could justify an exemption to GDC 27 and the use of the design-specific PDC.

Evaluation of Applicable Regulations: General Design Criterion 28

- Requires reactivity control systems be designed with appropriate limits on the potential amount and rate of reactivity increase to assure that postulated reactivity accidents can neither:
 - 1) result in damage to reactor pressure boundary greater than limited local yielding
 - 2) sufficiently disturb the core, its support structures or other reactor pressure vessel internals to impair significantly the capability to cool the core.
- Reactivity accidents that must be considered:
 - Rod ejection (unless prevented by positive means), rod dropout, steam line rupture, changes in coolant temperature/pressure, and cold water addition
- NEDC-33912P states that the BWRX-300 will meet GDC 28 by:
 - Design features of CRD system and rod control system limiting the amount and rate of reactivity increase
 - Safety analyses demonstrating compliance submitted in future licensing activities
 - Including analysis of CRDA event using approved methodology (NEDE-33885P-A)
- NRC staff finds this approach consistent with GDC 28

Evaluation of Applicable Regulations: General Design Criterion 28

Limitation and Condition 5.2:

Any applicant referencing NEDC-33912P must perform and document:

- A CRDA design-basis safety analysis applied to an equilibrium cycle in accordance with an approved methodology, providing justification for any deviations (e.g., performing a one-time analysis to bound cycle-by-cycle variations), or request an exemption to justify the CRDA as a beyond-design-basis event and document the CRDA analysis results in the probabilistic risk assessment.

Conclusion

- With specified Limitations and Conditions, NEDC-33912P provides an acceptable description of design requirements, acceptance criteria, and regulatory bases for design features of the BWRX-300 reactivity control functions.
- Detailed design of BWRX-300 SMR is not complete.
 - If applicant is not able to demonstrate compliance with NRC regulations, the applicant will be expected to justify an exemption from the applicable requirement.
 - NRC staff will evaluate regulatory compliance of the final BWRX-300 design with regards to reactivity control during future licensing activities for BWRX-300 applications.

Questions?