



# COOK NUCLEAR PLANT TRAINING CENTER

Bridgman, Michigan

## OPERATIONS JPM

**TRAINING PROGRAM TITLE**

INITIAL LICENSE TRAINING

**TIME:**

15 MINUTES

**NUMBER AND TITLE:**

2020NRC-A1a-RO  
Boron Volume Determination

**REVISION:**

0

Examinee's Name: \_\_\_\_\_

Evaluator's Name: \_\_\_\_\_

Date Performed: \_\_\_\_\_

Result (Circle One):            SAT    /    UNSAT

Number of Attempts: \_\_\_\_\_

Time to Complete: \_\_\_\_\_

Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

# OPERATIONS JPM

## REFERENCES/NRC KA/TASKS

Procedure: 2-OHP-4021-005-002

Operation of the Unit 2 Boric Acid Blender

K/A Number: 2.1.43

Ability to use procedures to determine the effects on reactivity of plant changes, such as reactor coolant system temperature, secondary plant, fuel depletion, etc..

K/A Imp.: RO: 4.1 SRO: 4.3

Task Number: 0050080101

Borate the RCS.

## TRAINING AIDS/TOOLS/EQUIPMENT

None

## HANDOUTS

Task Briefing

Copy of 2-OHP-4021-005-002 Attachment 9 Boron or Dilution Volume Determination

Copy of Unit 2 Technical Data Book curves (Sections 4, 5, 6, and 7)

## ATTACHMENTS

None

## EVALUATION SETTINGS

Classroom

EVALUATION METHOD:	PERFORM: <input checked="" type="checkbox"/>	SIMULATE: <input type="checkbox"/>
--------------------	--	------------------------------------

# OPERATIONS JPM

## SIMULATOR/LAB SETUP

None

## EVALUATOR INSTRUCTIONS

1. Brief the operator (May be performed by giving out Task Briefing Sheet)
2. Announce start of the JPM  
Information to be provided via Cues:

RCS Boron Concentration	1000 ppm
BAST Concentration	6800 ppm
Core Burnup	8000 MWD/MTU
Effective Fuel Temperature	1179.3°F
DTC	-2.235 pcm/°F
3. Perform evolution
4. At completion of evolution, announce the JPM is complete.
5. Document evaluation performance.

## TASK BRIEFING

You are an extra Control Room Operator on Unit 2.

The Unit Supervisor has directed you to calculate the required Boration or Dilution to restore  $T_{ave}$  to program.

Nuclear Engineering Reactor Design Summary (NERDS) is NOT available.

Reactor Power	96.3%
$T_{ave}$	574.2°F
$T_{ref}$	573°F

Calculate ONLY the amount of Boron or PW required to be added to the VCT. The previous blender operation was a boration.

## GENERAL STANDARDS/PRECAUTIONS

The required Boron Addition has been determined

# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS (“CS” Indicates Critical Standard)												
<table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 10px;"> <tr> <td style="text-align: center; font-size: small;">Continuous</td> <td style="text-align: center; font-size: small;">2-OHP-4021-005-002</td> <td style="text-align: center; font-size: small;">Rev. 12</td> <td style="text-align: center; font-size: small;">Page 52 of 76</td> </tr> <tr> <td colspan="4" style="text-align: center; font-weight: bold; font-size: small;">Operation of the Unit 2 Boric Acid Blender</td> </tr> <tr> <td style="text-align: center; font-size: small;">Attachment 9</td> <td style="text-align: center; font-size: small;">Boron or Dilution Volume Determination</td> <td colspan="2" style="text-align: center; font-size: small;">Pages: 52 - 55</td> </tr> </table> <p><b>1 PURPOSE AND SCOPE</b></p> <p>1.1 Provide instructions for determining the amount of boration or dilution required.</p> <p><b>2 PREREQUISITES</b></p> <p>2.1 None</p> <p><b>3 PRECAUTIONS AND LIMITATIONS</b></p> <p>3.1 Calculations in this attachment are based on design information and are accurate to within engineering tolerances. Current plant conditions may vary the actual requirements.</p> <p>3.2 Calculations are based on TEM minimum values of BA concentration. BA concentrations above minimum value will require a lower amount of BA.</p> <p>3.3 Ensure adequate Shutdown Margin will be maintained following dilution.</p> <p>3.4 If last addition to the RCS was PW, the first 27 gallons of next addition will be PW. This shall be considered in the total reactivity change to be made.</p> <p><b>4 DETAILS</b></p> <p>4.1 IF in MODES 1 or 2, THEN perform the following as applicable (N/A steps that are not applicable):</p> <p style="margin-left: 20px;">4.1.1 Amount determined for power change based on plant conditions.</p> <p style="margin-left: 40px;">a. Determine current RCS boron concentration from most recent representative sample.</p> <p style="margin-left: 40px;">_____ ppm _____</p>	Continuous	2-OHP-4021-005-002	Rev. 12	Page 52 of 76	Operation of the Unit 2 Boric Acid Blender				Attachment 9	Boron or Dilution Volume Determination	Pages: 52 - 55		<p>STANDARD: Determines that section 4.1.1 is not applicable</p> <p>SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p>
Continuous	2-OHP-4021-005-002	Rev. 12	Page 52 of 76										
Operation of the Unit 2 Boric Acid Blender													
Attachment 9	Boron or Dilution Volume Determination	Pages: 52 - 55											

# OPERATIONS JPM

EXPECTED ACTIONS				CUES/STANDARDS ("CS" Indicates Critical Standard)	
Continuous	2-OHP-4021-005-002	Rev. 12	Page 53 of 76		
Operation of the Unit 2 Boric Acid Blender					
Attachment 9	Boron or Dilution Volume Determination	Pages: 52 - 55			
<p>b. Determine change in power defect associated with load change from Technical Data Book (Figure 6.1) OR Nuclear Engineering Reactor Design Summary (NERDS) Reactivity Parameters Menu (option 4).</p> <p style="text-align: center;">_____ pcm _____</p>					
<p>c. Determine reactivity change (<math>\Delta\rho</math>) required by boration or dilution.</p> <p style="text-align: center;">_____ pcm _____</p>					
<p>d. Determine Differential Boron Worth (DBW) from Technical Data Book (Figure 4.1.a) or NERDS Reactivity Parameters Menu (option 1, 5).</p> <p style="text-align: center;">_____ pcm/ppm _____</p>					
<p>e. Determine required RCS Critical Boron (<math>\Delta C_b</math>) concentration change in PPM by the following:  <math>\Delta\rho/DBW = \Delta C_b</math></p> <p style="text-align: center;">(_____ pcm) / (_____ pcm/ppm) = (_____ ppm)                      step 4.1.1c      step 4.1.1d      _____</p>					
<p>f. Determine total amount of boration or dilution required to accomplish desired power change from Technical Data Book (2-Figure 7.5.1, or 2-Figure 7.2).</p> <p style="text-align: center;">_____ GAL - Boric Acid/Makeup Water                      (circle one) _____</p>				<p>STANDARD: Determines that section 4.1.2 is applicable                      SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p>	
<p>4.1.2 Amount determined for temperature change as follows:</p>					
<p>a. Determine desired RCS temperature change based on Auctioneered Hi T<sub>avg</sub>/T<sub>ref</sub> error from appropriate indications.</p> <p style="text-align: center;">(T<sub>avg</sub> - T<sub>ref</sub>) _____ °F _____</p>				<p>STANDARD (CS): Determines that 1.2°F temperature <b>change</b> is required (574.2 – 573 = 1.2) NOTE – the dash after (T<sub>avg</sub>-T<sub>ref</sub>) is not a negative sign                      SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p>	
<p>b. Determine Core Burnup:</p> <p style="text-align: center;">_____ MWD/MTU _____</p>					
				<p><b>CUE:</b> Provide Core burnup value (8,000 MWD/MTU after candidates explains Reactor Engineering tracks and supplies this number when NERDS is unavailable.                      STANDARD: Determines 8000 MWD/MTU is burnup                      SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p>	

# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS ("CS" Indicates Critical Standard)												
<table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 10px;"> <tr> <td style="width: 25%; text-align: center;">Continuous</td> <td style="width: 25%; text-align: center;">2-OHP-4021-005-002</td> <td style="width: 25%; text-align: center;">Rev. 12</td> <td style="width: 25%; text-align: center;">Page 54 of 76</td> </tr> <tr> <td colspan="4" style="text-align: center;">Operation of the Unit 2 Boric Acid Blender</td> </tr> <tr> <td style="text-align: center;">Attachment 9</td> <td style="text-align: center;">Boron or Dilution Volume Determination</td> <td colspan="2" style="text-align: center;">Pages: 52 - 55</td> </tr> </table> <p>c. Determine current RCS boron concentration from most recent representative sample.</p> <p style="text-align: center;">_____ ppm _____</p> <p>d. Determine Moderator Temperature Coefficient (MTC) from Technical Data Book (Figure 5.1) or Nuclear Engineering Reactor Design Summary (NERDS) Reactivity Parameters Menu (option 2, 5).</p> <p style="text-align: center;">_____ pcm/°F _____</p> <p>e. Determine Effective Fuel Temperature <math>T_{eff}</math> from NERDS Reactivity Parameters Menu (option 3, 3).</p> <p style="text-align: center;">_____ °F _____</p> <p>f. Determine Doppler Temperature Coefficient (DTC) from NERDS Reactivity Parameters Menu (option 3,2).</p> <p style="text-align: center;">_____ pcm/°F _____</p> <p>g. Determine Temperature Coefficient (TC) from the following: MTC + DTC = TC</p> <p style="text-align: center;">( _____ pcm/°F ) + ( _____ pcm/°F ) = ( _____ pcm/°F ) step 4.1.2d                      step 4.1.2f                      _____</p> <p>h. Determine required reactivity change (<math>\Delta\rho</math>) in PCM by the following: TC * Temperature Change = <math>\Delta\rho</math></p> <p style="text-align: center;">( _____ pcm/°F ) * ( _____ °F ) = ( _____ pcm ) step 4.1.2g                      step 4.1.2a                      _____</p> <p>i. Determine Differential Boron Worth (DBW) from Technical Data Book (Figure 4.1.a) or NERDS Reactivity Parameters Menu (option 1, 5).</p> <p style="text-align: center;">_____ pcm/ppm _____</p>	Continuous	2-OHP-4021-005-002	Rev. 12	Page 54 of 76	Operation of the Unit 2 Boric Acid Blender				Attachment 9	Boron or Dilution Volume Determination	Pages: 52 - 55		<p><b>CUE:</b> Provide RCS Boron (1,000 ppm) after candidates explains chemistry supplies this number after sampling and it is logged in the CR logs.</p> <p>STANDARD: Records 1000 ppm. SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p><b>STANDARD (CS):</b> Determines that MTC is -12.8 pcm/°F (Range -12.5 to -13.0) SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p><b>CUE:</b> Provide Effective Fuel Temp (1179.3 °F) after candidates explains Reactor Engineering would supply this number when NERDS is unavailable.</p> <p>STANDARD: Determines that the Effective Fuel Temperature is 1179.3°F SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p><b>CUE:</b> Provide Doppler Temperature Coefficient (DTC = - 2.235 pcm/°F) after candidates explains Reactor Engineering would supply this number when NERDS is unavailable.</p> <p>STANDARD: Determines that the DTC is -2.235 pcm/°F SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p style="text-align: center; font-size: 1.2em;">(Continued on next page)</p>
Continuous	2-OHP-4021-005-002	Rev. 12	Page 54 of 76										
Operation of the Unit 2 Boric Acid Blender													
Attachment 9	Boron or Dilution Volume Determination	Pages: 52 - 55											

# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS (“CS” Indicates Critical Standard)												
<table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 10px;"> <tr> <td style="width: 25%; text-align: center;">Continuous</td> <td style="width: 25%; text-align: center;">2-OHP-4021-005-002</td> <td style="width: 25%; text-align: center;">Rev. 12</td> <td style="width: 25%; text-align: center;">Page 54 of 76</td> </tr> <tr> <td colspan="4" style="text-align: center;">Operation of the Unit 2 Boric Acid Blender</td> </tr> <tr> <td style="text-align: center;">Attachment 9</td> <td style="text-align: center;">Boron or Dilution Volume Determination</td> <td colspan="2" style="text-align: center;">Pages: 52 - 55</td> </tr> </table> <p>c. Determine current RCS boron concentration from most recent representative sample.</p> <p style="margin-left: 40px;">_____ ppm</p> <p>d. Determine Moderator Temperature Coefficient (MTC) from Technical Data Book (Figure 5.1) or Nuclear Engineering Reactor Design Summary (NERDS) Reactivity Parameters Menu (option 2, 5).</p> <p style="margin-left: 40px;">_____ pcm/°F</p> <p>e. Determine Effective Fuel Temperature <math>T_{eff}</math> from NERDS Reactivity Parameters Menu (option 3, 3).</p> <p style="margin-left: 40px;">_____ °F</p> <p>f. Determine Doppler Temperature Coefficient (DTC) from NERDS Reactivity Parameters Menu (option 3.2).</p> <p style="margin-left: 40px;">_____ pcm/°F</p> <p>g. Determine Temperature Coefficient (TC) from the following: MTC + DTC = TC</p> <p style="margin-left: 40px;">( _____ pcm/°F ) + ( _____ pcm/°F ) = ( _____ pcm/°F ) step 4.1.2d    step 4.1.2f</p> <p>h. Determine required reactivity change (<math>\Delta\rho</math>) in PCM by the following: TC * Temperature Change = <math>\Delta\rho</math></p> <p style="margin-left: 40px;">( _____ pcm/°F ) * ( _____ °F ) = ( _____ pcm ) step 4.1.2g    step 4.1.2a</p> <p>i. Determine Differential Boron Worth (DBW) from Technical Data Book (Figure 4.1.a) or NERDS Reactivity Parameters Menu (option 1, 5).</p> <p style="margin-left: 40px;">_____ pcm/ppm</p>	Continuous	2-OHP-4021-005-002	Rev. 12	Page 54 of 76	Operation of the Unit 2 Boric Acid Blender				Attachment 9	Boron or Dilution Volume Determination	Pages: 52 - 55		<p style="text-align: center; font-size: 1.2em;">(Continued from previous page)</p>  <p>STANDARD (<b>CS</b>): Determines that TC is -15.035 pcm/°F (-12.8 + -2.235) (Range -14.735 to -15.235) SAT: <input type="checkbox"/>                          UNSAT: <input type="checkbox"/></p> <p>STANDARD (<b>CS</b>): Determines that PCM change is -18.042 (-15.035 pcm/°F x 1.2°F) (Range -17.682 to -18.282) SAT: <input type="checkbox"/>                          UNSAT: <input type="checkbox"/></p> <p>STANDARD (<b>CS</b>): Determines that DBW is -8.05 pcm/ppm (Range -8.0 to -8.1) SAT: <input type="checkbox"/>                          UNSAT: <input type="checkbox"/></p>
Continuous	2-OHP-4021-005-002	Rev. 12	Page 54 of 76										
Operation of the Unit 2 Boric Acid Blender													
Attachment 9	Boron or Dilution Volume Determination	Pages: 52 - 55											

# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS ("CS" Indicates Critical Standard)												
<table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 10px;"> <tr> <td style="font-size: small;">Continuous</td> <td style="font-size: small;">2-OHP-4021-005-002</td> <td style="font-size: small;">Rev. 12</td> <td style="font-size: small;">Page 55 of 76</td> </tr> <tr> <td colspan="4" style="text-align: center; font-weight: bold;">Operation of the Unit 2 Boric Acid Blender</td> </tr> <tr> <td style="font-size: small;">Attachment 9</td> <td style="font-size: small;">Boron or Dilution Volume Determination</td> <td colspan="2" style="font-size: small;">Pages: 52 - 55</td> </tr> </table> <p>j. Determine required RCS Critical Boron (<math>\Delta C_b</math>) concentration change in PPM by the following: <math>\Delta p / \text{DEW} = \Delta C_b</math></p> <p style="margin-left: 40px;"> <math>(\underline{\hspace{2cm}} \text{ pcm}) / (\underline{\hspace{2cm}} \text{ pcm/ppm}) = (\underline{\hspace{2cm}} \text{ ppm})</math>  <small>step 4.1.2h                      step 4.1.2i</small> </p> <p>k. Determine total amount of boration or dilution required to accomplish desired RCS temperature change from Technical Data Book (2-Figure 7.5.1 or 2-Figure 7.2).</p> <p style="margin-left: 40px;"> <math>\underline{\hspace{2cm}}</math> GAL - Boric Acid/Makeup Water  <small>(circle one)</small> </p> <p>4.2 Use either of the following methods in MODES 3, 4 and 5:</p> <p>4.2.1 Technical Data Book:</p> <p>a. Determine current RCS boron concentration from most recent representative sample.</p> <p style="margin-left: 40px;"><math>\underline{\hspace{2cm}}</math> ppm</p> <p>b. Determine total amount of boration or dilution required to accomplish desired RCS boron concentration from Technical Data Book (2-Figure 7.5.1, 12-Figure 7.5.2, 7.5.3 or 2-Figure 7.2).</p> <p style="margin-left: 40px;"> <math>\underline{\hspace{2cm}}</math> GAL - Boric Acid/Makeup Water  <small>(circle one)</small> </p>	Continuous	2-OHP-4021-005-002	Rev. 12	Page 55 of 76	Operation of the Unit 2 Boric Acid Blender				Attachment 9	Boron or Dilution Volume Determination	Pages: 52 - 55		<p><b>STANDARD (CS):</b> Determines that Boron change is +2.24 ppm (-18.042 pcm/-8.05 pcm/ppm) (Range +2.18 to +2.29)  SAT: <input type="checkbox"/>            UNSAT: <input type="checkbox"/></p> <p><b>STANDARD (CS):</b> Determines that Boron change requires +24 gallons of Boric Acid (circle Boric Acid) (Range 22 to 26 gallons)  SAT: <input type="checkbox"/>            UNSAT: <input type="checkbox"/></p> <p><b>Note:</b> Acceptable range based on graph reading from the lower limit line (20) and mid-scale (30) for the given boron concentration and required ppm change. The calculated limits of 23.92 to 25.66 is included within this range)</p> <p><b>STANDARD:</b> Determines that section 4.2 is not applicable  SAT: <input type="checkbox"/>            UNSAT: <input type="checkbox"/></p> <p><b>TERMINATION CUE:</b> "JPM is complete when completed Attachment 9 is provided to evaluator".</p>
Continuous	2-OHP-4021-005-002	Rev. 12	Page 55 of 76										
Operation of the Unit 2 Boric Acid Blender													
Attachment 9	Boron or Dilution Volume Determination	Pages: 52 - 55											



## Task Briefing

You are an extra Control Room Operator on Unit 2.

The Unit Supervisor has directed you to calculate the required Boration or Dilution to restore  $T_{ave}$  to program. Nuclear Engineering Reactor Design Summary (NERDS) is NOT available.

Reactor Power	96.3%
$T_{ave}$	574.2°F
$T_{ref}$	573°F

Calculate ONLY the amount of Boron or PW required to be added to the VCT. The previous blender operation was a boration.



# COOK NUCLEAR PLANT TRAINING CENTER

Bridgman, Michigan

## OPERATIONS JPM

**TRAINING PROGRAM TITLE**

INITIAL LICENSE TRAINING

**TIME:**

20 Minutes

**NUMBER AND TITLE:**

2020NRC-A1.b-RO  
Prepare Valve Stroke Data per 1-OHP-4030-114-011-Attachment 1

**REVISION:**

0

Examinee's Name: \_\_\_\_\_

Evaluator's Name: \_\_\_\_\_

Date Performed: \_\_\_\_\_

Result (Circle One):            SAT    /    UNSAT

Number of Attempts: \_\_\_\_\_

Time to Complete: \_\_\_\_\_

Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

# OPERATIONS JPM

## REFERENCES/NRC KA/TASKS

Procedures:

1-OHP-4030-114-011

Containment Isolation And IST Valve Operability Test, Rev. 36

TDB-1-Fig-19.-1

Power Operated Valve Stroke Time Limits, Rev. 125

### NRC KA

KA 2.2.12

Knowledge of surveillance procedures. (CFR: 41.10 / 45.13)

RO/SRO Importance

3.7/4.1

## TRAINING AIDS/TOOLS/EQUIPMENT

None

## HANDOUTS

PMP-4030-EXE-001, Conduct of surveillance Testing

1-OHP-4030-114-011, Containment Isolation and IST Valve Operability Test, Attachment 1

Copy of TDB Figure 1-19-1 Power Operated Valve Stroke Time limits

## ATTACHMENTS

## EVALUATION SETTINGS

Classroom

<b>EVALUATION METHOD:</b>	<b>PERFORM:</b> <input checked="" type="checkbox"/>	<b>SIMULATE:</b> <input type="checkbox"/>
---------------------------	---	---

# OPERATIONS JPM

## **SIMULATOR/LAB SETUP**

None

## **EVALUATOR INSTRUCTIONS**

Note: This JPM is based on 1-OHP-4030-114-011, Rev. 36 and TDB-1-Fig-19.-1, Rev. 125. Any subsequent revisions to the procedures will require a review of this JPM to ensure that the content of the JPM is still valid. This JPM may be used without revision if the procedure changes do not affect the JPM.

Give copy of Task Briefing, procedure, and attachments to examinee.

## **TASK BRIEFING**

You are the extra operator in Unit 1.

The Unit Supervisor has requested you to prepare 1-OHP-4030-114-011, Attachment 1 RCDT and Containment Sump Valves Test per step 2.4 of the attachment.

## **GENERAL STANDARDS/PRECAUTIONS**

All data has been filled in for the valves to be tested in attachment 1.

# OPERATIONS JPM

EXPECTED ACTIONS				CUES/STANDARDS (“CS” Indicates Critical Standard)	
Continuous	1-OHP-4030-114-011	Rev. 36	Page 10 of 206		
Containment Isolation And IST Valve Operability Test					
Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18			
<p><b>1 PURPOSE AND SCOPE</b></p> <p>1.1 To demonstrate OPERABILITY and satisfy testing requirements associated with the D.C. Cook Nuclear Plant IST Program for the following Containment Isolation Valves (CIVs), testable during plant operation in MODES 1 - 4, per TS SR 3.6.3.4 and the D.C. Cook Nuclear Plant IST Program:</p> <ul style="list-style-type: none"> <li>• 1-DCR-201, RCDT And PRT To Rad Waste Gas Compressor Train ‘A’ Contmt Isolation Valve</li> <li>• 1-DCR-203, RCDT And PRT To Rad Waste Gas Compressor Train ‘B’ Contmt Isolation Valve</li> <li>• 1-DCR-205, RCDT Pumps Suction From RDCT Train ‘A’ Contmt Isolation Valve</li> <li>• 1-DCR-206, RCDT Pumps Suction From RDCT Train ‘B’ Contmt Isolation Valve</li> <li>• 1-DCR-207, Reactor Plant Nitrogen To RDCT 1-TK-1 Contmt Isolation Valve</li> <li>• 1-DCR-600, Containment Sump Pumps Discharge To Dirty Waste Holdup Tank Train ‘A’ Containment Isolation Valve</li> <li>• 1-DCR-601, Containment Sump Pumps Discharge To Dirty Waste Holdup Tank Train ‘B’ Containment Isolation Valve</li> </ul> <p>1.2 To satisfy full-stroke exercise requirements associated with the D.C. Cook Nuclear Plant IST Program by moving the valves listed above to the required position in both directions.</p>					
<p><b>2 PREREQUISITES</b></p> <p>2.1 The working copy of this procedure is the current revision.</p> <p>2.2 A pre-test briefing has been conducted with the SM, US, or WCC-SRO per PMP-4010-JOB-001, Pre-Job Briefs and Post-Job Reviews.</p>				<p>INIT</p> <p>_____ ←</p> <p>_____</p>	<p><b>Cue:</b> Procedure is current revision and pre-test briefing is complete.</p>

# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS (“CS” Indicates Critical Standard)												
<table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 10px;"> <tr> <td style="width: 15%; text-align: center;">Continuous</td> <td style="width: 35%; text-align: center;">1-OHP-4030-114-011</td> <td style="width: 15%; text-align: center;">Rev. 36</td> <td style="width: 35%; text-align: center;">Page 11 of 206</td> </tr> <tr> <td colspan="4" style="text-align: center;">Containment Isolation And IST Valve Operability Test</td> </tr> <tr> <td style="text-align: center;">Attachment 1</td> <td style="text-align: center;">RCDT and Containment Sumps Valves Test</td> <td colspan="2" style="text-align: center;">Pages: 10 - 18</td> </tr> </table> <p>2.3 PMP-4030-EXE-001, Conduct of Surveillance Testing, Section 3.2, General Expectations for Surveillance Test Prerequisite Activity, has been reviewed. _____</p> <p>2.4 IST MIN and IST MAX stroke time acceptance criteria from Technical Data Book has been recorded in applicable action steps. ← _____</p> <p>2.5 IF Valve Position Indication (VPI) Verification Surveillance is scheduled for any valve listed in Step 1.1, THEN performance of this attachment is being coordinated with 1-OHP-4030-114-034, Local Valve Position Verification Test. _____</p> <p>2.6 Record Stopwatch data:</p> <p style="margin-left: 20px;">Primary Instrument Number _____</p> <p style="margin-left: 20px;">Next Due Calibration Date _____</p> <p style="margin-left: 20px;">Secondary Instrument Number _____ (N/A if not used)</p> <p style="margin-left: 20px;">Next Due Calibration Date _____</p> <p><b>3 PRECAUTIONS AND LIMITATIONS</b></p> <p>3.1 Inform SM of any abnormalities or problems encountered during this test.</p> <p>3.2 Recorded IST data shall be obtained from a calibrated instrument. Test instrumentation with a current calibration sticker and not identified as "rejected" is considered calibrated.</p> <p>3.3 Valves outside of IST MIN and IST MAX stroke time acceptance criteria when collecting as-found data could require an immediate retest per OHI-4016, Conduct of Operations: Guidelines.</p> <p>3.4 Components shall be evaluated against IST limits per OHI-4016 when determining OPERABILITY.</p> <p>3.5 The IST Fail-Safe Testing requirement is satisfied by satisfactory performance of the open and closed stroke time testing.</p>	Continuous	1-OHP-4030-114-011	Rev. 36	Page 11 of 206	Containment Isolation And IST Valve Operability Test				Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18		<p>STANDARD (CS) Operator determines that TDB-1-FIG 19.1 is required for the IST MIN and IST MAX Times SAT: <input type="checkbox"/> UNSAT: <input type="checkbox"/></p> <p><b>CUE:</b> Have candidate explain where TDB Figure is located / obtained, then Supply Copy of TDB-1-FIG 19.</p> <p>1</p>
Continuous	1-OHP-4030-114-011	Rev. 36	Page 11 of 206										
Containment Isolation And IST Valve Operability Test													
Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18											

# OPERATIONS JPM

EXPECTED ACTIONS				CUES/STANDARDS (“CS” Indicates Critical Standard)																	
Continuous	1-OHP-4030-114-011	Rev. 36	Page 12 of 206																		
Containment Isolation And IST Valve Operability Test																					
Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18																			
<p>3.6 On headers considered susceptible to pressure binding, the outer CIV shall remain open while the inner CIV is tested unless some other outlet for the displaced water has been established. Pressure binding can prevent an open CIV within an isolated segment from closing upon receipt of a signal. Pressure binding occurs when the required displacement of liquid necessary to allow for the movement of the air-operated isolation valve internals cannot occur due to a water-solid or near water-solid condition within the isolated piping segment caused by thermal expansion of the trapped fluid. Even if the CIV manages to fully close, sufficient pressure buildup in the isolated piping segment can cause the valve to reopen. This precaution applies to the following valves in this attachment: [Ref. 8.2.1i]</p> <ul style="list-style-type: none"> <li>• 1-DCR-205</li> <li>• 1-DCR-600</li> </ul>																					
<p>4 DETAILS <span style="float: right;">INIT</span></p>																					
<p>4.1 Perform the following to test RCDT valves:</p>																					
<p>4.1.1 Perform the following for 1-DCR-201, RC Drain Tank to Vent Header:</p>																					
<p>a. Verify 1-DCR-201 - OPEN. _____</p>																					
<p>b. Stroke AND time 1-DCR-201 - CLOSED.</p>																					
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 15%;">Stopwatch (Circle)</th> <th style="width: 15%;">IST MIN</th> <th style="width: 15%;">As Found</th> <th style="width: 15%;">IST MAX</th> <th colspan="3"></th> </tr> <tr> <td>Pri / Sec</td> <td>____ sec</td> <td>____ sec</td> <td>____ sec</td> <td colspan="3"></td> </tr> </thead> </table>				Stopwatch (Circle)	IST MIN	As Found	IST MAX				Pri / Sec	____ sec	____ sec	____ sec							
Stopwatch (Circle)	IST MIN	As Found	IST MAX																		
Pri / Sec	____ sec	____ sec	____ sec																		
<p>Is an Immediate Valve Retest Required per OHI-4016? (✓) <input type="checkbox"/> Yes <input type="checkbox"/> No _____</p>																					
<p>c. Open 1-DCR-201. _____</p>																					
<p>d. Full-Stroke Exercise Satisfactory? (✓) <input type="checkbox"/> Yes <input type="checkbox"/> No _____</p>																					
<p>e. Fail-Safe Test Satisfactory? (✓) <input type="checkbox"/> Yes <input type="checkbox"/> No _____</p>																					
				<p>STANDARD (CS): Operator enters IST MIN and IST MAX Times SAT: <input type="checkbox"/> UNSAT: <input type="checkbox"/></p>																	
				<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 15%;">1-DCR-201</td> <td style="width: 15%;">Closed</td> <td style="width: 15%;"></td> <td style="width: 15%; text-align: center;">0</td> <td style="width: 15%; text-align: center;">2.0</td> <td style="width: 15%; text-align: center;">2.0</td> <td style="width: 15%;"></td> </tr> </table>				1-DCR-201	Closed		0	2.0	2.0								
1-DCR-201	Closed		0	2.0	2.0																

# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS ("CS" Indicates Critical Standard)																										
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 15%;">Continuous</td> <td style="width: 30%;">1-OHP-4030-114-011</td> <td style="width: 15%;">Rev. 36</td> <td style="width: 40%;">Page 13 of 206</td> </tr> <tr> <td colspan="4" style="text-align: center;">Containment Isolation And IST Valve Operability Test</td> </tr> <tr> <td>Attachment 1</td> <td>RCDT and Containment Sumps Valves Test</td> <td colspan="2" style="text-align: right;">Pages: 10 - 18</td> </tr> </table>		Continuous	1-OHP-4030-114-011	Rev. 36	Page 13 of 206	Containment Isolation And IST Valve Operability Test				Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18															
Continuous	1-OHP-4030-114-011	Rev. 36	Page 13 of 206																								
Containment Isolation And IST Valve Operability Test																											
Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18																									
<p>4.1.2 Perform the following for 1-DCR-203, RC Drain Tank to Vent Header:</p> <p>a. Verify 1-DCR-203 - OPEN. _____</p> <p>b. Stroke AND time 1-DCR-203 - CLOSED.</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th style="width: 15%;">Stopwatch (Circle)</th> <th style="width: 15%;">IST MIN</th> <th style="width: 15%;">As Found</th> <th style="width: 15%;">IST MAX</th> </tr> <tr> <td>Pri / Sec</td> <td>____ sec</td> <td>____ sec</td> <td>____ sec</td> </tr> </table> <p>Is an Immediate Valve Retest Required per OHI-4016? (✓)      <input type="checkbox"/> Yes   <input type="checkbox"/> No    _____</p> <p>c. Open 1-DCR-203. _____</p> <p>d. Full-Stroke Exercise Satisfactory? (✓)      <input type="checkbox"/> Yes   <input type="checkbox"/> No    _____</p> <p>e. Fail-Safe Test Satisfactory? (✓)      <input type="checkbox"/> Yes   <input type="checkbox"/> No    _____</p> <div style="border: 1px solid black; padding: 2px; margin-top: 10px;"> <p><b>NOTE:</b> RCDT pressure should be considered when stroking Nitrogen Supply Valve.</p> </div> <p>4.1.3 Perform the following for 1-DCR-207, Nitrogen To RC Drain Tk:</p> <p>a. Open 1-DCR-207. _____</p> <p>b. Stroke AND time 1-DCR-207 - CLOSED.</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th style="width: 15%;">Stopwatch (Circle)</th> <th style="width: 15%;">IST MIN</th> <th style="width: 15%;">As Found</th> <th style="width: 15%;">IST MAX</th> </tr> <tr> <td>Pri / Sec</td> <td>____ sec</td> <td>____ sec</td> <td>____ sec</td> </tr> </table> <p>Is an Immediate Valve Retest Required per OHI-4016? (✓)      <input type="checkbox"/> Yes   <input type="checkbox"/> No    _____</p> <p>c. Full-Stroke Exercise Satisfactory? (✓)      <input type="checkbox"/> Yes   <input type="checkbox"/> No    _____</p>	Stopwatch (Circle)	IST MIN	As Found	IST MAX	Pri / Sec	____ sec	____ sec	____ sec	Stopwatch (Circle)	IST MIN	As Found	IST MAX	Pri / Sec	____ sec	____ sec	____ sec	<p>STANDARD (CS): Operator enters IST MIN and IST MAX Times SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 15%;">1-DCR-203</td> <td style="width: 15%;">Closed</td> <td style="width: 15%;">0</td> <td style="width: 15%;">2.0</td> <td style="width: 15%;">2.0</td> </tr> </table>  <p>STANDARD (CS): Operator enters IST MIN and IST MAX Times SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 15%;">1-DCR-207</td> <td style="width: 15%;">Closed</td> <td style="width: 15%;">0</td> <td style="width: 15%;">2.0</td> <td style="width: 15%;">2.0</td> </tr> </table>	1-DCR-203	Closed	0	2.0	2.0	1-DCR-207	Closed	0	2.0	2.0
Stopwatch (Circle)	IST MIN	As Found	IST MAX																								
Pri / Sec	____ sec	____ sec	____ sec																								
Stopwatch (Circle)	IST MIN	As Found	IST MAX																								
Pri / Sec	____ sec	____ sec	____ sec																								
1-DCR-203	Closed	0	2.0	2.0																							
1-DCR-207	Closed	0	2.0	2.0																							



# OPERATIONS JPM

EXPECTED ACTIONS				CUES/STANDARDS ("CS" Indicates Critical Standard)																							
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 25%;">Continuous</td> <td style="width: 25%;">1-OHP-4030-114-011</td> <td style="width: 25%;">Rev. 36</td> <td style="width: 25%;">Page 14 of 206</td> </tr> <tr> <td colspan="4" style="text-align: center;">Containment Isolation And IST Valve Operability Test</td> </tr> <tr> <td>Attachment 1</td> <td>RCDT and Containment Sumps Valves Test</td> <td colspan="2">Pages: 10 - 18</td> </tr> </table>				Continuous	1-OHP-4030-114-011	Rev. 36	Page 14 of 206	Containment Isolation And IST Valve Operability Test				Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18													
Continuous	1-OHP-4030-114-011	Rev. 36	Page 14 of 206																								
Containment Isolation And IST Valve Operability Test																											
Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18																									
<p>d. Fail-Safe Test Satisfactory? (✓)      <input type="checkbox"/> Yes <input type="checkbox"/> No      _____</p>																											
<p>4.1.4 Perform the following for 1-DCR-205, RC Drain Tank Pumps Suction:</p>																											
<p>a. Verify Selector Switch for 1-DCR-205, RC Drain Tk Outlet Train A Cnmt Isolation, in - NORMAL.      _____</p>																											
<p>b. Verify 1-DCR-206, RC Drain Tank Pump Suction - OPEN.      _____</p>																											
<p>c. Open 1-DCR-205.      _____</p>																											
<p>d. Stroke AND time 1-DCR-205 - CLOSED.</p>				<p>STANDARD (CS): Operator enters IST MIN and IST MAX Times SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p>																							
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th style="width: 15%;">Stopwatch (Circle)</th> <th style="width: 15%;">IST MIN</th> <th style="width: 15%;">As Found</th> <th style="width: 15%;">IST MAX</th> <th colspan="3"></th> </tr> <tr> <td>Pri / Sec</td> <td>____ sec</td> <td>____ sec</td> <td>____ sec</td> <td colspan="3"></td> </tr> </table>				Stopwatch (Circle)	IST MIN	As Found	IST MAX				Pri / Sec	____ sec	____ sec	____ sec				<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 15%;">1-DCR-205</td> <td style="width: 15%;">Closed</td> <td style="width: 15%; text-align: center;">1.2</td> <td style="width: 15%; text-align: center;">3.3</td> <td style="width: 15%; text-align: center;">4.4</td> <td style="width: 15%; text-align: center;">2.3</td> </tr> </table>				1-DCR-205	Closed	1.2	3.3	4.4	2.3
Stopwatch (Circle)	IST MIN	As Found	IST MAX																								
Pri / Sec	____ sec	____ sec	____ sec																								
1-DCR-205	Closed	1.2	3.3	4.4	2.3																						
<p>Is an Immediate Valve Retest Required per OHI-4016? (✓)      <input type="checkbox"/> Yes <input type="checkbox"/> No      _____</p>																											
<p>e. Full-Stroke Exercise Satisfactory? (✓)      <input type="checkbox"/> Yes <input type="checkbox"/> No      _____</p>																											
<p>f. Fail-Safe Test Satisfactory? (✓)      <input type="checkbox"/> Yes <input type="checkbox"/> No      _____</p>																											
<p>4.1.5 Perform the following for 1-DCR-206, RC Drain Tank Pump Suction:</p>				<p>STANDARD (CS): Operator enters IST MIN and IST MAX Times SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p>																							
<p>a. Stroke AND time 1-DCR-206 - CLOSED.</p>				<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 15%;">1-DCR-206</td> <td style="width: 15%;">Closed</td> <td style="width: 15%; text-align: center;">1.3</td> <td style="width: 15%; text-align: center;">3.7</td> <td style="width: 15%; text-align: center;">4.9</td> <td style="width: 15%; text-align: center;">2.</td> </tr> </table>				1-DCR-206	Closed	1.3	3.7	4.9	2.														
1-DCR-206	Closed	1.3	3.7	4.9	2.																						
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th style="width: 15%;">Stopwatch (Circle)</th> <th style="width: 15%;">IST MIN</th> <th style="width: 15%;">As Found</th> <th style="width: 15%;">IST MAX</th> <th colspan="3"></th> </tr> <tr> <td>Pri / Sec</td> <td>____ sec</td> <td>____ sec</td> <td>____ sec</td> <td colspan="3"></td> </tr> </table>				Stopwatch (Circle)	IST MIN	As Found	IST MAX				Pri / Sec	____ sec	____ sec	____ sec													
Stopwatch (Circle)	IST MIN	As Found	IST MAX																								
Pri / Sec	____ sec	____ sec	____ sec																								
<p>Is an Immediate Valve Retest Required per OHI-4016? (✓)      <input type="checkbox"/> Yes <input type="checkbox"/> No      _____</p>																											
<p>b. Fail-Safe Test Satisfactory? (✓)      <input type="checkbox"/> Yes <input type="checkbox"/> No      _____</p>																											
<p>c. Open 1-DCR-206.      _____</p>																											

# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS (“CS” Indicates Critical Standard)												
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 15%; text-align: center;">Continuous</td> <td style="width: 30%; text-align: center;">1-OHP-4030-114-011</td> <td style="width: 15%; text-align: center;">Rev. 36</td> <td style="width: 40%; text-align: center;">Page 15 of 206</td> </tr> <tr> <td colspan="4" style="text-align: center;">Containment Isolation And IST Valve Operability Test</td> </tr> <tr> <td style="text-align: center;">Attachment 1</td> <td style="text-align: center;">RCDT and Containment Sumps Valves Test</td> <td colspan="2" style="text-align: right;">Pages: 10 - 18</td> </tr> </table>		Continuous	1-OHP-4030-114-011	Rev. 36	Page 15 of 206	Containment Isolation And IST Valve Operability Test				Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18	
Continuous	1-OHP-4030-114-011	Rev. 36	Page 15 of 206										
Containment Isolation And IST Valve Operability Test													
Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18											
<p>d. Full-Stroke Exercise Satisfactory? (✓)    <input type="checkbox"/> Yes    <input type="checkbox"/> No    _____</p> <p>4.2 Perform the following to test Containment Sump to Dirty Waste Holdup Tank valves:</p> <p>4.2.1 Verify the following pumps in - STOP:</p> <ul style="list-style-type: none"> <li>• 1-PP-38A, Lower Contmt Sump Pump 2A    _____</li> <li>• 1-PP-38B, Lower Contmt Sump Pump 2B    _____</li> <li>• 1-PP-59A, Reactor Cavity Sump Pump 3A    _____</li> <li>• 1-PP-59B, Reactor Cavity Sump Pump 3B    _____</li> <li>• 1-PP-61A, Contmt Pipe Tnl Sump Pump 2A    _____</li> <li>• 1-PP-61B, Contmt Pipe Tnl Sump Pump 2B    _____</li> </ul> <p>4.2.2 Perform the following for 1-DCR-600, Contmt Sumps To Dirty Waste Hld Tk:</p> <p>a. Verify 1-DCR-601, Contmt Sumps To Dirty Waste Hld Tk - OPEN.    _____</p> <p>b. Stroke AND time 1-DCR-600 - CLOSED.</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: center;">Stopwatch (Circle)</th> <th style="text-align: center;">IST MIN</th> <th style="text-align: center;">As Found</th> <th style="text-align: center;">IST MAX</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">Pri / Sec</td> <td style="text-align: center;">_____ sec</td> <td style="text-align: center;">_____ sec</td> <td style="text-align: center;">_____ sec</td> </tr> </tbody> </table> <p>Is an Immediate Valve Retest Required per OHI-4016? (✓)    <input type="checkbox"/> Yes    <input type="checkbox"/> No    _____</p> <p>c. Fail-Safe Test Satisfactory? (✓)    <input type="checkbox"/> Yes    <input type="checkbox"/> No    _____</p> <p>d. Open 1-DCR-600.    _____</p> <p>e. Full-Stroke Exercise Satisfactory? (✓)    <input type="checkbox"/> Yes    <input type="checkbox"/> No    _____</p>	Stopwatch (Circle)	IST MIN	As Found	IST MAX	Pri / Sec	_____ sec	_____ sec	_____ sec	<p>STANDARD (CS): Operator enters IST MIN and IST MAX Times SAT: <input type="checkbox"/>    UNSAT: <input type="checkbox"/></p> <div style="text-align: center;"> </div>				
Stopwatch (Circle)	IST MIN	As Found	IST MAX										
Pri / Sec	_____ sec	_____ sec	_____ sec										

# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS (“CS” Indicates Critical Standard)																										
<table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 10px;"> <tr> <td style="width: 20%; text-align: center;">Continuous</td> <td style="width: 30%; text-align: center;">1-OHP-4030-114-011</td> <td style="width: 10%; text-align: center;">Rev. 36</td> <td style="width: 40%; text-align: center;">Page 16 of 206</td> </tr> <tr> <td colspan="4" style="text-align: center;">Containment Isolation And IST Valve Operability Test</td> </tr> <tr> <td style="text-align: center;">Attachment 1</td> <td style="text-align: center;">RCDT and Containment Sumps Valves Test</td> <td colspan="2" style="text-align: center;">Pages: 10 - 18</td> </tr> </table> <p>4.2.3 Perform the following for 1-DCR-601, Cntmt Sumps To Dirty Waste Hld Tk:</p> <p>a. Stroke AND time 1-DCR-601 - CLOSED.</p> <table border="1" style="width: 100%; border-collapse: collapse; margin: 10px 0;"> <thead> <tr> <th style="width: 15%;">Stopwatch (Circle)</th> <th style="width: 20%;">IST MIN</th> <th style="width: 20%;">As Found</th> <th style="width: 45%;">IST MAX</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">Pri / Sec</td> <td style="text-align: center;">___ sec</td> <td style="text-align: center;">___ sec</td> <td style="text-align: center;">___ sec</td> </tr> </tbody> </table> <p>Is an Immediate Valve Retest Required per OHI-4016? (✓)      <input type="checkbox"/> Yes   <input type="checkbox"/> No      _____</p> <p>b. Fail-Safe Test Satisfactory? (✓)      <input type="checkbox"/> Yes   <input type="checkbox"/> No      _____</p> <p>c. Open 1-DCR-601.      _____</p> <p>d. Full-Stroke Exercise Satisfactory? (✓)      <input type="checkbox"/> Yes   <input type="checkbox"/> No      _____</p> <p>4.2.4 Place the following in - AUTO, as required:</p> <ul style="list-style-type: none"> <li>• 1-PP-38A, Lower Cntmt Sump Pump 2A      _____</li> <li>• 1-PP-38B, Lower Cntmt Sump Pump 2B      _____</li> <li>• 1-PP-59A, Reactor Cavity Sump Pump 3A      _____</li> <li>• 1-PP-59B, Reactor Cavity Sump Pump 3B      _____</li> <li>• 1-PP-61A, Cntmt Pipe Tnl Sump Pump 2A      _____</li> <li>• 1-PP-61B, Cntmt Pipe Tnl Sump Pump 2B      _____</li> </ul>	Continuous	1-OHP-4030-114-011	Rev. 36	Page 16 of 206	Containment Isolation And IST Valve Operability Test				Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18		Stopwatch (Circle)	IST MIN	As Found	IST MAX	Pri / Sec	___ sec	___ sec	___ sec	<p>STANDARD (CS): Operator enters IST MIN and IST MAX Times SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <table border="1" style="width: 100%; border-collapse: collapse; margin: 10px 0;"> <tr> <td style="width: 20%;">1-DCR-601</td> <td style="width: 20%;">Closed</td> <td style="width: 10%; text-align: center;">0</td> <td style="width: 10%; text-align: center;">2.0</td> <td style="width: 10%; text-align: center;">2.0</td> <td style="width: 30%;"></td> </tr> </table> <p>STANDARD (CS): Operator completes entering IST MIN and IST MAX Times for all valves on Attachment #1. SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p><b>TERMINATION CUE:</b> “JPM is complete when the examinee provides the filled in Attachment1 to the evaluator”.</p>	1-DCR-601	Closed	0	2.0	2.0	
Continuous	1-OHP-4030-114-011	Rev. 36	Page 16 of 206																								
Containment Isolation And IST Valve Operability Test																											
Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18																									
Stopwatch (Circle)	IST MIN	As Found	IST MAX																								
Pri / Sec	___ sec	___ sec	___ sec																								
1-DCR-601	Closed	0	2.0	2.0																							

## **Task Briefing**

You are the extra operator in Unit 1.

The Unit Supervisor has requested you to prepare 1-OHP-4030-114-011, Attachment 1 RCDT and Containment Sump Valves Test per step 2.4 of the attachment.



# COOK NUCLEAR PLANT TRAINING CENTER

Bridgman, Michigan

## OPERATIONS JPM

**TRAINING PROGRAM TITLE**

INITIAL LICENSE TRAINING

**TIME:**

15 Minutes

**NUMBER AND TITLE:**

2020NRC-A2-RO  
Calculate QPTR

**REVISION:**

0

Examinee's Name: \_\_\_\_\_

Evaluator's Name: \_\_\_\_\_

Date Performed: \_\_\_\_\_

Result (Circle One):            SAT    /    UNSAT

Number of Attempts: \_\_\_\_\_

Time to Complete: \_\_\_\_\_

Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

# OPERATIONS JPM

## REFERENCES/NRC KA/TASKS

Procedures:

2-OHP-4030-214-032

Quadrant Power Tilt Calculation

### NRC KA

KA 2.2.12

Knowledge of surveillance procedures

RO/SRO Importance

3.7/4.1

## TRAINING AIDS/TOOLS/EQUIPMENT

Calculator

Magnifying glass

## HANDOUTS

Task Briefing

2-OHP-4030-214-032 and Data Sheet 2

Attachment 1 – N41, N42, N43, and N44 Pictures

## ATTACHMENTS

NI Calibration Data Card

Attachment 1 – N41, N42, N43, and N44 Pictures

## EVALUATION SETTINGS

Classroom

EVALUATION METHOD:

PERFORM:



SIMULATE:



## SIMULATOR/LAB SETUP

2020NRC-A2-RO (R3).doc

2020NRC-A2-RO  
Calculate QPTR

Revision: 0

Page 2 of 10

# OPERATIONS JPM

None

## EVALUATOR INSTRUCTIONS

1. Ensure classroom setup is complete
2. Brief the operator (May be performed by giving out Task Briefing Sheet)
3. Announce start of the JPM
4. Perform evolution
5. At completion of evolution, announce the JPM is complete.
6. Document evaluation performance.

## TASK BRIEFING

You are an extra RO.

The following conditions exist:

- Unit 2 is currently at 72% power.
- The Plant Process Computer (PPC) is INOPERABLE

The US directs you to perform a manual QPTR calculation per 2-OHP-4030-214-032, Quadrant Power Tilt Calculation.

The NI amp meters are set to display maximum resolution (.1 MILLI-APMS on the RANGE selector switches) and the fluke readings confirm that the indicators are reading properly.


### NOTE

Simulator Indications are NOT applicable to this JPM

## GENERAL STANDARDS/PRECAUTIONS

Candidate correctly calculates QPTR

# OPERATIONS JPM

EXPECTED ACTIONS				CUES/STANDARDS ("CS" Indicates Critical Standard)	
Continuous	2-OHP-4030-214-032	Rev. 6	Page 2 of 12		
<b>Quadrant Power Tilt Ratio Calculation</b>					
<p><b>1 PURPOSE AND SCOPE</b></p> <p>1.1 The purpose of this procedure is to determine the QUADRANT POWER TILT RATIO (QPTR) to satisfy Technical Specification SR 3.2.4.1.</p>					
<p><b>2 PREREQUISITES</b></p>				<b>INIT</b>	<b>Cue:</b> NI readings will be used for QPTR.
<p>2.1 If a fluke or equivalent test equipment will be used to determine QPTR, the instrument has been obtained from Measuring and Test Equipment Issue.</p>					
<p><b>3 PRECAUTIONS AND LIMITATIONS</b></p> <p>3.1 Improper use of a fluke or equivalent test equipment may cause blown fuses or rate trips. Fluke or equivalent test equipment readings shall not be taken if bistables are tripped on any power range drawer. [Ref. 8.2.2e]</p> <p>3.2 The 120% current values are obtained from calibration data cards located on the nuclear instrumentation (NI) drawers. If QPTR calculation is being performed during the quarterly card change out, using the "new" 120% current values is preferred. The "new" 120% current values, if not yet posted, may be obtained from MTI or Reactor Engineering.</p> <p>3.3 Do not utilize 120% values from both "new" and "old" cards for a single calculation.</p> <p>3.4 If a manual calculation is suspect, a verification calculation using a fluke or equivalent test equipment should be obtained prior to entering TS Conditions and Required Actions for QPTR.</p>					



# OPERATIONS JPM

EXPECTED ACTIONS				CUES/STANDARDS (“CS” Indicates Critical Standard)				
<table border="1"><tr><td>Continuous</td><td>2-OHP-4030-214-032</td><td>Rev. 6</td><td>Page 3 of 12</td></tr></table> <p style="text-align: center;"><b>Quadrant Power Tilt Ratio Calculation</b></p>				Continuous	2-OHP-4030-214-032	Rev. 6	Page 3 of 12	
Continuous	2-OHP-4030-214-032	Rev. 6	Page 3 of 12					
4	DETAILS		INIT					
<p><b>NOTE:</b> Only Section 4.1, 4.2, or 4.3 need be performed to obtain a QPTR. Sections not used may be N/A.</p>								
4.1	Plant Process Computer (PPC) calculation of QPTR							
4.1.1	Check the Plant Process Computer (PPC) OPERABLE for calculation of QPTR. _____			STANDARD Operator determines step 4.1 is N/A as PPC is INOPERABLE SAT: <input type="checkbox"/> UNSAT: <input type="checkbox"/>				
4.1.2	Select Tilting Factors. _____							
4.1.3	IF desired to use a PPC printout THEN perform the following:							
	a.	Print the Tilting Factors from the PPC screen. _____						
	b.	Record the Highest Upper or Lower Radial Flux Tilt meter _____						
	c.	Record the Highest Upper or Lower Radial Flux Tilt reading _____						
	d.	Attach the printout to this procedure _____						
4.1.4	IF desired to handwrite the PPC information THEN enter the Upper and Lower Radial Flux Tilts and the Highest Upper or Lower Radial Flux Tilt on Data Sheet 1, Quadrant Power Tilt Ratio From PPC. _____							
4.2	Manual calculation of QPTR with <u>all</u> NIs operable			STANDARD Operator determines step 4.2 is applicable and detector currents will be used. SAT: <input type="checkbox"/> UNSAT: <input type="checkbox"/>				
4.2.1	IF detector currents will be used to obtain power range excoré amperages, THEN perform the following:			<b>CUE:</b> Meter scales are selected for maximum resolution (.1 MILLI-AMPS [100 MICRO-AMPS] on the RANGE selector switches).				
<p><b>NOTE:</b> All eight amp meter settings do not need to be on the same scale setting.</p>				STANDARD (CS) Using the 0-100 MICROAMPERE scale, the Operator reads and records Upper & Lower Detector <del>blanks</del> currents for N-41, 42, 43 and 44 on Data Sheet 2. SAT: <input type="checkbox"/> UNSAT: <input type="checkbox"/>				
	a.	Select the amp meter scales for maximum resolution. _____						
	b.	Read AND record each individual NI detector current on Data Sheet 2, Quadrant Power Tilt Ratio Calculation Sheet. _____						

# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS ("CS" Indicates Critical Standard)								
<table border="1" style="width: 100%; margin-bottom: 10px;"> <tr> <td style="width: 25%;">Continuous</td> <td style="width: 25%;">2-OHP-4030-214-032</td> <td style="width: 25%;">Rev. 6</td> <td style="width: 25%;">Page 4 of 12</td> </tr> <tr> <td colspan="4" style="text-align: center;">Quadrant Power Tilt Ratio Calculation</td> </tr> </table> <div style="border: 2px solid black; padding: 5px; margin-bottom: 10px;"> <b>CAUTION:</b> Fluke or equivalent test equipment readings shall not be taken if bistables are tripped on any power range drawer.         </div> <p>4.2.2 IF a FLUKE or equivalent test equipment will be used to determine QPTR, THEN perform the following:</p> <p style="margin-left: 20px;">a. Record instrument number and calibration due date on Data Sheet 2, Quadrant Power Tilt Ratio Calculation Sheet. _____</p> <p style="margin-left: 20px;">b. Verify MTI has setup the fluke or equivalent test equipment. _____</p> <p style="margin-left: 20px;">c. Obtain the individual NI detector voltages AND substitute this voltage for the selected NI detector current on Data Sheet 2, Quadrant Power Tilt Ratio Calculation Sheet. _____</p> <p style="margin-left: 20px;">d. WHEN all individual NI detector data has been collected, THEN have MTI remove the fluke or equivalent test equipment. _____</p> <p>4.2.3 Enter the individual upper and lower power range 120% current values in the appropriate blanks. _____</p> <p>4.2.4 Divide the individual NI current by its 120% current value. _____</p> <p>4.2.5 Total the normalized values determined in Step 4.2.4. _____</p> <p>4.2.6 Using the formula on Data Sheet 2, Quadrant Power Tilt Ratio Calculation Sheet, determine the upper and lower QPTR. _____</p> <p>4.2.7 Enter the highest upper OR lower tilt ratio in the space provided on Data Sheet 2, Quadrant Power Tilt Ratio Calculation Sheet. _____</p> <p>4.2.8 Obtain the Maximum QPTR from the Plant Process Computer by performing the following (N/A if the PPC is unavailable or inoperable):</p> <p style="margin-left: 20px;">a. Select Tilting Factors. _____</p> <p style="margin-left: 20px;">b. Enter the highest Upper or Lower Radial Flux Tilt on Data Sheet 2, Quadrant Power Tilt Ratio Calculation Sheet. _____</p>	Continuous	2-OHP-4030-214-032	Rev. 6	Page 4 of 12	Quadrant Power Tilt Ratio Calculation				<p>STANDARD Operator determines step 4.2.2 is N/A as Fluke will not be used. SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p>STANDARD Operator enters 120% current values on Data Sheet 2. SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p>STANDARD (CS) Operator divides respective NI channel with its 120% value SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p>STANDARD (CS) Operator totals the Normalized Values SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p>STANDARD (CS) Operator completes formula calculations to determine QPTR SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p>STANDARD (CS) Operator enters the highest tilt ratio on Data Sheet 2 SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p>STANDARD Operator determines step 4.2.8 is N/A as PPC is INOP SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p>
Continuous	2-OHP-4030-214-032	Rev. 6	Page 4 of 12						
Quadrant Power Tilt Ratio Calculation									

# OPERATIONS JPM

EXPECTED ACTIONS				CUES/STANDARDS (“CS” Indicates Critical Standard)	
Continuous	2-OHP-4030-214-032	Rev. 6	Page 5 of 12		
<b>Quadrant Power Tilt Ratio Calculation</b>					
<p>4.3 Manual calculation of QPTR with <u>one</u> NI inoperable ←</p> <p>4.3.1 Record the OPERABLE NI numbers in the appropriate blanks on Data Sheet 3, Quadrant Power Tilt Ratio Calculation Sheet Using 3 NIs. _____</p> <p>4.3.2 Obtain power range excore amperages as follows:</p>				<p>STANDARD Operator determines step 4.3 is N/A as all NI’s are OPERABLE SAT: <input type="checkbox"/> UNSAT: <input type="checkbox"/></p>	
<p><b>NOTE:</b> All eight amp meter settings do not need to be on the same scale setting.</p>					
<p>a. Select the amp meter scales for maximum resolution. _____</p> <p>b. Read AND record each individual NI detector current on Data Sheet 3, Quadrant Power Tilt Ratio Calculation Sheet Using 3 NIs. _____</p> <p>4.3.3 Enter the individual upper and lower power range 120% current values in the appropriate blanks on Data Sheet 3, Quadrant Power Tilt Ratio Calculation Sheet Using 3 NIs. _____</p> <p>4.3.4 Divide each individual NI current by its 120% amperage. _____</p> <p>4.3.5 Total the normalized values determined in Step 4.3.4. _____</p> <p>4.3.6 Using the formula on Data Sheet 3, Quadrant Power Tilt Ratio Calculation Sheet Using 3 NIs, determine the upper and lower QPTR. _____</p> <p>4.3.7 Enter the highest upper OR lower tilt ratio in the space provided on Data Sheet 3, Quadrant Power Tilt Ratio Calculation Sheet Using 3 NIs. _____</p> <p>4.3.8 IF reactor power is greater than 75%, THEN request Reactor Engineering verify that QPTR is consistent with Incore Detector Readings. [Ref. SR 3.2.4.2] _____</p>				<p>STANDARD (CS) Operator determines ACCEPTANCE CRITERIA is NOT MET SAT: <input type="checkbox"/> UNSAT: <input type="checkbox"/></p>	
<p><b>5 ACCEPTANCE CRITERIA</b></p> <p>5.1 Acceptance Criteria: QPTR is less than OR equal to 1.02. ←</p>				<p><b>TERMINATION CUE:</b> “JPM is complete when examinee returns the completed surveillance package”</p>	

# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS ("CS" Indicates Critical Standard)																																																												
<table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 10px;"> <tr> <td style="width: 25%; text-align: center;">Continuous</td> <td style="width: 25%; text-align: center;">2-OHP-4030-214-032</td> <td style="width: 25%; text-align: center;">Rev. 6</td> <td style="width: 25%; text-align: center;">Page 10 of 12</td> </tr> <tr> <td colspan="4" style="text-align: center;">Quadrant Power Tilt Ratio Calculation</td> </tr> <tr> <td style="text-align: center;">Data Sheet 2</td> <td style="text-align: center;">Quadrant Power Tilt Ratio Calculation Sheet</td> <td colspan="2" style="text-align: center;">Pages: 10 - 11</td> </tr> </table> <div style="border: 1px solid black; padding: 5px; margin-bottom: 10px;"> <p><b>NOTE:</b> IF Unit 2 is operating at greater than 75% power, THEN consideration should be given to performing QPTR calculations immediately prior to declaring a Power Range INOPERABLE. This will lower the need to perform Data Sheet 3, Quadrant Power Tilt Ratio Calculation Sheet Using 3 NIS, and required Flux Map to comply with SR 3.2.4.2.</p> </div> <table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 10px;"> <thead> <tr> <th style="width: 10%;">Upper Detector</th> <th style="width: 20%;">Record Detector "A" Current</th> <th style="width: 20%;">Record Detector "A" 120% value</th> <th style="width: 50%;">Normalized Value Detector A ÷ 120% value</th> </tr> </thead> <tbody> <tr><td>N-41</td><td>99</td><td>135.4</td><td>.7311</td></tr> <tr><td>N-42</td><td>97.5</td><td>134.4</td><td>.7254</td></tr> <tr><td>N-43</td><td>98</td><td>134.4</td><td>.7292</td></tr> <tr><td>N-44</td><td>97.5</td><td>136.7</td><td>.7132</td></tr> <tr> <td colspan="3" style="text-align: right;">Upper Total</td> <td>2.8990</td> </tr> </tbody> </table> <table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 10px;"> <thead> <tr> <th style="width: 10%;">Lower Detector</th> <th style="width: 20%;">Record Detector "B" Current</th> <th style="width: 20%;">Record Detector "B" 120% value</th> <th style="width: 50%;">Normalized Value Detector B ÷ 120% value</th> </tr> </thead> <tbody> <tr><td>N-41</td><td>91.5</td><td>135.6</td><td>.6748</td></tr> <tr><td>N-42</td><td>96</td><td>134.7</td><td>.7127</td></tr> <tr><td>N-43</td><td>99</td><td>134.7</td><td>.7345</td></tr> <tr><td>N-44</td><td>98</td><td>136.2</td><td>.7195</td></tr> <tr> <td colspan="3" style="text-align: right;">Lower Total</td> <td>2.8419</td> </tr> </tbody> </table> <p>Upper Tilt Ratio = <math>\frac{\text{Max Upper Normalized Value}}{\text{Upper Total}} \times 4 = \underline{1.009}</math> ←</p> <p>Lower Tilt Ratio = <math>\frac{\text{Max Lower Normalized Value}}{\text{Lower Total}} \times 4 = \underline{1.034}</math> ←</p> <p>Enter the max upper or lower tilt ratio (Calculated QPTR) <span style="float: right;"><u>1.034</u> ←</span></p> <p>Highest Upper or Lower Radial Flux Tilt from PPC (N/A if unavailable or inoperable) <span style="float: right;"><u>N/A</u></span></p> <p>Notification Limit: 1.015</p> <p>Acceptance Criteria: Calculated QPTR is less than OR equal to 1.02</p>	Continuous	2-OHP-4030-214-032	Rev. 6	Page 10 of 12	Quadrant Power Tilt Ratio Calculation				Data Sheet 2	Quadrant Power Tilt Ratio Calculation Sheet	Pages: 10 - 11		Upper Detector	Record Detector "A" Current	Record Detector "A" 120% value	Normalized Value Detector A ÷ 120% value	N-41	99	135.4	.7311	N-42	97.5	134.4	.7254	N-43	98	134.4	.7292	N-44	97.5	136.7	.7132	Upper Total			2.8990	Lower Detector	Record Detector "B" Current	Record Detector "B" 120% value	Normalized Value Detector B ÷ 120% value	N-41	91.5	135.6	.6748	N-42	96	134.7	.7127	N-43	99	134.7	.7345	N-44	98	136.2	.7195	Lower Total			2.8419	<p style="text-align: center; margin-top: 100px;">Expected values</p> <p style="margin-top: 100px;">Range 1.0063 to 1.0165</p> <p style="margin-top: 10px;">Range 1.0265 to 1.0424</p> <p style="margin-top: 10px;">Value is the highest ratio entered in above 2 lines.</p>
Continuous	2-OHP-4030-214-032	Rev. 6	Page 10 of 12																																																										
Quadrant Power Tilt Ratio Calculation																																																													
Data Sheet 2	Quadrant Power Tilt Ratio Calculation Sheet	Pages: 10 - 11																																																											
Upper Detector	Record Detector "A" Current	Record Detector "A" 120% value	Normalized Value Detector A ÷ 120% value																																																										
N-41	99	135.4	.7311																																																										
N-42	97.5	134.4	.7254																																																										
N-43	98	134.4	.7292																																																										
N-44	97.5	136.7	.7132																																																										
Upper Total			2.8990																																																										
Lower Detector	Record Detector "B" Current	Record Detector "B" 120% value	Normalized Value Detector B ÷ 120% value																																																										
N-41	91.5	135.6	.6748																																																										
N-42	96	134.7	.7127																																																										
N-43	99	134.7	.7345																																																										
N-44	98	136.2	.7195																																																										
Lower Total			2.8419																																																										

## OPERATIONS JPM

Acceptable Ranges Based on Scale used on Pictures

### Detector A (UPPER)

SCALE	5	5	1	1	500	500	100	100
	Low	High	Low	High	Low	High	Low	High
N-41	4.925	4.975	0.985	0.995	493	498	98.5	99.5
N-42	4.85	4.9	0.97	0.98	485	490	97	98
N-43	4.875	4.925	0.975	0.985	488	493	97.5	98.5
N-44	4.85	4.9	0.97	0.98	485	490	97	98

Using the 100 Scale (UPPER QPTR ranges calculated using combinations of High/Low values above)

N41-High (99.5), N42-Low (97), N43-Low(97.5),N44-Low (97) ---- 1.0165

N41-low (98.5), N42-Low (97), N43-Low(97.5),N44-High (98)----- 1.0063

### Detector B (LOWER)

SCALE	5	5	1	1	500	500	100	100
	Low	High	Low	High	Low	High	Low	High
N-41	4.55	4.6	0.91	0.92	455	460	91	92
N-42	4.775	4.825	0.955	0.965	478	483	95.5	96.5
N-43	4.925	4.975	0.985	0.995	493	498	98.5	99.5
N-44	4.875	4.925	0.975	0.985	488	493	97.5	98.5

(LOWER QPTR Ranges Calculated using combinations of High/Low values above)

N41-Low (91), N42-Low (95.5), N43-High (99.5),N44-Low (97.5) ---- 1.0424

N41-High (92), N42-High (96.5), N43-Low(98.5),N44-High (97.5)----- 1.0265

## Task Briefing

You are an extra RO.

The following conditions exist:

- Unit 2 is currently at 72% power.
- The Plant Process Computer (PPC) is INOPERABLE

The US directs you to perform a manual QPTR calculation per 2-OHP-4030-214-032, Quadrant Power Tilt Calculation.

The NI amp meters are set to display maximum resolution and the fluke readings confirm that the indicators are reading properly.

### NI CALIBRATION DATA DET A 120% I in $\mu$ Amps

N41 = 135.4  
N42 = 134.4  
N43 = 134.4  
N44 = 136.7

### DET B 120% I in $\mu$ Amps

N41 = 135.6  
N42 = 134.7  
N43 = 134.7  
N44 = 136.2

**Verified:** Print John Smithe


Sign John Smithe

Date 5/11/2020


### NOTE

Simulator Indications are NOT applicable to this JPM

# N41 Upper Detector A




N41 Lower Detector B







N42 Upper Detector A




N42 Lower Detector B




N43 Upper Detector A




N43 Lower Detector B



N44 Upper Detector A



N44 Lower Detector B





# COOK NUCLEAR PLANT TRAINING CENTER

Bridgman, Michigan

## OPERATIONS JPM

**TRAINING PROGRAM TITLE**

INITIAL LICENSE TRAINING

**TIME:**

15 Minutes

**NUMBER AND TITLE:**

2020NRC-A3-RO

Respond to Failed Radiation Monitor Channel

**REVISION:**

0

Examinee's Name: \_\_\_\_\_

Evaluator's Name: \_\_\_\_\_

Date Performed: \_\_\_\_\_

Result (Circle One):            SAT    /    UNSAT

Number of Attempts: \_\_\_\_\_

Time to Complete: \_\_\_\_\_

Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

# OPERATIONS JPM

## REFERENCES/NRC KA/TASKS

Procedures:

2-OHP-4024-211

Annunciator #211 Response: Delta T

12-OHP-4024-139

Annunciator #139 Response: Radiation

### NRC KA

KA 2.3.15

Knowledge of radiation monitoring systems, such as fixed radiation monitors and alarms, portable survey instruments, personnel monitoring equipment, etc. (CFR: 41.12 / 45.9)

RO/SRO Importance

2.9/3.1

## TRAINING AIDS/TOOLS/EQUIPMENT

None

## HANDOUTS

2-OHP-4024-211 Annunciator #211 Response: Delta T

12-OHP-4024-139 Annunciator #139 Response: Radiation

## ATTACHMENTS

None

## EVALUATION SETTINGS

Simulator

EVALUATION METHOD:

PERFORM:



SIMULATE:



## SIMULATOR/LAB SETUP

Disable emulator for ERS-8306.

2020NRC-A3-RO Respond to Failed Radiation Monitor Channel	Revision: 0
2020NRC-A3-RO (R3).doc	Page 2 of 9



# OPERATIONS JPM

## EVALUATOR INSTRUCTIONS

Note: This JPM is based on 2-OHP-4024-211, Rev. 25 and 12-OHP-4024-139 Rev. 25. Any subsequent revisions to the procedures will require a review of this JPM to ensure that the content of the JPM is still valid. This JPM may be used without revision if the procedure changes do not affect the JPM.

Give copy of Task Briefing to examinee. Once examinee has located Annunciator response procedures provide attachment 2-OHP-4024-211 to examinee.

## TASK BRIEFING

You are the extra operator in Unit 2.

The Unit Supervisor has requested you to respond to Annunciator Panel 211: Drop 49, identify, and take all actions required for Unit 2.

## GENERAL STANDARDS/PRECAUTIONS

All actions for failed RMS Channel have been completed or identified

# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS (“CS” Indicates Critical Standard)						
<p style="text-align: right; margin-right: 100px;"><b>2-OHP-4024-211</b></p> <p><b>Level of Use: REFERENCE</b> <span style="float: right;"><b>Drop 49</b></span></p> <p style="text-align: center;"><b>ANNUNCIATOR #211 RESPONSE: DELTA T</b></p> <table border="1" style="width: 100%; margin: 10px 0;"> <thead> <tr> <th style="width: 33%;">INITIATING DEVICE(S) AEP</th> <th style="width: 33%;">Alias</th> <th style="width: 33%;">NOMINAL SETPOINT</th> </tr> </thead> <tbody> <tr> <td>Unit 2 PPC Digital Output (2-DOUT 02) via Unit 2 Control Terminal.</td> <td></td> <td style="text-align: center;">N/A</td> </tr> </tbody> </table> <div style="border: 1px solid black; padding: 5px; margin: 10px 0; text-align: center;"> <b>PPC-RMS U2 CT ALARM OR ABNORMAL</b> </div> <div style="border: 1px solid black; padding: 5px; margin: 10px 0; text-align: center;"> <b>NOTE</b>                      Each point has reflash capability.                 </div> <p><b>1.0 PROBABLE CAUSE(S):</b></p> <ul style="list-style-type: none"> <li>1.1 Non TS RMS Points Quality</li> <li>1.2 TS RMS Quality</li> </ul> <p style="margin-left: 40px;">Whenever a Technical Specification related RMS channel has a background color other than green, indicating a quality other than normal, the annunciator will alarm.</p> <ul style="list-style-type: none"> <li>1.3 CT Failure</li> </ul> <p><b>2.0 AUTOMATIC ACTION(S):</b></p> <ul style="list-style-type: none"> <li>2.1 Refer to 12-OHP-4024-139 for applicable Immediate Automatic Actions.</li> </ul> <p><b>3.0 OPERATOR ACTION(S):</b></p> <ul style="list-style-type: none"> <li>3.1 Check PPC RMS Annunciator display (RMSAN3) or the CT.</li> <li>3.2 Check RMS CT AND refer to Annunciator response in 12-OHP-4024-139, Radiation Monitoring System.</li> <li>3.3 IF it is desired to remove a point from RMS, THEN complete Attachment No. 2 [Page 114].</li> </ul> <p style="text-align: right; margin-right: 100px;">Page 106 of 115 Rev. 25</p>	INITIATING DEVICE(S) AEP	Alias	NOMINAL SETPOINT	Unit 2 PPC Digital Output (2-DOUT 02) via Unit 2 Control Terminal.		N/A	<p><b>STANDARD:</b> Operator reviews Drop 49 Probable Causes and automatic actions. SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p><b>STANDARD:</b> Operator determines that 12-OHP-4024-139 is required to be reviewed for channel in alarm. SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p><b>STANDARD (CS):</b> Operator identifies from the RMSAN1 channel ERA-8306 in alarm. SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p><b>CUE:</b> Once examinee indicates location of Annunciator Response provide copy of 12-OHP-4024-139 for Channel ERA-8300</p>
INITIATING DEVICE(S) AEP	Alias	NOMINAL SETPOINT					
Unit 2 PPC Digital Output (2-DOUT 02) via Unit 2 Control Terminal.		N/A					

# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS (“CS” Indicates Critical Standard)						
<p style="text-align: right;"><b>12-OHP-4024-139</b></p> <p><b>Level of Use: REFERENCE</b> <span style="float: right;"><b>2-ERA-8300</b></span></p> <p style="text-align: center;"><b>ANNUNCIATOR #139 RESPONSE: RADIATION</b></p> <p style="text-align: center;"><b>ERS-8300, Aux Building Equipment Room Area Monitor</b></p> <table border="1" style="width: 100%; border-collapse: collapse; margin: 10px 0;"> <thead> <tr> <th style="width: 10%; text-align: center;">AEP</th> <th style="width: 60%; text-align: center;">INITIATING DEVICE(S) Alias</th> <th style="width: 30%; text-align: center;">NOMINAL SETPOINT</th> </tr> </thead> <tbody> <tr> <td style="text-align: center; vertical-align: top;">2-ERA-8300</td> <td style="vertical-align: top;"> <p style="text-align: center;">CHANNEL ID:</p>                     8303 U2 East CCP Room                      8304 U2 West CCP Room                      8305 U2 East RHR Pump Room                      8306 U2 West RHR Pump Room                      8307 U2 North Safety Injection Pump Room                      8308 U2 South Safety Injection Pump Room                      8309 U2 Reactor Coolant Filter Room                 </td> <td style="text-align: center; vertical-align: middle;">Refer to Channel Parameter File</td> </tr> </tbody> </table> <p><b>1.0 PROBABLE CAUSE(S):</b></p> <p style="margin-left: 20px;"><b>1.1 RED / YELLOW:</b></p> <ul style="list-style-type: none"> <li>• Heat exchanger leakage</li> <li>• Movement of radioactive material in specified area</li> <li>• Crud burst upstream</li> <li>• Possible trouble sources separated by channel:                         <ul style="list-style-type: none"> <li>• ERA-8303, 8304: CCW heat exchanger leakage</li> <li>• ERA-8305, 8306: RHR system crud burst. During refueling may indicate fuel handling accident.</li> <li>• ERA-8307, 8308: SIS actuation</li> <li>• ERA-8309: Fuel cladding failure or RCS crud burst</li> </ul> </li> </ul> <p style="margin-left: 20px;"><b>1.2 WHITE:</b></p> <ul style="list-style-type: none"> <li>• Monitor is in POLL OFF at RMS HMI</li> <li>• Channel status is COMM FAIL, DELETED, MAINTENANCE, or PARAMETER DISAGREE, at RMS HMI</li> </ul> <p style="text-align: right; margin-top: 20px;"><b>Page 144 of 148</b> Rev. 25</p>	AEP	INITIATING DEVICE(S) Alias	NOMINAL SETPOINT	2-ERA-8300	<p style="text-align: center;">CHANNEL ID:</p> 8303 U2 East CCP Room 8304 U2 West CCP Room 8305 U2 East RHR Pump Room 8306 U2 West RHR Pump Room 8307 U2 North Safety Injection Pump Room 8308 U2 South Safety Injection Pump Room 8309 U2 Reactor Coolant Filter Room	Refer to Channel Parameter File	<p>NOTE: Candidate must perform actions from the RMS CT located on the back wall of the simulator.</p> <p style="margin-top: 100px;">STANDARD: Operator reviews probable causes for channel in WHITE alarm. SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p>
AEP	INITIATING DEVICE(S) Alias	NOMINAL SETPOINT					
2-ERA-8300	<p style="text-align: center;">CHANNEL ID:</p> 8303 U2 East CCP Room 8304 U2 West CCP Room 8305 U2 East RHR Pump Room 8306 U2 West RHR Pump Room 8307 U2 North Safety Injection Pump Room 8308 U2 South Safety Injection Pump Room 8309 U2 Reactor Coolant Filter Room	Refer to Channel Parameter File					

# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS (“CS” Indicates Critical Standard)
<p style="text-align: right; margin-right: 20px;"><b>12-OHP-4024-139</b></p> <p><b>Level of Use: REFERENCE</b> <span style="float: right;"><b>2-ERA-8300</b></span></p> <p><b>2.0 AUTOMATIC ACTION(S):</b></p> <p style="padding-left: 20px;">2.1 None</p> <p><b>3.0 OPERATOR ACTION(S):</b></p> <p style="padding-left: 20px;">3.1 RED:</p> <p style="padding-left: 40px;">3.1.1 Notify TS RP Technician of radiation monitor alarm.</p> <p style="padding-left: 40px;">3.1.2 Request RP verify requirements of 12-THP-6010-RPP-708, Response To Area Radiation Monitor Alarms, has been met.</p> <p style="padding-left: 40px;">3.1.3 IF the following rooms alarm, THEN place running AES Fan Charcoal Filter Test Selector switch in CHAR FILT:</p> <ul style="list-style-type: none"> <li>• ERA-8303 U2 East CCP Room</li> <li>• ERA-8304 U2 West CCP Room</li> <li>• ERA-8305 U2 East RHR Pump Room</li> <li>• ERA-8306 U2 West RHR Pump Room</li> <li>• ERA-8307 U2 North SI Pump Room</li> <li>• ERA-8308 U2 South SI Pump Room</li> </ul> <p style="padding-left: 40px;">3.1.4 WHEN condition has cleared in previous step, THEN place AES Fan Charcoal Filter Test Selector switch in BYPASS.</p> <p style="padding-left: 40px;">3.1.5 IF the following rooms alarm, THEN refer to 12-OHP-4022-002-019, High Reactor Coolant Activity or Failed Fuel.</p> <ul style="list-style-type: none"> <li>• ERA-8303 U2 East CCP Room</li> <li>• ERA-8304 U2 West CCP Room</li> <li>• ERA-8305 U2 East RHR Pump Room</li> <li>• ERA-8306 U2 West RHR Pump Room</li> <li>• ERA-8309 U2 Reactor Coolant Filter Room</li> </ul> <p style="padding-left: 20px;">3.2 YELLOW:</p> <p style="padding-left: 40px;">3.2.1 Notify TS RP Technician of radiation monitor alarm.</p> <p style="padding-left: 40px;">3.2.2 Request RP verify requirements of 12-THP-6010-RPP-708, Response To Area Radiation Monitor Alarms, has been met.</p> <p style="text-align: right; margin-right: 20px;"><b>Page 145 of 148</b> <b>Rev. 25</b></p>	<p><b>THIS PAGE INCLUDED FOR REFERENCE. NO ACTIONS REQUIRED AS ALARM IS WHITE.</b></p>

# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS (“CS” Indicates Critical Standard)
<p style="text-align: right; margin-right: 50px;"><b>12-OHP-4024-139</b></p> <p><b>Level of Use: REFERENCE</b> <span style="float: right;"><b>2-ERA-8300</b></span></p> <p><b>3.3 WHITE:</b></p> <p>3.3.1 Attempt to restore affected channel(s) to Normal.</p> <p>3.3.2 <b>IF</b> channel is declared Inoperable and it is desired to prevent nuisance alarms, <b>THEN</b> perform the following:</p> <ul style="list-style-type: none"> <li>• Coordinate with RP to remove desired RMS monitor/channel(s) from service</li> <li>• Remove desired RMS monitor/channel(s) from Scan on the PPC per 2-OHP-4024-211, Annunciator #211 Response: Delta T, Drop 48/49, Attachment’s 1 and 2</li> <li>• Initiate Action</li> </ul> <p><b>4.0 REFERENCE INDEX:</b></p> <p><b>4.1 Source Documents:</b></p> <p>4.1.1 Elementary Diagram:</p> <p style="padding-left: 20px;">a. OP-2-98822, Radiation Monitoring System Area Monitor ERA-8300</p> <p>4.1.2 EC-000053364, Unit Two Radiation Monitoring System (RMS) Replacement</p> <p><b>4.2 Reference Documents:</b></p> <p>4.2.1 12-THP-6010-RPP-708, Response To Area Radiation Monitor Alarms</p> <p>4.2.2 12-OHP-4022-002-019, High Reactor Coolant Activity or Failed Fuel</p> <p>4.2.3 2-OHP-4024-211, Annunciator #211 Response: Delta T</p> <p><b>4.3 Commitment Documents:</b></p> <p>4.3.1 None</p> <p style="text-align: right; margin-top: 20px;"><b>Page 146 of 148</b> <b>Rev. 25</b></p>	<p><b>CUE:</b> Inform the operator the Unit Supervisor has declared the channel Inoperable and it is desired to prevent nuisance alarms.</p> <p><b>CUE:</b> RP has been contacted for removing channel from service.</p> <p><b>STANDARD (CS):</b> Operator identifies Attachment 2 is required for removing channel from scan on Unit2. (<b>Only identifying Attachment 2 completion is critical</b> and will be completed). SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p><b>CUE:</b> Another operator will complete Attachment 1 to remove the channel from Scan on the Unit 1 PPC.</p>

# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS (“CS” Indicates Critical Standard)
<p style="text-align: right; margin-right: 50px;"><b>2-OHP-4024-211</b> Attachment 2</p> <p>Level of Use: N/A</p> <p style="text-align: center;"><b>DROP 49 – REMOVING/REPLACING RMS CHANNEL</b></p> <p><b>INSTRUCTIONS</b></p> <p><b>1.0</b> Record at least one of the following (N/A information not used):</p> <p><b>1.1</b> Record at least one of the following (N/A information not used)</p> <ul style="list-style-type: none"> <li>• RMS Channel: _____</li> <li>• Field Unit Database Point-ID: _____</li> <li>• Cook Plant Tag Number: _____</li> </ul> <p><b>1.2</b> Reason for Removing Channel: _____</p> <p><b>1.3</b> Approved by: _____ SRO Time: _____ Date: _____</p> <p><b>2.0</b> From Unit 2 PPC, perform the following:</p> <p><b>2.1</b> Activate U2 RMS Annunciator Status Tree from the Main Menu by clicking on the RMS button then the RMS Annunciator Status Tree U2 button, or typing in the turn-on code RMSAN3.</p> <p><b>2.2</b> Uncheck the box next to the specific RMS Channel or the box for the entire field unit that is being removed from the Unit 2 RMS annunciator control logic.</p> <p><b>3.0</b> Specifically note the RMS channel is removed from scan in the appropriate section of the Open Items Log or Abnormal Position Control Log as appropriate.</p> <p>Channel Removed by: _____ Time: _____ Date: _____</p> <p>Independently Verified by: _____ Time: _____ Date: _____</p> <p><b>4.0</b> Place Attachment in the RMS section of the Blocked Alarm Log.</p> <p style="text-align: right; margin-right: 50px;"><b>Page 114 of 115</b> Rev. 25</p>	<p>STANDARD (CS): Operator fills in the required information. SAT: <input type="checkbox"/> UNSAT: <input type="checkbox"/></p> <p><b>NOTE:</b> Only RMS Channel of ERA-8306 (west RHR Pump Room) is required</p> <p><b>NOTE:</b> Enters channel is in <i>Fail Status or other description. Exact wording is not required.</i></p> <p>STANDARD (CS): Operator activates U2 RMS Annunciator Status Tree. SAT: <input type="checkbox"/> UNSAT: <input type="checkbox"/></p> <p>STANDARD (CS): Operator unchecks the box next to ERA-8306. SAT: <input type="checkbox"/> UNSAT: <input type="checkbox"/></p> <p><b>TERMINATION CUE:</b> “JPM is Complete when examinee unchecks the box for ERA-8306 to remove it from scan.</p>

## **Task Briefing**

You are the extra operator in Unit 2.

The Unit Supervisor has requested you to respond to Annunciator Panel 211: Drop 49, identify, and take all actions required for Unit 2.



# COOK NUCLEAR PLANT TRAINING CENTER

Bridgman, Michigan

## OPERATIONS JPM

**TRAINING PROGRAM TITLE**

INITIAL LICENSE TRAINING

**TIME:**

15 MINUTES

**NUMBER AND TITLE:**

2020NRC-A1.a-SRO  
Review Boron Volume Determination

**REVISION:**

0

Examinee's Name: \_\_\_\_\_

Evaluator's Name: \_\_\_\_\_

Date Performed: \_\_\_\_\_

Result (Circle One):        SAT    /    UNSAT

Number of Attempts: \_\_\_\_\_

Time to Complete: \_\_\_\_\_

Comments: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_



# OPERATIONS JPM

## REFERENCES/NRC KA/TASKS

Procedure: 2-OHP-4021-005-002

Operation of the Unit 2 Boric Acid Blender

K/A Number: 2.1.43

Ability to use procedures to determine the effects on reactivity of plant changes, such as reactor coolant system temperature, secondary plant, fuel depletion, etc..

K/A Imp.: RO: 4.1 SRO: 4.3

Task Number: 0050080101

Borate the RCS.

## TRAINING AIDS/TOOLS/EQUIPMENT

None

## HANDOUTS

Task Briefing

Copy of 2-OHP-4021-005-002 Attachment 9 Boron or Dilution Volume Determination

Copy of Unit 2 Technical Data Book curves (Sections 4, 5, 6, and 7)

## ATTACHMENTS

None

## EVALUATION SETTINGS

Classroom

EVALUATION METHOD:	PERFORM: <input checked="" type="checkbox"/>	SIMULATE: <input type="checkbox"/>
--------------------	--	------------------------------------

# OPERATIONS JPM

## SIMULATOR/LAB SETUP

None

## EVALUATOR INSTRUCTIONS

1. Brief the operator (May be performed by giving out Task Briefing Sheet)  
Provide the following information as the examinee needs it for review verification:

RCS Boron Concentration	1000 ppm
BAST Concentration	6800 ppm
Core Burnup	8000 MWD/MTU
Effective Fuel Temperature	1179.3°F
DTC	-2.235 pcm/°F
2. Announce start of the JPM
3. Perform evolution
4. At completion of evolution, announce the JPM is complete.
5. Document evaluation performance.

## TASK BRIEFING

You are unit supervisor in Unit 2.

You have directed the RO to calculate the required Boration or Dilution to restore  $T_{ave}$  to program. Nuclear Engineering Reactor Design Summary (NERDS) is NOT available.

Reactor Power	96.3%
$T_{ave}$	574.2°F
$T_{ref}$	573°F

He has calculated ONLY the amount of Boron or PW required to be added to the VCT. The blender line is full of acid.

Review his calculation for correctness identifying any errors.

## GENERAL STANDARDS/PRECAUTIONS

The calculation has been reviewed and incorrect MTC and dilution / boration errors have been identified

# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS ("CS" Indicates Critical Standard)												
<table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 10px;"> <tr> <td style="width: 15%;">Continuous</td> <td style="width: 30%;">2-OHP-4021-005-002</td> <td style="width: 15%;">Rev. 12</td> <td style="width: 40%;">Page 52 of 76</td> </tr> <tr> <td colspan="4" style="text-align: center;">Operation of the Unit 2 Boric Acid Blender</td> </tr> <tr> <td>Attachment 9</td> <td>Boron or Dilution Volume Determination</td> <td colspan="2">Pages: 52 - 55</td> </tr> </table> <p><b>1 PURPOSE AND SCOPE</b></p> <p>1.1 Provide instructions for determining the amount of boration or dilution required.</p> <p><b>2 PREREQUISITES</b></p> <p>2.1 None</p> <p><b>3 PRECAUTIONS AND LIMITATIONS</b></p> <p>3.1 Calculations in this attachment are based on design information and are accurate to within engineering tolerances. Current plant conditions may vary the actual requirements.</p> <p>3.2 Calculations are based on TRM minimum values of BA concentration. BA concentrations above minimum value will require a lower amount of BA.</p> <p>3.3 Ensure adequate Shutdown Margin will be maintained following dilution.</p> <p>3.4 If last addition to the RCS was PW, the first 27 gallons of next addition will be PW. This shall be considered in the total reactivity change to be made.</p> <p><b>4 DETAILS</b></p> <p>4.1 IF in MODES 1 or 2, THEN perform the following as applicable (N/A steps that are not applicable):</p> <p>4.1.1 Amount determined for power change based on plant conditions.</p> <p style="margin-left: 20px;">a. Determine current RCS boron concentration from most recent representative sample.</p> <p style="margin-left: 40px;">_____ ppm</p> <p style="margin-left: 100px;"><i>N/A TO today</i></p>	Continuous	2-OHP-4021-005-002	Rev. 12	Page 52 of 76	Operation of the Unit 2 Boric Acid Blender				Attachment 9	Boron or Dilution Volume Determination	Pages: 52 - 55		<p>STANDARD: Agrees that section 4.1.1 is not applicable</p> <p>SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p>
Continuous	2-OHP-4021-005-002	Rev. 12	Page 52 of 76										
Operation of the Unit 2 Boric Acid Blender													
Attachment 9	Boron or Dilution Volume Determination	Pages: 52 - 55											



# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS ("CS" Indicates Critical Standard)												
<table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 10px;"> <tr> <td style="width: 25%; text-align: center;">Continuous</td> <td style="width: 25%; text-align: center;">2-OHP-4021-005-002</td> <td style="width: 25%; text-align: center;">Rev. 12</td> <td style="width: 25%; text-align: center;">Page 54 of 76</td> </tr> <tr> <td colspan="4" style="text-align: center;">Operation of the Unit 2 Boric Acid Blender</td> </tr> <tr> <td style="text-align: center;">Attachment 9</td> <td style="text-align: center;">Boron or Dilution Volume Determination</td> <td colspan="2" style="text-align: right;">Pages: 52 - 55</td> </tr> </table> <p>c. Determine current RCS boron concentration from most recent representative sample.</p> <p style="margin-left: 40px;"><u>1000</u> ppm <span style="float: right;"><u>JB</u></span></p> <p>d. Determine Moderator Temperature Coefficient (MTC) from Technical Data Book (Figure 5.1) or Nuclear Engineering Reactor Design Summary (NERDS) Reactivity Parameters Menu (option 2, 5).</p> <p style="margin-left: 40px;"><u>-10.5</u> pcm/°F <span style="float: right;"><u>JB</u></span></p> <p>e. Determine Effective Fuel Temperature <math>T_{eff}</math> from NERDS Reactivity Parameters Menu (option 3, 3).</p> <p style="margin-left: 40px;"><u>1179.3</u> °F <span style="float: right;"><u>JB</u></span></p> <p>f. Determine Doppler Temperature Coefficient (DTC) from NERDS Reactivity Parameters Menu (option 3.2).</p> <p style="margin-left: 40px;"><u>-2.235</u> pcm/°F <span style="float: right;"><u>JB</u></span></p> <p>g. Determine Temperature Coefficient (TC) from the following: MTC + DTC = TC</p> <p style="margin-left: 40px;"><math>(\frac{-10.5 \text{ pcm/°F}}{\text{step 4.1.2d}}) + (\frac{-2.235 \text{ pcm/°F}}{\text{step 4.1.2f}}) = (\frac{-12.735 \text{ pcm/°F}}{\text{step 4.1.2g}})</math> <span style="float: right;"><u>JB</u></span></p> <p>h. Determine required reactivity change (<math>\Delta\rho</math>) in PCM by the following: TC * Temperature Change = <math>\Delta\rho</math></p> <p style="margin-left: 40px;"><math>(\frac{-12.735 \text{ pcm/°F}}{\text{step 4.1.2g}}) * (\frac{1.2 \text{ °F}}{\text{step 4.1.2a}}) = (\frac{-15.282 \text{ pcm}}{\text{step 4.1.2h}})</math> <span style="float: right;"><u>JB</u></span></p> <p>i. Determine Differential Boron Worth (DBW) from Technical Data Book (Figure 4.1.a) or NERDS Reactivity Parameters Menu (option 1, 5).</p> <p style="margin-left: 40px;"><u>-8.05</u> pcm/ppm <span style="float: right;"><u>JB</u></span></p>	Continuous	2-OHP-4021-005-002	Rev. 12	Page 54 of 76	Operation of the Unit 2 Boric Acid Blender				Attachment 9	Boron or Dilution Volume Determination	Pages: 52 - 55		<p><b>CUE:</b> Provide RCS Boron (1,000 ppm) after candidates explains chemistry supplies this number after sampling and it is logged in the CR logs.</p> <p>STANDARD: Agrees 1000 ppm is from given information. SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p><b>STANDARD (CS):</b> Determines that MTC is actually -12.8. (-10.5pcm/°F is from wrong part of curve) (Range -12.5 to -13.0) SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p><b>CUE:</b> Provide Effective Fuel Temp (1179.3 °F) after candidates explains Reactor Engineering would supply this number when NERDS is unavailable.</p> <p>STANDARD: Agrees that the Effective Fuel Temperature is 1179.3°F SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p style="text-align: center; font-size: 1.2em; margin-top: 20px;">(Continued on next page)</p>
Continuous	2-OHP-4021-005-002	Rev. 12	Page 54 of 76										
Operation of the Unit 2 Boric Acid Blender													
Attachment 9	Boron or Dilution Volume Determination	Pages: 52 - 55											

OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS ("CS" Indicates Critical Standard)												
<table border="1" data-bbox="168 284 976 422"> <tr> <td>Continuous</td> <td>2-OHP-4021-005-002</td> <td>Rev. 12</td> <td>Page 54 of 76</td> </tr> <tr> <td colspan="4">Operation of the Unit 2 Boric Acid Blender</td> </tr> <tr> <td>Attachment 9</td> <td>Boron or Dilution Volume Determination</td> <td colspan="2">Pages: 52 - 55</td> </tr> </table> <p>c. Determine current RCS boron concentration from most recent representative sample.</p> <p><u>1000</u> ppm <u>JB</u></p> <p>d. Determine Moderator Temperature Coefficient (MTC) from Technical Data Book (Figure 5.1) or Nuclear Engineering Reactor Design Summary (NERDS) Reactivity Parameters Menu (option 2, 5).</p> <p><u>-10.5</u> pcm/°F <u>JB</u></p> <p>e. Determine Effective Fuel Temperature <math>T_{eff}</math> from NERDS Reactivity Parameters Menu (option 3, 3).</p> <p><u>1179.3</u> °F <u>JB</u></p> <p>f. Determine Doppler Temperature Coefficient (DTC) from NERDS Reactivity Parameters Menu (option 3.2).</p> <p><u>-2.235</u> pcm/°F <u>JB</u></p> <p>g. Determine Temperature Coefficient (TC) from the following: MTC + DTC = TC</p> <p><math>(\frac{-10.5 \text{ pcm/°F}}{\text{step 4.1.2d}}) + (\frac{-2.235 \text{ pcm/°F}}{\text{step 4.1.2f}}) = (\frac{-12.735 \text{ pcm/°F}}{\text{step 4.1.2g}})</math> <u>JB</u></p> <p>h. Determine required reactivity change (<math>\Delta\rho</math>) in PCM by the following: TC * Temperature Change = <math>\Delta\rho</math></p> <p><math>(\frac{-12.735 \text{ pcm/°F}}{\text{step 4.1.2g}}) * (\frac{1.2 \text{ °F}}{\text{step 4.1.2a}}) = (\frac{-15.282 \text{ pcm}}{\text{step 4.1.2a}})</math> <u>JB</u></p> <p>i. Determine Differential Boron Worth (DBW) from Technical Data Book (Figure 4.1.a) or NERDS Reactivity Parameters Menu (option 1, 5).</p> <p><u>-8.05</u> pcm/ppm <u>JB</u></p>	Continuous	2-OHP-4021-005-002	Rev. 12	Page 54 of 76	Operation of the Unit 2 Boric Acid Blender				Attachment 9	Boron or Dilution Volume Determination	Pages: 52 - 55		<p>(Continued from previous page)</p> <p><b>CUE:</b> Provide Doppler Temperature Coefficient (DTC = -2.235 pcm/°F) after candidate explains Reactor Engineering would supply this number when NERDS is unavailable.</p> <p>STANDARD: Agrees that the DTC is -2.235 pcm/°F SAT: <input type="checkbox"/> UNSAT: <input type="checkbox"/></p> <p>STANDARD: Determines that TC is -15.035 pcm/°F (-12.735 is from incorrect value in d)(Range -14.735 to -15.235) SAT: <input type="checkbox"/> UNSAT: <input type="checkbox"/></p> <p>STANDARD: Determines that PCM change is -18.042 (-15.035 pcm/°F x 1.2°F) (Range -17.682 to -18.282) (-15.282 is from incorrect value in g) SAT: <input type="checkbox"/> UNSAT: <input type="checkbox"/></p> <p>STANDARD: Agrees that DBW is -8.05 pcm/ppm (Range -8.0 to -8.1) SAT: <input type="checkbox"/> UNSAT: <input type="checkbox"/></p>
Continuous	2-OHP-4021-005-002	Rev. 12	Page 54 of 76										
Operation of the Unit 2 Boric Acid Blender													
Attachment 9	Boron or Dilution Volume Determination	Pages: 52 - 55											

OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS ("CS" Indicates Critical Standard)												
<table border="1" data-bbox="172 284 982 427"> <tr> <td>Continuous</td> <td>2-OHP-4021-005-002</td> <td>Rev. 12</td> <td>Page 55 of 76</td> </tr> <tr> <td colspan="4">Operation of the Unit 2 Boric Acid Blender</td> </tr> <tr> <td>Attachment 9</td> <td>Boron or Dilution Volume Determination</td> <td colspan="2">Pages: 52 - 55</td> </tr> </table> <p>j. Determine required RCS Critical Boron (<math>\Delta C_b</math>) concentration change in PPM by the following: <math>\Delta p / DBW = \Delta C_b</math></p> <p><math>(-12.735 \text{ pcm}) / (-8.05 \text{ pcm/ppm}) = (1.58 \text{ ppm})</math>  step 4.1.2h                      step 4.1.2i                      <u>DB</u></p> <p>k. Determine total amount of boration or dilution required to accomplish desired RCS temperature change from Technical Data Book (2-Figure 7.5.1 or 2-Figure 7.2)</p> <p><u>120</u> GAL - Boric Acid/Makeup Water  (circle one)                      <u>DB</u></p> <p>4.2 Use either of the following methods in MODES 3, 4 and 5:</p> <p>4.2.1 Technical Data Book:</p> <p>a. Determine current RCS boron concentration from most recent representative sample.</p> <p>_____ ppm</p> <p>b. Determine total amount of boration or dilution required to accomplish desired RCS boron concentration from Technical Data Book (2-Figure 7.5.1, 12-Figure 7.5.2, 7.5.3 or 2-Figure 7.2).</p> <p>_____ GAL - Boric Acid/Makeup Water  (circle one)                      _____</p>	Continuous	2-OHP-4021-005-002	Rev. 12	Page 55 of 76	Operation of the Unit 2 Boric Acid Blender				Attachment 9	Boron or Dilution Volume Determination	Pages: 52 - 55		<p>STANDARD (CS): Determines that required Boron change is +2.24 ppm (-18.042 pcm/-8.05 pcm/ppm) (Range +2.18 to +2.29) (1.58 is from incorrect value in g)  SAT: <input type="checkbox"/>                      UNSAT: <input type="checkbox"/></p> <p>STANDARD (CS): Determines that Boron change requires +24 gallons of Boric Acid (circle Boric Acid) (Range 22 - 26 gallons). Identifies RO used Dilution graph to determine volume.  SAT: <input type="checkbox"/>                      UNSAT: <input type="checkbox"/></p> <p><b>Note: Acceptable range based on graph reading from the lower limit line (20) and mid-scale (30) for the given boron concentration and required ppm change. The calculated limits of 23.92 to 25.66 is included within this range)</b></p> <p>STANDARD: Determines that section 4.2 is not applicable  SAT: <input type="checkbox"/>                      UNSAT: <input type="checkbox"/></p> <p><b>TERMINATION CUE:</b> "JPM is complete when review of the completed Attachment 9 and any identified errors is provided to evaluator".</p>
Continuous	2-OHP-4021-005-002	Rev. 12	Page 55 of 76										
Operation of the Unit 2 Boric Acid Blender													
Attachment 9	Boron or Dilution Volume Determination	Pages: 52 - 55											

## Task Briefing

You are unit supervisor in Unit 2.

You have directed the RO to calculate the required Boration or Dilution to restore  $T_{ave}$  to program.

Nuclear Engineering Reactor Design Summary (NERDS) is NOT available.

Reactor Power	96.3%
$T_{ave}$	574.2°F
$T_{ref}$	573°F

He has calculated ONLY the amount of Boron or PW required to be added to the VCT.

Review his calculation for correctness identifying any errors.





# COOK NUCLEAR PLANT TRAINING CENTER

## Bridgman, Michigan

OPERATIONS JPM

**TRAINING PROGRAM TITLE**

Initial License Training

**TIME:**

20 Minutes

**NUMBER AND TITLE:**

2020NRC-A1.b-SRO  
Review Valve Stroke Data per 1-OHP-4030-114-011-Attachment 1

**REVISION:**

0

Examinee's Name: \_\_\_\_\_

Evaluator's Name: \_\_\_\_\_

Date Performed: \_\_\_\_\_

Result (Circle One):            SAT    /    UNSAT

Number of Attempts: \_\_\_\_\_

Time to Complete: \_\_\_\_\_

Comments: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

# OPERATIONS JPM

## REFERENCES/NRC KA/TASKS

Procedures:

1-OHP-4030-114-011

Containment Isolation And IST Valve Operability Test, Rev. 36

TDB-1-Fig-19.-1

Power Operated Valve Stroke Time Limits, Rev. 125

### NRC KA

KA 2.2.12

Knowledge of surveillance procedures. (CFR: 41.10 / 45.13)

RO/SRO Importance

3.7/4.1

## TRAINING AIDS/TOOLS/EQUIPMENT

None

## HANDOUTS

PMP-4030-EXE-001, Conduct of surveillance Testing

1-OHP-4030-114-011, Containment Isolation and IST Valve Operability Test, Attachment 1

OHI-4016, Conduct of Operations: Guidelines (Available if requested)

## ATTACHMENTS

None

## EVALUATION SETTINGS

Classroom

EVALUATION METHOD:

PERFORM:



SIMULATE:



## SIMULATOR/LAB SETUP

2020NRC-A1.b-SRO  
Review Valve Stroke Data

Revision: 0

# OPERATIONS JPM

None

## EVALUATOR INSTRUCTIONS

Note: This JPM is based on 1-OHP-4030-114-011, Rev. 36 and TDB-1-Fig-19.-1, Rev. 125. Any subsequent revisions to the procedures will require a review of this JPM to ensure that the content of the JPM is still valid. This JPM may be used without revision if the procedure changes do not affect the JPM.

Give copy of Task Briefing and procedure to examinee.

## TASK BRIEFING

The SM has requested you to perform the SRO Review the recently performed 1-OHP-4030-114-011 Attachment 1, RCDT and Containment Sump Valve Test.

## GENERAL STANDARDS/PRECAUTIONS

The completed Attachment has been reviewed and any errors have been identified.

2020NRC-A1.b-SRO Review Valve Stroke Data	Revision: 0
2020NRC-A1.b-SRO (R3).doc	Page 3 of 13

# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS (“CS” Indicates Critical Standard)												
<table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 10px;"> <tr> <td style="width: 25%;">Continuous</td> <td style="width: 40%;">I-OHP-4030-114-011</td> <td style="width: 15%;">Rev. 32</td> <td style="width: 20%;">Page 10 of 206</td> </tr> <tr> <td colspan="4" style="text-align: center;"><b>Containment Isolation And IST Valve Operability Test</b></td> </tr> <tr> <td>Attachment 1</td> <td>RCDT and Containment Sumps Valves Test</td> <td colspan="2">Pages: 10 - 18</td> </tr> </table>		Continuous	I-OHP-4030-114-011	Rev. 32	Page 10 of 206	<b>Containment Isolation And IST Valve Operability Test</b>				Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18	
Continuous	I-OHP-4030-114-011	Rev. 32	Page 10 of 206										
<b>Containment Isolation And IST Valve Operability Test</b>													
Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18											
<p><b>1 PURPOSE AND SCOPE</b></p> <p>1.1 To demonstrate OPERABILITY and satisfy testing requirements associated with the D.C. Cook Nuclear Plant IST Program for the following Containment Isolation Valves (CIVs), testable during plant operation in MODES 1 - 4, per TS SR 3.6.3.4 and the D.C. Cook Nuclear Plant IST Program:</p> <ul style="list-style-type: none"> <li>• 1-DCR-201, RCDT And PRT To Rad Waste Gas Compressor Train 'A' Contmt Isolation Valve</li> <li>• 1-DCR-203, RCDT And PRT To Rad Waste Gas Compressor Train 'B' Contmt Isolation Valve</li> <li>• 1-DCR-205, RCDT Pumps Suction From RDCT Train 'A' Contmt Isolation Valve</li> <li>• 1-DCR-206, RCDT Pumps Suction From RDCT Train 'B' Contmt Isolation Valve</li> <li>• 1-DCR-207, Reactor Plant Nitrogen To RDCT 1-TK-1 Contmt Isolation Valve</li> <li>• 1-DCR-600, Containment Sump Pumps Discharge To Dirty Waste Holdup Tank Train 'A' Containment Isolation Valve</li> <li>• 1-DCR-601, Containment Sump Pumps Discharge To Dirty Waste Holdup Tank Train 'B' Containment Isolation Valve</li> </ul> <p>1.2 To satisfy full-stroke exercise requirements associated with the D.C. Cook Nuclear Plant IST Program by moving the valves listed above to the required position in both directions.</p> <p><b>2 PREREQUISITES</b> <span style="float: right;"><b>INIT</b></span></p> <p>2.1 The working copy of this procedure is the current revision. <span style="float: right;"><i>JH</i></span></p> <p>2.2 A pre-test briefing has been conducted with the SM, US, or WCC-SRO per PMP-4010-JOB-001, Pre-Job Briefs and Post-Job Reviews. <span style="float: right;"><i>JH</i></span></p>	<p>Note: Operator verifies prerequisites completed.</p>												

# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS ("CS" Indicates Critical Standard)												
<table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 10px;"> <tr> <td style="text-align: center;">Continuous</td> <td style="text-align: center;">1-OHP-4030-114-011</td> <td style="text-align: center;">Rev. 32</td> <td style="text-align: center;">Page 11 of 206</td> </tr> <tr> <td colspan="4" style="text-align: center;"><b>Containment Isolation And IST Valve Operability Test</b></td> </tr> <tr> <td style="text-align: center;">Attachment 1</td> <td style="text-align: center;">RCDT and Containment Sumps Valves Test</td> <td colspan="2" style="text-align: center;">Pages: 10 - 18</td> </tr> </table> <p>2.3 PMP-4030-EXE-001, Conduct of Surveillance Testing, Section 3.2, General Expectations for Surveillance Test Prerequisite Activity, has been reviewed. <span style="float: right;">JPM</span></p> <p>2.4 IST MIN and IST MAX stroke time acceptance criteria from Technical Data Book has been recorded in applicable action steps. <span style="float: right;">JPM</span></p> <p>2.5 <b>IF</b> Valve Position Indication (VPI) Verification Surveillance is scheduled for any valve listed in Step 1.1, <b>THEN</b> performance of this attachment is being coordinated with 1-OHP-4030-114-034, Local Valve Position Verification Test. <span style="float: right;">No SRO today N/A</span></p> <p>2.6 Record Stopwatch data:</p> <p>Primary Instrument Number <u>SP-05861</u></p> <p>Next Due Calibration Date <u>09-15-18</u> <span style="float: right;">JPM</span></p> <p>Secondary Instrument Number <u>N/A</u> (N/A if not used) <span style="float: right;">JPM</span></p> <p>Next Due Calibration Date <u>                    </u> <span style="float: right;">N/A</span></p> <p><b>3 PRECAUTIONS AND LIMITATIONS</b></p> <p>3/1 Inform SM of any abnormalities or problems encountered during this test.</p> <p>3/2 Recorded IST data shall be obtained from a calibrated instrument. Test instrumentation with a current calibration sticker and not identified as "rejected" is considered calibrated.</p> <p>3/3 Valves outside of IST MIN and IST MAX stroke time acceptance criteria when collecting as-found data could require an immediate retest per OHI-4016, Conduct of Operations: Guidelines.</p> <p>3/4 Components shall be evaluated against IST limits per OHI-4016 when determining OPERABILITY.</p> <p>3/5 The IST Fail-Safe Testing requirement is satisfied by satisfactory performance of the open and closed stroke time testing.</p>	Continuous	1-OHP-4030-114-011	Rev. 32	Page 11 of 206	<b>Containment Isolation And IST Valve Operability Test</b>				Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18		<p>STANDARD: Operator determines that TDB-1-FIG 19.1 is required for the IST MIN and IST MAX Times</p> <p>SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p>
Continuous	1-OHP-4030-114-011	Rev. 32	Page 11 of 206										
<b>Containment Isolation And IST Valve Operability Test</b>													
Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18											

# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS ("CS" Indicates Critical Standard)																										
<table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 10px;"> <tr> <td style="text-align: center;">Continuous</td> <td style="text-align: center;">1-OHP-4030-114-011</td> <td style="text-align: center;">Rev. 32</td> <td style="text-align: center;">Page 12 of 206</td> </tr> <tr> <td colspan="4" style="text-align: center;"><b>Containment Isolation And IST Valve Operability Test</b></td> </tr> <tr> <td style="text-align: center;">Attachment 1</td> <td style="text-align: center;">RCDT and Containment Sumps Valves Test</td> <td colspan="2" style="text-align: center;">Pages: 10 - 18</td> </tr> </table> <p>3/6 On headers considered susceptible to pressure binding, the outer CIV shall remain open while the inner CIV is tested unless some other outlet for the displaced water has been established. Pressure binding can prevent an open CIV within an isolated segment from closing upon receipt of a signal. Pressure binding occurs when the required displacement of liquid necessary to allow for the movement of the air-operated isolation valve internals cannot occur due to a water-solid or near water-solid condition within the isolated piping segment caused by thermal expansion of the trapped fluid. Even if the CIV manages to fully close, sufficient pressure buildup in the isolated piping segment can cause the valve to reopen. This precaution applies to the following valves in this attachment: [Ref. 8.2.1.]</p> <ul style="list-style-type: none"> <li>• 1-DCR-205</li> <li>• 1-DCR-600</li> </ul> <p><b>4 DETAILS</b> <span style="float: right;"><b>INIT</b></span></p> <p>4.1 Perform the following to test RCDT valves:</p> <p>4.1.1 Perform the following for 1-DCR-201, RC Drain Tank to Vent Header:</p> <p>a. Verify 1-DCR-201 - OPEN. <span style="float: right;"><i>JJC</i></span></p> <p>b. Stroke <b>AND</b> time 1-DCR-201 - CLOSED.</p> <table border="1" style="width: 100%; border-collapse: collapse; margin: 10px 0;"> <thead> <tr> <th style="text-align: center;">Stopwatch (Circle)</th> <th style="text-align: center;">IST MIN</th> <th style="text-align: center;">As Found</th> <th style="text-align: center;">IST MAX</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">Pri / Sec</td> <td style="text-align: center;"><u>0</u> sec</td> <td style="text-align: center;"><u>1.7</u> sec</td> <td style="text-align: center;"><u>2</u> sec</td> </tr> </tbody> </table> <p>Is an Immediate Valve Retest Required per OHI-4016? (✓) <span style="float: right;"><input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <i>JJC</i></span></p> <p>c. Open 1-DCR-201. <span style="float: right;"><i>JJC</i></span></p> <p>d. Full-Stroke Exercise Satisfactory? (✓) <span style="float: right;"><input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <i>JJC</i></span></p> <p>e. Fail-Safe Test Satisfactory? (✓) <span style="float: right;"><input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <i>JJC</i></span></p>	Continuous	1-OHP-4030-114-011	Rev. 32	Page 12 of 206	<b>Containment Isolation And IST Valve Operability Test</b>				Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18		Stopwatch (Circle)	IST MIN	As Found	IST MAX	Pri / Sec	<u>0</u> sec	<u>1.7</u> sec	<u>2</u> sec	<p>STANDARD: Operator determine IST MIN and IST MAX Times entered correctly and results are acceptable</p> <p>SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <table border="1" style="width: 100%; border-collapse: collapse; margin-top: 10px;"> <tr> <td style="width: 15%;">1-DCR-201</td> <td style="width: 15%;">Closed</td> <td style="width: 15%; text-align: center;">0</td> <td style="width: 15%; text-align: center;">2.0</td> <td style="width: 15%; text-align: center;">2.0</td> <td style="width: 15%;"></td> </tr> </table>	1-DCR-201	Closed	0	2.0	2.0	
Continuous	1-OHP-4030-114-011	Rev. 32	Page 12 of 206																								
<b>Containment Isolation And IST Valve Operability Test</b>																											
Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18																									
Stopwatch (Circle)	IST MIN	As Found	IST MAX																								
Pri / Sec	<u>0</u> sec	<u>1.7</u> sec	<u>2</u> sec																								
1-DCR-201	Closed	0	2.0	2.0																							

# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS ("CS" Indicates Critical Standard)																																								
<table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 10px;"> <tr> <td style="font-size: small;">Continuous</td> <td style="font-size: small;">1-OHP-4030-114-011</td> <td style="font-size: small;">Rev. 32</td> <td style="font-size: small;">Page 13 of 206</td> </tr> <tr> <td colspan="4" style="text-align: center; font-weight: bold;">Containment Isolation And IST Valve Operability Test</td> </tr> <tr> <td style="font-size: small;">Attachment 1</td> <td style="font-size: small;">RCDT and Containment Sumps Valves Test</td> <td colspan="2" style="font-size: small;">Pages: 10 - 18</td> </tr> </table> <p>4.1.2 Perform the following for 1-DCR-203, RC Drain Tank to Vent Header:</p> <p>a. Verify 1-DCR-203 - OPEN. <span style="float: right;"><i>JPM</i></span></p> <p>b. Stroke <b>AND</b> time 1-DCR-203 - CLOSED.</p> <table border="1" style="width: 100%; border-collapse: collapse; margin: 10px 0;"> <thead> <tr> <th style="font-size: x-small;">Stopwatch (Circle)</th> <th style="font-size: x-small;">IST MIN</th> <th style="font-size: x-small;">As Found</th> <th style="font-size: x-small;">IST MAX</th> </tr> </thead> <tbody> <tr> <td style="font-size: x-small;">Pri / Sec</td> <td style="text-align: center;">0 sec</td> <td style="text-align: center;">1,6 sec</td> <td style="text-align: center;">2 sec</td> </tr> </tbody> </table> <p>Is an Immediate Valve Retest Required per OHI-40167 (✓) <span style="float: right;"><i>JPM</i></span></p> <p style="margin-left: 100px;"><input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>c. Open 1-DCR-203. <span style="float: right;"><i>JPM</i></span></p> <p>d. Full-Stroke Exercise Satisfactory? (✓) <span style="float: right;"><i>JPM</i></span></p> <p style="margin-left: 100px;"><input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>e. Fail-Safe Test Satisfactory? (✓) <span style="float: right;"><i>JPM</i></span></p> <p style="margin-left: 100px;"><input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p> <div style="border: 1px solid black; padding: 2px; margin: 10px 0; font-size: x-small;"> <b>NOTE:</b> RCDT pressure should be considered when stroking Nitrogen Supply Valve.         </div> <p>4.1.3 Perform the following for 1-DCR-207, Nitrogen To RC Drain Tk:</p> <p>a. Open 1-DCR-207. <span style="float: right;"><i>JPM</i></span></p> <p>b. Stroke <b>AND</b> time 1-DCR-207 - CLOSED.</p> <table border="1" style="width: 100%; border-collapse: collapse; margin: 10px 0;"> <thead> <tr> <th style="font-size: x-small;">Stopwatch (Circle)</th> <th style="font-size: x-small;">IST MIN</th> <th style="font-size: x-small;">As Found</th> <th style="font-size: x-small;">IST MAX</th> </tr> </thead> <tbody> <tr> <td style="font-size: x-small;">Pri / Sec</td> <td style="text-align: center;">0 sec</td> <td style="text-align: center;">1,7 sec</td> <td style="text-align: center;">2 sec</td> </tr> </tbody> </table> <p>Is an Immediate Valve Retest Required per OHI-40167 (✓) <span style="float: right;"><i>JPM</i></span></p> <p style="margin-left: 100px;"><input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>c. Full-Stroke Exercise Satisfactory? (✓) <span style="float: right;"><i>JPM</i></span></p> <p style="margin-left: 100px;"><input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p>	Continuous	1-OHP-4030-114-011	Rev. 32	Page 13 of 206	Containment Isolation And IST Valve Operability Test				Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18		Stopwatch (Circle)	IST MIN	As Found	IST MAX	Pri / Sec	0 sec	1,6 sec	2 sec	Stopwatch (Circle)	IST MIN	As Found	IST MAX	Pri / Sec	0 sec	1,7 sec	2 sec	<p style="font-weight: bold; margin-top: 20px;">STANDARD: Operator determine IST MIN and IST MAX Times entered correctly and results are acceptable</p> <table border="1" style="width: 100%; border-collapse: collapse; margin: 10px 0;"> <tr> <td style="width: 15%;">1-DCR-203</td> <td style="width: 15%;">Closed</td> <td style="width: 15%; text-align: center;">0</td> <td style="width: 15%; text-align: center;">2.0</td> <td style="width: 15%; text-align: center;">2.0</td> <td style="width: 15%;"></td> </tr> </table> <p style="font-weight: bold; margin-top: 20px;">STANDARD: Operator determine IST MIN and IST MAX Times entered correctly and results are acceptable</p> <table border="1" style="width: 100%; border-collapse: collapse; margin: 10px 0;"> <tr> <td style="width: 15%;">1-DCR-207</td> <td style="width: 15%;">Closed</td> <td style="width: 15%; text-align: center;">0</td> <td style="width: 15%; text-align: center;">2.0</td> <td style="width: 15%; text-align: center;">2.0</td> <td style="width: 15%;"></td> </tr> </table>	1-DCR-203	Closed	0	2.0	2.0		1-DCR-207	Closed	0	2.0	2.0	
Continuous	1-OHP-4030-114-011	Rev. 32	Page 13 of 206																																						
Containment Isolation And IST Valve Operability Test																																									
Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18																																							
Stopwatch (Circle)	IST MIN	As Found	IST MAX																																						
Pri / Sec	0 sec	1,6 sec	2 sec																																						
Stopwatch (Circle)	IST MIN	As Found	IST MAX																																						
Pri / Sec	0 sec	1,7 sec	2 sec																																						
1-DCR-203	Closed	0	2.0	2.0																																					
1-DCR-207	Closed	0	2.0	2.0																																					

# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS ("CS" Indicates Critical Standard)																																								
<div style="border: 1px solid black; padding: 2px; margin-bottom: 10px;"> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="font-size: small;">Continuous</td> <td style="font-size: small;">1-OHP-4030-114-011</td> <td style="font-size: small;">Rev. 32</td> <td style="font-size: small;">Page 14 of 206</td> </tr> <tr> <td colspan="4" style="text-align: center; font-weight: bold;">Containment Isolation And IST Valve Operability Test</td> </tr> <tr> <td style="font-size: small;">Attachment 1</td> <td style="font-size: small;">RCDT and Containment Sumps Valves Test</td> <td colspan="2" style="font-size: small;">Pages: 10 - 18</td> </tr> </table> </div> <p>d. Fail-Safe Test Satisfactory? (✓) <span style="border: 2px solid red; border-radius: 50%; padding: 2px;"><input type="checkbox"/> Yes <input type="checkbox"/> No</span></p> <p>4.1.4 Perform the following for 1-DCR-205, RC Drain Tank Pumps Suction:</p> <p>a. Verify Selector Switch for 1-DCR-205, RC Drain Tk Outlet Train A Contmt Isolation, in - NORMAL. <i>J.P.</i></p> <p>b. Verify 1-DCR-206, RC Drain Tank Pump Saction - OPEN. <i>J.P.</i></p> <p>c. Open 1-DCR-205. <i>J.P.</i></p> <p>d. Stroke <b>AND</b> time 1-DCR-205 - CLOSED.</p> <table border="1" style="width: 100%; border-collapse: collapse; margin-top: 10px;"> <thead> <tr> <th style="font-size: x-small;">Stopwatch (Circle)</th> <th style="font-size: x-small;">IST MIN</th> <th style="font-size: x-small;">As Found</th> <th style="font-size: x-small;">IST MAX</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;"><i>PS</i> / Sec</td> <td style="text-align: center;">1.2 sec</td> <td style="text-align: center;"><i>4.6</i> sec</td> <td style="text-align: center;">4.4 sec</td> </tr> </tbody> </table> <p>Is an Immediate Valve Retest Required per OHI-4016? (✓) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <i>J.P.</i></p> <p>e. Full-Stroke Exercise Satisfactory? (✓) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <i>J.P.</i></p> <p>f. Fail-Safe Test Satisfactory? (✓) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <i>J.P.</i></p> <p>4.1.5 Perform the following for 1-DCR-206, RC Drain Tank Pump Suction:</p> <p>a. Stroke <b>AND</b> time 1-DCR-206 - CLOSED.</p> <table border="1" style="width: 100%; border-collapse: collapse; margin-top: 10px;"> <thead> <tr> <th style="font-size: x-small;">Stopwatch (Circle)</th> <th style="font-size: x-small;">IST MIN</th> <th style="font-size: x-small;">As Found</th> <th style="font-size: x-small;">IST MAX</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;"><i>PS</i> / Sec</td> <td style="text-align: center;">1.2 sec</td> <td style="text-align: center;"><i>4.0</i> sec</td> <td style="text-align: center;">4.9 sec</td> </tr> </tbody> </table> <p>Is an Immediate Valve Retest Required per OHI-4016? (✓) <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <i>J.P.</i></p> <p>b. Fail-Safe Test Satisfactory? (✓) <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <i>J.P.</i></p> <p>c. Open 1-DCR-206. <i>J.P.</i></p>	Continuous	1-OHP-4030-114-011	Rev. 32	Page 14 of 206	Containment Isolation And IST Valve Operability Test				Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18		Stopwatch (Circle)	IST MIN	As Found	IST MAX	<i>PS</i> / Sec	1.2 sec	<i>4.6</i> sec	4.4 sec	Stopwatch (Circle)	IST MIN	As Found	IST MAX	<i>PS</i> / Sec	1.2 sec	<i>4.0</i> sec	4.9 sec	<p>STANDARD (CS): Operator determines Box not checked and Initials missed SAT: <input type="checkbox"/> UNSAT: <input type="checkbox"/></p> <p>STANDARD (CS): Operator determines IST MAX Times were incorrectly entered from the limits column SAT: <input type="checkbox"/> UNSAT: <input type="checkbox"/></p> <table border="1" style="width: 100%; border-collapse: collapse; margin-top: 10px;"> <tr> <td style="font-size: x-small;">1-DCR-205</td> <td style="font-size: x-small;">Closed</td> <td style="font-size: x-small;">1.2</td> <td style="border: 2px solid red; font-size: x-small;">3.3</td> <td style="font-size: x-small;">4.4</td> <td style="font-size: x-small;">2.3</td> </tr> </table> <p>STANDARD (CS): Operator determines IST MAX Time and LIMIT was exceeded and re-test is NOT allowed SAT: <input type="checkbox"/> UNSAT: <input type="checkbox"/></p> <p>STANDARD (CS): Operator determines IST Limit Time was not exceeded but the IST MAX was exceeded so retest is allowed SAT: <input type="checkbox"/> UNSAT: <input type="checkbox"/></p> <table border="1" style="width: 100%; border-collapse: collapse; margin-top: 10px;"> <tr> <td style="font-size: x-small;">1-DCR-206</td> <td style="font-size: x-small;">Closed</td> <td style="font-size: x-small;">1.3</td> <td style="border: 2px solid red; font-size: x-small;">3.7</td> <td style="border: 2px solid red; font-size: x-small;">4.9</td> <td style="font-size: x-small;">2.5</td> </tr> </table>	1-DCR-205	Closed	1.2	3.3	4.4	2.3	1-DCR-206	Closed	1.3	3.7	4.9	2.5
Continuous	1-OHP-4030-114-011	Rev. 32	Page 14 of 206																																						
Containment Isolation And IST Valve Operability Test																																									
Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18																																							
Stopwatch (Circle)	IST MIN	As Found	IST MAX																																						
<i>PS</i> / Sec	1.2 sec	<i>4.6</i> sec	4.4 sec																																						
Stopwatch (Circle)	IST MIN	As Found	IST MAX																																						
<i>PS</i> / Sec	1.2 sec	<i>4.0</i> sec	4.9 sec																																						
1-DCR-205	Closed	1.2	3.3	4.4	2.3																																				
1-DCR-206	Closed	1.3	3.7	4.9	2.5																																				



# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS ("CS" Indicates Critical Standard)																										
<div style="border: 1px solid black; padding: 2px; margin-bottom: 5px;"> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="font-size: small;">Continuous</td> <td style="font-size: small;">1-OHP-4030-114-011</td> <td style="font-size: small;">Rev. 32</td> <td style="font-size: small;">Page 15 of 206</td> </tr> <tr> <td colspan="4" style="text-align: center; font-weight: bold; font-size: small;">Containment Isolation And IST Valve Operability Test</td> </tr> <tr> <td style="font-size: small;">Attachment 1</td> <td style="font-size: small;">RCDT and Containment Sumps Valves Test</td> <td colspan="2" style="font-size: small;">Pages: 10 - 18</td> </tr> </table> </div> <p>d. Full-Stroke Exercise Satisfactory? (✓) <span style="border: 2px solid red; border-radius: 50%; padding: 2px;"><input type="checkbox"/> Yes <input type="checkbox"/> No</span></p> <p>4.2 Perform the following to test Containment Sump to Dirty Waste Holdup Tank valves:</p> <p>4.2.1 Verify the following pumps in - STOP:</p> <ul style="list-style-type: none"> <li>• 1-PP-38A, Lower Contmt Sump Pump 2A <span style="float: right;"><i>JPM</i></span></li> <li>• 1-PP-38B, Lower Contmt Sump Pump 2B <span style="float: right;"><i>JPM</i></span></li> <li>• 1-PP-59A, Reactor Cavity Sump Pump 3A <span style="float: right;"><i>JPM</i></span></li> <li>• 1-PP-59B, Reactor Cavity Sump Pump 3B <span style="float: right;"><i>JPM</i></span></li> <li>• 1-PP-61A, Contmt Pipe Tnl Sump Pump 2A <span style="float: right;"><i>JPM</i></span></li> <li>• 1-PP-61B, Contmt Pipe Tnl Sump Pump 2B <span style="float: right;"><i>JPM</i></span></li> </ul> <p>4.2.2 Perform the following for 1-DCR-600, Contmt Sumps To Dirty Waste Hld Tk:</p> <p>a. Verify 1-DCR-601, Contmt Sumps To Dirty Waste Hld Tk - OPEN. <span style="float: right;"><i>JPM</i></span></p> <p>b. Stroke <b>AND</b> time 1-DCR-600 - CLOSED.</p> <table border="1" style="width: 100%; border-collapse: collapse; margin: 5px 0;"> <thead> <tr> <th style="font-size: x-small;">Stopwatch (Circle)</th> <th style="font-size: x-small;">IST MIN</th> <th style="font-size: x-small;">As Found</th> <th style="font-size: x-small;">IST MAX</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;"><span style="border: 1px solid black; border-radius: 50%; padding: 2px;">0</span> / Sec</td> <td style="text-align: center;"><i>0</i> sec</td> <td style="text-align: center;"><i>1.5</i> sec</td> <td style="text-align: center;"><i>2</i> sec</td> </tr> </tbody> </table> <p>Is an Immediate Valve Retest Required per OHI-4016? (✓) <span style="float: right;"><input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <i>JPM</i></span></p> <p>c. Fail-Safe Test Satisfactory? (✓) <span style="float: right;"><input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <i>JPM</i></span></p> <p>d. Open 1-DCR-600. <span style="float: right;"><i>JPM</i></span></p> <p>e. Full-Stroke Exercise Satisfactory? (✓) <span style="float: right;"><input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <i>JPM</i></span></p>	Continuous	1-OHP-4030-114-011	Rev. 32	Page 15 of 206	Containment Isolation And IST Valve Operability Test				Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18		Stopwatch (Circle)	IST MIN	As Found	IST MAX	<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">0</span> / Sec	<i>0</i> sec	<i>1.5</i> sec	<i>2</i> sec	<p>STANDARD (CS): Operator determines Box not checked and Initials missed SAT: <input type="checkbox"/> UNSAT: <input type="checkbox"/></p> <p>STANDARD: Operator determine IST MIN and IST MAX. Times entered correctly and results are acceptable</p> <table border="1" style="width: 100%; border-collapse: collapse; margin-top: 10px;"> <tr> <td style="width: 15%;">1-DCR-600</td> <td style="width: 15%;">Closed</td> <td style="width: 15%; text-align: center;">0</td> <td style="width: 15%; text-align: center;">2.0</td> <td style="width: 15%; text-align: center;">2.0</td> <td style="width: 15%;"></td> </tr> </table>	1-DCR-600	Closed	0	2.0	2.0	
Continuous	1-OHP-4030-114-011	Rev. 32	Page 15 of 206																								
Containment Isolation And IST Valve Operability Test																											
Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18																									
Stopwatch (Circle)	IST MIN	As Found	IST MAX																								
<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">0</span> / Sec	<i>0</i> sec	<i>1.5</i> sec	<i>2</i> sec																								
1-DCR-600	Closed	0	2.0	2.0																							

# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS ("CS" Indicates Critical Standard)													
<table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 10px;"> <tr> <td style="width: 25%;">Continuous</td> <td style="width: 25%;">1-OHP-4030-114-011</td> <td style="width: 10%;">Rev. 32</td> <td style="width: 40%;">Page 16 of 206</td> </tr> <tr> <td colspan="4" style="text-align: center;"><b>Containment Isolation And IST Valve Operability Test</b></td> </tr> <tr> <td>Attachment 1</td> <td>RCDT and Containment Sumps Valves Test</td> <td colspan="2">Pages: 10 - 18</td> </tr> </table>		Continuous	1-OHP-4030-114-011	Rev. 32	Page 16 of 206	<b>Containment Isolation And IST Valve Operability Test</b>				Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18		
Continuous	1-OHP-4030-114-011	Rev. 32	Page 16 of 206											
<b>Containment Isolation And IST Valve Operability Test</b>														
Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18												
<p>4.2.3 Perform the following for 1-DCR-601, Contnt Sumps To Dirty Waste Hld Tk:</p> <p>a. Stroke <b>AND</b> time 1-DCR-601 - CLOSED.</p> <table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 10px;"> <thead> <tr> <th style="width: 15%;">Stopwatch (Circle)</th> <th style="width: 15%;">IST MIN</th> <th style="width: 15%;">As Found</th> <th style="width: 15%;">IST MAX</th> </tr> </thead> <tbody> <tr> <td>Pri / Sec</td> <td style="text-align: center;">0 sec</td> <td style="text-align: center;">1.5 sec</td> <td style="text-align: center;">2 sec</td> </tr> </tbody> </table> <p>Is an Immediate Valve Retest Required per OHH-4016? (✓)      <input type="checkbox"/> Yes    <input checked="" type="checkbox"/> No    <i>JPM</i></p> <p>b. Fail-Safe Test Satisfactory? (✓)      <input checked="" type="checkbox"/> Yes    <input type="checkbox"/> No    <i>JPM</i></p> <p>c. Open 1-DCR-601.      <i>JPM</i></p> <p>d. Full-Stroke Exercise Satisfactory? (✓)      <input checked="" type="checkbox"/> Yes    <input type="checkbox"/> No    <i>JPM</i></p> <p>4.2.4 Place the following in - AUTO, as required:</p> <ul style="list-style-type: none"> <li>• 1-PP-38A, Lower Contnt Sump Pump 2A      <i>JPM</i></li> <li>• 1-PP-38B, Lower Contnt Sump Pump 2B      <i>JPM</i></li> <li>• 1-PP-59A, Reactor Cavity Sump Pump 3A      <i>JPM</i></li> <li>• 1-PP-59B, Reactor Cavity Sump Pump 3B      <i>JPM</i></li> <li>• 1-PP-61A, Contnt Pipe Trl Sump Pump 2A      <i>JPM</i></li> <li>• 1-PP-61B, Contnt Pipe Trl Sump Pump 2B      <i>JPM</i></li> </ul>	Stopwatch (Circle)	IST MIN	As Found	IST MAX	Pri / Sec	0 sec	1.5 sec	2 sec	<p>STANDARD: Operator determine IST MIN and IST MAX Times entered correctly and results are acceptable</p> <table border="1" style="width: 100%; border-collapse: collapse; margin-top: 20px;"> <tr> <td style="width: 15%;">1-DCR-601</td> <td style="width: 15%;">Closed</td> <td style="width: 15%; text-align: center;">0</td> <td style="width: 15%; text-align: center;">2.0</td> <td style="width: 15%; text-align: center;">2.0</td> </tr> </table>	1-DCR-601	Closed	0	2.0	2.0
Stopwatch (Circle)	IST MIN	As Found	IST MAX											
Pri / Sec	0 sec	1.5 sec	2 sec											
1-DCR-601	Closed	0	2.0	2.0										

# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS (“CS” Indicates Critical Standard)												
<table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 10px;"> <tr> <td style="font-size: small;">Continuous</td> <td style="font-size: small;">1-OHP-4030-114-011</td> <td style="font-size: small;">Rev. 32</td> <td style="font-size: small;">Page 17 of 206</td> </tr> <tr> <td colspan="4" style="text-align: center; font-weight: bold;">Containment Isolation And IST Valve Operability Test</td> </tr> <tr> <td style="font-size: small;">Attachment 1</td> <td style="font-size: small;">RCDT and Containment Sumps Valves Test</td> <td colspan="2" style="font-size: small;">Pages: 10 - 18</td> </tr> </table> <p><b>5 ACCEPTANCE CRITERIA</b></p> <p><i>SM</i> The As-Found stroke times obtained were within IST MIN and IST MAX stroke times as delineated in the Technical Data Book. (Steps 4.1.1b, 4.1.2b, 4.1.3b, 4.1.4d, 4.1.5a, 4.2.2b, and 4.2.3a)</p> <p><i>SM</i> Valves requiring full-stroke exercise checks were moved to the required position in both directions. (Steps 4.1.1d, 4.1.2d, 4.1.3c, 4.1.4e, 4.1.5d, 4.2.2e and 4.2.3d)</p> <p><i>SM</i> Valves requiring fail-safe testing traveled to required fail-safe position. (Steps 4.1.1e, 4.1.2e, 4.1.3d, 4.1.4f, 4.1.5b, 4.2.2c and 4.2.3b)</p> <p><b>6 CORRECTIVE MEASURES</b> <span style="float: right;"><b>INIT</b></span></p> <p>6.1 <b>IF</b> any Acceptance Criteria is not met during this test, <b>THEN</b> notify SM or US <b>AND</b> initiate corrective action per PMP-7030-CAP-001, Action Initiation. <span style="float: right;"><i>JLB</i></span></p> <p>6.2 <b>IF</b> any condition is found to be unsatisfactory during conduct of this test, <b>THEN</b> initiate corrective action per PMP-7030-CAP-001, Action Initiation, to effect necessary corrective action as required. <span style="float: right;"><i>JLB</i></span></p>	Continuous	1-OHP-4030-114-011	Rev. 32	Page 17 of 206	Containment Isolation And IST Valve Operability Test				Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18		<p><b>STANDARD (CS):</b> Operator determines</p> <ul style="list-style-type: none"> <li>DCR 207 “Fail-Safe” (not the Full-Stroke test) was not signed off;</li> <li>DCR-205, failed the “Stroke-Time” test, and was inappropriately re-tested as well as failing the “Stroke-Time” test on the re-test; and</li> <li>DCR-206 also failed the “Stroke-Time” test, but should have been re-tested, and the “Full-Stroke” test was not signed off.</li> </ul> <p>SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p><b>STANDARD (CS):</b> Determine That DCR-205 and DCR-206 were incorrectly tested and should be declared inoperable (DCR-206 could be retested)</p> <p>SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p>
Continuous	1-OHP-4030-114-011	Rev. 32	Page 17 of 206										
Containment Isolation And IST Valve Operability Test													
Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18											

OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS ("CS" Indicates Critical Standard)												
<table border="1" style="width:100%; border-collapse: collapse; margin-bottom: 10px;"> <tr> <td style="font-size: small;">Continuous</td> <td style="font-size: small;">1-OHP-4030-114-011</td> <td style="font-size: small;">Rev. 32</td> <td style="font-size: small;">Page 18 of 206</td> </tr> <tr> <td colspan="4" style="text-align: center; font-weight: bold;">Containment Isolation And IST Valve Operability Test</td> </tr> <tr> <td style="font-size: small;">Attachment 1</td> <td style="font-size: small;">RCDT and Containment Sumps Valves Test</td> <td colspan="2" style="font-size: small;">Pages: 10 - 18</td> </tr> </table> <p><b>7 FINAL CONDITIONS</b></p> <p>7.1 Test Performance:</p> <p>Start Time: <u>0500</u> Date: <u>Today</u> Stop Time: <u>0600</u> Date: <u>Today</u></p> <p>Comments: <u>None</u></p> <p>_____</p> <p style="text-align: center;"><u><i>P. Sanderson</i></u> Test Performer or Lead Worker</p> <p>7.2 Department Review:</p> <p>Were all applicable Acceptance Criteria met? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No, Action: _____</p> <p>Is this a Scheduled Surveillance? <input checked="" type="checkbox"/> Yes, Work Order: <u>2020567</u> <input type="checkbox"/> No</p> <p>If yes, is this a complete surveillance? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No, Action: _____ <input type="checkbox"/> N/A</p> <p>Additional Work Orders: _____</p> <p>Comments: _____</p> <p>_____</p> <p>Reviewed By: <u><i>P. Sanderson</i></u> Time: <u>0800</u> Date: <u>Today</u> Dept Supervisor or Designee</p> <p>7.3 Senior Reactor Operator (SRO) Review and Acceptance:</p> <p><input type="checkbox"/> A review of the test results was performed and the applicable Acceptance Criteria were met. Equipment is OPERABLE or the corresponding Event Initiated Surveillance has been satisfied.</p> <p><input type="checkbox"/> A review of the test results was performed and NOT all of the applicable Acceptance Criteria were met. Equipment is INOPERABLE with applicable Technical Specification LCO Actions in effect.</p> <p>Comments: _____</p> <p>_____</p> <p>Reviewed By: _____ Time: _____ Date: <u> / /</u> Work Control or On-Shift SRO</p>	Continuous	1-OHP-4030-114-011	Rev. 32	Page 18 of 206	Containment Isolation And IST Valve Operability Test				Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18		<p>STANDARD (CS): Determine that Acceptance Criteria was NOT met SAT: <input type="checkbox"/> UNSAT: <input type="checkbox"/></p> <p>STANDARD: examinee signs and dates or explains why he would not sign the attachment SAT: <input type="checkbox"/> UNSAT: <input type="checkbox"/></p> <p>TERMINATION CUE: JPM is complete when examinee signs or explains why he would not sign the attachment.</p>
Continuous	1-OHP-4030-114-011	Rev. 32	Page 18 of 206										
Containment Isolation And IST Valve Operability Test													
Attachment 1	RCDT and Containment Sumps Valves Test	Pages: 10 - 18											

## **Task Briefing**

The SM has requested you to perform the SRO Review the recently performed 1-OHP-4030-114-011 Attachment 1, RCDT and Containment Sump Valve Test.



# COOK NUCLEAR PLANT TRAINING CENTER

Bridgman, Michigan

## OPERATIONS JPM

**TRAINING PROGRAM TITLE**

INITIAL LICENSE TRAINING

**TIME:**

20 Minutes

**NUMBER AND TITLE:**

2020NRC-A2-SRO  
Review QPTR

**REVISION:**

0

Examinee's Name: \_\_\_\_\_

Evaluator's Name: \_\_\_\_\_

Date Performed: \_\_\_\_\_

Result (Circle One):            SAT     /     UNSAT

Number of Attempts: \_\_\_\_\_

Time to Complete: \_\_\_\_\_

Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

# OPERATIONS JPM

## REFERENCES/NRC KA/TASKS

Procedures:

2-OHP-4030-214-032

Quadrant Power Tilt Calculation

### NRC KA

KA 2.2.40

Ability to apply Technical Specifications for a system

RO/SRO Importance

3.4/4.7

Task Number: 0130180201

Perform Quadrant Power Tilt Ratio Calculation

## TRAINING AIDS/TOOLS/EQUIPMENT

Calculator

Ruler

Magnifying glass

## HANDOUTS

Task Briefing

Completed 2-OHP-4030-214-032 and Data Sheet 2

Attachment 1 – N41, N42, N43, and N44 Pictures

## ATTACHMENTS

NI Calibration Data Card

Attachment 1 – N41, N42, N43, and N44 Pictures

## EVALUATION SETTINGS

Classroom

EVALUATION METHOD:

PERFORM:



SIMULATE:



## SIMULATOR/LAB SETUP

2020NRC-A2-SRO  
Review QPTR

Revision: 0

2020NRC-A2-SRO (R3).doc

Page 2 of 8

# OPERATIONS JPM

None

## EVALUATOR INSTRUCTIONS

1. Brief the operator (May be performed by giving out Task Briefing Sheet)
2. Announce start of the JPM
3. Perform evolution
4. At completion of evolution, announce the JPM is complete.
5. Document evaluation performance.

## TASK BRIEFING

You are the Unit SRO.

The following conditions exist:

- Unit 2 is currently at 72% power.
- The Plant Process Computer (PPC) is INOPERABLE

The SM directs you to Review the manual 2-OHP-4030-214-032, Quadrant Power Tilt Calculation.

The NI amp meters are set to display maximum resolution (.1 MILLI-APMS on the RANGE selector switches).

### NOTE

Simulator Indications are NOT applicable to this JPM

## GENERAL STANDARDS/PRECAUTIONS

Completed QPTR has been reviewed and identifies that values for N42 Upper, N41 Lower and N43 Lower were incorrectly read/entered

2020NRC-A2-SRO Review QPTR	Revision: 0
2020NRC-A2-SRO (R3).doc	Page 3 of 8



# OPERATIONS JPM

EXPECTED ACTIONS				CUES/STANDARDS ("CS" Indicates Critical Standard)																							
Continuous	2-OHP-4030-214-032	Rev. 6	Page 10 of 12	<p>STANDARD (CS) Operator identifies that values for N42 Upper, N41 Lower and N43 Lower were incorrectly read/entered.                      ( Correct Values are: N42 Upper- 95.5, N41 Lower – 91.5, N43 Lower – 99)                      (Range +/- 0.5 Micro-Amps for all readings)                      SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p>If required Direct Operator to makes required corrections and recalculate.</p> <p>STANDARD (CS) Operator enters and calculates correct values for:</p> <ul style="list-style-type: none"> <li>• N42 upper 95.5 (95.0 to 96.0) Normalized - .6991 (.6955 to .7028)</li> <li>• Upper Total 2.873 (2.869 to 2.876)</li> <li>• N41 Lower 91.5 (91.0 to 92.0) Normalized - .6748 (.6711 to .6785)</li> <li>• N43 Lower 99 (98.5 to 99.5) Normalized - .7350 (.7313 to .7387)</li> <li>• Lower Total 2.848 (2.840 to 2.855)</li> </ul> <p>• Upper QPTR 1.018 (1.0168 to 1.0194)                      • Lower QPTR 1.032 (1.0244 to 1.040)</p> <p>SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p>STANDARD (CS) Operator identifies that value was incorrectly calculated.                      Should be 1.032 resulting in excessive QPTR.                      1.032 (range 1.0244 to 1.040)                      SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p>STANDARD (CS) Operator Determines that Both Upper and Lower are &gt; Notification Limit                      SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p>STANDARD Operator Determines that Acceptance Criteria is NOT Met (QPTR &gt; 1.02)                      SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p>																							
<b>Quadrant Power Tilt Ratio Calculation</b>																											
Data Sheet 2	Quadrant Power Tilt Ratio Calculation Sheet	Pages: 10 - 11																									
<p><b>NOTE:</b> IF Unit 2 is operating at greater than 75% power, THEN consideration should be given to performing QPTR calculations immediately prior to declaring a Power Range INOPERABLE. This will lower the need to perform Data Sheet 3, Quadrant Power Tilt Ratio Calculation Sheet Using 3 NIS, and required Flux Map to comply with SR 3.2.4.2</p>																											
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left;">Upper Detector</th> <th style="text-align: center;">Record Detector "A" Current</th> <th style="text-align: center;">Record Detector "A" 120% value</th> <th style="text-align: center;">Normalized Value Detector A ÷ 120% value</th> </tr> </thead> <tbody> <tr><td>N-41</td><td style="text-align: center;">99</td><td style="text-align: center;">135.4</td><td style="text-align: center;">.7311</td></tr> <tr><td>N-42</td><td style="text-align: center;">97.5 (95.5)</td><td style="text-align: center;">136.6</td><td style="text-align: center;">.7138 (.6991)</td></tr> <tr><td>N-43</td><td style="text-align: center;">98</td><td style="text-align: center;">134.4</td><td style="text-align: center;">.7292</td></tr> <tr><td>N-44</td><td style="text-align: center;">97.5</td><td style="text-align: center;">136.7</td><td style="text-align: center;">.7132</td></tr> <tr><td colspan="3" style="text-align: right;">Upper Total</td><td style="text-align: center;">2.887 (2.873)</td></tr> </tbody> </table>				Upper Detector	Record Detector "A" Current	Record Detector "A" 120% value	Normalized Value Detector A ÷ 120% value	N-41	99	135.4	.7311	N-42	97.5 (95.5)	136.6	.7138 (.6991)	N-43	98	134.4	.7292	N-44	97.5	136.7	.7132	Upper Total			2.887 (2.873)
Upper Detector	Record Detector "A" Current	Record Detector "A" 120% value	Normalized Value Detector A ÷ 120% value																								
N-41	99	135.4	.7311																								
N-42	97.5 (95.5)	136.6	.7138 (.6991)																								
N-43	98	134.4	.7292																								
N-44	97.5	136.7	.7132																								
Upper Total			2.887 (2.873)																								
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left;">Lower Detector</th> <th style="text-align: center;">Record Detector "B" Current</th> <th style="text-align: center;">Record Detector "B" 120% value</th> <th style="text-align: center;">Normalized Value Detector B ÷ 120% value</th> </tr> </thead> <tbody> <tr><td>N-41</td><td style="text-align: center;">96.5 (91.5)</td><td style="text-align: center;">135.6</td><td style="text-align: center;">.7117 (.6748)</td></tr> <tr><td>N-42</td><td style="text-align: center;">96</td><td style="text-align: center;">133.6</td><td style="text-align: center;">.7186</td></tr> <tr><td>N-43</td><td style="text-align: center;">98 (99)</td><td style="text-align: center;">134.7</td><td style="text-align: center;">.7275 (.7350)</td></tr> <tr><td>N-44</td><td style="text-align: center;">98</td><td style="text-align: center;">136.2</td><td style="text-align: center;">.7195</td></tr> <tr><td colspan="3" style="text-align: right;">Lower Total</td><td style="text-align: center;">2.877 (2.848)</td></tr> </tbody> </table>				Lower Detector	Record Detector "B" Current	Record Detector "B" 120% value	Normalized Value Detector B ÷ 120% value	N-41	96.5 (91.5)	135.6	.7117 (.6748)	N-42	96	133.6	.7186	N-43	98 (99)	134.7	.7275 (.7350)	N-44	98	136.2	.7195	Lower Total			2.877 (2.848)
Lower Detector	Record Detector "B" Current	Record Detector "B" 120% value	Normalized Value Detector B ÷ 120% value																								
N-41	96.5 (91.5)	135.6	.7117 (.6748)																								
N-42	96	133.6	.7186																								
N-43	98 (99)	134.7	.7275 (.7350)																								
N-44	98	136.2	.7195																								
Lower Total			2.877 (2.848)																								
<p>Upper Tilt Ratio = <math>\frac{\text{Max Upper Normalized Value}}{\text{Upper Total}} \times 4 =</math> <u>1.0129</u></p> <p>Lower Tilt Ratio = <math>\frac{\text{Max Lower Normalized Value}}{\text{Lower Total}} \times 4 =</math> <u>1.0114</u></p> <p>Enter the max upper or lower tilt ratio (Calculated QPTR) <u>1.0129</u></p> <p>Highest Upper or Lower Radial Flux Tilt from PPC (N/A if unavailable or inoperable) <u>N/A</u></p> <p>Notification Limit: 1.015</p> <p>Acceptance Criteria: Calculated QPTR is less than OR equal to 1.02</p>																											

# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS (“CS” Indicates Critical Standard)								
<table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 10px;"> <tr> <td style="width: 25%; text-align: center;">Continuous</td> <td style="width: 25%; text-align: center;">2-OHP-4030-214-032</td> <td style="width: 25%; text-align: center;">Rev. 6</td> <td style="width: 25%; text-align: center;">Page 6 of 12</td> </tr> <tr> <td colspan="4" style="text-align: center;">Quadrant Power Tilt Ratio Calculation</td> </tr> </table> <p><b>6 CORRECTIVE MEASURES</b></p> <p>6.1 IF QPTR exceeds Notification Limit of 1.015, THEN notify SM and Reactor Engineering.</p> <p>6.2 IF QPTR exceeds Acceptance Criteria, THEN perform the following:</p> <ul style="list-style-type: none"> <li>• Notify SM and Reactor Engineering.</li> <li>• Enter appropriate Conditions and Required Actions of TS 3.2.4.</li> </ul>	Continuous	2-OHP-4030-214-032	Rev. 6	Page 6 of 12	Quadrant Power Tilt Ratio Calculation				<p>STANDARD (CS) Operator Determines that Acceptance Criteria is NOT Met (QPTR &gt; 1.02) and Notifies SM &amp; Reactor Engineering            SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p><b>CUE:</b> SM Acknowledges that QPTR has Exceeded TS value requests that you review the Required Technical Specification and determine the required Actions.</p>
Continuous	2-OHP-4030-214-032	Rev. 6	Page 6 of 12						
Quadrant Power Tilt Ratio Calculation									

# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS (“CS” Indicates Critical Standard)						
<p style="text-align: right; margin-right: 20px;">QPTR 3.2.4</p> <p>3.2 POWER DISTRIBUTION LIMITS</p> <p>3.2.4 QUADRANT POWER TILT RATIO (QPTR)</p> <p>LCO 3.2.4      The QPTR shall be ≤ 1.02.</p> <p>APPLICABILITY:    MODE 1 with THERMAL POWER &gt; 50% RTP.</p> <p><u>ACTIONS</u></p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 20%;">CONDITION</th> <th style="width: 50%;">REQUIRED ACTION</th> <th style="width: 30%;">COMPLETION TIME</th> </tr> </thead> <tbody> <tr> <td style="vertical-align: top;">A. QPTR not within limit.</td> <td style="vertical-align: top;">                     A.1 Reduce THERMAL POWER ≥ 3% from RTP for each 1% of QPTR &gt; 1.00.   <u>AND</u>                      A.2 Determine QPTR.   <u>AND</u>                      A.3 Perform SR 3.2.1.1, SR 3.2.1.2, and SR 3.2.2.1.                 </td> <td style="vertical-align: top;">                     2 hours after each QPTR determination                       Once per 12 hours                       24 hours after achieving equilibrium conditions from a THERMAL POWER reduction per Required Action A.1   <u>AND</u>                      Once per 7 days thereafter                 </td> </tr> </tbody> </table>	CONDITION	REQUIRED ACTION	COMPLETION TIME	A. QPTR not within limit.	A.1 Reduce THERMAL POWER ≥ 3% from RTP for each 1% of QPTR > 1.00.  <u>AND</u> A.2 Determine QPTR.  <u>AND</u> A.3 Perform SR 3.2.1.1, SR 3.2.1.2, and SR 3.2.2.1.	2 hours after each QPTR determination  Once per 12 hours  24 hours after achieving equilibrium conditions from a THERMAL POWER reduction per Required Action A.1  <u>AND</u> Once per 7 days thereafter	<p><b>CUE:</b> (If Required) Ask Operator to determine the Technical Specification LCO that applies.</p> <p>STANDARD (CS) Determines that Power is limited to 3% for each 1% over 1.00 (3.2 x 3% = 9.6%) per LCO 3.2.4 Action A.1 – (note action is met at current power – 90.4% is limit)                      (Range of 7.32% to 12.0% reduction with a 92.68% to 88.0% power limit)                      SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p>STANDARD (CS) Determines that QPTR must be calculated every 12 hours,                      SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p>STANDARD (CS) Verify <math>F_{\rho}^C(Z)</math> is within limit, Verify <math>F_{\rho}^W(Z)</math> is within limit, &amp; Verify <math>F_{\Delta h}^N</math> is within limits specified in the COLR every 7 days                      SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p>
CONDITION	REQUIRED ACTION	COMPLETION TIME					
A. QPTR not within limit.	A.1 Reduce THERMAL POWER ≥ 3% from RTP for each 1% of QPTR > 1.00.  <u>AND</u> A.2 Determine QPTR.  <u>AND</u> A.3 Perform SR 3.2.1.1, SR 3.2.1.2, and SR 3.2.2.1.	2 hours after each QPTR determination  Once per 12 hours  24 hours after achieving equilibrium conditions from a THERMAL POWER reduction per Required Action A.1  <u>AND</u> Once per 7 days thereafter					
Cook Nuclear Plant Unit 2                      3.2.4-1                      Amendment No. 289							

# OPERATIONS JPM

EXPECTED ACTIONS			CUES/STANDARDS ("CS" Indicates Critical Standard)
QPTR 3.2.4			
ACTIONS (continued)			
CONDITION	REQUIRED ACTION	COMPLETION TIME	
	<p>A.4 Reevaluate safety analyses and confirm results remain valid for duration of operation under this condition.</p> <p><u>AND</u></p> <p>A.5 -----NOTES-----                      1. Perform Required Action A.5 only after Required Action A.4 is completed.                       2. Required Action A.6 shall be completed whenever Required Action A.5 is performed.                      -----</p> <p>Normalize excore detectors to restore QPTR to within limit.</p> <p><u>AND</u></p> <p>A.6 -----NOTE-----                      Perform Required Action A.6 only after Required Action A.5 is completed.                      -----</p> <p>Perform SR 3.2.1.1, SR 3.2.1.2, and SR 3.2.2.1.</p>	<p>Prior to increasing THERMAL POWER above the limit of Required Action A.1</p> <p>Prior to increasing THERMAL POWER above the limit of Required Action A.1</p> <p>Within 24 hours after achieving equilibrium conditions at RTP not to exceed 48 hours after increasing THERMAL POWER above the limit of Required Action A.1</p>	<p><b>STANDARD (CS):</b> Identify that safety analyses must be evaluated before raising power above the limit.(90.4% power limit)                      SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p><b>STANDARD (CS):</b> A.5 &amp; A.6 required prior to raising power above the limit.(90.4% power limit)                      SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p><b>TERMINATION CUE:</b> JPM is complete when examinee identifies all applicable Tech Spec Required Actions</p>
Cook Nuclear Plant Unit 2	3.2.4-2	Amendment No. 289	

## Task Briefing

You are the Unit SRO.

The following conditions exist:

- Unit 2 is currently at 72% power.
- The Plant Process Computer (PPC) is INOPERABLE

The SM directs you to Review the manual 2-OHP-4030-214-032, Quadrant Power Tilt Calculation.

The NI amp meters are set to display maximum resolution.

### NI CALIBRATION DATA DET A 120% I in $\mu$ Amps

N41 =	<u>135.4</u>
N42 =	<u>136.6</u>
N43 =	<u>134.4</u>
N44 =	<u>136.7</u>

### DET B 120% I in $\mu$ Amps

N41 =	<u>135.6</u>
N42 =	<u>133.6</u>
N43 =	<u>134.7</u>
N44 =	<u>136.2</u>

**Verified:** Print John Smithe


Sign *John Smithe*

Date 5/11/2016


### NOTE

Simulator Indications are NOT applicable to this JPM – Use Supplied Pictures for readings.


# N41 Upper Detector A



# N41 Lower Detector B




N42 Upper Detector A







N42 Lower Detector B




N43 Upper Detector A




N43 Lower Detector B



N44 Upper Detector A



N44 Lower Detector B





# COOK NUCLEAR PLANT TRAINING CENTER

Bridgman, Michigan

OPERATIONS JPM

**TRAINING PROGRAM TITLE**

Initial License Training

**TIME:**

15 Minutes

**NUMBER AND TITLE:**

2020NRC-A3-SRO  
Approve a Containment Purge release

**REVISION:**

0

Examinee's Name: \_\_\_\_\_

Evaluator's Name: \_\_\_\_\_

Date Performed: \_\_\_\_\_

Result (Circle One):            SAT    /    UNSAT

Number of Attempts: \_\_\_\_\_

Time to Complete: \_\_\_\_\_

Comments: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

# OPERATIONS JPM

## REFERENCES/NRC KA/TASKS

Procedures:

1-OHP-4021-028-005

Operation of the Containment Purge System

### NRC KA

KA 2.3.6

Ability to approve release permits. (CFR: 41.12 / 45.10)

RO/SRO Importance

2.0/3.8

## TRAINING AIDS/TOOLS/EQUIPMENT

None

## HANDOUTS

1-OHP-4021-028-005 data Sheet 1, Containment Purge Release Permit

## ATTACHMENTS

None

## EVALUATION SETTINGS

Classroom

EVALUATION METHOD:

PERFORM:



SIMULATE:



# OPERATIONS JPM

## SIMULATOR/LAB SETUP

None

## EVALUATOR INSTRUCTIONS

Note: This JPM is based on 1-OHP-4030-028-005, Rev. 38. Any subsequent revisions to the procedures will require a review of this JPM to ensure that the content of the JPM is still valid. This JPM may be used without revision if the procedure changes do not affect the JPM.

Give copy of Task Briefing and procedure to examinee.

## TASK BRIEFING

The Unit was shut down yesterday due to an RCS leak. RCS cooldown is in progress with RCS temperature currently at 425 F.

The SM has requested you to review and approve the Containment Purge Release Permit to allow containment entry for leak location identification.

## GENERAL STANDARDS/PRECAUTIONS

The Containment Purge Release Permit has been reviewed and identifies Purge cannot be authorized due to incorrect Purge method and <24-hour time requirement has expired.

2020NRC-A3-SRO Approve a Containment Purge Release	Revision: 0
2020NRC-A3-SRO (R3).doc	Page 3 of 8



# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS ("CS" Indicates Critical Standard)												
<table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 10px;"> <tr> <td style="width: 25%; text-align: center;">Continuous</td> <td style="width: 25%; text-align: center;">1-OHP-4021-028-005</td> <td style="width: 25%; text-align: center;">Rev. 38</td> <td style="width: 25%; text-align: center;">Page 50 of 57</td> </tr> <tr> <td colspan="4" style="text-align: center;"><b>Operation Of The Containment Purge System</b></td> </tr> <tr> <td style="text-align: center;">Data Sheet 1</td> <td style="text-align: center;">Containment Purge Release Permit</td> <td colspan="2" style="text-align: center;">Pages: 50 - 53</td> </tr> </table> <p style="margin-left: 40px;">RELEASE NO. <u>6-20-14</u></p> <div style="border: 1px solid black; padding: 5px; margin-bottom: 10px;"> <p style="text-align: center;"><b>SECTION 1.0 - OPERATIONS</b></p> <p>It has been deemed necessary to PURGE the Unit 1 Containment. Samples of Upper Containment, Lower Containment, and the Instrument Room are requested for PURGE release.</p> <p style="text-align: center;"><i>T Kassar</i> _____ Supervisor/Manager</p> </div> <div style="border: 1px solid black; padding: 5px; margin-bottom: 10px;"> <p><b>NOTE:</b></p> <ul style="list-style-type: none"> <li>Good coordination between RP and Chemistry is required to ensure the limitations on radionuclide LLDs are met.</li> <li>Flowrates in parenthesis are not design values but reference values, determined by testing, for off site dose calculations. Actual flowrates may be lower and operators are not required to maintain these reference values. The 1-VRS-1505 (Primary)/1-VRS-1525 (backup) setpoint will be conservative if calculated at a higher than actual flowrate.</li> <li>Purge system is in Full Flow operation when the desired flow path includes, both Purge Exhaust flow paths and both Purge Exhaust fans.</li> <li>Purge system is in Half Flow operation when any single flow path is selected to include 1 Purge Exhaust flow path and 1 Purge Exhaust fan.</li> </ul> </div> <div style="border: 1px solid black; padding: 5px;"> <p style="text-align: center;"><b>SECTION 2.0 - OPERATIONS</b></p> <p><b>UNIT 1 CONTAINMENT PURGE:</b></p> <ul style="list-style-type: none"> <li><input checked="" type="checkbox"/> Full PURGE rate (12,000 cfm) in MODE 5, 6, or DEFUELED only.</li> <li><input type="checkbox"/> Upper Containment Supply/Lower Containment Exhaust. (10,000 cfm)</li> <li><input type="checkbox"/> Upper Containment Supply/Lower Containment Exhaust with airlocks closed. (3,500 cfm)</li> <li><input type="checkbox"/> Upper Containment only. (6,000 cfm)</li> <li><input type="checkbox"/> Lower Containment only. (6,000 cfm)</li> <li><input type="checkbox"/> Instrument Room only. (1,000 cfm)</li> </ul> <p style="text-align: center;"><i>T Kassar</i> _____ Supervisor/Manager</p> </div> <p style="text-align: center; margin-top: 10px;"><b>FORWARD TO RADIATION PROTECTION</b></p>	Continuous	1-OHP-4021-028-005	Rev. 38	Page 50 of 57	<b>Operation Of The Containment Purge System</b>				Data Sheet 1	Containment Purge Release Permit	Pages: 50 - 53		<p>STANDARD: Operator verifies release number entered. SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p>STANDARD: Operator verifies Operations signed for initiating release permit. SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p>STANDARD (CS): Operator identifies incorrect release method has been selected. Full PURGE rate is not allowed as plant is in Mode 3 from conditions given in brief SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p>
Continuous	1-OHP-4021-028-005	Rev. 38	Page 50 of 57										
<b>Operation Of The Containment Purge System</b>													
Data Sheet 1	Containment Purge Release Permit	Pages: 50 - 53											

# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS ("CS" Indicates Critical Standard)																																						
<table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 10px;"> <tr> <td style="width: 25%; text-align: center;">Continuous</td> <td style="width: 25%; text-align: center;">1-OHP-4021-028-005</td> <td style="width: 25%; text-align: center;">Rev. 38</td> <td style="width: 25%; text-align: center;">Page 51 of 57</td> </tr> <tr> <td colspan="4" style="text-align: center;"><b>Operation Of The Containment Purge System</b></td> </tr> <tr> <td style="text-align: center;">Data Sheet 1</td> <td style="text-align: center;">Containment Purge Release Permit</td> <td colspan="2" style="text-align: center;">Pages: 50 - 53</td> </tr> </table> <div style="border: 1px solid black; padding: 5px;"> <p style="text-align: center;"><b>SECTION 3.0 - APPROVAL</b></p> <p>Verify release compliance with PMP-6010-OSD-001 (Off-Site Dose Calculation Manual) Section 3.2.4, as per 12-THP-6020-CHM-308, Effluent Batch Releases.</p> <p>This release is approved provided the following conditions exist:</p> <ul style="list-style-type: none"> <li>• At least one Unit 1 Auxiliary Building Exhaust Fan is operating during the entire release.</li> <li>• Less than 24 hours have elapsed from the time approval of PURGE is granted, to commencement of PURGE.</li> </ul> <p>1) The PURGE is in compliance with the ODCM and is approved. 2) Supporting release permit calculation paperwork is attached.</p> <table style="width: 100%; margin-top: 10px;"> <tr> <td style="width: 60%; text-align: center;"><i>J. Sadiem</i> _____ Chemistry</td> <td style="width: 40%; text-align: center;">8/4/20 0500 _____ Date/Time</td> </tr> <tr> <td style="text-align: center;"><i>C. Gannon</i> _____ RP</td> <td style="text-align: center;">8/4/20 0510 _____ Date/Time</td> </tr> <tr> <td style="text-align: center;"><i>J. Fall</i> _____ Environmental</td> <td style="text-align: center;">8/4/20 0525 _____ Date/Time</td> </tr> </table> <p style="margin-top: 10px;">This PURGE is NOT APPROVED for the following reason:</p> <table style="width: 100%; margin-top: 10px;"> <tr> <td style="width: 60%;">_____</td> <td style="width: 40%;">_____</td> </tr> <tr> <td style="text-align: center;">Chemistry</td> <td style="text-align: center;">Date/Time</td> </tr> <tr> <td>_____</td> <td>_____</td> </tr> <tr> <td style="text-align: center;">RP</td> <td style="text-align: center;">Date/Time</td> </tr> <tr> <td>_____</td> <td>_____</td> </tr> <tr> <td style="text-align: center;">Environmental</td> <td style="text-align: center;">Date/Time</td> </tr> </table> <p style="margin-top: 10px;">SM/WCC-SRO Authorization to begin Containment PURGE (release dose rates values are within ODCM limits; must commence within 24 hours of obtaining RP approval)</p> <table style="width: 100%; margin-top: 10px;"> <tr> <td style="width: 60%;">_____</td> <td style="width: 40%;">_____</td> </tr> <tr> <td style="text-align: center;">SM/WCC-SRO</td> <td style="text-align: center;">Date/Time</td> </tr> </table> <p style="margin-top: 10px;">IF NOT APPROVED above, THEN approval of Plant Manager is REQUIRED for release.</p> <table style="width: 100%; margin-top: 10px;"> <tr> <td style="width: 60%;">_____</td> <td style="width: 40%;">_____</td> </tr> <tr> <td style="text-align: center;">Plant Manager</td> <td style="text-align: center;">Date/Time</td> </tr> </table> </div>	Continuous	1-OHP-4021-028-005	Rev. 38	Page 51 of 57	<b>Operation Of The Containment Purge System</b>				Data Sheet 1	Containment Purge Release Permit	Pages: 50 - 53		<i>J. Sadiem</i> _____ Chemistry	8/4/20 0500 _____ Date/Time	<i>C. Gannon</i> _____ RP	8/4/20 0510 _____ Date/Time	<i>J. Fall</i> _____ Environmental	8/4/20 0525 _____ Date/Time	_____	_____	Chemistry	Date/Time	_____	_____	RP	Date/Time	_____	_____	Environmental	Date/Time	_____	_____	SM/WCC-SRO	Date/Time	_____	_____	Plant Manager	Date/Time	<p style="margin-top: 10px;">STANDARD (CS): Operator identifies &gt; 24 hours has elapsed since Chem, RP, and ENV approved the Purge release. SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p style="margin-top: 10px;">STANDARD (CS): Operator identifies Purge cannot be authorized due to incorrect Purge method and &lt;24 hour time requirement has expired. SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p style="margin-top: 10px;">TERMINATION CUE: JPM is complete when examinee states Purge is not authorized.</p>
Continuous	1-OHP-4021-028-005	Rev. 38	Page 51 of 57																																				
<b>Operation Of The Containment Purge System</b>																																							
Data Sheet 1	Containment Purge Release Permit	Pages: 50 - 53																																					
<i>J. Sadiem</i> _____ Chemistry	8/4/20 0500 _____ Date/Time																																						
<i>C. Gannon</i> _____ RP	8/4/20 0510 _____ Date/Time																																						
<i>J. Fall</i> _____ Environmental	8/4/20 0525 _____ Date/Time																																						
_____	_____																																						
Chemistry	Date/Time																																						
_____	_____																																						
RP	Date/Time																																						
_____	_____																																						
Environmental	Date/Time																																						
_____	_____																																						
SM/WCC-SRO	Date/Time																																						
_____	_____																																						
Plant Manager	Date/Time																																						

OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS ("CS" Indicates Critical Standard)														
<table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 10px;"> <tr> <td style="width: 25%; text-align: center;">Continuous</td> <td style="width: 25%; text-align: center;">1-OHP-4021-028-005</td> <td style="width: 25%; text-align: center;">Rev. 38</td> <td style="width: 25%; text-align: center;">Page 52 of 57</td> </tr> <tr> <td colspan="4" style="text-align: center;"><b>Operation Of The Containment Purge System</b></td> </tr> <tr> <td style="text-align: center;">Data Sheet 1</td> <td style="text-align: center;">Containment Purge Release Permit</td> <td colspan="2" style="text-align: center;">Pages: 50 - 53</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="text-align: center;"><b>SECTION 4.0 - RADIATION PROTECTION</b></td> </tr> <tr> <td> <p><b>NOTE:</b> If the release setpoints for 1-VRS-1505/1-VRS-1525 are less than the original setpoints, the setpoints for 1-VRS-1505, 1-VRS-1525 and 1-VFR-1510 do not have to be changed.</p> <p>1-VRS-1505 Setpoints:</p> <p>Original setpoints: Alert: _____ μCi/CC                      High: _____ μCi/CC                      Release setpoints: Alert: _____ μCi/CC                      High: _____ μCi/CC</p> <p>1-VRS-1525 Setpoints:</p> <p>Original setpoints: Alert: _____ μCi/CC                      High: _____ μCi/CC                      Release setpoints: Alert: _____ μCi/CC                      High: _____ μCi/CC</p> <p>1-VFR-1510 Setpoints:</p> <p>Original setpoints:    Low Flow: _____ cfm                      High Flow: _____ cfm</p> <p>1-VFR-1510 setpoint is based on assumed release flowrate calculated as follows:</p> <p>_____ cfm + _____ cfm = _____ cfm                      Source Flow Rate [Purge fan(s)                      Unit Vent Flow Rate                      Release flowrate                      flowrate from section 2.0]                      (Initial 1-VFR-1510 flowrate)</p> <p>High Limit Flow Rate (Release Setpoint) = (Release flowrate) X 1.1</p> <p>High Limit Flow Rate (Release Setpoint) = _____ cfm</p> <p>_____                      _____                      _____                      Environmental                      Date                      Time</p> <p>_____                      _____                      _____                      Radiation Protection                      Date                      Time</p> <p>1-VRS-1505 alarm setpoint verified returned to original value <b>OR</b> ENV determined value, as applicable:                      1-VRS-1525 alarm setpoint verified returned to original value <b>OR</b> ENV determined value, as applicable:                      1-VFR-1510 alarm setpoint verified returned to original value <b>OR</b> ENV determined value, as applicable:</p> <p>_____                      _____                      _____                      Environmental                      Date                      Time</p> <p>_____                      _____                      _____                      Radiation Protection                      Date                      Time</p> </td> </tr> </table>	Continuous	1-OHP-4021-028-005	Rev. 38	Page 52 of 57	<b>Operation Of The Containment Purge System</b>				Data Sheet 1	Containment Purge Release Permit	Pages: 50 - 53		<b>SECTION 4.0 - RADIATION PROTECTION</b>	<p><b>NOTE:</b> If the release setpoints for 1-VRS-1505/1-VRS-1525 are less than the original setpoints, the setpoints for 1-VRS-1505, 1-VRS-1525 and 1-VFR-1510 do not have to be changed.</p> <p>1-VRS-1505 Setpoints:</p> <p>Original setpoints: Alert: _____ μCi/CC                      High: _____ μCi/CC                      Release setpoints: Alert: _____ μCi/CC                      High: _____ μCi/CC</p> <p>1-VRS-1525 Setpoints:</p> <p>Original setpoints: Alert: _____ μCi/CC                      High: _____ μCi/CC                      Release setpoints: Alert: _____ μCi/CC                      High: _____ μCi/CC</p> <p>1-VFR-1510 Setpoints:</p> <p>Original setpoints:    Low Flow: _____ cfm                      High Flow: _____ cfm</p> <p>1-VFR-1510 setpoint is based on assumed release flowrate calculated as follows:</p> <p>_____ cfm + _____ cfm = _____ cfm                      Source Flow Rate [Purge fan(s)                      Unit Vent Flow Rate                      Release flowrate                      flowrate from section 2.0]                      (Initial 1-VFR-1510 flowrate)</p> <p>High Limit Flow Rate (Release Setpoint) = (Release flowrate) X 1.1</p> <p>High Limit Flow Rate (Release Setpoint) = _____ cfm</p> <p>_____                      _____                      _____                      Environmental                      Date                      Time</p> <p>_____                      _____                      _____                      Radiation Protection                      Date                      Time</p> <p>1-VRS-1505 alarm setpoint verified returned to original value <b>OR</b> ENV determined value, as applicable:                      1-VRS-1525 alarm setpoint verified returned to original value <b>OR</b> ENV determined value, as applicable:                      1-VFR-1510 alarm setpoint verified returned to original value <b>OR</b> ENV determined value, as applicable:</p> <p>_____                      _____                      _____                      Environmental                      Date                      Time</p> <p>_____                      _____                      _____                      Radiation Protection                      Date                      Time</p>	<p><b>NO ACTIONS CONTAINED ON THIS PAGE</b></p>
Continuous	1-OHP-4021-028-005	Rev. 38	Page 52 of 57												
<b>Operation Of The Containment Purge System</b>															
Data Sheet 1	Containment Purge Release Permit	Pages: 50 - 53													
<b>SECTION 4.0 - RADIATION PROTECTION</b>															
<p><b>NOTE:</b> If the release setpoints for 1-VRS-1505/1-VRS-1525 are less than the original setpoints, the setpoints for 1-VRS-1505, 1-VRS-1525 and 1-VFR-1510 do not have to be changed.</p> <p>1-VRS-1505 Setpoints:</p> <p>Original setpoints: Alert: _____ μCi/CC                      High: _____ μCi/CC                      Release setpoints: Alert: _____ μCi/CC                      High: _____ μCi/CC</p> <p>1-VRS-1525 Setpoints:</p> <p>Original setpoints: Alert: _____ μCi/CC                      High: _____ μCi/CC                      Release setpoints: Alert: _____ μCi/CC                      High: _____ μCi/CC</p> <p>1-VFR-1510 Setpoints:</p> <p>Original setpoints:    Low Flow: _____ cfm                      High Flow: _____ cfm</p> <p>1-VFR-1510 setpoint is based on assumed release flowrate calculated as follows:</p> <p>_____ cfm + _____ cfm = _____ cfm                      Source Flow Rate [Purge fan(s)                      Unit Vent Flow Rate                      Release flowrate                      flowrate from section 2.0]                      (Initial 1-VFR-1510 flowrate)</p> <p>High Limit Flow Rate (Release Setpoint) = (Release flowrate) X 1.1</p> <p>High Limit Flow Rate (Release Setpoint) = _____ cfm</p> <p>_____                      _____                      _____                      Environmental                      Date                      Time</p> <p>_____                      _____                      _____                      Radiation Protection                      Date                      Time</p> <p>1-VRS-1505 alarm setpoint verified returned to original value <b>OR</b> ENV determined value, as applicable:                      1-VRS-1525 alarm setpoint verified returned to original value <b>OR</b> ENV determined value, as applicable:                      1-VFR-1510 alarm setpoint verified returned to original value <b>OR</b> ENV determined value, as applicable:</p> <p>_____                      _____                      _____                      Environmental                      Date                      Time</p> <p>_____                      _____                      _____                      Radiation Protection                      Date                      Time</p>															

# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS ("CS" Indicates Critical Standard)																
<table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 10px;"> <tr> <td style="width: 15%; text-align: center;">Continuous</td> <td style="width: 30%; text-align: center;">1-OHP-4021-028-005</td> <td style="width: 15%; text-align: center;">Rev. 37</td> <td style="width: 40%; text-align: center;">Page 53 of 57</td> </tr> <tr> <td colspan="4" style="text-align: center;">Operation Of The Containment Purge System</td> </tr> <tr> <td style="text-align: center;">Data Sheet 1</td> <td style="text-align: center;">Containment Purge Release Permit</td> <td colspan="2" style="text-align: center;">Pages: 50 - 53</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th style="text-align: center;">SECTION 5.0 - OPERATIONS</th> </tr> <tr> <td style="padding: 5px;">           Unit 1 Containment was PURGED to atmosphere at:            _____ cfm            1-VFR-315 or 1-VFR-1510 (Circle Instrument Used)         </td> </tr> <tr> <td style="padding: 5px;">           Data Sheet No. 2 information recorded if applicable:           <ul style="list-style-type: none"> <li>• From Time: _____ Date: __/__/__</li> <li>• To Time: _____ Date: __/__/__</li> <li>• Purge Time hrs and Minutes _____</li> <li>• Cumulative Total Time _____</li> </ul> </td> </tr> <tr> <td style="padding: 5px;">           Operations: _____  <div style="text-align: center;">Signature</div> </td> </tr> </table>	Continuous	1-OHP-4021-028-005	Rev. 37	Page 53 of 57	Operation Of The Containment Purge System				Data Sheet 1	Containment Purge Release Permit	Pages: 50 - 53		SECTION 5.0 - OPERATIONS	Unit 1 Containment was PURGED to atmosphere at: _____ cfm 1-VFR-315 or 1-VFR-1510 (Circle Instrument Used)	Data Sheet No. 2 information recorded if applicable: <ul style="list-style-type: none"> <li>• From Time: _____ Date: __/__/__</li> <li>• To Time: _____ Date: __/__/__</li> <li>• Purge Time hrs and Minutes _____</li> <li>• Cumulative Total Time _____</li> </ul>	Operations: _____ <div style="text-align: center;">Signature</div>	<p style="font-size: 1.2em; font-weight: bold;">NO ACTIONS CONTAINED ON THIS PAGE</p>
Continuous	1-OHP-4021-028-005	Rev. 37	Page 53 of 57														
Operation Of The Containment Purge System																	
Data Sheet 1	Containment Purge Release Permit	Pages: 50 - 53															
SECTION 5.0 - OPERATIONS																	
Unit 1 Containment was PURGED to atmosphere at: _____ cfm 1-VFR-315 or 1-VFR-1510 (Circle Instrument Used)																	
Data Sheet No. 2 information recorded if applicable: <ul style="list-style-type: none"> <li>• From Time: _____ Date: __/__/__</li> <li>• To Time: _____ Date: __/__/__</li> <li>• Purge Time hrs and Minutes _____</li> <li>• Cumulative Total Time _____</li> </ul>																	
Operations: _____ <div style="text-align: center;">Signature</div>																	

## **Task Briefing**

The Unit was shut down yesterday due to an RCS leak. RCS cooldown is in progress with RCS temperature currently at 425 F.

The SM has requested you to review and approve the Containment Purge Release Permit to begin purging containment to allow containment entry for leak location identification.



# COOK NUCLEAR PLANT TRAINING CENTER

Bridgman, Michigan

OPERATIONS JPM

**TRAINING PROGRAM TITLE**

Initial License Training

**TIME:**

20 Minutes

**NUMBER AND TITLE:**

2020NRC-A4-SRO  
Determine if PAR required and determine PAR

**REVISION:**

0

TIME CRITICAL JPM

Examinee's Name: \_\_\_\_\_

Evaluator's Name: \_\_\_\_\_

Date Performed: \_\_\_\_\_

Result (Circle One):            SAT    /    UNSAT

Number of Attempts: \_\_\_\_\_

Time to Complete: \_\_\_\_\_

Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

# OPERATIONS JPM

## REFERENCES/NRC KA/TASKS

Procedures:

PMP-2080-EPP-101	EMERGENCY CLASSIFICATION
PMP-2080-EPP-100	EMERGENCY RESPONSE

## NRC KA

KA 2.4.44	Knowledge of emergency plan protective action recommendations.
SRO Importance	4.4

Task Number: EPP0120703 Develop a Protective Action Recommendation

## TRAINING AIDS/TOOLS/EQUIPMENT

None

## HANDOUTS

Task Briefing sheet  
Task briefing  
PMP-2080-EPP-100, Emergency Response, Attachment 1 Protective Action Recommendations  
PMP-2080-EPP-101, Emergency Plan Classification, Attachment 1  
EP Binder with full PMP-2080-EPP-100, Emergency Response procedure

## ATTACHMENTS

None

## EVALUATION SETTINGS

Classroom

<b>EVALUATION METHOD:</b>	<b>PERFORM:</b> <input checked="" type="checkbox"/>	<b>SIMULATE:</b> <input type="checkbox"/>
---------------------------	---	---

# OPERATIONS JPM

## SIMULATOR/LAB SETUP

None

## EVALUATOR INSTRUCTIONS

1. Brief the operator (May be performed by giving out Task Briefing Sheet)
2. Announce start of the JPM
3. Perform evolution
4. At completion of evolution, announce the JPM is complete.
5. Document evaluation performance.

## TASK BRIEFING

You are the Shift Manager and had declared a Site area Emergency 20 minutes ago based on Security Hazard HS1 - HS1 HOSTILE ACTION within the plant PROTECTED AREA based on a report from Security.

You have just upgraded the Emergency level to General Emergency as the hostile forces have detonated explosives on all four U1 4KV Emergency buses. The upgrade was due to Loss of Emergency AC Power - SG1 Prolonged loss of all offsite and all onsite AC power to emergency buses.

You are to determine if a PAR is required and if so what the PAR determination is.

This is a Time Critical JPM.

## GENERAL STANDARDS/PRECAUTIONS

Determine PAR is required and recommends PAR IAW EPP-100 attachment 1.



# OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS ("CS" Indicates Critical Standard)																																																						
<table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 10px;"> <tr> <td style="width: 25%; text-align: center;">Reference</td> <td style="width: 25%; text-align: center;">PMP-2080-EPP-100</td> <td style="width: 25%; text-align: center;">Rev. 40</td> <td style="width: 25%; text-align: center;">Page 14 of 60</td> </tr> <tr> <td colspan="4" style="text-align: center;">Emergency Response</td> </tr> <tr> <td style="text-align: center;">Attachment 1</td> <td style="text-align: center;">Protective Action Recommendations</td> <td colspan="2" style="text-align: center;">Pages: 14 - 17</td> </tr> </table> <div style="border: 1px solid black; padding: 5px; margin-bottom: 10px;"> <p><b>NOTE:</b> The Shift Manager (SM) should utilize a recent dose assessment completed within the last 15 minutes when developing or determining any PAR.</p> </div> <p><b>1</b> IF a General Emergency is currently classified OR current conditions exist that would require the classification of a General Emergency, THEN develop a PAR using this attachment.</p> <div style="border: 1px solid black; padding: 5px; margin-bottom: 10px;"> <p><b>NOTE:</b> Dose assessment results may be necessary to determine if conditions for RG1.1, RG1.2 OR RG1.3 General Emergency EAL have been met for initial PAR.</p> </div> <p><b>1.1</b> IF this is the initial PAR (concurrent with the GE classification), THEN utilize the Initial PAR flowchart.</p> <p><b>1.2</b> IF this is any PAR determination after the initial PAR determination, THEN utilize the Follow-Up PAR flowchart.</p> <ul style="list-style-type: none"> <li>• New PARs may be necessary based on changes in wind direction.</li> <li>• New PARs shall be developed if dose assessment indicates new Protective Action Areas meet EPA Protective Action Guidelines of 1 Rem TEDE or 5 Rem Thyroid CDE.</li> </ul> <p><b>2</b> Determine a PAR</p> <table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 10px;"> <tr> <td colspan="6" style="text-align: left;"><input type="checkbox"/> None</td> </tr> <tr> <td colspan="6" style="text-align: left;">Recommend the following protective actions, implement the State of Michigan Potassium Iodide (KI) plan, and all other areas monitor and prepare.</td> </tr> <tr> <td style="width: 20%;">Evacuation of Area(s)</td> <td style="width: 10%;"><input type="checkbox"/>1</td> <td style="width: 10%;"><input type="checkbox"/>2</td> <td style="width: 10%;"><input type="checkbox"/>3</td> <td style="width: 10%;"><input type="checkbox"/>4</td> <td style="width: 10%;"><input type="checkbox"/>5</td> </tr> <tr> <td>In-Place Shelter of Area(s)</td> <td><input type="checkbox"/>1</td> <td><input type="checkbox"/>2</td> <td><input type="checkbox"/>3</td> <td><input type="checkbox"/>4</td> <td><input type="checkbox"/>5</td> </tr> <tr> <td>Clear Lake Area(s)</td> <td colspan="3" style="text-align: center;"><input type="checkbox"/>6</td> <td colspan="2" style="text-align: center;"><input type="checkbox"/>7</td> </tr> <tr> <td>PARs based on Dose Calculations</td> <td colspan="2"><input type="checkbox"/>Yes <input type="checkbox"/>No</td> <td colspan="3"></td> </tr> <tr> <td>PARs beyond 10 Miles</td> <td colspan="2"><input type="checkbox"/>Yes <input type="checkbox"/>No</td> <td colspan="3"></td> </tr> </table> <p>Time: _____ INIT: _____ (Shift Manager)</p>	Reference	PMP-2080-EPP-100	Rev. 40	Page 14 of 60	Emergency Response				Attachment 1	Protective Action Recommendations	Pages: 14 - 17		<input type="checkbox"/> None						Recommend the following protective actions, implement the State of Michigan Potassium Iodide (KI) plan, and all other areas monitor and prepare.						Evacuation of Area(s)	<input type="checkbox"/> 1	<input type="checkbox"/> 2	<input type="checkbox"/> 3	<input type="checkbox"/> 4	<input type="checkbox"/> 5	In-Place Shelter of Area(s)	<input type="checkbox"/> 1	<input type="checkbox"/> 2	<input type="checkbox"/> 3	<input type="checkbox"/> 4	<input type="checkbox"/> 5	Clear Lake Area(s)	<input type="checkbox"/> 6			<input type="checkbox"/> 7		PARs based on Dose Calculations	<input type="checkbox"/> Yes <input type="checkbox"/> No					PARs beyond 10 Miles	<input type="checkbox"/> Yes <input type="checkbox"/> No					<p><b>EVALUATOR NOTE:</b> A General Emergency requires a Protective Action Recommendation (PAR) to be made to the state.</p> <p>Start Time: _____.</p> <p><b>STANDARD (CS):</b> Candidate determines PAR is required. SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p> <p><b>STANDARD:</b> Candidate proceeds to Initial PAR flowchart. SAT: <input type="checkbox"/>      UNSAT: <input type="checkbox"/></p>
Reference	PMP-2080-EPP-100	Rev. 40	Page 14 of 60																																																				
Emergency Response																																																							
Attachment 1	Protective Action Recommendations	Pages: 14 - 17																																																					
<input type="checkbox"/> None																																																							
Recommend the following protective actions, implement the State of Michigan Potassium Iodide (KI) plan, and all other areas monitor and prepare.																																																							
Evacuation of Area(s)	<input type="checkbox"/> 1	<input type="checkbox"/> 2	<input type="checkbox"/> 3	<input type="checkbox"/> 4	<input type="checkbox"/> 5																																																		
In-Place Shelter of Area(s)	<input type="checkbox"/> 1	<input type="checkbox"/> 2	<input type="checkbox"/> 3	<input type="checkbox"/> 4	<input type="checkbox"/> 5																																																		
Clear Lake Area(s)	<input type="checkbox"/> 6			<input type="checkbox"/> 7																																																			
PARs based on Dose Calculations	<input type="checkbox"/> Yes <input type="checkbox"/> No																																																						
PARs beyond 10 Miles	<input type="checkbox"/> Yes <input type="checkbox"/> No																																																						

OPERATIONS JPM

EXPECTED ACTIONS	CUES/STANDARDS (“CS” Indicates Critical Standard)																																								
<div style="border: 1px solid black; padding: 5px; margin-bottom: 10px;"> <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:25%; text-align: center;">Reference</td> <td style="width:25%; text-align: center;">PMP-2080-EPP-100</td> <td style="width:25%; text-align: center;">Rev. 40</td> <td style="width:25%; text-align: center;">Page 15 of 60</td> </tr> <tr> <td colspan="4" style="text-align: center;">Emergency Response</td> </tr> <tr> <td style="text-align: center;">Attachment 1</td> <td colspan="2" style="text-align: center;">Protective Action Recommendations</td> <td style="text-align: center;">Pages: 14 - 17</td> </tr> </table> </div> <p><b>3 Direct notifications per Attachment 8, Notification of Off-Site Agencies.</b></p> <p style="text-align: center;"><b>Initial - Protective Action Recommendations</b></p> <div style="border: 1px solid black; padding: 5px; margin-top: 10px;"> <p style="text-align: center;"><b>INITIAL PAR TABLE</b></p> <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width:15%;">Wind Direction (from)</th> <th style="width:35%; background-color: #ffcccc;">RAPID</th> <th style="width:15%; background-color: #ffffcc;">HAB</th> <th style="width:35%; background-color: #ccffcc;">INITIAL</th> </tr> </thead> <tbody> <tr> <td>168.75 to 213.75</td> <td>Area 1, 2, 4, and clear lake areas 6 &amp; 7</td> <td></td> <td>Area 1, 2 and clear lake area 6</td> </tr> <tr> <td>213.75 to 236.25</td> <td>Area 1, 2, 3, 4 and clear lake areas 6 &amp; 7</td> <td>Area 1</td> <td>Area 1, 2, 3, and clear lake area 6</td> </tr> <tr> <td>236.25 to 303.75</td> <td>Area 1, 2, 3, 4, 5 and clear lake areas 6</td> <td>Area 1 and clear lake</td> <td>Area 1, 2, 3 and clear lake area 6</td> </tr> <tr> <td>303.75 to 348.75</td> <td>Area 1, 3, 5 and clear lake area 6</td> <td>Area 1 and clear lake</td> <td>Area 1, 3 and clear lake area 6</td> </tr> <tr> <td>348.75 to 56.25</td> <td>Area 1, 3, 5 and clear lake areas 6 &amp; 7</td> <td>Area 1 and clear lake</td> <td>Area 1, 3 and clear lake area 6</td> </tr> <tr> <td>56.25 to 168.75</td> <td>Area 1, and clear lake areas 6 &amp; 7</td> <td>Area 6</td> <td>Area 1 and clear lake area 6</td> </tr> </tbody> </table> <p><small>Notes: 1. Lake areas are "cleared" for either evacuation or sheltering. 2. Area 6 is the lake area at 0 to 5 mile radius; Area 7 is the lake area 5 to 10 mile radius. 3. IF Impediments exist as determined by the Offsite Response Organizations, the ORO may shelter in place.</small></p> </div>	Reference	PMP-2080-EPP-100	Rev. 40	Page 15 of 60	Emergency Response				Attachment 1	Protective Action Recommendations		Pages: 14 - 17	Wind Direction (from)	RAPID	HAB	INITIAL	168.75 to 213.75	Area 1, 2, 4, and clear lake areas 6 & 7		Area 1, 2 and clear lake area 6	213.75 to 236.25	Area 1, 2, 3, 4 and clear lake areas 6 & 7	Area 1	Area 1, 2, 3, and clear lake area 6	236.25 to 303.75	Area 1, 2, 3, 4, 5 and clear lake areas 6	Area 1 and clear lake	Area 1, 2, 3 and clear lake area 6	303.75 to 348.75	Area 1, 3, 5 and clear lake area 6	Area 1 and clear lake	Area 1, 3 and clear lake area 6	348.75 to 56.25	Area 1, 3, 5 and clear lake areas 6 & 7	Area 1 and clear lake	Area 1, 3 and clear lake area 6	56.25 to 168.75	Area 1, and clear lake areas 6 & 7	Area 6	Area 1 and clear lake area 6	<p>STANDARD (CS): Candidate determines this is NOT Rapidly Progressing and a HOSTILE ACTION is occurring. SAT: <input type="checkbox"/> UNSAT: <input type="checkbox"/></p> <p>STANDARD (CS): Candidate determines PAR using Initial PAR flowchart. Candidate determines Shelter in Place for Area 1 and clearing lake area 6 is required. SAT: <input type="checkbox"/> UNSAT: <input type="checkbox"/></p> <p>STANDARD (CS): Uses HAB column to determine areas affected and fills in information on step 2. SAT: <input type="checkbox"/> UNSAT: <input type="checkbox"/></p> <p><b>Termination Cue:</b> JPM is complete when examinee provides recommended PAR.</p> <p>Completion Time _____ (&lt;= 12 minutes)</p>
Reference	PMP-2080-EPP-100	Rev. 40	Page 15 of 60																																						
Emergency Response																																									
Attachment 1	Protective Action Recommendations		Pages: 14 - 17																																						
Wind Direction (from)	RAPID	HAB	INITIAL																																						
168.75 to 213.75	Area 1, 2, 4, and clear lake areas 6 & 7		Area 1, 2 and clear lake area 6																																						
213.75 to 236.25	Area 1, 2, 3, 4 and clear lake areas 6 & 7	Area 1	Area 1, 2, 3, and clear lake area 6																																						
236.25 to 303.75	Area 1, 2, 3, 4, 5 and clear lake areas 6	Area 1 and clear lake	Area 1, 2, 3 and clear lake area 6																																						
303.75 to 348.75	Area 1, 3, 5 and clear lake area 6	Area 1 and clear lake	Area 1, 3 and clear lake area 6																																						
348.75 to 56.25	Area 1, 3, 5 and clear lake areas 6 & 7	Area 1 and clear lake	Area 1, 3 and clear lake area 6																																						
56.25 to 168.75	Area 1, and clear lake areas 6 & 7	Area 6	Area 1 and clear lake area 6																																						

# OPERATIONS JPM

EXPECTED ACTIONS				CUES/STANDARDS (“CS” Indicates Critical Standard)
Reference	PMP-2080-EPP-100	Rev. 40	Page 17 of 60	
<b>Emergency Response</b>				
Attachment 1	Protective Action Recommendations		Pages: 14 - 17	

The map displays Berrien County, Michigan, overlaid with a grid and concentric circles. The circles are labeled with numbers 2, 3, 4, 5, 6, and 7, representing different zones or distances from a central point marked by a green dot. The word 'BERRIEN' is printed across the center of the map. The map also shows major roads and the coastline of Lake Michigan to the north.

## **Task Briefing**

You are the Shift Manager and had declared a Site area Emergency 20 minutes ago based on Security Hazzard HS1 - HS1 HOSTILE ACTION within the plant PROTECTED AREA based on a report from Security.

You have just upgraded the Emergency level to General Emergency as the hostile forces have detonated explosives on all four U1 4KV Emergency buses. The upgrade was due to Loss of Emergency AC Power - SG1 Prolonged loss of all offsite and all onsite AC power to emergency buses.

You are to determine if a PAR is required and if so what the PAR determination is.

This is a Time Critical JPM.