

PWR Reactor Internals Engineering Evaluations and Functionality Assessments - 2020

Updates to MRP-230 for SLR

Kyle Amberge, EPRI-Materials Reliability Program
Principal Technical Leader

Tom Malota, Arizona Power Services
Chair, EPRI-MRP Internals and Integrity TAC

Steven Smith, Westinghouse Electric Co.
Senior Engineer

Stephen Speicher, Westinghouse Electric Co.
Principal Engineer

EPRI and NRC Public Meeting/Webinar, January 12, 2021

OPEN SESSION



Introduction


- Today's meeting is the latest in a series of NRC-industry technical information exchange meetings related to MRP-227 guidance
- Industry endeavors to support continued operations of PWRs
- Subsequent License Renewal (SLR) is a critical initiative for fleet
- Use of EPRI MRP materials research and testing results forms the foundation of a solid materials aging management strategy
- Multiple technical exchange meetings with NRC have taken place since mid-2000s
- These exchange meetings are beneficial and important to review continuing research findings that result in guidance updates

Background

- MRP-230 Revision 0 originally published in 2008 (product ID 1016597)
- Revision 1 published in 2009 (product ID 1019091)
- Revision 2 published in 2012 (product ID 1021026)
- Revision 2 Supplement 1 published in 2016 (product ID 3002007955)
- Revision 2 Supplement 2 published in 2019 (product ID 3002013070)
- Revision 3 published in 2020 (product ID 3002018248)
- EPRI submitted to NRC for information in August 2020 under letter MRP 2020-016 (ML20244A027)
 - Supports subsequent license renewal and forthcoming MRP-227, Revision 2
- Technical report performs critical role in developing MRP-227
 - Evaluates materials aging functionality of component for CE and Westinghouse plants
 - Documents the results of finite element modeling evaluations for components
 - Key input document for MRP-227 guidance for subsequent license renewal

Background (cont.)

- MRP-230 contains everything in the “Analysis” box
 - Provides key input to downstream steps
 - Made updates based on new test data
- Higher risk category components
 - Become leading components (“Primary”)
- Approach is the same as for MRP-227 Revision 0 and 1



CLOSED SESSION BEGINS

Together...Shaping the Future of Electricity