



Tennessee Valley Authority, 1101 Market Street, Chattanooga, Tennessee 37402

CNL-20-106

January 5, 2021

10 CFR 50.54(q)
10 CFR 72.44(f)

ATTN: Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555-0001

Browns Ferry Nuclear Plant, Units 1, 2, and 3
Renewed Facility Operating License Nos. DPR-33, DPR-52, and DPR-68
NRC Docket Nos. 50-259, 50-260, 50-296, and 72-052

Sequoyah Nuclear Plant, Units 1 and 2
Renewed Facility Operating License Nos. DPR-77 and DPR-79
NRC Docket Nos. 50-327, 50-328, and 72-034

Watts Bar Nuclear Plant, Units 1 and 2
Facility Operating License Nos. NPF-90 and NPF-96
NRC Docket Nos. 50-390, 50-391, and 72-1048

Subject: **TENNESSEE VALLEY AUTHORITY - RADIOLOGICAL EMERGENCY PLAN REVISION**

In accordance with the requirements of Title 10 of the *Code of Federal Regulations* (10 CFR) 50.54(q) and 10 CFR 72.44(f), Tennessee Valley Authority (TVA) is submitting a description of changes to the TVA Radiological Emergency Plan (REP). The affected document is a Central Emergency Control Center (CECC) Emergency Plan Implementing Procedure (EPIP).

<u>Document</u>	<u>Revision</u>	<u>Title</u>	<u>Effective Date</u>
CECC EPIP-9	61	Emergency Environmental Radiological Monitoring Procedures	12/8/2020

Description of Changes and Summary of Analysis

CECC EPIP-9

TVA revised this EPIP as follows.


- Changed to indicate that environmental monitoring at BFN will be mandatory at the Alert level and optional at the Unusual Event level.
- Removed references to the Bicon Analyst, which is no longer in use.
- Expanded a footnote regarding formula conversion.
- Added information about the preferred method to detect tritium.
- Added instructions to take a detector and sample holder for counting air samples using the Thermo RadEye Gx to the monitoring team vehicle upon activation.

In addition, TVA made editorial changes with this EPIP revision to update a page number reference and to correct the abbreviation for the unit of activity.

The above changes were evaluated in accordance with 10 CFR 50.54(q)(3) and 10 CFR 72.44(f). TVA determined that the changes did not reduce the effectiveness of the TVA REP. The TVA REP, as revised, continues to meet the requirements in Appendix E to 10 CFR 50 and the planning standards of 10 CFR 50.47(b).

There are no new regulatory commitments associated with this submittal. If you have any questions regarding this information, please contact Kimberly D. Hulvey, Senior Manager, Fleet Licensing at (423) 751-3275.

Respectfully,



James T. Polickoski
Director, Nuclear Regulatory Affairs

cc:

NRC Regional Administrator - Region II
NRC Senior Resident Inspector - Browns Ferry Nuclear Plant
NRC Senior Resident Inspector - Sequoyah Nuclear Plant
NRC Senior Resident Inspector - Watts Bar Nuclear Plant
NRC Project Manager - Browns Ferry Nuclear Plant
NRC Project Manager - Sequoyah Nuclear Plant
NRC Project Manager - Watts Bar Nuclear Plant
NRC Director - Division of Spent Fuel Management, NMSS