

Attachment 2

Report and Analysis Summary

**SAN ONOFRE NUCLEAR GENERATING STATION
REPORT AND ANALYSIS SUMMARY
10 CFR 50.54(q)(5) / 10 CFR 72.44(f)**

Document Number: EPP-1, Revision 1 Title: Emergency Response Action Request #: 0820-76520	
Change Description	Analysis Summary
<p>The 10CFR50.54(q) evaluation for EPP-1 Revision 1 is covered under AR 0820-76520 assignment 3. This revision includes:</p> <ul style="list-style-type: none"> • Directions to develop an ERO relief shift roster. • Clarification of the timing of Follow-Up Notifications. • Clarification of steps that are required when radiological surveys are performed. • Instructions to set up an electronic dosimeter. • Revision to the frequency of formal briefings. • Editorial changes. 	<p>The changes do not contradict the licensing basis or the emergency plan content. The changes do not modify the licensing basis with regards to a reduction in effectiveness.</p> <p>Formal briefings are administrative in nature. Briefings are provided to ensure the Emergency Response Organization (ERO) is aware of the latest status of the emergency. Given the small size of the ERO, they are in contact continuously and aware of the current situation via normal communications and updates.</p> <p>Adding directions to develop an ERO relief shift roster ensures the response organization is staffed on a continuing basis.</p> <p>Clarifying the timing of Follow-Up Notifications ensures notifications are completed as required per the Emergency Plan, and when significant changes in event status occur.</p> <p>Clarifying steps that are required when radiological surveys are performed and adding instructions to set up an electronic dosimeter ensure emergency workers have resources for controlling radiological exposures, and personnel understand how to utilize dosimeters during emergency conditions.</p> <p>The Emergency Plan maintains a response organization with staff to respond and augment the initial response on a continuing basis. The Emergency Plan continues to have procedures for notification of State and local governmental agencies that can alert them of the declared emergency within 60 minutes after declaration of an emergency and providing follow-up notifications. The Emergency Plan maintains means for controlling emergency workers radiological exposures during an emergency.</p> <p>The Emergency Plan continues to meet the regulatory requirements of 10CFR50.47(b) and 10CFR50 Appendix E, as exempted. The capability and timeliness to perform the planning functions and elements related to the planning functions are maintained.</p> <p>The changes can be implemented without prior NRC approval.</p>
PREPARED BY: Lucia Sischo DATE: 12-15-2020	REVIEWED BY: Kelli Sholler DATE: 12-16-2020