

PROPOSED OUTLINE COMMENTS

Facility: Palo Verde

First Exam Date: 11/30/2020

Written Exam Outline (7/09/20)		
	Comment	Resolution
1	NRC Generated	
2		
3		
4		
5		

Administrative JPM Outline (7/09/20)		
	Comment	Resolution
1	None	
2		
3		
4		
5		

Control Room / In-Plant System JPM Outline (7/09/20)		
	Comment	Resolution
1	None	
2		
3		
4		
5		

Simulator Scenario Outline Comments (7/09/20)		
	Comment	Resolution
1	Sc. 1: CT 2: Where does 30 minutes come from? Could there be better bounding criteria?	Modify to specify that the 30 minutes is based on twice the 15 minute STA requirement for safety function status checks and to ensure adequate margin from exceeding containment pressure limits.
2	Sc. 1: No EOP Contingency	none

3	Sc. 2: Ensure event 7 not too similar to Sc 2 event 7 on the 2019 exam	Modify to have to manually open the normal supply breaker to satisfy the interlock for the EDG breaker to automatically close.
4	Sc. 3 CT 1: Where does 30 minutes come from? Could there be better bounding criteria?	Modify to specify that the 30 minutes is based on twice the 15 minute STA requirement for safety function status checks and to ensure adequate subcooling margin.
5	Sc. 3: No EOP Contingency	none
6	Sc. 4: Low power	none