MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question:

1

(1 point)

Regarding Containment isolation signals:

- 1) The S/G CF Containment Isolation valves (CF-35, 30, 28, & 26) will close if Containment pressure rises to a MINIMUM of _____ PSIG.
- 2) A Containment Phase A isolation will occur if NC system pressure lowers to less than a MAXIMUM of _____ PSIG.

Which ONE of the following completes the statements above?

A. 1. 3.0 2. 1845
B. 1. 3.0 2. 1945
C. 1. 1.0 2. 1945
D. 1. 1.0 2. 1845

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question:

(1 point)

Given the following on Unit 1:

2

- A large break LOCA has occurred
- The CRS has implemented FR-Z.1 (RESPONSE TO HIGH CONTAINMENT PRESSURE)

Subsequently:

- The crew attempts to align the 1A Train of ND to supply Containment Spray
- 1NS-43A (1A ND HX OUTLET TO NS CONT OUTSIDE ISOL) failed to open

Which ONE of the following describes the interlock that prevented 1NS-43A from opening?

- A. 1NI-185A (RB SUMP TO TRAIN A ND & NS) was not OPEN
- B. CPCS signal was not present
- C. 1NI-173A (1A ND TO A & B COLD LEGS CONT OUTSIDE ISOL) was not CLOSED
- D. 1ND-58A (TRAIN A ND TO NV & NI PUMPS) was not CLOSED

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question:

(1 point)

Given the following on Unit 2:

3

- Unit is at 100% RTP
- A malfunction of 2KC-132 (L/D HX OUTLET TEMP CONTROL) has occurred
- 2AD-7, H2 (LETDN HX OUTLET HI TEMP) is in alarm

Based on the conditions above:

- 1) This event will result in the addition of _____ reactivity.
- 2) If letdown temperature continues to rise to 138 °F, letdown flow will be automatically aligned to the _____.

- A. 1. positive 2. VCT
- B. 1. negative 2. VCT
- C. 1. positive 2. RHT
- D. 1. negative 2. RHT

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question:

(1 point)

Given the following on Unit 1:

4

- Unit 1 is at 75% RTP
- CRD BANK SELECT I AUTO
- Valve Positions on 1MC10:



If operation is continued in this alignment, automatic control rod <u>(2)</u> will occur.

- A. 1. ALT DILUTE 2. withdrawal
- B. 1. DILUTE 2. withdrawal
- C. 1. ALT DILUTE 2. insertion
- D. 1. DILUTE 2. insertion

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 5

(1 point)

Given the following on Unit 1:

- A LOCA has occurred
- Initial depressurization to S/G pressures of 190 PSIG has been completed
- All T-Hot temperatures are less than 388 °F

The crew is currently performing the following:

• S/G depressurization to atmospheric pressure per FR-C.1 (RESPONSE TO INADEQUATE CORE COOLING)

Per FR-C.1:

- 1) A RVLIS reading of less than a MAXIMUM of _____ indicates an inadequate core cooling condition.
- 2) The subsequent S/G depressurization to atmospheric pressure is performed in order to allow injection from the _____.

- A. 1. 39% 2. ND system
- B. 1. 60% 2. ND system
- C. 1. 39% 2. Cold Leg accumulators
- D. 1. 60% 2. Cold Leg accumulators

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question:

(1 point)

Given the following on Unit 1:

6

- Unit is at 100% RTP
- There is leak-by on ONE PZR PORV
- PRT Temperature on 1NCP-5350 is currently 90 °F and rising 2 °/minute

At the current rate, the PRT temperature will reach the PRT high temperature alarm on 1AD-6 within _____ minutes.

Which ONE of the following completes the statements above?

A. 12
B. 20
C. 25
D. 40

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question:

(1 point)

Given the following on Unit 2:

7

- A reactor trip has occurred
- The CRS has implemented E-0 (REACTOR TRIP OR SAFETY INJECTION)

Subsequently,

• ONE (1) PZR PORV fails partially open

Based on the conditions above,

- 1) the PRT ______ will operate to reduce PRT pressure.
- as Containment pressure rises, the LCO for TS 3.6.4 (CONTAINMENT PRESSURE) will be exceeded when Containment pressure exceeds a MINIMUM of _____ PSIG.

- A. 1. relief valve 2. 0.3
- B. 1. rupture disc 2. 0.3
- C. 1. relief valve 2. 0.2
- D. 1. rupture disc 2. 0.2

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question:

(1 point)

Given the following on Unit 2:

8

- Unit is at 100% RTP
- 2A1 KC Pump is in service
- 2A2 KC Pump is secured
- The 2B sequencer is in TEST

Subsequently:

• An inadvertent SI signal is received on Unit 2 B Train ONLY

Which ONE of the following describes the Unit 2 KC pumps that are in service? (Assume no operator action)

- A. 2A1 KC pump ONLY
- B. 2A1, 2B1, and 2B2 KC pumps ONLY
- C. 2A1 and 2A2 KC pumps ONLY
- D. 2A1, 2A2, 2B1 and 2B2 KC pumps

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question:

(1 point)

Given the following on Unit 1:

9

- The unit is at 100% RTP
- Pressurizer Pressure is 2235 PSIG

Subsequently:

- Pressurizer Pressure is slowly lowering
- Pressurizer Pressure Master Controller Error is -15 PSIG
- Backup Heaters are in AUTO
- The following is observed on 1AD6:



At the current error signal, all backup heaters are <u>(1)</u>.

1AD6 Annunciators <u>(2)</u> consistent with the given plant conditions.

- A 1. OFF
 - 2. are NOT
- B 1. ON 2. are NOT
- C 1. OFF 2. are
- D 1. ON 2. are

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 10

(1 point)

Given the following on Unit 2:

- The Unit is conducting a startup at 6% RTP
- The N-35 channel [LEVEL TRIP] switch is in [BYPASS]

Subsequently:

• Intermediate Range channel N-35 begins to operate erratically

Removal of 2N-35 Instrument Power fuses (1) result in a reactor trip.

Removal of 2N-35 Control Power fuses (2) result in a reactor trip.

- A. 1. will
 - 2. will
- B. 1. will2. will NOT
- C. 1. will NOT 2. will
- D. 1. will NOT 2. will NOT

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 11

(1 point)

Given the following on Unit 2:

• A startup is in progress and reactor power is currently 1% RTP

Subsequently:

- 2NC-27C (PRESSURIZER SPRAY CONTROL) fails OPEN
- The crew enters AP-11 (PRESSURIZER PRESSURE ANOMALIES)
- The valve will not close from the SLIM on 2MC-10.

Based on the conditions above,

- 1) The BOP will attempt to stop spray flow by _____.
- 2) IF unwarranted spray flow is allowed to continue without operator action an _____ reactor trip would occur.

- A. 1. securing NC Pumps A and B2. ΟΤΔΤ
- B. 1. securing NC Pumps A and B2. OPΔT
- C. 1. placing emergency close switch to [®]CLOSE[®].2. OTΔT
- D. 1. placing emergency close switch to ICLOSEI.2. OPΔT

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 12

(1 point)

Given the following on Unit 1:

- A SBLOCA has occurred
- Containment pressure peaked at 1.3 PSIG and now is 0.9 PSIG and stable
- The Pressurizer Booster and Pipe Tunnel Booster Fans have shunt tripped OFF

Based on the conditions above,

- 1) The Pressurizer Booster fans ______ swapped to emergency power.
- 2) The Pipe Tunnel Booster fans _____ remain OFF.

- A. 1. have 2. will
- B. 1. have 2. will NOT
- C. 1. have NOT 2. will
- D. 1. have NOT 2. will NOT

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 13

(1 point)

Given the following on Unit 2:

- 13:00 A LOCA occurred
- 13:01 Containment Pressure is 3.5 PSIG and rising

At time 13:02, the Containment Air Return Fans (1) be running.

In order to open, Containment Air Return Dampers require differential pressure between lower and upper containment to be less than or equal to a MAXIMUM of ______ PSID.

- A. 1. will 2. 0.35
- B. 1. will NOT 2. 0.5
- C. 1. will 2. 0.5
- D. 1. will NOT 2. 0.35

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 14

(1 point)

Given the following on Unit 1:

• 1AD-9, A/6 (GLYCOL EXPANSION TNK LO-LO LVL) has alarmed

Based on the above conditions, 1NF-234A (RB GLYCOL RETURN CONT OUTSIDE ISOL) _____ close.

A (2) signal will close all NF isolation valves.

- A. 1. will NOT 2. Phase B
- B. 1. will NOT2. Phase A
- C. 1. will 2. Phase B
- D. 1. will 2. Phase A

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 15

(1 point)

Concerning operation of the Containment Spray System (NS):

Aligning suction from the ______ with a specific ______ limits postaccident lodine concentration and minimizes stress corrosion.

- A. 1. FWST
 - 2. pH
- B. 1. containment sump
 - 2. pH
- C. 1. FWST
 - 2. boron concentration
- D. 1. containment sump
 - 2. boron concentration

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 16

(1 point)

Given the following on Unit 2:

- A LBLOCA has occurred
- One train of NS has been aligned for recirc per ES-1.3 (TRANSFER TO COLD LEG RECIRC)

As Containment pressure lowers, the NS Pump will automatically secure at a MAXIMUM Containment pressure of (1) PSIG.

Following this NS Pump shutdown, if Containment pressure rises above the autosecure setpoint, the NS Pump discharge valves _____(2)____ automatically OPEN.

- A. 1. 0.35 2. will NOT
- B. 1. 0.8 2. will NOT
- C. 1. 0.35 2. will
- D. 1. 0.8 2. will

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 17

(1 point)

Given the following on Unit 1:

- A reactor trip has occurred due to a secondary system malfunction
- E-0 (REACTOR TRIP OR SAFETY INJECTION) has been performed and the crew has transitioned to ES-0.1 (REACTOR TRIP RESPONSE)

Subsequently,

• The crew enters FR-H.3 (RESPONSE TO STEAM GENERATOR HIGH LEVEL)

FR-H.3 will NOT allow steam to be released from any S/G if NR level exceeds a MINIMUM of _____ due to _____ concerns, without an overfill evaluation being completed.

- A. 1. 82%2. steamline water hammer
- B. 1. 82%2. condenser tube damage
- C. 1. 92%2. steamline water hammer
- D. 1. 92%2. condenser tube damage

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 18

(1 point)

Given the following on Unit 1:

- A shutdown is in progress
- Turbine Inlet Pressure is 400 PSIG

At time 13:00 the following conditions are observed:

- CF-32 (A S/G CF CNTRL VALVE) 20% OPEN with CF-104 (A S/G CF CNTRL VLV BYPASS) CLOSED
- CF-23 (B S/G CF CNTRL VALVE) 10% OPEN with CF-105 (B S/G CNTRL VLV BYPASS) 100% OPEN
- CF-28 (C S/G CF CONT OUTSIDE ISOL) CLOSED
- CF-26 (D S/G CF CONT OUTSIDE ISOL) CLOSED

At time 13:01, based on the above conditions, AMSAC actuation _____(1) ____ occur.

Depressing [BLOCK] on the AMSAC ACTUATION BLOCK/UNBLOCK pushbutton prevents AMSAC ACTUATION if a loss of ______ (2) _____ occurs.

(CONSIDER EACH QUESTION SEPARATELY)

- A. 1. will 2. CF pumps
- B. 1. will 2. CF flow path
- C. 1. will NOT 2. CF pumps
- D. 1. will NOT 2. CF flow path

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 19

(1 point)

Given the following on Unit 2:

- A small break LOCA has occurred
- Safety Injection has been initiated
- The sequencer has not been reset
- S/G NR levels indicate the following:

<u>S/G</u>	2A	2B	2C	2D
<u>NR Level</u> (%)	20	19	16	20

Subsequently:

• The normal incoming breaker to 2ETA opens

Based on the conditions above, the 2A and 2B SGs are _____.

- A. not being fed
- B. being fed by the 2A MDCA pump ONLY
- C. being fed by the U2 TDCA pump ONLY
- D. being fed by the 2A MDCA pump AND U2 TDCA pump

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 20

(1 point)

Given the following on Unit 1:

- Unit is at 100% RTP
- The following separate annunciators are illuminated on 1AD-11:

AUX SHUTDOWN PNL SWITCH IN LOCAL	TCC re
ETA DEGRADED VOLTAGE	

TCC reports low grid voltage is present

IPB TROUBLE	 Both IPB Fans are OFF and will not restart NO fire is present
IPB AIR FLOW TROUBLE	

- NO other annunciators are present
- NO lockouts are present

Based on the conditions above, an automatic action will occur after a MINIMUM of ______ minutes. (Assume No operator action)

- A. 3
- B. 5
- C. 10
- D. 30

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 21

(1 point)

Given the following on Unit 1:

- A fault required battery EVCA to be removed from service
- The crew is aligning charger EVCC and battery EVCC to supply distribution center EVDA per OP/0/A/6350/001A Enclosure 4.13 (REMOVAL OF BATTERY EVCA FROM SERVICE)

Subsequently:

- 1AD-11 C3 (BATT EVCC GROUND) alarms in the Control Room
- Relay Board 2EB5 indicates a negative leg ground exists on EVCC

Based on the conditions above:

- 1) The detector lamp on 2EB5 will be ______ to indicate a ground.
- 2) Per Enclosure 4.13, Limits and Precautions, the alignment of EVCC should NOT occur if a _____ leg ground exists on EVDA.

- A. 1. bright
 - 2. positive
- B. 1. dim2. positive
- C. 1. bright 2. negative
- D. 1. dim 2. negative

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 22

(1 point)

Given the following on Unit 2:

- A Loss of Offsite Power has occurred
- 2B D/G started but subsequently tripped on overspeed
- 60 seconds have passed since the Loss of Offsite Power occurred

Based on the conditions above:

- 1) 125 VDC Power Panel Board 2EVDD will be energized from _____.
- 2) This can be verified by checking control power available to 4160V pumps powered from _____.

- A. 1. Battery EVCD
 - 2. 2ETA
- B. 1. Standby Charger EVCS2. 2ETA
- C. 1. Battery EVCD 2. 2ETB
- D. 1. Standby Charger EVCS2. 2ETB

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 23

(1 point)

Given the following on Unit 1:

- The 1A D/G has been placed in operation to facilitate a power swap on 1ETA from 1ATC to SATA
- Indicated load is 400 KW and 75 KVARS
- 1A DG is currently powering 1ETA with the 1ETA Normal Breaker and 1ETA Stdby Breaker OPEN

Based on the conditions above,

- depressing the "1A D/G Gov Cntrl" "Raise" pushbutton will result in raising 1A D/G _____.
- rotating the "1A D/G Volt Adjust" switch to "Raise," will result in raising 1A D/G _____.

- A. 1. frequency 2. KVARs
- B. 1. load 2. KVARs
- C. 1. frequency 2. voltage
- D. 1. load 2. voltage

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 24

(1 point)

Given the following on Unit 2:

- Unit is at 100% RTP
- Train "A" equipment is in service
- The power supply to 2EMF-46A (TRAIN A KC) has FAILED

Based on the conditions above,

- 1) 2KC-122 (KC SURGE TANK VENT) _____ receive a signal to auto-close.
- 2) 2RAD-1/F5 (CABINET 1-2 TROUBLE) alarm _____ be generated.

- A. 1. does 2. will
- B. 1. does NOT 2. will
- C. 1. does 2. will NOT
- D. 1. does NOT 2. will NOT

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 25

(1 point)

Given the following on Unit 1:

- Unit is at 100% RTP
- 1B DG is running for PT/1/A/4350/002B, Diesel Generator 1B Operability Test.

Subsequently:

• The BOP operator reports that 1B D/G Room average temperature is 105°F and rising at 2°F per minute

Based on the conditions above, the SLC 16.9.16 (AREA TEMPERATURE MONITORING) limit for D/G Room temperature will be exceeded in a MINIMUM of ______ minutes.

Which ONE of the following completes the statement above?

A. 5
B. 7.5
C. 10
D. 12.5

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 26

(1 point)

Given the following on Unit 1:

- The Unit is at 100% RTP
- Electrical supplies are aligned normally
- "A" Train KC is in service

Subsequently:

• A Blackout occurs on 1ETA

The blackout occurred due to a loss of Unit 1 6900 volt bus _____(1) ____.

As a result of the Blackout, "A" Train KC pumps will <u>(2)</u>.

- A. 1. 1TA2. receive a manual start permissive
- B. 1. 1TC2. receive a manual start permissive
- C. 1. 1TA 2. automatically start
- D. 1. 1TC 2. automatically start

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 27

(1 point)

Regarding the Low Pressure Station Air System (VS):

The backup supply to the Low Pressure Air system is the _____(1)____.

When running in automatic, the Low Pressure Station Air compressor will trip on low (2) flow to the oil cooler.

- A. 1. Low Pressure Station Air compressor2. RL
- B. 1. VI system through 1VI-8202. RL
- C. 1. Low Pressure Station Air compressor2. KR
- D. 1. VI system through 1VI-820 2. KR

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 28

(1 point)

Given the following conditions:

- Unit 1 is at 12% RTP
- Power ascension in progress

Subsequently:

• 1C NC pump trips

Loop C delta-T will stabilize at a <u>(2)</u> value.

- A. 1. P-7 2. higher
- B. 1. P-8 2. lower
- C. 1. P-8 2. higher
- D. 1. P-7 2. lower

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 29

(1 point)

Give the following on Unit 1:

- Unit is in MODE 3
- Shutdown Banks are being withdrawn in preparation for startup per OP/1/A/6100/003 (CONTROLLING PROCEDURE FOR UNIT OPERATION)

Subsequently:

- 1AD-2 / D10 (RPI URGENT ALARM) has just alarmed
- DRPI and OAC RODS position indication for rod D-8 in Shutdown Bank E has been lost

What action is required by **SLC 16.7.9** (ROD POSITION INDICATION SYSTEM - SHUTDOWN)?

- A. IMMEDIATELY place rods in manual
- B. IMMEDIATELY open the reactor trip breakers
- C. IMMEDIATELY insert the shutdown banks
- D. Restore rod position indication within 1 hour

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 30

(1 point)

Given the following on Unit 1:

- Unit is at 100% RTP
- The SLIM for 1NV-238 (CHARGING FLOW CONTROL) has been placed in MANUAL due to a malfunction of the Pressurizer Level Master Controller
- 1NV-238 SLIM output is lowered to reduce Pressurizer level
- Charging Line Flow is lowered to 18 GPM

Based on the conditions above:

- 1) If the 1NV-238 controller output remains constant, pressurizer level will be
- 2) The crew will use _____ to address pressurizer level.

Which ONE of the following completes the statements above?

PROCEDURE LEGEND:

OP/1/A/6102/003 (DISTRIBUTED CONTROL SYSTEM OPERATION) AP/1/A/5500/12 (LOSS OF LETDOWN, CHARGING OR SEAL INJECTION)

- A. 1. rising 2. AP/1/A/5500/12
- B. 1. rising 2. OP/1/A/6102/003
- C. 1. lowering 2. AP/1/A/5500/12
- D. 1. lowering 2. OP/1/A/6102/003

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 31

(1 point)

Given the following initial conditions on Unit 2:

- A reactor startup is being performed per OP/2/A/6100/003 (CONTROLLING PROCEDURE FOR UNIT OPERATION)
- Reactor power is 7X10⁻⁶ % (IR)

Subsequently:

• The IR Signal Processor output for detector channel N36 fails low

Based on the conditions above:

- 1) Reactor power indication on _____ has been lost.
- 2) If the power increase is continued, Permissive P-6 logic _____ be met by the remaining channel.

- A. 1. N36 ONLY 2. will
- B. 1. N36 ONLY2. will NOT
- C. 1. N32 AND N36 2. will
- D. 1. N32 AND N36 2. will NOT

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 32

(1 point)

Which ONE of the following sets of indications can be read outside the Main Control Room on <u>BOTH</u> the Auxiliary Shutdown Panel (ASP) <u>AND</u> the Safe Shutdown Facility (SSF) Control Panel?

- A. Incore Thermocouples AND S/G WR Levels
- B. Incore Thermocouples AND Pressurizer Level
- C. SR Neutron Flux AND S/G WR Levels
- D. SR Neutron Flux AND Pressurizer Level

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 33

(1 point)

Given the following on Unit 1:

- A LOCA has occurred
- Containment hydrogen concentration is slowly rising.
- The TSC has recommended placing the H2 Purge Blower in service.

The H2 Purge Blower is placed in service to maintain hydrogen concentration less than a MAXIMUM of (1) %.

While in operation, the H2 Purge blower return line vents air from containment to the (2)

- A. 1. 42. Auxiliary Building
- B. 1. 62. Auxiliary Building
- C. 1. 4 2. Annulus
- D. 1. 6
 - 2. Annulus

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 34

(1 point)

Given the following on Unit 1:

- The reactor is stable at approximately 2% RTP
- A Steam Generator safety valve fails OPEN
- NO Reactor Trip or Safety Injection actuation occurs

NC system temperature will stabilize at a lower temperature if this event were to occur at _____1.

Reactor power will stabilize at (2) .

(Consider each question separately)

- A. 1. BOL2. a higher value at BOL than at EOL
- B. 1. BOL2. approximately the same value at BOL and EOL
- C. 1. EOL2. a higher value at BOL than at EOL
- D. 1. EOL2. approximately the same value at BOL and EOL

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 35

(1 point)

Given the following Unit 1 conditions:

- The Unit was operating at 100% RTP
- A Reactor Trip occurs
- Reactor Trip breaker 1RTB fails to open on the trip

Based on the conditions above with regards to the Steam Dump System:

The _____ controller will be in service.

Operator action (2) be required to lower T_{AVG} to 557°F.

- A. 1. Plant Trip 2. will
- B. 1. Load Rejection 2. will
- C. 1. Plant Trip 2. will NOT
- D. 1. Load Rejection 2. will NOT

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 36

(1 point)

The turbine Overspeed Protection Control (OPC) circuit limits turbine speed to a MAXIMUM of (1) by closing the (2).

- A. 1. 103% 2. IVs ONLY
- B. 1. 110%2. IVs ONLY
- C. 1. 103% 2. GVs and IVs
- D. 1. 110% 2. GVs and IVs
MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 37

(1 point)

Given the following on Unit 2:

- 2A S/G has developed a 200 GPD tube leak
- 2EMF-33 (CSAE DISCHARGE) Trip 2 light is illuminated

The normal discharge flowpath for the Condenser Steam Jet Air Ejectors (CSAE) is to the _____1.

A Trip 2 condition on 2EMF-33, <u>(2)</u> isolate the CSAE drains to the turbine building sump.

- A. 1. Turbine Building roof 2. will NOT
- B. 1. Unit vent 2. will NOT
- C. 1. Turbine Building roof 2. will
- D. 1. Unit vent
 - 2. will

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 38

(1 point)

Given the following on Unit 1:

- Unit is at 100% RTP
- The Unit 1 VUCDT is being released

Subsequently:

- Annunciator 1RAD2 C/2 (1EMF-44 CONT VENT DRN TANK HI RAD) alarms
- 1WL-320 (VUCDT RAD MONITOR OUTLET) indicates OPEN
- 1WP-35 (WMT & VUCDT TO RC CNTRL) indicates CLOSED
- 1WP-37 (LIQUID WASTE TO RC CNTRL) indicates OPEN

Based on the conditions above, _____ has/have failed to automatically close.

If VUCDT activity level is too high for a normal "batch" release to RC, the VUCDT would be transferred to the _____.

- A. 1. 1WL-320 ONLY2. WMT (Waste Monitor tank)
- B. 1. 1WL-320 ONLY2. FDT (Floor Drain tank)
- C. 1. 1WL-320 AND 1WP-372. WMT (Waste Monitor tank)
- D. 1. 1WL-320 AND 1WP-372. FDT (Floor Drain tank)

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 39

(1 point)

Given the following on Unit 1:

- The unit has tripped due to a loss of both Feed pumps
- Rod H12 fails to fully insert into the core
- The crew has entered ES-0.1 (REACTOR TRIP RESPONSE)

Based on the conditions above and per ES-0.1, emergency boration ____(1) required.

Per T.S. 3.1.1 (SHUTDOWN MARGIN) if boration is required due to SDM not within the limit, then initiation of boration must occur within ____(2)___ minutes

- A. 1. is
 2. 30
 B. 1. is NOT
 2. 30
- C. 1. is 2. 15
- D. 1. is NOT 2. 15

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 40

(1 point)

Given the following on Unit 2:

• Unit 2 is at 100% RTP

Subsequently:

• PORV NC-32B inadvertently lifts and fails to reseat

Based on the conditions above:

1) The output (error signal) of the Pressurizer Pressure Master Controller will

2) The transient will cause the setpoint for **OPΔT** to _____.

- A. 1. raise2. remain the same
- B. 1. lower 2. lower
- C. 1. raise 2. lower
- D. 1. lower 2. remain the same

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 41

(1 point)

Given the following on Unit 1:

- A Safety Injection due to High Containment pressure has occurred
- The crew has implemented E-0 (REACTOR TRIP OR SAFETY INJECTION)
- NV pump flow to the NC system Cold Legs is 390 GPM
- NC system pressure is 1350 PSIG and STABLE
- SG pressures are 1092 PSIG and STABLE
- NC system subcooling on the ICCM is 22 °F and STABLE

Per E-0 Foldout Page, the crew (1) secure NC pumps.

Upon transition to E-1 (LOSS OF REACTOR OR SECONDARY COOLANT), Steam Generators _______ be required for heat removal.

Which ONE of the following completes the statements above?

A. 1. will NOT 2. will NOT

- B. 1. will NOT 2. will
- C. 1. will 2. will NOT
- D. 1. will
 - 2. will

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 42

(1 point)

Given the following on Unit 1:

- A LBLOCA has occurred.
- The crew has just transitioned to ES-1.3 (TRANSFER TO COLD LEG RECIRCULATION).
- CONT SUMP LEVEL GREATER THAN 2.5 FT on 1AD-14 is LIT.
- CONT SUMP LEVEL GREATER THAN 3.0 FT on 1AD-14 is DARK.

Per ES-1.3:

- 1) The MINIMUM Containment sump level required to align ND to cold leg recirculation _____ met.
- 2) When FWST level lowers to a MAXIMUM of _____ INCHES, NV and NI can be aligned to cold leg recirculation.

- A. 1. is 2. 95
- B. 1. is NOT 2. 95
- C. 1. is 2. 20
- D. 1. is NOT 2. 20

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 43

(1 point)

Given the following on Unit 2:

- Unit is in MODE 3 with Shutdown Banks withdrawn
- 2B, 2C, and 2D NC pumps are in service
- Bus 2TA is de-energized with its supply breaker racked out for maintenance

Subsequently:

• The 2B NC pump 6.9KV NC pump feeder breaker trips

Based on the conditions above:

- 1) The 2C and 2D NC pumps SAFETY BREAKERS indicate _____.
- 2) The Unit 2 Reactor Trip breakers _____.

- A. 1. CLOSED 2. remain CLOSED
- B. 1. CLOSED2. are TRIPPED
- C. 1. OPEN 2. remain CLOSED
- D. 1. OPEN 2. are TRIPPED

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 44

(1 point)

Given the following on Unit 1:

- Unit is at 100% RTP
- The CRS has implemented AP-12 (LOSS OF LETDOWN, CHARGING OR SEAL INJECTION) following a trip of 1A NV Pump

Subsequently:

• 1B NV Pump has been started

When initially restoring seal injection flow, the BOP will **slowly** throttle _____(1) ____ on 1NV-241 (U1 SEAL WATER INJ FLOW CONTROL) to _____(2)___.

- A. 1. OPEN2. establish 8-10 gpm seal flow per NC pump
- B. 1. OPEN2. limit NCP lower bearing cooldown rate to 1 °F/min
- C. 1. CLOSED2. limit NCP lower bearing cooldown rate to 1 °F/min
- D. 1. CLOSED2. establish 8-10 gpm seal flow per NC pump

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 45

(1 point)

Given the following on Unit 2:

- Unit is in MODE 5 and drained to Mid-loop
- ND Train 2A is in service
- ND system flow rate is 3200 GPM
- NC System level is 7 inches and stable
- 2A ND pump amps and discharge pressure begin to oscillate
- The crew has entered AP-19 (LOSS OF ND OR ND SYSTEM LEAKAGE)

Based on the conditions above:

The 2A ND pump is _____1)___.

Per AP/19, the crew will FIRST (2).

- A. 1. cavitating2. secure 2A ND Pump
- B. 1. cavitating2. reduce ND flow to less than 3000 GPM
- C. 1. operating at runout condition2. secure 2A ND Pump
- D. 1. operating at runout condition2. reduce ND flow to less than 3000 GPM

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 46

(1 point)

Given the following on Unit 1:

• Unit is at 100% RTP, normal temperature and pressure

Subsequently:

- The Pressurizer Pressure Master controller suffers an internal failure resulting in a IPressurizer Pressure ErrorI of +100 PSIG
- Actual Pressurizer Pressure is 2100 PSIG and lowering

Pressurizer Spray valves are currently _____(1) ____.

At the time of the failure, <u>(2)</u> received a signal to open.

- A. 1. CLOSED 2. PORV NC-34A ONLY
- B. 1. CLOSED2. PORVs NC-32B AND NC-36B
- C. 1. OPEN 2. PORVs NC-32B AND NC-36B
- D. 1. OPEN 2. PORV NC-34A ONLY

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 47

(1 point)

Given the following on Unit 1:

• Unit was at 100% RTP

Subsequently:

- A turbine trip occurs
- The CRS has implemented FR-S.1 (RESPONSE TO NUCLEAR POWER GENERATION/ATWS) due to inability to open the trip breakers
- A Pzr safety lifted and did not reseat
- Pzr pressure lowered to a pressure of 1600 PSIG and is now slowly trending up
- The following indications are observed:



- 1. Which ONE of the following valves is in the CORRECT position?
- 2. FR-S.1 _____ direct the use of the ESF Monitor Light Panel to check all ESF valve positions.

- A. 1. 1NV-150B 2. will
- B. 1. 1NV-150B 2. will NOT
- C. 1. 1NV-245B 2. will
- D. 1. 1NV-245B 2. will NOT

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 48

(1 point)

Why does the loss of reactor coolant pumps during a steam generator tube rupture increase the risk of voiding during the subsequent cooldown and depressurization?

- A. The NCS hot legs reach saturation temperature during the rapid depressurization from the tube rupture, causing the NCS to flash.
- B. More ECCS flow is injected into the ruptured loop cold leg due to the reduced pressure, resulting in less flow to the core and less heat removal.
- C. The upper head region becomes inactive and the fluid temperature in that region significantly lags the temperatures in the NCS loop.
- D. The isolation of the steam generator in the affected loop causes that loop to stagnate; therefore, insufficient heat removal capacity is available to cool the NCS.

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 49

(1 point)

Regarding the operation of the CA system:

- 1) <u>ONLY</u> the Motor-Driven CA pump(s) will start if a _____ occurs.
- 2) The CA system is capable of supplying sufficient flow to maintain S/G inventory provided reactor power is less than a MAXIMUM of _____.

- A. 1. Blackout signal on 1ETA and/or 1ETB2. 5%
- B. 1. Blackout signal on 1ETA and/or 1ETB2. 3%
- C. 1. Trip of both CF pumps 2. 5%
- D. 1. Trip of both CF pumps 2. 3%

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 50

(1 point)

Given the following conditions:

- Both units have experienced a Loss of Offsite Power (LOOP)
- ECA-0.0 (LOSS OF ALL AC POWER) was implemented on Unit 1 and the crew transitioned to ECA-0.1 (LOSS OF ALL AC POWER RECOVERY WITHOUT S/I REQUIRED)

Current conditions:

- NC Subcooling is greater than 0°F
- S/G pressures are STABLE at 470 PSIG
- NC Thots are STABLE
- Core Exit T/Cs STABLE
- NC Tcolds are 500 °F and STABLE

Consider Each Statement Separately

Natural Circulation flow ______ currently established.

If Natural Circulation flow is NOT established, then ____(2) will be used to dump steam.

Which ONE of the following completes the statements above?

REFERENCE PROVIDED

- A. 1. is2. Main Steam PORVs
- B. 1. is 2. Steam Dumps
- C. 1. is NOT 2. Main Steam PORVs
- D. 1. is NOT 2. Steam Dumps

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 51

(1 point)

Given the following:

- VC/YC Mode Select Switch is in TRAIN A with all A Train equipment in operation, except CR-OAPFT-1
- VC/YC Train B Mode Select Switch is in OFF with all B Train equipment selected to AUTO
- No smoke or fire detection alarms, associated with VC/YC, are active

Subsequently:

• A blackout on 1ETB occurs.

Based on the conditions above,

- 1) The Train B CR-AHU _____ be running.
- 2) The Train A CR-OAPFT-1 will _____.

Which ONE of the following completes the statement above?

A. 1. will NOT 2. start

- B. 1. will NOT2. remain OFF
- C. 1. will 2. start
- D. 1. will 2. remain OFF

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 52

(1 point)

Given the following on Unit 1:

- A loss of EVDD has occurred
- The CRS has implemented AP-15 (LOSS OF VITAL OR AUX CONTROL POWER)

Due to the isolation of <u>(1)</u>, the operating crew will be required to respond to rising containment pressure.

To aid in controlling containment pressure, LOWER Containment TEMPERATURE will be maintained less than a MAXIMUM of ______, as required by TS 3.6.5 (CONTAINMENT AIR TEMPERATURE).

- A. 1. the VQ (Containment Air Addition and Release) system
 2. 100 °F
- B. 1. RV (Containment Cooling) to Lower Containment
 2. 100 °F
- C. 1. the VQ (Containment Air Addition and Release) system
 2. 120 °F
- D. 1. RV (Containment Cooling) to Lower Containment
 2. 120 °F

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 53

(1 point)

Given the following initial conditions on Unit 1:

• The Unit is operating at 100% RTP

Subsequently,

- 1AD8 / D2 (SUMP B GROUNDWATER DRAINAGE HI HI LVL) alarms
- An AO has been dispatched to investigate reports that the B Groundwater sump is overflowing

Which ONE (1) of the following describes the source of the flooding?

- A. 2A RN strainer basket shaft seal failure
- B. 2B RN Pump Suction piping weld failure
- C. RF piping break in the Unit 1 CA pump Room
- D. 1B RN strainer automatic backwash valve has failed open

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 54

(1 point)

Given the following:

- Both Units at 100% RTP
- A loss of VI has occurred
- AP-22 (LOSS OF VI) has been implemented on both units

Subsequently:

• A Loss of Off-Site Power occurs

Based on the conditions above, the Auxiliary Bldg Instrument Air headers _____(1) ____ be supplied from the D/G Starting Air system (VG).

The air supplied by the Auxiliary Bldg Instrument Air headers will be used to ensure valves essential to safe operation ____(2)___.

- A. 1. can NOT2. can be used to achieve unit shutdown to COLD Shutdown
- B. 1. can NOT2. attain their "fail safe" position
- C. 1. can2. can be used to achieve unit shutdown to COLD Shutdown
- D. 1. can2. attain their "fail safe" position

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 55

(1 point)

Given the following on Unit 2:

- A LOCA has occurred
- Containment pressure peaked at 3.2 PSIG and is currently 2.5 PSIG
- <u>NO</u> CA flow is available
- E-1 (LOSS OF REACTOR OR SECONDARY COOLANT) has been implemented

Given the following parameters:

	<u>TIME</u>			
Highest SG NR Level	<u>0200</u>	<u>0210</u>	<u>0220</u>	<u>0230</u>
2A S/G	35%	25%	15%	10%
2B S/G	31%	24%	15%	9%
2C S/G	34%	25%	12%	8%
2D S/G	32%	23%	10%	7%

Which ONE of the following is the EARLIEST time that the crew is required to implement FR-H.1 (LOSS OF SECONDARY HEAT SINK)?

- A. 0200
- B. 0210
- C. 0220
- D. 0230

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 56

(1 point)

ECA-2.1 (UNCONTROLLED DEPRESSURIZATION OF ALL STEAM GENERATORS) contains actions to limit total AFW flow to any S/G with a N/R level less than 11% (32% ACC).

The basis for the minimum feed flow value is to _____.

- A. prevent Steam Generator dryout
- B. prevent water hammer in the feed rings
- C. meet the minimum heat sink flow requirements
- D. minimize water inventory to prevent a Steam Generator overfill condition

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 57

(1 point)

Given the following Unit 1 initial conditions:

- Unit is at 40% RTP and stable
- Rod Control is in automatic
- The MW feedback loop is OUT of service
- NC T-Avg is 567°F

Subsequently,

- Control Bank IDI Rod M-12 drops fully into the core
- The crew has implemented AP-14 (ROD CONTROL MALFUNCTION)
- NC T-Avg is 563°F

Turbine power ______ stabilize at a lower value.

Per AP-14, the crew _____ FIRST adjust control rods in order to restore T-Avg to T-Ref.

- A. 1. will 2. will
- B. 1. will
 - 2. will NOT
- C. 1. will NOT 2. will
- D. 1. will NOT 2. will NOT

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 58

(1 point)

Given the following on Unit 2:

- The CRS has implemented FR-S.1, (RESPONSE TO NUCLEAR POWER GENERATION ATWS)
- The crew is initiating emergency boration
- 2NV-265B (BA TO NV PMPS) is OPEN
- 2A NV pump is IONI
- Both Boric Acid Transfer Pumps are OFF.
- 2NV-244A and 2NV-245B, (CHRG LINE CONT ISOLs) are OPEN

Per FR-S.1, the crew is required to start (1) boric acid transfer pump(s) and to ensure a MINIMUM boric acid flow of (2).

- A. 1. ONE 2. 30 gpm
- B. 1. Both 2. 30 gpm
- C. 1. ONE 2. 50 gpm
- D. 1. Both 2. 50 gpm

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 59

(1 point)

Given the following on Unit 2:

- Unit is in Mode 6
- The core is being off-loaded
- It has just been identified (and verified) that the RCS boron concentration is 2650 ppm
- The refueling boron concentration required by the COLR is 2675 ppm

Per TS 3.9.1 (BORON CONCENTRATION), the crew is required to ______.

- A. initiate action to restore boron concentration and suspend core alterations
- B. initiate action to restore boron concentration and establish containment integrity
- C. suspend positive reactivity changes and establish containment integrity
- D. suspend movement of irradiated fuel assemblies within containment and suspend operations that dilute the RCS

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 60

(1 point)

Given the following on Unit 2:

- The crew has implemented AP-10 (NC SYSTEM LEAKAGE), Case 1 (S/G TUBE LEAKAGE)
- Letdown flow is 45 GPM
- Charging flow is 110 GPM
- Pressurizer level is stabilized

Upon entry into AP-10, the Balance of Plant Operator will establish a <u>(1)</u> GPM mismatch between letdown flow and charging flow per Excellence Criteria.

Based on the conditions above, the estimated leak rate is <u>(2)</u> GPM.

- A. 1. 30
 2. 53
 B. 1. 30
 2. 65
 C. 1. 10
 2. 53
- D. 1. 10 2. 65

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 61

(1 point)

Given the following on Unit 1:

- Unit is at 40% RTP
- Exhaust Hood temperature is 165°F
- Condenser vacuum on 1MC-1 indicates 26 inches HG and DEGRADING
- (1ZJP5000) CSAE steam pressure, is reading 100 PSIG
- AP-23 (LOSS OF CONDENSER VACUUM) has been implemented
- Main Condenser Vacuum has been established as a critical parameter

Alternate condenser vacuum indication is available on _____.

Based on the conditions above, the CRS will direct <u>(2)</u> to mitigate the event.

- A. 1. the OAC ONLY2. dispatching an operator to increase CSAE steam pressure
- B. 1. the OAC ONLY2. opening the Exhaust Hood Spray valves
- C. 1. 1MC-13 and the OAC2. opening the Exhaust Hood Spray valves
- D. 1. 1MC-13 and the OAC2. dispatching an operator to increase CSAE steam pressure

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 62

(1 point)

Given the following:

• The Control Room has been evacuated due to toxic gas

An adequate heat sink is maintained by controlling S/G levels within the specified range by _____.

Shutdown margin will be maintained by use of the _____.

- A. 1. manually throttling the motor operated isolation valves in the doghouses2. Standby Makeup Pump
- B. 1. manually throttling the motor operated isolation valves in the doghouses2. Boric Acid Transfer Pumps
- C. 1. adjusting the manual loaders at the local CA pump panels2. Standby Makeup Pump
- D. 1. adjusting the manual loaders at the local CA pump panels2. Boric Acid Transfer Pumps

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 63

(1 point)

Given the following on Unit 1:

- Unit was at 100% RTP
- A SBLOCA has occurred
- The CRS is transitioning from E-1 (LOSS OF REACTOR OR SECONDARY COOLANT) to ES-1.2 (POST LOCA COOLDOWN AND DEPRESSURIZATION)

Per ES-1.2:

- The crew will <u>FIRST</u> attempt to establish an NC system cooldown using the ______.
- 2) The crew will cooldown at <u>(2)</u>.

- A. 1. Condenser Dumps2. a rate not to exceed 100°F in an hour
- B. 1. Condenser Dumps2. maximum rate
- C. 1. SM PORVs2. a rate not to exceed 100°F in an hour
- D. 1. SM PORVs
 - 2. maximum rate

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 64

(1 point)

Given the following on Unit 1:

- An event has occurred that resulted in a RED condition on the NC Integrity CSF Status Tree
- The CRS has implemented FR-P.1 (RESPONSE TO IMMINENT PRESSURIZED THERMAL SHOCK)
- The crew is performing the 60 minute soak per Step 26 of FR-P.1

Which of the following actions is permitted by FR-P.1 during the soak?

- A. Energize PZR heaters
- B. Start an additional NV Pump
- C. Place Auxiliary Spray in service
- D. Initiate a cooldown at less than 50 °F per hour

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 65

(1 point)

Given the following on Unit 1:

I A large break LOCA has occurred

I At 1215 containment sump level is 10 feet and slowly rising

If containment sump level is rising at a constant rate of 0.25 feet per minute, FR-Z.2 (RESPONSE TO CONTAINMENT FLOODING) entry will be REQUIRED at _____1)____.

The reason that safe plant recovery is not assured for a design-basis Large Break LOCA when Containment water level requires entry into FR Z.2 is because operation of _____.

- A. 1. 1225
 - 2. the hydrogen skimmer system is compromised by the suction line becoming submerged
- B. 1. 1229
 - 2. the hydrogen skimmer system is compromised by the suction line becoming submerged
- C. 1. 1225
 - 2. critical ECCS components needed for safe recovery are endangered by submersion
- D. 1. 1229
 - 2. critical ECCS components needed for safe recovery are endangered by submersion

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 66

(1 point)

Per AD-OP-ALL-0107 (MAINTENANCE OF RO AND SRO LICENSES), at a MINIMUM, a Reactor Operator must:

- 1) Perform _____ 12 hour shifts per calendar quarter as RO or BOP.
- 2) Complete a doctor's medical exam _____.

- A. 1. four
 - 2. yearly
- B. 1. four2. every two years
- C. 1. five 2. every two years
- D. 1. five 2. yearly

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 67

(1 point)

Per AD-OP-ALL-1000 (CONDUCT OF OPERATIONS),

- 1) Plant announcements are required if starting or stopping plant equipment of greater than or equal to a MINIMUM of ______.
- 2) The use of cameras ______ an acceptable alternative to verify that plant personnel are clear of equipment prior to starting.

- A. 1. 4 kv 2. is NOT
- B. 1. 4 kv 2. is
- C. 1. 6.9 kv 2. is NOT
- D. 1. 6.9 kv 2. is

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 68

(1 point)

Given the following on Unit 1:

- Unit is in Mode 6 with refueling in progress
- 1B D/G is tagged for maintenance
- 1ETB is powered by SATB from Unit 2
- 1A ND pump is in service
- 1B ND pump is in standby

Subsequently:

• 1B busline is de-energized in preparation for tagging

Based on the conditions above:

- 1) TS 3.8.2 (AC SOURCES SHUTDOWN) _____ met.
- 2) TS 3.9.5 (RHR and COOLANT CIRCULATION HIGH LEVEL) _____ met.

- A. 1. is 2. is NOT
- B. 1. is
 - 2. is
- C. 1. is NOT 2. is NOT
- D. 1. is NOT 2. is

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 69

(1 point)

Given the following on Unit 1:

- Unit is in Mode 3
- NC System pressure is 2750 PSIG

Per TS 2.1 (SAFETY LIMITS), NC System pressure is required to be reduced to less than or equal to a MAXIMUM of (1) PSIG and this is required to be accomplished within a MAXIMUM of (2).

- A. 1. 2485
 - 2. 1 hour
- B. 1. 2485 2. 5 minutes
- C. 1. 2735 2. 1 hour
- D. 1. 2735 2. 5 minutes

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 70

(1 point)

In accordance with AD-HU-ALL-004 (PROCEDURE AND WORK INSTRUCTION USE AND ADHERENCE):

- 1) A user ______ allowed to perform Information Use procedures without referring to the procedure.
- 2) For technical procedures, the user shall verify the latest revision of the procedure prior to job start and at least every _____ days while work is being performed.

Which ONE of the following completes the statements above?

A. 1. is
2. 7
B. 1. is
2. 14
C. 1. is NOT
2. 7

D. 1. is NOT 2. 14

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 71

(1 point)

Given the following:

- An operator has been assigned work in the radiologically controlled area
- The dose rate in the area is 500 mRem/hr
- The operator has a current yearly dose of 0.5 Rem TEDE

Which ONE of the following identifies the MAXIMUM time that the operator can perform work, without receiving an extension, BEFORE reaching the Duke Energy Annual Administrative Dose Limit?

- A. 2.2 hours
- B. 2.6 hours
- C. 3.0 hours
- D. 5.8 hours

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 72

(1 point)

An Operator needs to access an area with a general area radiation dose rate of 1100 mREM/hr to hang a clearance tag.

Per CSD-RP-ALL-1013 (RADIATION PROTECTION STANDARD GLOSSARY OF TERMS), the correct radiation posting for this area is a _____(1)____.

Per AD-RP-ALL-2017 (ACCESS CONTROLS TO VERY HIGH RADIATION AREAS AND SUPPLEMENTAL ACCESS CONTROLS FOR HRA AND LHRA), continuous RP coverage (2) required for this area.

- A. 1. High Radiation Area 2. is NOT
- B. 1. High Radiation Area2. is
- C. 1. Locked High Radiation Area 2. is NOT
- D. 1. Locked High Radiation Area 2. is
MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 73

(1 point)

E-3 (STEAM GENERATOR TUBE RUPTURE) contains the following statement:

Preference should be given to running 1B NC pump to provide Pzr spray capability. If 1B NC pump is not available, running 1A NC pump along with one or two additional NC pumps may be required for adequate spray.

The statement above ______ a NOTE because it gives ______ (2) _____ information.

- A. 1. is 2. advisory
- B. 1. is 2. critical
- C. 1. is NOT 2. advisory
- D. 1. is NOT 2. critical

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 74

(1 point)

Per AD-OP-ALL-1001 (CONDUCT OF ABNORMAL OPERATIONS), the dispatch of Auxiliary Operators (AOs) to perform tasks outside the control room ____(1)___.

Per OMP 4-3 (USE OF EMERGENCY AND ABNORMAL PROCEDURES AND FLEX SUPPORT GUIDELINES), during an emergency if a dispatched operator cannot operate a manual valve, a valve wrench ______ (2) _____ be used without supervisor approval.

- A. 1. is performed by the Reactor Operators2. can
- B. 1. is performed by the Reactor Operators2. can NOT
- C. 1. requires CRS approval 2. can
- D. 1. requires CRS approval2. can NOT

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 75

(1 point)

Given the following on Unit 1:

- A Site Area Emergency has been declared
- A Site Assembly is being conducted in accordance with RP/0/A/5700/011 (CONDUCTING A SITE ASSEMBLY, SITE EVACUATION, OR CONTAINMENT EVACUATION)

Per RP-011,

- the announcement for the Site Assembly shall be repeated every
 _____ minutes until notification that the Site Assembly has been completed.
- 2) the Site Assembly shall be completed within a MAXIMUM of _____ minutes.

A.	1. 15 2. 30
В.	1. 10 2. 30
C.	1. 15 2. 60
D.	1. 10 2. 60

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 76

(1 point)

Given the following on Unit 1:

- Unit is in MODE 5
- □ NC temperature is 70 °F
- LTOP is in service
- Engineering requests a test procedure be performed which requires BOTH NI Pumps to be capable of injecting into the NC system
- Both NV pumps will be racked out and tagged for the test

Entry into the Action statement of T. S. 3.4.12 (LTOP SYSTEM) (1) required to perform this test.

Per T.S. 3.4.12 Bases, ONE OPERABLE ND suction relief valve ONLY (2) satisfy the LTOP RCS vent requirement.

- A. 1. is 2. will NOT
- B. 1. is 2. will
- C. 1. is NOT 2. will NOT
- D. 1. is NOT 2. will

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 77

(1 point)

Given the following on Unit 1:

- The CRS has implemented ECA-1.2 (LOCA OUTSIDE CONTAINMENT)
- The crew has determined the leak is NOT on the ND system
- NC System pressure is 1700 PSIG and lowering
- Pzr Level is 22% and lowering
- FWST level is 110 inches and lowering

The CRS will NEXT be required to transition to _____(1)____.

After transition is made, if FWST level lowers to less than a MAXIMUM of _____(2) inches, the CRS will direct securing ALL pumps taking suction on the FWST.

Which ONE of the following completes the statements above?

PROCEDURE LEGEND:

ECA-1.1 (LOSS OF EMERGENCY COOLANT RECIRC) ES-1.2 (POST LOCA COOLDOWN AND DEPRESSURIZATION)

- A. 1. ECA-1.1 2. 95
- B. 1. ECA-1.1 2. 20
- C. 1. ES-1.2 2. 95
- D. 1. ES-1.2 2. 20

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 78

(1 point)

Given the following on Unit 2:

- I Unit is at 100% RTP
- A loss of 2EKVD has occurred
- The CRS has implemented AP-15 (LOSS OF VITAL OR AUX CONTROL POWER)
- NO Tech Spec actions have been addressed

The current Containment Pressure channel logic, for the remaining Containment Pressure channels, which will cause a **Phase B** actuation is _____(1)___.

Per TS 3.3.2 (ESFAS INSTRUMENTATION) LCO Actions, when the failed channel is removed from service, I&E will place the Containment Pressure **Hi-Hi** Bistable in _____(2)____.

- A. 1. 1/3 2. Trip
- B. 1. 1/3 2. Bypass
- C. 1. 2/3 2. Trip
- D. 1. 2/3 2. Bypass

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 79

(1 point)

Given the following Initial Conditions:

- Unit 1 tripped from 100% RTP following a loss of both Main Feed pumps
- All CA pumps failed to start automatically and cannot be started manually
- The CRS has implemented FR-H.1 (LOSS OF SECONDARY HEAT SINK)
- S/G WR levels are 32% and lowering in all S/Gs

Current Conditions:

- Safety Injection has NOT occurred
- CM flow has been established to the S/Gs
- The crew has just transitioned to ES-0.1 (REACTOR TRIP RESPONSE)
- The BOP reports SI initiation criteria for Pzr level is met per the ES-0.1 foldout page

Based on <u>initial conditions</u>, when attempting to establish feed flow from the CM system, the CRS will direct the crew to depressurize ____(1)____ to 500 PSIG.

Based on <u>current conditions</u>, the CRS _____(2) ____ direct the BOP to initiate SI.

- A. 1. one S/G
 - 2. should NOT
- B. 1. one S/G2. should
- C. 1. two S/Gs 2. should NOT
- D. 1. two S/Gs 2. should

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 80

(1 point)

Given the following on Unit 1:

- Unit is responding to a Pressurized Thermal Shock condition in accordance with FR-P.1 (RESPONSE TO IMMINENT PRESSURIZED THERMAL SHOCK CONDITION)
- NC T-Colds are 170 °F and lowering
- All S/Gs are FAULTED

Per FR-P.1, CA flow will be throttled to _____ GPM to each S/G and the basis for this action _____ to minimize the effects of the RCS cooldown.

- A. 1. 100 2. is
- B. 1. 100 2. is NOT
- C. 1. 25 2. is
- D. 1. 25 2. is NOT

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 81

(1 point)

Given the following conditions on Unit 1:

- Unit is in MODE 6 with core RELOAD in progress
- NC system boron concentration is 2705 PPM
- Boric Acid Tank level is 10%
- The following surveillances are being performed:
 - PT/1/A/4600/100 (SURVEILLANCE REQUIREMENTS FOR SHUTDOWN CONDITIONS)
 - PT/1/A/4600/003 C (WEEKLY SURVEILLANCE ITEMS CHECKLIST)

The surveillance for NC system boron concentration performed during PT/1/A/4600/100 (SR 3.9.1.1) ensures that k_{eff} during MODE 6 remains less than or equal to a MAXIMUM of _____.

Based on the conditions above the MINIMUM required Boric Acid Tank level (2) met.

Which ONE of the following completes the statements above?

REFERENCE PROVIDED

- A. 1. 0.99 2. is
- B. 1. 0.99 2. is NOT
- C. 1. 0.95
 - 2. is
- D. 1. 0.95 2. is NOT

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 82

(1 point)

Given the following on Unit 1:

- Core off-load is in progress
- During removal of a fuel assembly, the fuel hoist is stopped mid travel due to an overload cutoff limit

Fuel hoist travel was stopped due to the fuel hoist load cell sensing a MINIMUM of ______ pounds.

Per AD-NS-1001 (CONDUCT OF REFUELING), any interlock bypass, not approved by procedure, requires approval from the _____.

- A. 1. 29002. Fuel Handling SRO ONLY
- B. 1. 10002. Fuel Handling SRO ONLY
- C. 1. 29002. Fuel Handling SRO AND Control Room SRO
- D. 1. 10002. Fuel Handling SRO AND Control Room SRO

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 83

(1 point)

Given the following:

• Radwaste reports the radioactivity in the "A" WGDT exceeds the SLC limit

Per SLC 16.11.20 (GAS STORAGE TANKS), the required action is to IMMEDIATELY ____(1)___.

Per SLC 16.11.20 Bases, the radioactivity limit is based on exposure received by a (2) during an accidental release.

- A. 1. reduce tank contents within the limits2. plant worker
- B. 1. reduce tank contents within the limits2. member of the public
- C. 1. suspend all additions of radioactive material to the tank2. plant worker
- D. 1. suspend all additions of radioactive material to the tank2. member of the public

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 84

(1 point)

Given the following on Unit 1:

- A small break LOCA has occurred
- Containment pressure peaked at 3.2 PSIG and is currently stable at 1.5 PSIG
- The CRS has implemented E-0 (REACTOR TRIP OR SAFETY INJECTION)

Based on the conditions above, the CRS <u>(1)</u> direct the performance of E-0, Enclosure 4 (VX MANUAL START AND ISOLATING RV COOLING).

The basis for isolating RV cooling in Enclosure 4 is to ____(2) ____.

- A. 1. will NOT
 - 2. gain containment sump level margin and avoid sump dilution during small LOCAs
- B. 1. will NOT2. maintain containment pressure low during the long transient of a LOCA
- C. 1. will
 - 2. gain containment sump level margin and avoid sump dilution during small LOCAs
- D. 1. will2. maintain containment pressure low during the long transient of a LOCA

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 85

(1 point)

Given the following on Unit 2:

- Unit is at 100% RTP
- SPOC has determined that 2KC-56A (KC To A ND HX) will not open due to breaker damage

Based on the failure of 2KC-56A, 2A ND (2) OPERABLE.

If required for core cooling, ES-1.3 (TRANSFER TO COLD LEG RECIRCULATION) will verify a MINIMUM flow of ______ GPM through 2KC-56A.

- A. 1. is 2. 6000
- B. 1. is NOT 2. 6000
- C. 1. is 2. 5000
- D. 1. is NOT 2. 5000

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 86

(1 point)

Given the following on Unit 1:

- The unit is at 100% RTP
- A loss of Battery Charger EVCA has occurred

Following restoration, Battery EVCA conditions are as follows:

- For two connected cells, the Specific Gravity is 1.185
- For all connected cells, the average Specific Gravity is 1.202
- Electrolyte temperature is 76 °F
- 1) Based on the conditions above, TS 3.8.6 (BATTERY CELL PARAMETERS) Condition(s) ______ is/are required to be entered.
- 2) One DC CHANNEL ______ adequate to satisfy the MINIMUM requirements of operability for the DC Distribution System.

Which ONE of the following completes the statements above?

REFERENCE PROVIDED

- A. 1. A ONLY 2. is
- B. 1. A ONLY2. is NOT
- C. 1. A AND B 2. is
- D. 1. A AND B 2. is NOT

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 87

(1 point)

Given the following:

- Unit 1 & 2 are at 100% RTP
- The DEC TOP (Transmission Operations) has notified the Control Room that the "Real Time Contingency Analysis" (RTCA) indicates that switchyard voltage would not be adequate should a Unit Trip occur
- AP-05, (GENERATOR VOLTAGE AND ELECTRIC GRID DISTURBANCES) has been implemented on BOTH units

Per Unit 1 AP-05,

- 1) The CRS ______ be directed to enter Tech. Spec. LCO 3.0.3.
- 2) T.S. 3.8.1 (AC SOURCES-OPERATING) is required to be entered due to BOTH ______ being INOPERABLE.

- A. 1. will2. Emergency D/Gs
- B. 1. will2. Offsite Power Sources
- C. 1. will NOT 2. Emergency D/Gs
- D. 1. will NOT2. Offsite Power Sources

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 88

(1 point)

Given the following on Unit 2:

- The CRS has implemented ECA-1.2 (LOCA OUTSIDE CONTAINMENT)
- U2 FWST level is slowly lowering
- NC system pressure is 1600 PSIG and slowly lowering

Per ECA-1.2, a cooldown and depressurization of the NC System is performed to allow the _____1___.

Per ECA 1.2 basis document, the target temperature selected for the NC system cooldown ensures a ______ event does NOT occur.

- A. 1. Cold Leg Accumulators to inject2. Pressurized Thermal Shock (PTS)
- B. 1. Cold Leg Accumulators to inject2. Core re-criticality
- C. 1. ND isolation valves (2NI-173A and 2NI-178B) to be closed2. Pressurized Thermal Shock (PTS)
- D. 1. ND isolation valves (2NI-173A and 2NI-178B) to be closed2. Core re-criticality

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 89

(1 point)

Given the following on Unit 1:

- A LOCA has occurred
- The CRS has transitioned from ES-1.3 (TRANSFER TO COLD LEG RECIRC) to ECA-1.1 (LOSS OF EMERGENCY COOLANT RECIRC)
- Containment pressure is currently 3.2 PSIG

Per ECA-1.1, while attempting to establish recirculation flow the crew will cool the core by (1).

While performing ECA-1.1, if a RED Path occurs on Core Cooling the crew (2) transition to FR-C.1 (RESPONSE TO INADEQUATE CORE COOLING).

- A. 1. aligning the NC system for Feed and Bleed2. will NOT
- B. 1. aligning the NC system for Feed and Bleed2. will
- C. 1. dumping steam from the intact Steam Generators2. will NOT
- D. 1. dumping steam from the intact Steam Generators2. will

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 90

(1 point)

Given the following on Unit 1:

- A unit startup is in progress
- Reactor power is at 4% RTP and holding
- The crew determines that Control Bank 'D', Rod M-4 is misaligned by greater than 12 steps

Per AP-14 (ROD CONTROL MALFUNCTION), Enclosure 1 (RESPONSE TO DROPPED OR MISALIGNED ROD):

- 1) The crew will use ______ to determine reactor power during implementation of Enclosure 1.
- Based on current plant conditions, the CRS will direct the crew to _____.

- A. 1. Thermal Power Best Estimate2. shutdown to MODE 3
- B. 1. Thermal Power Best Estimate2. maintain power stable until the cause of the misaligned rod is corrected
- C. 1. Excore Nuclear Instruments2. shutdown to MODE 3
- D. 1. Excore Nuclear Instruments2. maintain power stable until the cause of the misaligned rod is corrected

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 91

(1 point)

Given the following on Unit 1:

- Unit is at 100% RTP
- The Upper Airlock Inner door will not close and had been declared INOPERABLE

Based on the conditions above:

Per TS 3.6.2 (CONTAINMENT AIR LOCKS), the Upper Airlock <u>Outer</u> door ______ required to be CLOSED within ONE hour.

Per TS 3.6.1 (CONTAINMENT), containment _____(2) OPERABLE.

- A. 1. is NOT 2. is NOT
- B. 1. is NOT 2. is
- C. 1. is 2. is NOT
- D. 1. is 2. is

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 92

(1 point)

Given the following on Unit 2:

- I Unit is at 100% RTP
- 2EMF-48 (REACTOR COOLANT HI RAD) is in alarm

Subsequently:

- The CRS has implemented AP-18 (HIGH ACTIVITY IN REACTOR COOLANT)
- Chemistry reports Dose Equivalent 1-131 is 75 µCi/gm

Per TS 3.4.16 (RCS SPECIFIC ACIVITY), a Unit shutdown (1) required.

Per TS 3.4.16 Bases, the analysis for the SGTR and ______ accidents establish the acceptance criteria for RCS specific activity.

- A. 1. is 2. LOCA
- B. 1. is NOT2. LOCA
- C. 1. is 2. SLB
- D. 1. is NOT 2. SLB

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

(1 point)

Given the following on Unit 2:

Unit was at 100% RTP when a spurious Safety Injection occurred due to an instrument malfunction

The CRS will direct initiation of the SI termination sequence per ____(1) ___.

SI Termination must be completed within a MAXIMUM of ______ minutes.

Which ONE of the following completes the statements above?

PROCEDURE LEGEND:

E-0 (REACTOR TRIP OR SAFETY INJECTION) ES-1.1 (SAFETY INJECTION TERMINATION)

- A. 1. E-0 2. 10
- B. 1. E-0 2. 15
- C. 1. ES-1.1 2. 10
- D. 1. ES-1.1 2. 15

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 94

(1 point)

Per AD-OP-ALL-1001 (CONDUCT OF ABNORMAL OPERATIONS), regarding variances:

- 1) Prior to taking action, the CRS approving the Variance ______ from a second SRO.
- When invoking a Variance that requires departing from Technical Specifications, the NRC Operations Center must be notified within a MAXIMUM of _____.

- A. 1. must ALWAYS obtain concurrence2. 15 minutes
- B. 1. must ALWAYS obtain concurrence2. 1 HOUR
- C. 1. will obtain concurrence if time allows 1. 1 HOUR
- D. 1. will obtain concurrence if time allows2. 15 minutes

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 95

(1 point)

Given the following on Unit 1:

- Unit is at 100% RTP
- 1EMF-33 (CONDENSER AIR EJECTOR EXHAUST) is in Trip 2 alarm
- 1EMF-71 (S/G A LEAKAGE) is in Trip 2 alarm
- Pressurizer level has been stabilized using AP-10 (NC LEAKAGE WITHIN THE CAPACITY OF BOTH NV PUMPS)
- Letdown flow is 45 GPM
- Charging flow is 78 GPM

The MAXIMUM time that AP-10 allows for the unit to reach MODE 3 for the conditions specified is _____1

Per SLC 16.9.7 (STBY S/D SYSTEM) Condition C (LEAKAGE), the Standby Makeup Pump is _____.

- A. 1. 6 hours2. NON-FUNCTIONAL
- B. 1. 6 hours2. FUNCTIONAL
- C. 1. 3 hours 2. NON-FUNCTIONAL
- D. 1. 3 hours 2. FUNCTIONAL

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 96

(1 point)

Given the following on Unit 1:

- Unit shutdown and cooldown has been performed in preparation for a refueling outage
- Unit is currently in MODE 6
- NC System level is required to be lowered to 70 inches WR Level

Per AD-WC-ALL-0420 (SHUTDOWN RISK MANAGEMENT), this evolution will place the Unit in a ______ Inventory condition.

Per OP/1/A/6100/SO-1 (MAINTAINING NC SYSTEM LEVEL), an SOER 91-01/IPTE briefing ______ required prior to commencing this evolution.

Which ONE of the following completes the statements above?

REFERENCE PROVIDED

- A. 1. Lowered 2. is NOT
- B. 1. Lowered 2. is
- C. 1. Reduced 2. is NOT
- D. 1. Reduced
 - 2. is

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 97

(1 point)

Given the following on Unit 2:

- Unit is at 100% RTP
- 2A Boric Acid Transfer pump has been removed from service for motor replacement
- 2B Boric Acid Transfer pump is protected

Subsequently:

- 2B Boric Acid Transfer pump is secured due to high bearing temperatures
- Maintenance has requested to collect an oil sample from the 2B Boric Acid Transfer pump for troubleshooting

Per AD-OP-ALL-0201 (PROTECTED EQUIPMENT),

- 1) The WCC SRO (1) approve a request for work on protected equipment.
- 2) Prior to approval, a person from <u>(2)</u> is required to conduct a job site inspection to evaluate impact on other protected equipment.

- A. 1. can2. the requesting work group
- B. 1. can2. Operations
- C. 1. can NOT2. the requesting work group
- D. 1. can NOT
 - 2. Operations

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 98

(1 point)

Given the following conditions:

- A General Emergency has been declared
- An AO must be dispatched from the Operations Support Center to an area with an identified radiation field of 110 R/hr in order to isolate the pathway for a large release to the environment
- The operator will be in the area for 15 minutes

Per AD-EP-ALL-0205 (EMERGENCY EXPOSURE CONTROLS),

- 1) the AO selected to perform this isolation <u>(1)</u> required to be a volunteer.
- 2) Performance of this task <u>(2)</u> considered a Planned Special Exposure (PSE).

- A. 1. is
 - 2. is NOT
- B. 1. is 2. is
- C. 1. is NOT 2. is NOT
- D. 1. is NOT 2. is

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 99

(1 point)

Given the following on Unit 1:

- A Loss of Offsite Power occurs following a LOCA
- No ECCS injection flow is available
- FR-C.1 (RESPONSE TO INADEQUATE CORE COOLING) has been entered from E-0 (REACTOR TRIP OR SAFETY INJECTION)
- All S/G N/R levels are < 0% with no feed flow available
- All Pzr PORVs have been OPENED
- "A" train NC vent path was aligned by opening 1NC-272AC and 1NC-273AC (U1 A TRAIN HEAD VENT TO PRT ISOL)
- Core Exit Thermocouple temperatures are 1205°F and RISING

Based on current conditions, the CRS will ______ to further mitigate this event.

- A. Implement FR-H.1 (LOSS OF SECONDARY HEAT SINK)
- B. Implement E-1 (LOSS OF REACTOR OR SECONDARY COOLANT)
- C. Remain in FR-C.1 until Core Exit Thermocouples indicate < 1200 °F
- D. Implement SAMG/SAG-1 (CONTROL ROOM SEVERE ACCIDENT GUIDELINE INITIAL RESPONSE)

MNS ILT 20-1R NRC Written MNS SRO NRC Retake Examination

Question: 100

(1 point)

Given the following:

- The Control Room has been notified by the NRC Headquarters Operations Center that a 747 commercial aircraft has been hijacked
- Ground intelligence indicates a nuclear plant is the intended target
- The airplane's current flight path will intersect with McGuire in 32 minutes

In accordance with AP-47 (SECURITY EVENTS),

- 1) the CRS will transition to _____.
- 2) all non-essential personnel on site will be directed to _____.

Which ONE of the following completes the statements above?

PROCEDURE LEGEND:

Enclosure 2 (AIRCRAFT PROBABLE THREAT) Enclosure 3 (AIRCRAFT INFORMATIONAL THREAT)

- A. 1. Enclosure 32. relocate to the MOC
- B. 1. Enclosure 32. seek shelter in the nearest building
- C. 1. Enclosure 2 2. relocate to the MOC
- D. 1. Enclosure 22. seek shelter in the nearest building

Copy of TS 3.8.6 Generic Enclosure 33 (page 211) OP/1/A/6100/SO-1 page 89 Unit 1 COLR - Borated Water Sources pages 28-30 MNS EP/1/A/5000/G-1 UNIT 1

GENERIC ENCLOSURES

Enclosure 33 - Page 1 of 1 Natural Circulation Parameters PAGE NO. 211 of 211 Rev. 42



McGuire 1 Cycle 27 Core Operating Limits Report

2.15 Borated Water Source – Shutdown (SLC 16.9.14)

2.15.1 Volume and boron concentrations for the Boric Acid Tank (BAT) and the Refueling Water Storage Tank (RWST) during MODE 4 with any RCS cold leg temperature ≤ 300 °F and MODES 5 and 6.

Parameter	<u>Limit</u>
Note: When cycle burnup is > 452 EFPD, Figure determine required BAT minimum level.	6 may be used to
BAT minimum contained borated water volume	10,599 gallons 13.6% Level
BAT minimum boron concentration	7,150 ppm
BAT minimum water volume required to maintain SDM at 7,150 ppm	2,300 gallons
RWST minimum contained borated water volume	47,700 gallons 41 inches
RWST minimum boron concentration	2,675 ppm
RWST minimum water volume required to maintain SDM at 2,675 ppm	8,200 gallons

McGuire 1 Cycle 27 Core Operating Limits Report

2.16 Borated Water Source - Operating (SLC 16.9.11)

2.16.1 Volume and boron concentrations for the Boric Acid Tank (BAT) and the Refueling Water Storage Tank (RWST) during MODES 1, 2, 3, and MODE 4 with all RCS cold leg temperature > 300 °F.*

*Note: The SLC 16.9.11 applicability is down to Mode 4 temperatures of > 300°F. The minimum volumes calculated support cooldown to 200°F to satisfy UFSAR Chapter 9 requirements.

Parameter	<u>Limit</u>				
Note: When cycle burnup is > 452 EFPD, Figure 6 may be used to determine required BAT minimum level.					
BAT minimum contained borated water volume	22,049 gallons 38.0% Level				
BAT minimum boron concentration	7,150 ppm				
BAT minimum water volume required to maintain SDM at 7,150 ppm	13,750 gallons				
RWST minimum contained borated water volume	96,607 gallons 103.6 inches				
RWST minimum boron concentration	2,675 ppm				
RWST maximum boron concentration (TS 3.5.4)	2,875 ppm				
RWST minimum water volume required to	57,107 gallons				

2.17 Standby Shutdown System - (SLC-16.9.7)

maintain SDM at 2,675 ppm

2.17.1 Minimum boron concentration limit for the spent fuel pool required for Standby Makeup Pump Water Supply. Applicable for MODES 1, 2, and 3.

Parameter	<u>Limit</u>
Spent fuel pool minimum boron concentration for TR 16.9.7.2.	2,675 ppm

McGuire 1 Cycle 27 Core Operating Limits Report

Figure 6 Boric Acid Storage Tank Indicated Level Versus RCS Boron Concentration

(Valid When Cycle Burnup is > 452 EFPD)

This figure includes additional volumes listed in SLC 16.9.14 and 16.9.11



3.8 ELECTRICAL POWER SYSTEMS

3.8.6 Battery Cell Parameters

LCO 3.8.6 Battery cell parameters for the channels of DC batteries shall be within the limits of Table 3.8.6-1.

APPLICABILITY: When associated channels of DC sources are required to be OPERABLE.

ACTIONS

CONDITION		REQUIRED ACTION		COMPLETION TIME
А.	One or more batteries with one or more battery cell parameters not within Category A or B limits.	A.1 <u>AND</u>	Verify pilot cells electrolyte level and float voltage meet Table 3.8.6-1 Category C limits.	1 hour
		A.2	Verify battery cell parameters meet Table 3.8.6-1 Category C limits.	24 hours <u>AND</u> Once per 7 days thereafter
		<u>AND</u>		
		A.3	Restore battery cell parameters to Category A and B limits of Table 3.8.6-1.	31 days

(continued)

ACTIONS (continued)

CONDITION		REQUIRED ACTION	COMPLETION TIME	
B.	Required Action and associated Completion Time of Condition A not met.	B.1	Declare associated battery inoperable.	Immediately
	<u>OR</u>			
	One or more batteries with average electrolyte temperature of the representative cells < 60°F.			
	OR			
	One or more batteries with one or more battery cell parameters not within Category C values.			

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.8.6.1	Verify battery cell parameters meet Table 3.8.6-1 Category A limits.	In accordance with the Surveillance Frequency Control Program
		(continued)

SURVEILLANCE REQUIREMENTS (continued)

	FREQUENCY		
SR 3.8.6.2	Verify battery cell parameters meet Table 3.8.6-1 Category B limits.	In accordance with the Surveillance Frequency Control Program	
		AND	
		Once within 7 days after a battery discharge < 110 V	
		AND	
		Once within 7 days after a battery overcharge > 150 V	
SR 3.8.6.3	Verify average electrolyte temperature of representative cells is $\ge 60^{\circ}$ F.	In accordance with the Surveillance Frequency Control Program	
PARAMETER	CATEGORY A: LIMITS FOR EACH DESIGNATED PILOT CELL	CATEGORY B: LIMITS FOR EACH CONNECTED CELL	CATEGORY C: ALLOWABLE LIMITS FOR EACH CONNECTED CELL
------------------------	--	---	--
Electrolyte Level	> Minimum level indication mark, and ≤ ¼ inch above maximum level indication mark(a)	> Minimum level indication mark, and ≤ ¼ inch above maximum level indication mark(a)	Above top of plates, and not overflowing
Float Voltage	≥ 2.13 V	≥ 2.13 V	> 2.07 V
Specific Gravity(b)(c)	≥ 1.200	 ≥ 1.195 <u>AND</u> Average of all connected cells > 1.205 	Not more than 0.020 below average of all connected cells or \geq 1.195 <u>AND</u> Average of all connected cells \geq 1.195

Table 3.8.6-1 (page 1 of 1) Battery Cell Parameters Requirements

- (a) It is acceptable for the electrolyte level to temporarily increase above the specified maximum during equalizing charges provided it is not overflowing.
- (b) Corrected for electrolyte temperature and level. Level correction is not required, however, when battery charging is < 2 amps when on float charge.
- (c) A battery charging current of < 2 amps when on float charge is acceptable for meeting specific gravity limits following a battery recharge, for a maximum of 7 days. When charging current is used to satisfy specific gravity requirements, specific gravity of each connected cell shall be measured prior to expiration of the 7 day allowance.

MAINTAINING NC SYSTEM LEVEL

OP/1/A/6100/SO-1

Rev. 074

Page 89 of 165

ATTACHMENT 3 Page 1 of 3

<< NC Level Instrument Overlap >>

Pzr Cold Cal	NC WR Level	NC NR Level	NC Sightglass	RVLIS ³	Ultrasonics		Physical	
1NCP-5173 (%)	1NCP-5990 ¹ (inches)	1NCP-5991 ¹ (inches)	1NCLG-7940 ¹ (inches)	Upper Range ² (%/inches)	1NCLT8460 1NCLT8470 (inches)	Elevation	Reference	
High Tap 100	% = 801' + 9.75	"						
34.8	400					773' + 7.25"-		
29.6	372.75					771' + 4"	Refueling Canal Water	
20	222.0						Level	
20 15 5	300							
10								
0	219 75					758' + 6 25"	Pzr Level Low Tap	
	195.5			106% / 196.74"		756' + 6"	Top of RVLIS Standpipe ³	
	155		155	97.55%/154.99"			Top of Sightglass	
	100		100				1 3 3	
	84.75		84.75	83% / 83.12"		747' + 4"	Top Rx Vessel Flange	
	60		60	78% / 58.42"		745' + 2.5"		
	28		28	72% / 28.78"		742' + 6.25"	S/G 'B' Spillover	
	25	25	25	71% / 23.84"		742' + 3.25"	Top of NR Transmitter	
	14.5	14.5	14.5	68% / 13.96"	14.5	741' + 4.75"-	Ultrasonics upper range	
	0	0	0	66% / 0.00"	0	740' + 2.25"	(C/L) C Hotleg	
		11	11	64%/ -10.74"	11	739' + 3.5"	Bottom of Sightglass	
		12.5			12.5	739' + 2"	Hotleg tap for UR and LR RVLIS	
		14.5		63% / -15.68"	14.5	738' + 11.75"-	Ultrasonics lower range	
		25				738' + 1.25"	Bottom of NR Transmitter	

Table 1 NC Level Instrument Overlan

Q	A	Q	A	Q	A	Q	A
1	D	26	С	51	D	76	А
2	А	27	С	52	С	77	В
3	В	28	В	53	В	78	D
4	D	29	В	54	С	79	С
5	А	30	А	55	В	80	С
6	А	31	С	56	Α	81	D
7	В	32	D	57	В	82	А
8	В	33	С	58	В	83	D
9	А	34	В	59	Α	84	А
10	С	35	В	60	Α	85	D
11	С	36	С	61	D	86	В
12	А	37	В	62	D	87	В
13	В	38	В	63	Α	88	С
14	D	39	D	64	С	89	D
15	В	40	D	65	С	90	А
16	А	41	В	66	С	91	D
17	С	42	С	67	В	92	С
18	В	43	С	68	В	93	В
19	В	44	С	69	D	94	С
20	С	45	В	70	В	95	С
21	А	46	D	71	С	96	В
22	С	47	А	72	D	97	D
23	С	48	С	73	А	98	А
24	А	49	D	74	А	99	D
25	С	50	С	75	В	100	А

Examination KEY ILT 20-1R NRC Written MNS SRO NRC Retake Exami