Official Transcript of Proceedings NUCLEAR REGULATORY COMMISSION

Title:	Advisory Committee on Reactor Safeguards Future Plant Designs Subcommittee
Docket Number:	(n/a)
Location:	teleconference
Date:	Thursday, February 18, 2021

Work Order No.: NRC-1399

Pages 1-238

NEAL R. GROSS AND CO., INC. Court Reporters and Transcribers 1323 Rhode Island Avenue, N.W. Washington, D.C. 20005 (202) 234-4433

	1
1	
2	
З	
4	DISCLAIMER
5	
6	
7	UNITED STATES NUCLEAR REGULATORY COMMISSION'S
8	ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
9	
10	
11	The contents of this transcript of the
12	proceeding of the United States Nuclear Regulatory
13	Commission Advisory Committee on Reactor Safeguards,
14	as reported herein, is a record of the discussions
15	recorded at the meeting.
16	
17	This transcript has not been reviewed,
18	corrected, and edited, and it may contain
19	inaccuracies.
20	
21	
22	
23	
	NEAL R. GROSS
	COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W.
	(202) 234-4433 WASHINGTON, D.C. 20005-3701 www.nealrgross.com

	1
1	UNITED STATES OF AMERICA
2	NUCLEAR REGULATORY COMMISSION
3	+ + + +
4	ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
5	(ACRS)
6	+ + + + +
7	FUTURE PLANT DESIGNS SUBCOMMITTEE
8	+ + + + +
9	THURSDAY
10	FEBRUARY 18, 2021
11	+ + + + +
12	The Subcommittee met via Video-
13	Teleconference, at 9:30 a.m. EST, Dennis Bley,
14	Chairman, presiding.
15	
16	COMMITTEE MEMBERS:
17	DENNIS BLEY, Member
18	RONALD G. BALLINGER, Member
19	CHARLES H. BROWN, JR. Member
20	VESNA B. DIMITRIJEVIC, Member
21	WALTER L. KIRCHNER, Member
22	JOSE MARCH-LEUBA, Member
23	DAVID A. PETTI, Member
24	JOY L. REMPE, Member
25	

1	ACRS CONSULTANT:
2	MIKE CORRADINI
3	
4	DESIGNATED FEDERAL OFFICIAL:
5	DEREK A. WIDMAYER
6	KENT HOWARD
7	
8	ALSO PRESENT:
9	BOB BEALL, NMSS
10	CYRIL DRAFFIN, Public Participant
11	SCOTT MOORE, Executive Director, ACRS
12	WILLIAM RECKLEY, NRR
13	JOHN SEGALA, NRR
14	MARTIN STUTZKE, NRR
15	NANETTE VALLIERE, NRR
16	
17	*Present via telephone
18	
19	
20	
21	
22	
23	
24	
25	
I	1

2

	3
1	C-O-N-T-E-N-T-S
2	Opening Remarks, Staff Introduction 4
3	Subcommittee Meeting Purpose and Objectives 5
4	10 CFR Part 53 - Subpart C - Design and
5	Analysis Requirements 7
6	Lunch
7	10 CFR Part 53 - Subpart C - Design and
8	Analysis Requirements (cont.) 120
9	10 CFR Part 53 - Subpart D -
10	Siting Requirements
11	Adjourn
12	
13	
14	
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	
25	
ļ	I

	4
1	P-R-O-C-E-E-D-I-N-G-S
2	(9:30 a.m.)
3	CHAIRMAN BLEY: Good morning, the meeting
4	will come to order. This is a meeting of the Advisory
5	Committee on Reactor Safeguards, Subcommittee for
6	Future Plant Designs.
7	I am Dennis Bley, Chairman of the
8	subcommittee. And ACRS Members in attendance, I'm
9	going to track them all down, Derek, maybe you can
10	help me as I go through it?
11	Joy Rempe, Ron Ballinger, Charlie Brown,
12	Walt Kirchner, Dave Petti, Vesna Dimitrijevic, Jose
13	March-Leuba, and our consultant Mike Corradini, I
14	think is with us, but I haven't seen him on there
15	among us.
16	Two of our members were not able to get
17	here, one because of all the miserable weather in
18	Texas. Derek Widmayer of the NRC staff is the
19	designated federal official to this meeting. And Kent
20	Howard of the ACRS staff is the backup designated
21	federal official. Charlie Brown is my backup in case
22	I get knocked off, and will take over chairing until
23	I can get back.
24	The purpose of today's meeting is to
25	discuss the primary rule language for 10 CFR Part 53
ļ	

(202) 234-4433

Licensing and Regulation of Advanced Nuclear Reactors, Subpart C, Design and Analysis Requirements and Subpart D, Siting Requirements. The subcommittee will gather information as well as relevant issues and facts and formulate proposed positions and actions as appropriate.

7 The subcommittee meeting is the second of 8 several scheduled to discuss preliminary proposed rule 9 language for Part 53. The current plan is for all 10 these subcommittee meetings to be held before any 11 proposed rule language is presented to the ACRS full 12 committee.

However, at the subcommittee's discretion any matters can be considered for presentation to the full committee. The ACRS was established by statute and is governed by the Federal Advisory Committee Act, FACA. However, a committee can only speak through its published letter reports.

19 hold these meetings We to qather information and perform preparatory work that will 20 support our deliberations, our deliberations at a full 21 committee meeting. The rules for participation in all 22 including today's, were 23 ACRS meetings already 24 announced in the Federal Register on June 13th, 2019. The ACRS section of the U.S. NRC public 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

6 website provides our charter, bylaws, agendas, letter reports and transcripts of all full and subcommittee meetings, including slides presented there. The meeting notice and agenda for this meeting were also posted there.

As stated in the Federal Register Notice, and in the public meeting notice posted to the website, members of the public that desire to provide written or oral input to the subcommittee may do so. You should contact the designated federal official, five days prior to the meeting when it's practicable.

Today's meeting is public 12 open to attendance, and we have received no written statements 13 14 or requests to make an oral statement. We have also 15 set aside ten minutes in the agenda for spontaneous comments from members of the public who are attending 16 17 or listening to our meetings.

Due to the COVID pandemic, today's meeting 18 19 is being held over Microsoft TEAMS for ACRS and NRC staff attendees. There is also a telephone bridge 20 line allowing participation of public over the phone. 21 A transcript of today's meeting is being 22 kept. We therefore request that meeting participants 23 24 on the bridge line, identify themselves when they ask to speak and to speak with sufficient clarity and 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

	7
1	volume so they can be readily heard.
2	At this time, I ask that attendees on
3	TEAMS and on the bridge line, keep their devices on
4	mute to minimize disruptions and any online
5	discussion.
6	We will now proceed with the meeting and
7	I'll call on John Segala, Chief of the Advanced
8	Reactor Policy Branch of NRR to make introductory
9	remarks. John, please go ahead.
10	MS. SEGALA: Thank you and good morning.
11	Consistent with the Nuclear Energy Innovation and
12	Modernization Act, we are developing 10 CFR Part 53 a
13	new alternative regulatory framework for Advanced
14	Reactors that embraces risk-informed approaches and
15	performance-based criteria that will be technology
16	inclusive to a wide range of new technologies.
17	In order to meet the Commissions directed,
18	schedule to publish the final Part 53 rule by October
19	of 2024, we are having extensive stakeholder
20	engagement to solicit feedback to better inform the
21	staff's proposals. And to ensure a shared
22	understanding of what will be included in the final
23	rule.
24	We are here today, in the second of many
25	ACRS meetings we will be having this year, to seek

(202) 234-4433

	8
1	ACRS feedback on NRC's development of Part 53
2	preliminary proposed rule language for Advanced
3	Reactors. We previously briefed the ACRS Subcommittee
4	meet in January on the first set of preliminary rule
5	language, Subparts B and F.
6	Today we will be seeking ACRS feedback on
7	the second set of preliminary rule language in Subpart
8	C, Design and Analysis Requirements. And Subpart D,
9	Siting Requirements. Since November, we have held
10	three public meetings with stakeholders and have
11	received a wide range of feedback, which the NRC staff
12	is still assessing. We plan to share some of the
13	stakeholder feedback with the ACRS today.
14	We are looking forward to hearing from the
15	ACRS today on this second set of preliminary rule
16	language for Part 53 and any insights and feedback
17	that you all may have. This completes my opening
18	remarks. Thanks.
19	CHAIRMAN BLEY: Thank you, John.
20	MR. CORRADINI: Hi, John, just can I ask
21	quick question?
22	CHAIRMAN BLEY: Sure, go ahead, Mike.
23	MR. CORRADINI: John, the industry
24	feedback seems to be, a quick read of it, seems to be
25	I'm trying to find a good word, but I'll just say,
Į	I

(202) 234-4433

	9
1	all over the map and not as positive as I suspect
2	you'd want from a brand new rule for Part 53.
3	What is the plan for the staff? Are you
4	going to answer the comments one by one? Or are you
5	going to kind of give some sort of discussion on broad
6	aspects of industry feedback?
7	MS. SEGALA: Well I think, you know,
8	because Part 53 is, you know, technology inclusive,
9	you know, we do have a broad range of stakeholders
10	that are interested in this new regulation. So, it's
11	not surprising that we're receiving, you know, a
12	spectrum of comments and feedback on the proposed
13	rule.
14	But what we've been doing is as we have
15	been engaging with stakeholders on a particular
16	subpart, we're trying to make sure that we hear from
17	all stakeholders on a particular subpart. And then
18	start looking at those, the feedback that we got and
19	propose changes to those subparts and then discuss
20	those at future stakeholder meetings to get feedback
21	on where we're going.
22	So I think that's the general approach
23	we're taking. I don't know if, Bob Beall or Bill
24	Reckley, or Nan Valliere want to add anything to that?
25	CHAIRMAN BLEY: Okay, well thank you,
l	I

(202) 234-4433

10
John.
MEMBER BALLINGER: This is Ron Ballinger.
CHAIRMAN BLEY: Go ahead, Ron.
MEMBER BALLINGER: You know, I went
through and I've tried to more or less correlate the
comments in the NEI letter with the slides that you're
going to present today. And apart from not calling it
NEI comments, stakeholder comment, a lot of the
stakeholder comments that are in your slides seem to
be relevant or correlated with the NEI letter. So I'm
kind of looking forward to that discussion.
CHAIRMAN BLEY: Okay, thank you, Ron.
Before we go ahead, I had something too that I need to
bring up. In our last meeting, at least on my part
and I think some of the other members, there was a lot
of confusion about the two tiers that were introduced
in Part B.
And we kind of I know Bill told us they
were going to go back and think about that and get
back to us. And I've done some of that as well. And
I've talked to some of the lawyers who interceded and
were involved back when this concept first developed,
before it was used in the design certification
process, which is a little different.

At least my impression is that it was kind

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

	11
1	of needed under Part 50, and similarly under 52 it
2	would have been needed. When your regulation is
3	essentially rule-based, to be able to separate the
4	essential rules from the important but not quite as
5	essential rules.
6	It seems to me that Part 53 is moving
7	toward a risk-informed structure, and that those
8	concepts not only aren't needed, but don't quite make
9	sense, at least to me. So, if you'll keep that in
10	mind as you go ahead. And I hope you'll talk some
11	about this. So whoever is up, please go ahead.
12	MR. RECKLEY: Thank you, Dennis. This is
13	Bill Reckley, and we have a slide and I'll try to talk
14	to that point.
15	If we could go to Slide 2, the agenda. As
16	was just talked about, our primary desire today is to
17	talk about Subpart C, the Design and Analysis subpart.
18	And then this afternoon we get into Subpart D on the
19	Siting Requirements.
20	But before we get into those discussions,
21	we do have a bit of a summary of our past discussions
22	on Subpart B, which lays out the safety criteria. And
23	also the whole structure, and this will go to some
24	degree to Dennis's last point.
25	So, if we could just go ahead and go to
ļ	

(202) 234-4433

	12
1	Slide 3, this is
2	MEMBER REMPE: Bill, this is Joy. I know
3	we mentioned this a long time ago, maybe before we
4	even had the meeting in January, the prior year or so.
5	But when you came to us and talked to us about the,
6	what your intent was. And one of the members, and
7	maybe it was Dennis asked, how do interact with the
8	folks that are doing the ongoing Part 50.52, alignment
9	and lessons learned rulemaking?
10	How do you, is there still interaction
11	with the group doing that? And how much are you guys
12	learning from each other? Could you mention that,
13	upfront here?
14	MEMBER REMPE: Hi, Joy. This is Bob Beall
15	in the rulemaking branch. Yes, I interact with my
16	counterpart, Jim O'Connell. He's, we're making PM for
17	the 50.52 lessons learned rulemaking.
18	And so Jim and I share a lot of
19	information and conversations, and about what he's
20	doing and what we're doing. So that we don't have any
21	I understand what he's trying to do. And if
22	there's anything I need to incorporate in Part 53 and
23	bring back to the Working Group.
24	And so we do have those interaction. And
25	like an example, we had some of the basically the
	I

(202) 234-4433

	13
1	questions you just asked, Jim shared that with me
2	earlier this week and I shared that with the Working
3	Group.
4	So that's an example how we're interacting
5	and ensuring that we're in some type of lockstep so
6	that we understand what each of the two different
7	rulemakings are doing.
8	MEMBER REMPE: Great, thank you.
9	MR. RECKLEY: Okay, I would just weigh in,
10	and Nan is following it at NRR as well, but so we're
11	trying to fully, as Bob said, stay aware of what each
12	other is doing. We're a little freer, since we're
13	building the rule from scratch, if you will.
14	And so, but I won't say we'll be totally
15	consistent with where they come out, but we're
16	coordinating the activities. But each activity has
17	different constraints, if you will, so.
18	MEMBER REMPE: So, that's an interesting
19	response back. But we're starting to get ready to
20	prepare for a meeting on this Part 50.52 thing. And
21	when I think about what I've seen there, versus here,
22	if I were to draw a diagram that shows the various
23	steps that the applicant had to follow and what the
24	inputs are like the SDA, or multiple SDAs, or do
25	they have to have a PRA, et cetera?
	I

(202) 234-4433

	14
1	And when do you have public interactions,
2	the review? Would the steps and the inputs, and the
3	outputs still be the same even though you might get
4	licensing-basis events differently?
5	Those kind of issues are something that
6	I'm just kind of wondering about.
7	MR. RECKLEY: They would probably be very
8	similar. And we get, we'll get to that. Keep in
9	mind, Part 52 is a licensing process rule. The
10	technical requirements and a different licensing
11	process is in 50. We plan, and I'll get into this in
12	a second. We plan in Subpart H to support either of
13	those approaches.
14	And so there, the similarities might be
15	more clear because those processes are laid out in
16	legislation, and in existing infrastructure for
17	licensing in 52 and 50, and the related requirements
18	in Part 2 and other places.
19	And so there, there probably will be a lot
20	of similarity and Nan, did you want to weigh in since
21	this is getting into the licensing arena primarily?
22	MS. VALLIERE: Yes, I think you're going
23	to see a lot of similarity, a high degree of
24	consistency in the licensing process area. So, as
25	Bill said, I don't expect that, you know, they're
I	I

(202) 234-4433

Í	15
1	going to take a lot of divergence from the existing
2	processes in that respect.
3	MEMBER REMPE: So, when we get to
4	discussing that part, or if we ever discuss that part,
5	I would really like to understand what not only the
6	similarities are, but where are the differences?
7	MS. VALLIERE: Okay, thank you.
8	MR. RECKLEY: We'll get to that in
9	probably, May or June, so.
10	MEMBER REMPE: Looking forward to it.
11	MR. RECKLEY: So this is the graphic
12	reviews really from the start of this activity ever
13	since, as John mentioned, NEIMA directed us to do this
14	rulemaking. We started giving thought to what it
15	might look like, and really I've been using this same
16	basic slide since then, well over a year ago.
17	And we'll go through a little more detail,
18	than we went through in a public meeting a couple
19	weeks ago that some thought was more helpful than this
20	slide. But just at the highest level, Subpart B that
21	we talked about with this Subcommittee back in
22	January, is intended to layout the basic criteria, the
23	objectives of the overall rule.
24	And then the subparts follow an approach
25	that reflects the life-cycle of the facility and how
	1

(202) 234-4433

those different aspects of the life-cycle need to address or support meeting the safety functions that 2 3 are defined in Subpart B. And so Design and Analysis, that we'll be talking about today, as well as Siting we'll talk about this afternoon.

Then Subpart E would be Construction. 6 7 We're getting ready to release the preliminary 8 language on construction to support a public meeting 9 coming up in a couple weeks. And then Subpart F on Operations, and Subpart G on Decommissioning. 10 And then as we just mentioned, the licensing aspects will 11 be getting dedicated subparts. 12 We currently as a preliminary outline, have them in H and I. 13

14 And I want to talk each about, each of 15 those subparts in a little more detail. Kind of in a "Table of Contents" format, so we can maybe discuss 16 17 them a little more than we have in the past.

So, if we go to the next slide, Slide 4 18 19 this goes to kind of the process that we were kind of And how we would do interactions with 20 laying out. ACRS. We have a similar slide for interactions with 21 public stakeholders and internal communications and 22 23 interactions.

24 And it basically just lays out a staircase if you will, starting with the framework, overall 25

> **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

4

5

17 framework, the safety criteria in Subpart B, and then 1 2 the rest of the subparts. 3 I look at this however, it's kind of like 4 writing a novel, in that we're constantly iterating, 5 or we expect to be constantly iterating as we go forward. So, given this schedule on the interactions 6 7 issue, as you might imagine, we're currently writing 8 Subpart F on Operations. We're still talking with stakeholders 9 10 about Subpart B, and to some degree even the overall framework. Talking to you today about Design and 11 Siting, and so our plan is to constantly support this 12 communications and interactions and iterate. 13 14 So, one of the comments and criticisms was 15 we haven't put out an iteration on Subpart B and C. 16 That is in part, from our perspective, just because we different 17 have these interactions with public stakeholders, ACRS, and internal 18 our own 19 communications that we have to try coordinate. So, we have or are preparing a, you know, 20 the next iteration even on Subparts B. 21 And then today's meeting will help us in terms of an iteration 22 on C and D that might come a month or two from now. 23 24 So --Bill, Bill --25 CHAIRMAN BLEY:

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	18
1	MR. RECKLEY: Yes, Dennis.
2	CHAIRMAN BLEY: This is Dennis. I know
3	you're going to get to it and I knew you're eagerly
4	awaiting it, but it seems to me Subpart B frankly,
5	meeting in today's staff there was questions we had on
6	Subpart B, so are causing me trouble.
7	So, it seems to me that's a really
8	important rule to get smoothed out as soon as
9	possible, because it effects everything else. Go
10	ahead.
11	MR. RECKLEY: We fully agree with that,
12	Dennis.
13	MR. CORRADINI: So Bill, this Corradini.
14	So to follow Dennis's question. So you're going to
15	return to B very shortly. Is that the plan? Because
16	I'm in the same boat as Dennis, I'm still confused
17	about that. And that leads me then to look at
18	everything else expecting a change in the future.
19	MR. RECKLEY: Yes, we'll get to a summary
20	or a review of Subpart B, where we are. And you all
21	are right, if we make major changes to Subpart B, then
22	what we're presenting to you today would have to be
23	adjusted likewise in a major way. And we're cognizant
24	of that.
25	MR. CORRADINI: So Bill, can I ask a
Į	I

(202) 234-4433

	19
1	question, a general question? And then you can stick
2	it away or choose to ignore it. As these reactors
3	become, I'll use the word, simpler, or less complex,
4	is the licensing approach of 53 able to handle that?
5	Or is this one size fits all?
6	In other words if I go from a 3000
7	megawatt thermal machine to a 10 megawatt thermal
8	machine, I wouldn't expect Part 53 would require the
9	same complexity of information that the staff would
10	need. Am I off base, or and I'm struggling to see
11	what so far I've read, how that's accommodated?
12	MR. RECKLEY: And that will be a
13	challenge. And when we get to feedback you can see
14	that's some of the feedback we're getting. And if I
15	can just hold until we talk about that feedback. But
16	
17	MR. CORRADINI: Okay, I'm sorry. I don't
18	want to
19	(Simultaneous speaking.)
20	MR. RECKLEY: Yes, but only at a high
21	level let me take a shot at it now. Our thinking is
22	that this rule will accommodate the whole range. And
23	that inherent in the processes that we were calling
24	out, there's the ability to grade those requirements
25	to accommodate that wider, that whole range or
ļ	I

(202) 234-4433

	20
1	spectrum of reactor designs.
2	And our current thinking as we're laying
3	it out to you here, is that we don't have to have
4	different high level requirements. The grading
5	happens within each element. So, if you have a simple
6	design, the analysis that's required, and we'll talk
7	about it later since today's discussion is on design
8	and analysis, the design and analysis activities
9	should be easier because your machine is simpler.
10	MR. CORRADINI: Okay. I see where you're
11	going.
12	MR. RECKLEY: But we currently, but that's
13	the challenge. And some people said we missed the
14	mark on this. That, and they think the rule has to
15	specifically accommodate a difference. Saying this
16	machine is simpler, therefore a different set of rules
17	apply. We're considering that. That's the feedback
18	that we've gotten.
19	But as we've laid it out here, we say do
20	an analysis, and the assumption was the analysis could
21	be graded based, or almost by its nature be simpler,
22	if the machine itself was simpler, so. But we'll get
23	into that discussion when we get into the actual
24	Subpart C.
25	MR. CORRADINI: So let me end by an
ļ	I

(202) 234-4433

(202) 234-4433

	21
1	interesting way in which you've said it. The way you
2	said it, maybe I misinterpreted is that you would
3	start with a design and the analysis that's required
4	of it. And as the design becomes simpler, the
5	analysis could be simpler.
6	It would seem to me, the case I would
7	make, if I were a developer, if I really have an
8	advanced reactor of any size, I would try to do the
9	simplest analysis possible at the beginning and only
10	get complicated if I don't satisfy the margins I need
11	to guarantee safety.
12	So simple is the way I'd start it off
13	regardless of size. And I'm trying to struggle to see
14	at least in the language that we've seen so far, how
15	things are simpler here and more easy to at least
16	accommodate?
17	CHAIRMAN BLEY: Bill, I want to jump in,
18	this is Dennis and I do want to give you a chance to
19	go ahead and then we'll see how it progresses. But at
20	least the flavor that I got from the last meeting,
21	wasn't usually this ability to have gradations of what
22	you do depending on characteristics of the design.
23	Would it be addressed in guidance
24	documents, is that still the intent rather than the
25	rule itself? Let's say, you have to look at whatever
Į	I

(202) 234-4433

1 reactivity you're on, and the quidance will tell you how much you have to do depending on characteristics 2 3 of your design. Go ahead, and I'll be quiet a while. 4 MR. RECKLEY: That's a good point. And 5 yes, Dennis by and large we think how that gradation would work and how a simple design might differ from 6 7 a more complicated machine would be reflected in the 8 quidance. 9 MEMBER REMPE: So before you go on, I know 10 we're taking too many comments now, but I, this is why I keep harping on the alignment, the 50.52 topic. 11 Because I think the guidance, for example, what's 12 required in a PRA could really help both your effort 13 14 as well as their effort. For this guidance is going 15 to be a very important feature. And the sooner it's 16 done, maybe it will dissolve some of the comments 17 we're seeing? MR. RECKLEY: We hope that's the case. 18 19 And in our March meeting, public meeting, Guidance Development is going to be one of the topics to see. 20 The staff has a number of things under way. And the 21 industry also has a number of things underway. 22 And just to coordinate who's developing 23 24 what quidance? What quidance might be the most important to support the rulemaking activity and so 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

22

	23
1	forth? So, all of that, it's a good point and we
2	realize it.
3	And that's one of the things we'll be
4	talking to the industry about, is what may, what might
5	they start to develop guidance for our review and
6	endorsement. And what guidance will the staff be
7	developing basically on its own?
8	CHAIRMAN BLEY: Bill, I lied, I'm going to
9	jump in one last time. Where on this schedule, do you
10	have a column here for interaction with the
11	stakeholders or with the ACRS on initial guidance?
12	And I think getting some preliminary idea
13	of the structure of what these folks will believe or
14	think about for guidance, and what kind of schedule
15	that would be, would literally help alleviate some of
16	the questions we're asking, if we know where it's
17	going to fit.
18	So, don't respond to that now, but I hope
19	you can during the talks today.
20	MR. RECKLEY: Okay. All right. So again,
21	this kind of lays out where we think we will be in
22	needing to interact with the ACRS on the various
23	topics basically throughout the rest of this year,
24	into early next year.
25	And the schedule aspect of this is driven
I	1

(202) 234-4433

1 as John mentioned, in the direction that was given to 2 the staff by the Commission in the staff requirements 3 memorandum for our rulemaking plan. So, I think we 4 can go then to next slide.

And I've used this slide a number of times 5 too and it goes -- I like to come back to it because 6 7 it basically reflects all the discussions we've had up to this point even, and will continue to have. 8 In 9 founding things or that one of the the first 10 principles that we come back to is to try in a technology inclusive manner, address what it is we're 11 trying to do. 12

this 13 And by and large, is а 14 simplification, but what we're trying to do is make 15 sure that there's enough barriers in place such that 16 the inventory of radionuclides that will be generated 17 from a nuclear reactor, that's the one thing they all have in common, is that the process itself is making 18 19 the radioactive materials and creating the hazard that we as the NRC, have as our mission to try to make sure 20 is controlled before it reaches the public through 21 this simple diagram, the atmospheric dispersion arrow. 22 And that is accomplished by looking at 23 24 that inventory, and then again, the barriers that are in place to retain it, or attenuate any releases, and 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	25
1	how they behave in normal operations. And how they
2	will behave when challenged by transients or
3	accidents.
4	And so, somewhat to Mike's point, if you
5	can develop a machine that this equation is largely
6	based on the DOE principles for non-reactor
7	facilities. And in that model, the inventory is
8	called material at risk, and the first factor is
9	called damage ratio.
10	If I can have a reactor such that the
11	material at risk and the damage ratio is close to
12	zero, meaning I don't have a way to get the
13	radioactive materials even out of the fuel, then
14	that's a simple design.
15	And should be, we should be able in the
16	probabilistic risk analysis, the deterministic
17	analysis, all of those analyses should be able to say,
18	hey, in this particular design, I've achieved really
19	the ultimate goal, which is the radionuclides never
20	get out of the first floor. They stay in the fuel
21	room most cases here, that we'll be talking about. So
22	
23	MEMBER BROWN: Bill, isn't that kind of
24	pie in the this is Charlie. That kind of pie in
25	the sky?
I	I

(202) 234-4433

	26
1	MR. RECKLEY: Um.
2	MEMBER BROWN: The idea that somebody
3	MR. RECKLEY: That's a
4	MEMBER BROWN: I mean
5	MR. RECKLEY: Yes, that would give them a
6	little challenge. I'll leave it at, it would be a
7	real challenge.
8	CHAIRMAN BLEY: Bill, you've used this
9	slide. I think it's a wonderful slide to make your
10	point, but research reactors are essentially this.
11	They're sited within cities, and they're essentially
12	damaged, I can't remember the DNA terms but the real,
13	the potential releases is minimal.
14	MR. RECKLEY: And we've, I mean we've
15	looked at that. And to the degree the inventories are
16	similar and you have things like the TRIGA fuel that
17	can minimize any releases and address potential
18	accidents to limit thing like temperatures that might
19	relate to a release.
20	We're looking at that to see if we can
21	control. But when you know, there are a number of
22	things that are different. Most research reactors,
23	even if they're of a similar size as some of the
24	micro-reactors under discussion, end up with lesser
25	inventories for example.
I	I

(202) 234-4433

	27
1	Because they're intermittent operation
2	versus what would be basically continuous operation
3	over the life of a facility, be it 10 or 20 years.
4	And so
5	MEMBER BROWN: But they're also much less
6	power.
7	MR. RECKLEY: In general
8	MEMBER BROWN: We're talking about power
9	reactors that are going to generate electricity for a
10	huge, large populations.
11	MR. RECKLEY: But yes, and but the
12	discussion typically has been on the micro-reactor
13	side, so even if it's on the megawatt, single megawatt
14	size, the inventory will be bigger for a power
15	production facility, than a research facility.
16	MEMBER BROWN: Most.
17	MR. RECKLEY: In most cases.
18	So, we are looking at all of that. And
19	again, we would be open to an argument that says if,
20	again back to if the damage ratio is very, very small,
21	then that is a great thing. We wouldn't want to
22	discourage it. And we'll take that into account in
23	assessing how many other barriers you need. So
24	CHAIRMAN BLEY: Bill.
25	MR. RECKLEY: but, so let me take it,
	I

(202) 234-4433

	28
1	Dennis, or?
2	CHAIRMAN BLEY: Yes. Two things I wanted
3	to jump in with. One is it seems a reasonable idea
4	to, however damage ratio, there's a lot hidden in
5	there, and maybe a whole PRA is one way of thinking.
6	How do you get the damage ratio for all possible
7	scenarios?
8	But for the smaller reactors, the things
9	that approach experiments, this was brought up to me
10	yesterday by a few people. And we just had an
11	incident at the NIST reactor. We're going to try to
12	get a look at that. Are you guys thinking you can
13	learn anything from that that might be useful to you
14	here?
15	MR. RECKLEY: Yes, I'm sure we will. And
16	actually that's being, you know, our division actually
17	has the responsibility for the oversight of NIST.
18	There's a team there now, so yes, we'll be looking at
19	that.
20	MEMBER BALLINGER: This is Ron. I'm just
21	struggling to try to find where damage ratio is
22	defined in a document? I'm sure it is, but can you
23	tell me?
24	MR. RECKLEY: Let me get back to you on
25	what DOE letter that is. Offhand I forget the number.
I	I

(202) 234-4433

MEMBER PETTI: Hey, Bill. I just want to support your thinking. I'm involved in a microreactor project. And I don't think it's pie in the sky to think for some of these technologies, if we know about them in the end, what's called power reactor embodiment. So take an HGTR something I know about,

and make it a micro-reactor. In fact the safety issues just become much, much less because of some simple considerations like surface dividing ratio of a small micro-reactor compared to an MHTGR.

I think the same is probably true of an SFR, if you were to, you know, shrink them down. So, I think your thinking is right. And a lot of these technologies will, a lot of our experience might be on the larger size, but when you make them smaller, you do get some safety benefits.

And that should all come through, you know, in terms of the analysis that you do. But I think fundamentally that's not a bad way to think about it.

22 MR. RECKLEY: Thank you. And I guess to 23 a couple points that's been made in that particular 24 example even. We also don't want to mislead people on 25 how much might have to go into determining that first

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

8

9

10

11

factor, right.

1

2 And then obviously, the work on TRISO fuel 3 would support what Dave was just suggesting. But 4 that's been extensive to actually provide the 5 confidence that the -- and again I didn't want to really introduce it into the reactor realm, but if 6 7 we're going to use the damage ratio term, the damage ratio for TRISO fuel is supported by a decades-long 8 9 research activity that actually supports that 10 discussion.

So, even if you can break it down simply, and say, yes, we're going to be able to give a lot of credit to the first barrier. But I don't want to mislead people, that that makes it easy. Because providing the confidence in the first layer will likely require proving the performance of that first layer by a lot of experiments and analysis.

So, I mean we're trying to find the balance here and I think you guys can appreciate the challenge. And to Dennis's point, that if you're going to be relying on the first layer more than we have traditionally, you do have to then look at all the events that we're challenging.

24 What temperatures it's going to reach. 25 What other challenges it may have? And that gets into

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	31
1	having to define as we'll talk about in the next few
2	slides, the licensing-basis events and the range of
3	challenges. And do you do that through a PRA, or is
4	there a simpler way? That's where we are on the
5	discussions with the stakeholders.
6	So, I think the point I was trying to make
7	on this slide has been made, hopefully. We can go
8	onto the next slide which shows another challenge that
9	we're trying to accommodate, and it's again another
10	slide I've used many times.
11	The other thing we're trying to do in Part
12	53 is to integrate the whole regulatory scheme. And
13	so in looking at Part 53 and where we want to end up,
14	we'll be facing challenges such as how does the rule
15	accommodate alternatives on the mitigation side of
16	this bow-tie diagram?
17	We know that a desire of generation four
18	technology plants, from the beginning, has been to
19	reduce reliance on things like emergency planning. We
20	have a proposed rule under way that gives some
21	alternative approaches to determining emergency
22	planning zone versus using the default, ten miles.
23	We have continued that discussion, that
24	seems to be a continuing desire to get relief in areas
25	such as emergency planning and siting. You need to be
ļ	I

(202) 234-4433

32 cognizant of that as you're looking at the actual 1 behavior of a plant, and the analysis and the design 2 3 activities you're going to require. 4 Because you're building into this, the 5 possibility that you may not rely on things like siting and emergency planning to provide additional 6 7 layers of defense-in-depth as we've traditionally 8 done. So, that puts more onus on the design and 9 analysis, to support those possible approaches. 10 One of the challenges is we're trying to leave it open such that we're not -- that if any 11 design or designer, or licensee, applicant were to 12 choose to take credit for emergency planning, that 13 14 that remains open to them. It would have made our life simpler if we 15 16 try to write this rule such that it was not needed. 17 But a challenge again that we're facing is we're trying to leave it open for future designers, future 18 19 applicants to decide the balance between prevention and mitigation. 20 And so that is another area when we get 21 into Subpart C that we have a specific requirement and 22 it'll be a point of discussion I can imagine. 23 24 MEMBER PETTI: So Bill, Bill, just a question on that prevention, mitigation and defense-25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

in-depth. I'm sure it's not something you put in the rule, but in the guidance the balance between those could depend a lot on the safety features and the technology and the size of the machine.

5 So, Ι could imagine that how one implements defense-in-depth at a micro-reactor might 6 7 be very different than this same technology at a power 8 plant scale. Are those things that you guys are 9 thinking about, how you incorporate the inherent safety characteristics of some of these technologies 10 and what that means in terms of the, let's call them 11 the "overarching safety philosophies" that the Agency 12 has always used, and how it might change? 13

14 MR. RECKLEY: Well, they're trying to, 15 And again, even on inherent, I have a slide yes. later and it's a question we've posed. We have some 16 17 notions but any thoughts when we get to the slide, where we basically are asking a question, not posing 18 19 a position on whether additional quidance or even language might be appropriate to 20 newer address inherent features. So, when we get to that slide a 21 little later, please. 22 MEMBER PETTI: 23 Okay.

24 MR. RECKLEY: If you have a thought. 25 So, this basically then is a challenge to

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

(202) 234-4433

33

	34
1	us but we're trying to keep in mind the overall
2	structure. And what we might be getting in terms of
3	future requests.
4	So, if we go down to Slide 7, what I
5	thought I would do just to quickly provide a little
6	more detail than that structure figure that we've
7	used. Is to go through the subparts kind of in a
8	"Table of Contents" format. And we can discuss a
9	little more detail, some of them.
10	Subpart A is General Provisions, and I
11	wasn't planning to talk very much about this, but we
12	need to have a place in Part 53 where we provide the
13	normal things that you would see in 50 or 52 in
14	regards to how to communicate with us, and
15	definitions, and employee protection, and so forth.
16	So, this list of bullets is largely the
17	items out of Part 50 and 52. And the talk about those
18	kind of high level provisions and requirements,
19	responsibilities of licensees and so forth. So
20	CHAIRMAN BLEY: Bill.
21	MR. RECKLEY: Yes.
22	CHAIRMAN BLEY: Yeah, I'm glad you're
23	going this. I've gotten comments from a lot of
24	members. So, to my favorite thing in regulations,
25	where does it fit in the structure? It sounds like
	I

(202) 234-4433

	35
1	you're kind of doing that, and I think that will help
2	a lot for all of us. Go ahead.
3	MR. RECKLEY: Okay, thank you. And no
4	apologize, we've had this, we just didn't present it.
5	Sometimes you over think how much or how well you're
6	communicating for example, just on that one figure.
7	So, then we can go to Subpart B.
8	MEMBER KIRCHNER: Bill, before you go on,
9	this is Walt Kirchner. On the definitions, have you
10	tried to, we had a conversation earlier this morning
11	on reconciling with 50 and 52, our consistency and
12	such. One of the most important definitions in 50.52
13	is safety related.
14	Have you come to some, do you have some
15	thinking on how you might define that for 10 CFR 53,
16	whether it's taking the formulation that is somewhat
17	Light-water reactor specific and make it a more
18	generic definition that would apply?
19	MR. RECKLEY: Yes, we are proposing a
20	definition in Subpart C, that we'll get to in a little
21	bit. And it's a little different and one of the
22	things that we're trying to come to grips with is,
23	when we have the same term and it's defined in 50 and
24	52, whether we change terms, whether we use a
25	different definition.
ļ	I

(202) 234-4433

	36
1	In terms of safety related and again we'll
2	get to it in a little bit, but I don't think our
3	concept fundamentally is different. And we might try
4	to argue that ours is a more global definition in Part
5	53, and if you were to apply it to a Light-water
6	reactor you'd end up with the definition that's in
7	Part 50 and 52, but that will be a bit of a challenge,
8	but we
9	MEMBER KIRCHNER: Okay, I'll look forward
10	to that because I've been thinking pretty hard on that
11	particular item.
12	MR. RECKLEY: And that will be again, one
13	of the, we have a running we're, the colliding
14	terms that we'll need to define. And there are some
15	terms that, and we pointed this out in, when we were
16	working on the Licensing Modernization Project NEI
17	18-04, they had similar or the same terms with
18	different definitions. So that will be a continuing
19	issue.
20	CHAIRMAN BLEY: Bill and Ron, your mics
21	are open. You going ahead oh, go ahead Ron.
22	MEMBER BALLINGER: And that's, it's open
23	because I want to speak, and I have a cat. The term
24	damage ratio was defined in a DOE handbook in 1994,
25	related to airborne release fractions for non-reactor
ļ	I

(202) 234-4433

	37
1	nuclear facilities. If anybody wants to it
2	actually has an ML number, so, anyway you don't need
3	to tell me what it is, I know where it came from.
4	MR. RECKLEY: Okay, thank you. And again,
5	I don't want to exaggerate its incorporation here.
6	But it's a similar concept.
7	So, if we go then to Slide 8, it says
8	Subpart B, and I'm going to talk about this in a
9	little more detail. So this is just the format that
10	we provided in our January meeting. And instead of
11	dwelling here, I think we have a few slides I'd like
12	to revisit Subpart B.
13	So then Subpart C, we're going to talk
14	about today, that's Slide 9, the Design and Analysis.
15	And this is the existing format for the iteration that
16	we provided to you. Just in terms of timing, the
17	iteration, the first iteration that we provided to you
18	is for today's meeting, was actually released before
19	our last meeting with you in January.
20	So, we did touch on Subpart C in our
21	January discussions. We know the language you were
22	looking at doesn't reflect any of those conversations.
23	We will be looking to do future iterations and even
24	have some notes in today's presentation where we're
25	thinking of making some changes based not only on
I	I

(202) 234-4433

stakeholder observations, but also our meeting in And then obviously, we'll take today's 2 January. 3 meeting and that might get incorporated into even a 4 future iteration.

5 So, if we go to Slide 10. We'll also be talking about this this afternoon. So this is just 6 7 the general outline of Subpart D. Some general observations on siting. And then looking at external 8 hazards, the traditional site characteristics that one 9 considerations 10 needs to define, related to populations, and then the connection with Part 51 in 11 environmental. But again, we'll talk about this this 12 13 afternoon.

14 So Subpart E on Construction, Slide 11. 15 We're getting ready to release an iteration on Subpart 16 to support public meetings in March. We've E 17 basically broken this into two halves. One is on typical construction. When I say typical, it would be 18 19 a project that would look a lot like what we're used to, be it under a construction permit, or a combined 20 license approach, Part 52 approach. 21

But it is a construction, if you put it in 22 terms of housing, a stick build, if you will. This is 23 24 the current approach for, underway at Voqtle for It would fall under this part. 25 example.

> **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

And we've defined the activities as what management in control is needed, what you would have to do throughout the construction process. What kind of inspections and acceptance reviews would be needed? And a section on communications. This is, this section is dominated by quality assurance, quality control kind of requirements.

8 And when you see it, you'll be able to 9 recognize right away that this is basically, again 10 dominated by quality assurance considerations.

The second half of this subpart 11 on construction and manufacturing, we're putting out 12 quality assurance, 13 language again, to cover the 14 quality control aspects. But then also we're using it 15 as an opportunity to really begin the discussion on, if this is going to be the approach, include it. And 16 17 we're assuming when we say manufacturing that we're going to get into the realm of a manufacturing 18 19 license.

20 So, if the distinction for us between the 21 two is you can have modular construction, you can even 22 build modules just like is being done for Vogtle or 23 you would see in ship building activities and so 24 forth.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

You can build large modules, but if that's

(202) 234-4433

25

1

2

3

4

5

6

7

	40
1	being done as part of a, just to help in the
2	construction process, that's still a construction
3	activity.
4	Manufacturing as we're proposing it in
5	this first iteration is the activity that would be
6	undertaken through a manufacturing license from the
7	NRC, which is, it's a different vehicle. And really
8	reflects a more kind of factory fabrication of the
9	whole reactor, or at least major parts of the reactor.
10	We have questions and again, we're going
11	to use the upcoming interactions to talk about how far
12	this might go in terms of would people envision
13	loading fuel at the factory and then transporting a
14	loaded reactor to a site and so forth?
15	So, we currently have some rough
16	provisions for that. But if our normal goal would be
17	to say, we're shooting for the 80-20 kind of language,
18	when we're putting it out as preliminary, I'd say in
19	this area, we're somewhat less than 80-20.
20	Because we have a lot of questions on what
21	it is that the people foresee as kind of the business
22	model, the manufacturing model, and what we would need
23	to support in Part 53? So
24	MEMBER KIRCHNER: Bill, this is Walt
25	again. If I might ask for clarification. New
I	1

(202) 234-4433

	41
1	manufacturing licenses, by and large they usually
2	involve special nuclear material. They usually
3	revolve around fuel. Isn't that the case?
4	MR. RECKLEY: There is a current provision
5	in Subpart F of Part 52. In ISO manufacturing, this
6	isn't like a fuel cycle facility that would have a
7	materials license to make fuel. So this isn't, you
8	know, the Westinghouse facility, or the General
9	Electric facility making fuel.
10	A manufacturing license is for a reactor
11	facility, and the only exercise that we've had for
12	manufacturing licenses is offshore power systems back
13	in the early 80s. And it is a different reactor
14	approach. And if you look at the history of Part 52,
15	or at least the way I look at it, Part 52 was oriented
16	towards standardization.
17	And so the design certification process
18	was a large element of getting the design
19	standardized. The manufacturing license was one step
20	further. And said, not only is this the design that's
21	standardized, but this is the process by which the
22	machine is going to get put together.
23	This is going to be the welding
24	techniques, this is going to be the, just think of
25	whatever else might be included in that and the NRC

(202) 234-4433

	42
1	would review and approve not only the design, but how
2	it would be put together and issue that in a
3	manufacturing license.
4	So that was, to me that was kind of like
5	the ultimate standardization. And why it fits into
6	this new discussion of a factory assembled, a factory
7	setting for reactors.
8	MEMBER BALLINGER: This is Ron again.
9	With respect to say Part, transportation. How, with
10	a small source term, for some of these small reactors,
11	how is transportation to and from the site, even for
12	a plant that's been operated, differ from just
13	transporting spent nuclear fuel?
14	CHAIRMAN BLEY: Well, with that, as we
15	build this out, we'll see. We think you're right,
16	that we can handle the transportation element under
17	the existing requirements. The difference will be
18	that the design of the reactor itself will have to
19	foresee its use.
20	Not only as a reactor, but maybe as a
21	transportation package.
22	MEMBER BALLINGER: Got it.
23	MEMBER KIRCHNER: And also, the kind of
24	mechanical loadings and such are, that you have to
25	accommodate will have an impact on the design as well.
	I

(202) 234-4433

	43
1	(Simultaneous speaking.)
2	MEMBER BALLINGER: Right, but it's pretty
3	much the same, kind of analysis
4	MEMBER KIRCHNER: You'll have to iterate
5	on that
6	MEMBER BALLINGER: that you have to do,
7	right?
8	CHAIRMAN BLEY: No, I don't think so.
9	Well, it is currently my understanding is that NRC's
10	role in the transportation of the spent nuclear fuel
11	is to certify the casks. Everything else in that
12	process belongs to other agencies who protect that
13	cask in various ways.
14	But if we're shipping a new kind of
15	reactors with built in control systems and new fuel
16	and all that, I think the world of NRC is a lot
17	broader than it currently is. So, you know it, today
18	you guys still remember that time?
19	MR. RECKLEY: Some, but not to the degree
20	that we would need to take this concept all the way.
21	And that's why we're wanting to engage stakeholders
22	before we undertake it, because it and you're
23	right, it would have to address various things.
24	You will have control systems that you'd
25	have to make sure were either disabled, or otherwise
	I

(202) 234-4433

	44
1	irrelevant. Maybe during the transport phase, but
2	again, we really wanted to engage stakeholders to see
3	if there's a real interest in this.
4	We think there is, but we wanted to
5	confirm it before undertaking this activity, and doing
6	more interactions, even internally with our
7	transportation folks in NMSS.
8	So, that would be Subpart E on
9	Construction and Manufacturing. Subpart F gets into
10	Operations. And so, go to Slide 12. If you go to
11	Construction and Manufacturing, there's two segments.
12	Thinking on Operations, is it can somewhat be broken
13	down into three segments.
14	The first one is on the equipment, and the
15	focus would be on configuration controls, like it is
16	now. So, for safety-related equipment, those would be
17	addressed in Technical Specifications. And we'd have
18	the equivalent of limiting conditions for operations
19	and completion times.
20	Not really a new concept, but
21	configuration control for the safety-related functions
22	would be governed by Tech Specs. The configuration
23	management for safety-significant, this is the non-
24	safety-related, but safety-significant category that
25	we'll talk about under Subpart C.
I	1

(202) 234-4433

	45
1	We would really have to define, would the
2	it's envisioned, you'd have more licensing, you'd
3	have more flexibility for those structure systems and
4	components, but we need in the rules to define that
5	there does need to be controls for those equipment.
6	So, what kind of reliability assurance
7	program? How is maintenance performed and controlled?
8	So, that's an area we're currently working on. This
9	goes to, again, our goal would be that NEI 18-04, the
10	Licensing Modernization Project, remains as one way to
11	meet Part 53.
12	And that guidance includes the non-safety
13	related with special treatment category, and talks
14	about various forms of special treatment that might be
15	applied to that equipment.
16	Our challenge here is to incorporate that
17	concept into the rule, to make sure that that
18	equipment is actually controlled. There's measures in
19	place to make sure it is available, that it's
20	reliable.
21	Because as it's currently constructed,
22	there's a probabilistic element there, where the
23	contribution of this non-safety related with special
24	treatment equipment, might be to limit the frequency
25	of events.
Į	I

(202) 234-4433

46 1 What that then means, you have to monitor 2 the availability and reliability of this equipment to 3 make sure that your frequency estimations in the PRA 4 are remaining valid. 5 So, it's an additional element that we would be adding to support this -- and we'll get into 6 7 the discussion, in these two tiers, or two layers that 8 we're trying to carry throughout Part 53. 9 Then some other thoughts that we would 10 have for the operations, the equipment aspect of operations is there would be a QA element, maybe 11 address age and management from the beginning. 12 control, this 13 Design would be the 14 need to make processes you sure that you're 15 maintaining the design, or if you're changing the 16 design, that it's being assessed. And as we'll talk about a little later 17 this morning, that the design and the analysis stays 18 19 either connected or you redo the analysis. But that's an interface, back and forth, between maintaining the 20 design during operations in the subpart we'll be 21 talking about today. 22 And we talked about briefly, well, 23 we 24 talked about it at the last meeting, the Facility And the notion of using such a 25 Safety Program.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1 concept to look at the new information and assess 2 whether changes to the facility would be warranted. 3 Then the next seqment of Operations 4 Subpart F, go to Slide 14, is Personnel. Let's see. I'm not seeing it change, I'm not sure if others are. 5 6 MEMBER KIRCHNER: No, we have it. Slide 7 13 is showing, Bill. 8 MR. RECKLEY: Okay. So, this gets into 9 another very interesting area. And so, we're going to start the discussions, I think, in April and May with 10 stakeholders, and this will include ACRS, on the 11 12 appropriate staffing and control of staffing for Advanced Reactor Designs under Part 53. 13 14 And we have heard of proposals and 15 possible justifications for not only reducing staffing 16 levels, but for more dramatic change, like not having And the 17 licensed personnel attending the reactor. possibility of going to an unmanned reactor, a totally 18 19 autonomous reactor, if you will. So, we're looking at those to see, again, 20 the range of activities we're hearing the 21 over possibility of autonomous, unstaffed, all the way up 22 to facilities that would look more similar to current, 23 24 or plants, or plants like NuScale that have justified reduced staffing, 25 but keeping a structure with

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

47

	48
1	licensed operators, for example.
2	So, we're just thinking about how to roll
3	this out. We've prepared a paper, a White Paper to
4	support the discussions. We'll be releasing probably
5	in March to support more discussions in, like I say
6	April and May.
7	But one very rough outline would be if
8	we're to support that kind of flexibility that remove
9	and require a developer or an applicant to prepare a
10	concept of operations, which is a real systematic look
11	at what is the level of personnel in the facility.
12	So, it's somewhat analogous to looking at
13	the equipment, and doing a systematic review of what
14	operators do to either prevent or mitigate transients
15	or accidents and also help personnel might
16	contribute to causing them.
17	But in any case, that concept of
18	operations could look at the role in meeting the
19	criteria set up for what we'll talk about a little
20	later, the design-basis accident.
21	As well as the role in meeting, create
22	more risk-informed approaches, like the NRC Safety
23	Guide, and what might be the role of personnel. And
24	maybe we can make a distinction between those roles,
25	just like we do for equipment.
ļ	1

(202) 234-4433

But then we would lay out what are the requirements for licensed personnel, and what are the requirements for non-licensed personnel. We are even looking at whether we could look at keeping the notion of licensed personnel, but trying to scale that such that it would not be as onerous as the current system we have in place, under Part 55 and the current structure.

9 So, this is going to be, in my view, one 10 of the more challenging things to try to address. Not 11 only in the rule, but in the guidance, and this might 12 be a case where we can write a rule, but the guidance 13 would be essential.

So, go ahead Dennis, I'm sorry.

15 CHAIRMAN BLEY: A few things jump at me on 16 this. One is especially if we talk about unmanned 17 facilities. One either has to think about concepts 18 like your material, but risk and damage ratio, getting 19 so small that it doesn't matter so much.

Or some kind of remote operations. If you get into remote operations, man, that's going to be a bag of worms. There's so many things that could interfere with that.

24 If you're unmanned, then you become like 25 a lot of chemical facilities and you have to have

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

8

14

	50
1	coordinated, you, the owners, have to have coordinated
2	with local police and fire organizations so that they
3	can deal with whatever problems might occur. Because
4	I know we're talking about this on your next slide, so
5	(audio interference) over there.
6	But it seems to me, and you guys can
7	correct me on this, we've got a lot of regulation to
8	protect operators, maintenance people, workers on
9	site, from radiation.
10	For normal, and maybe abnormal operations,
11	we're not so much looking at ongoing accident
12	conditions, or at least beyond-design basis accidents,
13	and I don't know if you thought about that at all.
14	And second some of the possible designs
15	might offer greater chemical and energetic kinds of
16	problems that are not maybe nuclide related, but are
17	especially dangerous for workers, or maybe for nearby
18	populations, are you thinking about that?
19	Or are you thinking somehow, OSHA, FEMA or
20	somebody else has to step in and regulate that side of
21	things, which could make regulation pretty tricky for
22	people.
23	MR. RECKLEY: We have a slide in talking
24	about other hazards coming up.
25	CHAIRMAN BLEY: Prepare.
I	I

(202) 234-4433

	51
1	MR. RECKLEY: So, on other hazards, let me
2	just defer until we get to that. In terms of the
3	other discussion this is again, this is another area
4	that we're probably not going to be 80-20, when we
5	start putting out preliminary language.
6	We're going to be somewhere short of that
7	because we need to know what it is, and what is the
8	range. And there can be a dramatic difference, as you
9	mentioned, between totally unmanned, and just having
10	some staffing.
11	And the staffing might serve multiple
12	roles, but would it be feasible, and I don't know the
13	answer to this, but would it be feasible to ever have
14	a facility that didn't have anybody there? Even just
15	to support security aspects, as well as maintenance
16	aspects, as well as other things.
17	And if it's not foreseen, then we might be
18	able to back up a step and say, okay we may not have
19	to write this rule to go to that, to that level.
20	MEMBER BALLINGER: This is Ron again.
21	Dennis and I have been having these pie in the sky
22	discussions about autonomous and unattended, or
23	operation. Have you guys checked out with NASA, and
24	what they do, and how they treat autonomous and
25	unattended operation with respect to safety and things
I	I

(202) 234-4433

	52
1	like that for this kind of thing?
2	Because they're used to that, and they
3	developed a set of criteria for mission control if you
4	will, for lack of a better word, but it deals with
5	autonomous and unattended operation with respect to
6	safety.
7	MR. RECKLEY: We looked at some of that.
8	But what you're specifically mentioning I'm not
9	familiar with, so I'm going to look that up. But we
10	have looked at guidance in this regard, for nuclear
11	and non-nuclear facilities.
12	And interacted with the national
13	laboratories, some of which are involved with Sandia
14	in particular, with the NASA programs, but let me make
15	a note to look specifically at that.
16	(Simultaneous speaking.)
17	MEMBER KIRCHNER: This is Walt Kirchner.
18	I have two comments. One, I'm struggling with whether
19	the payoff is there for you to make the distinction in
20	concept of operations for first tier and second tier
21	safety.
22	It would seem to me, it's the same
23	personnel. And you would want, if you get into a
24	situation where you are beyond the design-basis events
25	into, for lack of a better term, into a severe
I	

(202) 234-4433

	53
1	accident like situation, it's the same personnel that
2	you would want to depend on, in my opinion, and have
3	trained for that contingency.
4	So, I'm struggling with the undue
5	complication that this potentially represents. Then
6	my second comment is that, to the extent that you
7	reduce the requirements for licensed personnel, or in
8	the ultimate, an unmanned, unintended plant, it seems
9	to me then that the requirements in terms of quality,
10	defense-in-depth go up inversely with the lack of
11	people present, I to first order.
12	In other words, the dependence on safety-
13	related equipment and functions, I think you call them
14	safety functions, such as controlled reactivity and
15	safe shutdown become even more important as you reduce
16	the training, the requirements, the staffing.
17	So, that you have a robust defensive-in-
18	depth to compensate for what you're entertaining here,
19	going down the view graph. Does that make any sense?
20	MR. RECKLEY: Yes, it does. And again,
21	this is very, very preliminary, and we have to talk
22	internally about various things. And you're right.
23	If you were going to try to justify, if someone were
24	to try to justify a much less defined role for
25	personnel, then that has to be compensated on the
ļ	I

(202) 234-4433

design side.

1

2

3

4

5

6

One of the, and when we get to the discussions on inherent, you know, one of the definitions for inherent, when you talk to control system people, inherent means total reliable. It's a, so no question, right.

7 And so, if you're going to be relying on 8 inherent features, which aqain we're open to 9 discussing this, but then you're basically saying there is no question of how this machine is going to 10 behave, and it's governed by the physics. And if that 11 could be proved, then that can be a supporting thing 12 for a lesser role for personnel. 13

The other point you made Walt, which is good, which is you can get into this error that you would have to think about. Where the role of people and the possible mitigation, which on equipment side would, tended to say, might have more flexibility if ultimately you're increasing the role of people on the severe accident side.

If you want to use that terminology. Then the logic that I laid out here, where various people would have to have lesser controls, if you will, that might not make sense.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

So, all of this is stuff we need to talk

(202) 234-4433

25

(202) 234-4433

54

	55
1	about. And so, when we get into the discussions in
2	April and May we will have hopefully, thought this
3	through a little bit more, and be providing some
4	preliminary language. But all of this discussion
5	today is stuff we can take into account.
6	So, if we can then support, yes, the last
7	part of Subpart F, this segment, the third segment,
8	we'll talk about programs. And this isn't an all-
9	inclusive list, but it would look into the programs
10	that a licensee has to have and maintain, radiation
11	protection, emergency preparedness, security.
12	You would have, possibly, some others in
13	here on QA, radiation protection, probably would, well
14	it would address both on-site and off-site things.
15	And so, this is just kind of a placeholder.
16	The list will grow as we go through the
17	process, but just to define it again, Subpart F into
18	its three parts. There would be the Equipment part,
19	the Personnel part, and then the Programmatic part, is
20	the way we're currently envisioning that would go.
21	So, Subpart H, next slide. Oh, skip G.
22	G is Decommissioning, and that would involve laying
23	out the requirements for the termination of
24	operations. The transition, as we currently do from
25	operations, that would be a possession only license.
I	I

(202) 234-4433

	56
1	We would include the financial assurance requirements
2	here, most likely, and then the requirements for
3	transition to unrestricted use.
4	But we haven't really, this is one that
5	we've given less thought to how it would go, but the
6	initial thinking is, it may not be that dramatically
7	different then what we have now for a construction
8	kind of project.
9	How this looks for a manufacturing model,
10	we have to think through.
11	CHAIRMAN BLEY: Have you gotten any
12	stakeholder comments on this slide?
13	MR. RECKLEY: We really have not engaged
14	shareholders yet in the discussions on
15	decommissioning. The one comment that we do have is
16	maybe we could, if we had an error that we might not
17	have for instance, the guidance developed for a
18	particular subpart, maybe this would be one we would
19	hold off on the guidance because it's at the end of
20	the process.
21	But so, the short answer is no, we really
22	haven't had much discussion on decommissioning. So,
23	if we go to sixteen, that's getting into the licensing
24	arena. This goes to Joy's point, and what Nan weighed
25	in earlier.
	I

(202) 234-4433

We're not necessarily seeing dramatic changes to these processes. The guidance will become important, things like the content of applications might change as you change the design and analysis requirements.

There's a different project on the content to applications, not different related. A project that we have currently ongoing, and an interaction again with the, it's a DOE fund cost-shared industryled effort, similar to licensing modernization on content of applications.

Our hope is that that can help inform us, 12 and provide the quidance for what would be in terms of 13 14 a content to applications for Subpart H. So, really all this slide does is break down existing reviews and 15 16 types into siting, where we have site license 17 suitability reviews, that's still an appendix in Part 50, limited work authorization, early site permits. 18

Then under the design element, the designoriented things that we have, are standard design approvals, design certifications, and manufacturing licenses, again Subpart F, currently in Part 52.

But an area we haven't looked at in years, and probably doesn't reflect the factory setting that's currently envisioned. The first bullet under

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

8

9

10

11

	58
1	design, we've found in the past that the stakeholders
2	have asked to have a conceptual design review in the
3	process of findings in the past, as we have that
4	available.
5	This would be something similar that we've
6	did in the 80s for PRISM, for the MHTGR, those pre-
7	application reviews. That's not currently captured in
8	a rule but we think we have available, so, but we just
9	have a question mark there.
10	Whether the rule should, might accommodate
11	something akin to a site suitability review, but less
12	than in the design realm, but less than the design
13	approval. Just a question. And then
14	(Simultaneous speaking.)
15	MEMBER BROWN: Bill.
16	MR. RECKLEY: Yes, go ahead.
17	MEMBER BROWN: Is the thought process on
18	that similar to what you did with I&C about 12 years
19	ago, with the pre-licensing application, not
20	application, but pre-licensing review for I&C systems,
21	so they knew what to expect? Is that the kind of
22	thought process? I've forgotten what ISG it is, it's
23	ISG four, five, six, or seven.
24	MR. RECKLEY: In the digital I&C area?
25	MEMBER BROWN: Yes, and that turned out
I	

(202) 234-4433

	59
1	very fruitful for the subsequently redesigns, I know
2	they did those. And therefore, when they finally
3	submitted their license applications, their
4	application, it went pretty smoothly on AP1000 through
5	the NuScale.
6	MR. RECKLEY: Yes, I would put that more
7	in a guidance realm. Well, I mean again, we'll talk
8	to stakeholders about what they may want, but this
9	would be more the review of a specific design versus
10	developing the guidance, which I think you're
11	referring to. And I wasn't involved in that.
12	MEMBER BROWN: Well, it was pre before
13	they submitted the stuff, it was just, they sat down
14	with NRC, with the I&C folks
15	MR. RECKLEY: Oh, okay.
16	MEMBER BROWN: and when through this is
17	how we'll approach, and then they, NRC identified what
18	they were expecting. And therefore they didn't end up
19	with as, you know, much back and forth when they
20	finally got the stuff submitted, so
21	MR. RECKLEY: Oh, okay. Yes, then it
22	would be more similar to that.
23	MEMBER BROWN: I'm just wondering what
24	your thoughts
25	MR. RECKLEY: Yes.

(202) 234-4433

	60
1	MEMBER BROWN: You might want to talk to
2	them, and you'll find out how that worked, see if it's
3	practical, that's all.
4	MR. RECKLEY: Yes, thank you. Yes, in my
5	mind, the difference that we've traditionally set is
6	that the standard design approvals, like the topical
7	reports and other features that we have in place, or
8	the product lines that we have in place, provide a
9	document that you can reference in an application.
10	You get full credit for that interaction,
11	and that review. Whereas, the conceptual design
12	review, as we've traditionally described it, you don't
13	get that safety evaluation that you can actually
14	reference in an application.
15	It might be very fruitful, but you don't
16	get a referenceable document. It's the distinction we
17	typically make.
18	MEMBER KIRCHNER: Hey Bill, this is Walt
19	again, Kirchner. I participated in those reviews of
20	the PRISM and the MHTGR, on behalf of the NRC. And I
21	thought, and those were fairly mature designs, for a
22	conceptual design. I thought they were very useful.
23	And, I think furthermore, how should I say
24	it, advanced concepts that have less of a technology
25	base, that a conceptual design review is a good
I	I

(202) 234-4433

	61
1	starting place to flush out a lot of the potential
2	licensing issues, concerns, matters, that whereas,
3	jumping right into a request for a design
4	certification or a combined operating license.
5	My goodness, that's a, for some of the
6	advanced concepts, it's almost like it's too much of
7	a leap. That's just one member's opinion. So, I
8	think, providing for this might prove useful for the
9	more advanced concepts with limited experimental data
10	behind them.
11	MR. RECKLEY: Thanks Walt. And we don't
12	disagree with that. We just thought we'd start, we
13	had that existing process to pre-application reviews,
14	and we had the ability to do it without changing any
15	rules.
16	So yes, we certainly want to continue to
17	encourage it. The question would be whether we want
18	to build something into Part 53 to specifically
19	address that?
20	Then under Site and Design, the actual
21	facility, the processes in Subpart H on licensing
22	would reflect current processes, either a construction
23	permit and operating license, or combined licenses.
24	And then, that last bullet there, is we're
25	just trying to think how to best describe the content
	I

(202) 234-4433

	62
1	of applications for these various options and
2	combinations, and we're thinking maybe we can do that
3	in a table.
4	And if we go on to Slide 17
5	CHAIRMAN BLEY: Bill.
6	MR. RECKLEY: Yes, go ahead, Dennis.
7	CHAIRMAN BLEY: Let's go ahead with the
8	next two slides on Subparts I and J, and then we'll
9	take a break.
10	MR. RECKLEY: Okay good. Subpart A I,
11	I mean, is the Maintaining-Licensing Basis. Remember
12	this is separate from Subpart H, we'll start talking
13	about, but you do need within the rule, to have
14	processes for how to amend a license, that that's
15	currently the 50.90 series of regulations in Part 50.
16	How to update the FSAR? Our current plan
17	is to include a PRA. So, how do PRA's get updated?
18	We'd have a requirement. Then the standard
19	regulations related to NRC actions like suspension or
20	modifying a license, when taking special nuclear
21	material, back fitting, and requesting information as
22	we currently do under 50.54(f).
23	So, that's just maintaining the licensing
24	basis. And then ultimately, the next Slide, 18, Slide
25	18
Į	I

(202) 234-4433

	63
1	CHAIRMAN BLEY: Well, before you leave 17.
2	MR. RECKLEY: Yes.
3	CHAIRMAN BLEY: I want to make a
4	suggestion to you. Including the PRA, excuse me, I
5	think it's a very good idea, but I think that's a
6	place you should already be starting to think of what
7	kind of guidance you want here.
8	Just off the top of my head, the place it
9	has to be done thoroughly, and the same ideas would
10	have to be done if you weren't doing a PRA is the
11	search for damage scenarios. Scenarios that can lead
12	to damage, initiating events, that sort of thing, has
13	to be as thorough as possible.
14	However, just as we've talked in other
15	areas, the depth of analysis that's done after that,
16	somehow ought to scale to the hazard and the
17	complexity of the design.
18	So, I think that's a place we don't
19	currently have any guidance. People have done this,
20	working outside of the nuclear field. But I think,
21	it's a place you really have to start thinking early
22	about what that guidance could look like, go ahead.
23	MR. RECKLEY: Okay, thanks Dennis. I
24	agree with that, just another of many items we're
25	going to have to address, both in the rule and in
I	I

(202) 234-4433

	64
1	associated guidance. So, if you'll go onto the next
2	Slide 18. There are
3	CHAIRMAN BLEY: I've lost the slides.
4	Does everybody else have them? I've got hard copies
5	if we need them.
6	MR. RECKLEY: Yes, I'm still seeing them.
7	Is everyone else?
8	PARTICIPANT: I can see them.
9	CHAIRMAN BLEY: Okay, go ahead.
10	MR. RECKLEY: Okay. Then on Slide 18,
11	there are, we're just currently kind of keeping this
12	as the catch all. They may not all end up in Subpart
13	J, but there will be administrative and reporting
14	requirements that we have, that we have to track.
15	But this is also being, as items come up,
16	this is kind of our parking lot. So, there are a
17	whole host of other things to consider like financial
18	qualifications, the insurance crime that's currently
19	in 50.53(w). That's property insurance as well as
20	references over to financial protection, liability
21	regulation.
22	MEMBER KIRCHNER: Bill.
23	MR. RECKLEY: Yes.
24	MEMBER KIRCHNER: This is Walt Kirchner.
25	This is a rhetorical question, I don't expect you to
I	1

(202) 234-4433

	65
1	answer it. I posed it to Dennis in an email. You've
2	mentioned quality assurance now, several times, but
3	I'm getting the impression that you're not going to
4	make a requirement equivalent to 50.52 of Appendix B.
5	And it begs the following question, if you
6	don't build an advanced reactor to the quality, and
7	codes, and standards of the existing fleet, why should
8	you potentially be covered under Price-Anderson?
9	And I'm not an expert, I'm not a lawyer in
10	this area, but it's a rhetorical question, that has
11	occurred to me. That somehow if we're building
12	advanced reactors to lesser standards, or quality,
13	then the existing fleet, it raises, in my mind, those
14	kinds of questions.
15	It's a more of a policy kind of thing than
16	
17	MR. RECKLEY: Yes, and I don't think, and
18	we'll get into this a little bit under Design and
19	Analysis, but I don't think that I know, from a
20	status point of view the intent is not to do lesser
21	quality.
22	The question that's been posed is, do
23	alternatives to NQA-1 in Appendix B provide the same
24	quality, the same confidence in the performance of the
25	equipment? That's the question, whether there is an
I	I

(202) 234-4433

	66
1	equivalency, not can we allow a lesser standard?
2	MEMBER KIRCHNER: Yes so, so I can see ISO
3	9000, for example, being pretty comparable to NQA-1.
4	MR. RECKLEY: So, but as we go through,
5	the other thing, and this will be, as we put this
6	thing together and look at it. Our first attempt
7	here, on this iteration, was instead of having a
8	dedicated appendix on quality assurance, was to build
9	quality assurance into each of the subparts.
10	That's an area that if we look at it as we
11	put it together and say, it's actually more confusing
12	to do it that way, we could, at a later time for
13	clarity, without actually changing the intent or how
14	it would work, come up with Subpart K, Quality
15	Assurance, and then put it all back together.
16	But we'll see as we put it together if
17	that turns out to be the case. Again, we're currently
18	are taking the approach of quality assurance has been
19	incorporated into each subpart, versus referring to
20	Appendix B, where all the quality assurance stuff was
21	together, so
22	CHAIRMAN BLEY: Well we're going to get to
23	the Subpart C
24	MR. RECKLEY: Right.
25	CHAIRMAN BLEY: and we'll look forward
	I

(202) 234-4433

	67
1	hearing what say there. My reading, I might have
2	missed something, you know, consensus standards show
3	up in there at least as a one liner. I'm not sure
4	about QA, but you'll talk about that when we get
5	there.
6	MR. RECKLEY: Right.
7	So, I think, Dennis if you wanted to take
8	a break, then when we get back, we'll do a recap of
9	Subpart B, just because it's important. And then
10	we'll get right into Subpart C on Design and Analysis.
11	CHAIRMAN BLEY: Okay yes, I wanted to stop
12	here because I think your four slides on Subpart B
13	might take us a while. We're doing pretty well, let's
14	take a half hour break, come back at 11:40. We'll
15	recess to 11:40.
16	(Whereupon, the above-entitled matter went
17	off the record at 11:07 a.m. and resumed at 11:40
18	a.m.)
19	CHAIRMAN BLEY: At this time, we're back
20	in session. Bill, you're back on.
21	MR. RECKLEY: Okay, thank you, Dennis.
22	So, say we take a couple of slides and recap the first
23	iteration that we prepared, and made public, on
24	Subpart B, the Safety Criteria, and also discuss some
25	of the feedback that we've been getting in that, and
I	I

(202) 234-4433

68 what we're considering in providing an iteration, or 1 an update to Subpart B. 2 So, that the current structure, as we 3 4 provided it last time, and discussed it at the last 5 meeting, was that the highest-level safety objectives would provide reasonable 6 assurance of adequate 7 protection and that's taken out of Section 182 of the 8 Atomic Energy Act. 9 And that the requirements would also set 10 out to define such additional measures, to minimize danger to life and property, that Section 161 of the 11 Act empowers the NRC to do. And how our thoughts 12 were, that we needed to address both of those elements 13 14 in order to meet what we are taking from previous Commission direction. 15 16 That any advanced reactor has to be, at 17 least, as safe as the reactors we've licensed to date. And we have regulations and have addressed in the 18 19 licensing processes fairly concrete measures to do both of those activities. 20 So, under Safety Objectives, we put in 21 Subpart B that the primary safety function is to limit 22 release of radioactive materials from 23 the the 24 facility, and that applicant needs to identify such supporting functions that might be necessary. 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	69
1	And for many reactor designs, that would
2	be the traditional need to control power or reactivity
3	and the need to remove heat, the need to control
4	chemical interactions, and so forth.
5	The then we went into the tiers, and
6	I'm going to have a slide where we made an attempt to
7	address some of the comments we got last time, and
8	hopefully clarify the two tiers.
9	But we've identified the first tier that
10	included normal operations and staying under the
11	limits of Part 20, that's the 100 millirem value. And
12	then for Licensing-Basis Events, to stay under the
13	guidelines that are currently included in Parts 50 and
14	Part 72.
15	Sometimes we'll refer to the siting
16	criteria, that's the 25 rem over two hours at the
17	exclusionary boundary over the course of the event, at
18	the low populations on boundary. And laid that out as
19	the first tier criteria for unplanned events.
20	And then to define the second tier that,
21	which is associated with as low as reasonably
22	achievable for normal operations. And then for
23	licensing-basis events, bringing in the criteria of
24	the NRC safety goals.
25	And then the rest of Subpart B, defined

(202) 234-4433

	70
1	the need to identify licensing-basis events, to
2	support the assessments of the first and second tier
3	criteria, to provide defense-in-depth, and to provide
4	measures to protect plant workers.
5	So, if we go onto Slide 20, this is our
6	attempt, it's I understand it's a concept that's,
7	I think we're generally familiar with it. And we've
8	seen its use in things like 50.69. Certainly under
9	the Licensing Modernization Project, and NEI-00-04, we
10	saw the attempt to make a distinction between
11	different criteria.
12	I'm hearing a bit of an echo.
13	There we go. Thank you, Derek.
14	So, under the first tier let me back up
15	one step. And so, in setting out the tiers, for the
16	levels, the goal was to try to support what we've seen
17	evolve under 50, and 52, over the years. Because this
18	distinction between those things needed for under
19	50.69 safety-related.
20	But maybe the requirements for safety-
21	related didn't line up with the risk significance, and
22	in some cases, the risk significance of an SSC, didn't
23	necessarily get captured in the regulatory treatments
24	that 50.69 was trying to align, better align safety
25	and risk management with the treatment of SSC's.
I	I

(202) 234-4433

Again, under LMP, you had safety-related and non-safety related with special treatment that set this out in some detail. So, we're just trying to capture the motion of setting out a distinction between the treatment of equipment, and as I mentioned earlier, when we were talking about staffing, possible distinction in the role of staffing. So, that throughout Part 53, we could set out these different controls, different levels of NRC control, additional flexibility for licensees, those elements in the second tier. So, that was the goal, was to try to build it from the beginning, would enable a distinction between two levels of equipment, two levels of staffing, two levels of regulation. So, the first tier was set out as being -well it has generally been used over the years, as at least one of the components of adequate protection. And that's been the 25 rem criteria as it's defined in, or in both 50 and 52. And how it's applied to traditional design basis accidents. And so, we kind of kept that, hopefully made it more clear that that's what we were using it

24 for. And so, under the left column, under the darker blue, the first tier. 25

> **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

(202) 234-4433

71

а

for

72 1 We set out the first tier, Unplanned 2 Events, the Guidance, the criteria being 50.34, 52.79. 3 Then we go down and say, you have to identify required 4 Safety Functions to meet those criteria. Do you need, 5 obviously you need to retain the radionuclides. Do you need other things like controlling 6 7 heat removal, heat generation, controlling chemical interactions, in order to keep the dose below those 8 9 To the degree you need any of those thresholds? 10 things, that shows up in the safety classification, the application of Appendix B, the inclusion in Tech 11 Specs and so forth. 12 So, that class of equipment, 13 or that 14 grouping of equipment, that grouping of human actions, if you're relying on programmatic controls, those 15 16 programmatic controls are going to get the most 17 scrutiny. Licensees would the have least 18 19 flexibility. For instance, if they are included in Tech Specs, they couldn't change them without NRC 20 And you set out this whole grouping of 21 approval. requirements needed to meet the first tier. 22 23 And then, but in doing that recognizing 24 that even for the current fleet, my view, my view is that that's not, we wouldn't be satisfied with just 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	73
1	saying that those have a certain boundary that's less
2	than 25 rem. Our current requirements go beyond that.
3	And so, capture those things in a second
4	tier. And really, to kind of get your head this, and
5	my own view is that the current framework that we have
6	for the operating fleet started off as basically
7	binary. It's safety-related. It's regulated. It's
8	non-safety related. It's basically unregulated.
9	I might exaggerate a bit, but if you go
10	back far enough, it was somewhat close to that kind of
11	a binary treatment. Over the years, starting
12	especially in the 80s and carrying through now,
13	especially with all the risks in trying to incorporate
14	the risk-controlled insights.
15	You started to try to introduce the
16	anatomy of the second tier. And so, this got you
17	things like, blackout diesels. Important to safety,
18	but not safety-related. In under 50.69 again, it got
19	you controls over that class of equipment that might
20	be important in the PRA, but not previously treated as
21	safety-related.
22	So, the whole notion of the second tier
23	was to try to set up from the outset, the new need for
24	more than just showing you meet 25 rem. And capturing
25	in that second tier, those things that would be
	I

(202) 234-4433

	74
1	important to control in the risk from the facilities.
2	And so, that led to using the safety
3	goals, because we were trying to, as much as possible,
4	use existing standards, versus creating new things, as
5	being the criterion for the safety goal for the second
6	tier.
7	And then, if you go down, to identify the
8	Safety Functions that would come out of considering
9	that second tier.
10	It's going to be what is the equipment, in
11	terms of both its ability to limit the consequences of
12	unplanned events and to control the frequency of those
13	events, in terms of the risk and safety significance,
14	and to provide an added defense-in-depth. So, that's
15	the way the second tier would show up under the Safety
16	Functions' row there.
17	And then you go down to Design Features
18	and Programmatic Controls, again, and our desire is to
19	come up with a consistent treatment across all of the
20	subparts on how we would the second tier.
21	That brings in for equipment, special
22	treatment. It might bring in a special treatment on
23	equipment. It would bring in licensee programs. It
24	might bring in the role of, to our previous
25	discussion, might bring in the role of unlicensed
I	I

(202) 234-4433

	75
1	staff.
2	But as we go through the subparts, we'll
3	just try to build this out. So, that is the notion,
4	Dennis, you had brought up earlier, the tiers, and
5	I'll be honest, I went into a thesaurus and tried to
6	use a word different than tier.
7	Just because Tier 1, Tier 2, Tier 2 is
8	used under Part 52 and having developed the appendices
9	in Part 52 for the various designs. And every other
10	word had just as much confusion, or had been used in
11	a different context.
12	But, the notion here is, and as we develop
13	this through the licensing process, the hope is that
14	this structure can hold, as we get into the licensing.
15	And it will be pretty close to what is in currently in
16	Tier 1 for Part 52.
17	It's supposed to be those things that are
18	most important, those things that licensees can't
19	control, can't change without prior approval. That
20	this logic will hold, and we can use this structure,
21	even as we go in, and it will be used throughout.
22	You're right, as we've used that language,
23	and again, if we could come up with different words,
24	maybe it would be better, but when we were developing
25	under Part 52, this tiered structure, in order to
I	1

(202) 234-4433

	76
1	identify what would be certified in the design, what
2	would require prior NRC approval of changes, what
3	would actually, quote, "be certified".
4	And then, under Tier 2, Tier 2 what would
5	be appropriate to be in the FSAR, and go beyond, and
6	provide more detail then what would be under the Tier
7	1 and included in the certification?
8	We had to develop that, and Derek, are
9	you over there? Thanks.
10	We had to develop that, and use it both in
11	a legal construct, in terms of the rulemaking in Part
12	52, and try to align it with the technical
13	distinctions.
14	Again, I think we can work, and try to
15	make this align as we get into the development of
16	Subpart H. Maybe we, that will be an area to see if
17	we're successful. That's all.
18	I think I'll leave it there, and see
19	did this help, hurt, or whatever? I think Walt, you
20	were the one that suggested maybe we could tweak this
21	figure to try to make it a little more clear. I tried
22	to do that, but Dennis, or any other members?
23	MEMBER PETTI: Well, my concern
24	PARTICIPANT: Hello?
25	MEMBER PETTI: is that by bifurcating
ļ	1

(202) 234-4433

	77
1	it, some people might comeback with the argument that
2	well, the first tier is right, the ones I really have
3	to meet, because they're the ones that are in the law.
4	And the second tier, I may not have to
5	meet, but that's not what the intent is. I don't know
6	how you argue against that, but whenever, you know,
7	separate things like that, that's a risk right there.
8	MEMBER BLEY: Well, and that gets to, you
9	know, that gets to be to be an interesting concept, in
10	that one of the things that might be different, and
11	especially when you look at the micro-designs, is
12	there's a possibility that they would have no Tier 1,
13	I mean the first tier.
14	Now I'm slipping. In other words, there
15	may be the ability to have inherent features such that
16	you wouldn't exceed 25 rem, which is a fairly high
17	threshold. But then the regulation of those micro-
18	reactors would be in the second tier, because they
19	would have to logically have controls on other things.
20	But then, I shouldn't say an absolute.
21	I'm not sure that even a micro-reactor would have
22	nothing in the first tier, but they could have very
23	little in the first tier.
24	And most of the regulation of the micro-
25	reactors could fall to the second tier, which would be
	I

(202) 234-4433

(202) 234-4433

78 1 appropriate, perhaps, in that they would have more flexibility, there would be fewer things they would 2 3 need to get prior NRC approval for, there would be 4 fewer safety-related components, and so forth. 5 So, it could be, one of the results of this, when you apply it to the micro-reactors, can be 6 7 a shift. And the second tier becomes the dominant 8 tier in terms of where the regulatory requirements 9 would actually be coming from. 10 MR. CORRADINI: That's okay, Walt, but just a quick follow-up. So, explain to me 11 the flexibility in the second tier. Maybe I'm missing it. 12 It strikes me a requirement is a requirement. 13 14 So, you just explained how the first tier might not be, what should I say, controlling, but the 15 second tier would be. 16 Where is the flexibility? It seems to me 17 the way this is presented, both of these are sets of 18 19 requirements that must be met. And normally the first two would be the controlling ones, the others would 20 Can you help me there? 21 not be. MR. RECKLEY: 22 Sure. MR. CORRADINI: And then I'll come to 23 Walt. 24 MR. RECKLEY: Well, the flexibility would 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	79
1	come in in what is built into the second tier for
2	flexibility.
3	If it's not requiring safety-related
4	equipment, then you have the flexibility of the whole
5	commercial market, for example, in order to procure
6	equipment.
7	In terms of programs, if it's not in tech
8	specs and it's in the FSAR, you have the you have
9	the additional flexibility of making changes without
10	NRC approval. So, there's where you get the
11	flexibility.
12	You still need to meet the rule, but the
13	rule would have built into it that the things
14	controlled under the second tier the licensee has more
15	control, has more ability to make changes, has more
16	responsibility put on them to maintain things in
17	accordance with their licensing documents as opposed
18	to having things defined in a structure such as
19	technical specifications and requiring prior NRC
20	approval.
21	So, at the highest level, yeah, they still
22	are regulatory requirements, but they have the
23	flexibility built into them, would be the goal.
24	So, I'm sorry, Walt. Go ahead.
25	MEMBER KIRCHNER: Yeah. Bill, after your
I	

(202) 234-4433

1 last presentation on this, I kind of thought that 2 rather than showing -- and it's not just the optics, but kind of consistent with Mike's question, I kind of 3 4 would think it would have been serial so that, as you 5 suggested there maybe for a larger power plant the 6 dose, you know, at the boundaries may be the controlling requirements. 7 I kind of thought of these serially. 8 I'm 9 very -- for example, safety functions. I think 10 defense-in-depth is part of the required safety functions, in my mind, that is built into the design. 11 12 And it may prove that with a smaller reactor they can, you know, very -- excuse the choice 13 14 of words -- deterministic manner address those and 15 show that they're well below both the QHO and the dose in 50.34 or 52.79. 16 So -- but you would still want to see that 17 defense-in-depth integrated into that diagram that you 18 19 showed earlier today and such. So, I kind of thought of them more serial 20 than in parallel, or either/or, that you would go 21 through each tier as you've shown them in a more 22 serial manner rather than in an optional manner; but 23 24 if it's a requirement, they're both going to apply. 25 So, maybe it's just my inability to

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

80

	81
1	perceive this correctly.
2	MR. RECKLEY: It's probably more likely my
3	limitations as a graphic artist, I think, and we're
4	not as the previous version of this, for instance,
5	under Safety Functions, just they listed the same
6	functions.
7	And I tried through discussion to say that
8	under tier under the first tier, if controlling
9	heat removal was a required safety function, then that
10	then at least one means of controlling heat removal
11	was going to end up in safety-related and in tech
12	specs, for example, and it's being set out to make
13	sure the dose relays under 25 rem.
14	MEMBER KIRCHNER: Yeah.
15	MR. RECKLEY: I had the same list of
16	functions under the second tier, but tried to explain
17	that the functions are basically the same.
18	I mean, equipment is either it's doing
19	something like removing heat or controlling
20	reactivity, but the reason you would have a second
21	system for heat removal is because of its risk
22	significance, its importance in defense-in-depth, its
23	contribution to the PRA, et cetera.
24	So, you would have an additional piece of
25	equipment for heat removal, but I understand the
l	I

(202) 234-4433

	82
1	discussion, then, was having the same functions listed
2	was confusing.
3	So, it's not easy to try to get this, at
4	least for me, try to show this, but that would be the
5	distinction.
6	So, if you're removing heat from a passive
7	reactor cavity cooling system under the first tier,
8	you might actually have some fans under the second
9	tier which, you know, you wouldn't want to rely on as
10	your primary means because now you have to power a
11	fan, but it might be a very good way to reduce the
12	overall risk by having a backup to the passive heat
13	removal system.
14	MEMBER KIRCHNER: And if I might, since
15	I've interrupted, under these required safety
16	functions, I would take a different attack than what
17	is listed here.
18	I like the first sub-bullet, of course.
19	That's the whole idea of preventing, you know, the
20	atmospheric release from your earlier diagram, but
21	control of heat generation, heat removal, chemical
22	interactions, that's going to be fairly design-
23	specific.
24	At a more fundamental level, I would
25	assert that if it's an advanced reactor, you can

(202) 234-4433

	83
1	maintain control reactivity and shut it down.
2	That, to me, is primary. It's the
3	fundamental thing about nuclear reactors from any
4	other power production system.
5	You want to control the integrity, as
6	designed, of the plant's fuel and inventory, and don't
7	you want to maintain the capability of those barriers
8	to mitigate prevent or mitigate the consequences?
9	So, I would assert that the three bullets;
10	control heat, regeneration removal, and the chemical
11	interactions, are more design features and that there
12	is a higher level of means to define the required
13	safety functions that I think would apply to almost
14	all reactors of any size and any fuel configuration,
15	including liquid fuel.
16	That's just but I'm concerned about the
17	absence of control of reactivity and the ability to
18	achieve a safe shutdown as a primary safety function.
19	That's just a member's opinion.
20	MR. RECKLEY: And it's good and we've
21	heard that in stakeholders I think we have a bullet
22	on that and we will get to it when we talk about the
23	feedback.
24	One of the reasons that we weight it out
25	the way we did in terms of these are examples of
Į	I

(202) 234-4433

safety functions that are likely to come into play, is 2 because under the advance reactor construct that we're trying to do for Part 53, in some -- since it's technology-inclusive, in some reactors the actual inventory -- or inventories that you have to look at 6 will vary.

7 And if there's a significant inventory in 8 waste gas, then the designer and licensees for that 9 design, where significant inventory is in waste gas, will have to define the safety functions for the 10 retention of that inventory and reactivity may not be 11 a safety function for that inventory. 12

And so, we needed the -- the thought was 13 14 we needed the flexibility to have this rule address 15 all of the all source the inventories, _ _ 16 traditionally all the source terms and the safety different for different 17 functions would be inventories. That was part of the logic. 18

19 MEMBER KIRCHNER: No, I agree with you. And I would assert that you need to maintain the 20 control and integrity of the as-design configuration 21 plant's fuel 22 of both the and its radionuclide inventories, whatever they are. 23

24 So, if they're a liquid fuel system and off-gassing 25 they're and, you know, they're

> **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

3

4

5

	85
1	accumulating fission product gases in some kind of
2	design vessel or something, that would, in my mind, be
3	part of a critical safety function, but that's
4	separate from control reactivity and shutdown.
5	MR. RECKLEY: Right.
6	MEMBER KIRCHNER: So, it may be in that
7	particular design that may be the most and this is
8	where the risk the PRA kind of analyses come in
9	that you may find that's your most that may be your
10	Achilles heel, so to speak, in terms of a contributor
11	to risk.
12	MEMBER REMPE: So, along that point I
13	really liked the approach you laid out in the prior
14	slide, Bill, and we discussed it, I think, in the
15	meeting we had a couple well, a month ago or
16	whenever.
17	But I also note that even in the existing
18	regulation the critical safety functions and guidance
19	documents are slide differently in different
20	existing literature that the staff has.
21	And a couple of weeks ago we had an
22	advanced reactor code meeting and they had gone with
23	a different layout than what you presented on the
24	prior slide.
25	And I like the this is the NRC and
I	I

(202) 234-4433

	86
1	today you mentioned it tied to the Atomic Energy Act
2	about controlling radionuclide release and then
3	defining subsidiary goals that make sure you can
4	control radionuclide release. The applicant would
5	come in and the staff would agree with them.
6	And so, I think consistently giving that
7	picture might be a good approach. What do you think?
8	MR. RECKLEY: Yeah, I think that I agree,
9	if we can. And it is very similar I mean, even
10	this construct is basically the same as the general
11	design criteria layout from 1968, or whenever that
12	activity was undertaken, in terms of if you look at
13	how that is laid out, it's basically laid out in terms
14	of reactivity fluid systems, which is really heat
15	removal, and the retention of radionuclides through a
16	structure. So, I think we're largely consistent.
17	I do agree with you to the degree we can
18	start to always talk about it in the same terms that
19	would be beneficial.
20	CHAIRMAN BLEY: You know, I appreciate
21	your (audio interference) here. I'm hanging up on
22	several points.
23	One, it seems like we're working really
24	hard to retain something that kind of grew randomly
25	over the years in response to those challenges.
ļ	I

(202) 234-4433

Two, adequate protection is a legal concept for minimizing the danger, I think I can easier think of it as a scientific concept, but (audio interference).

5 This picture that you gave us today works better than the one you gave us a week ago, but it 6 7 still -- I have trouble keeping it -- putting it all 8 together and seeing -- even though I've read C and D, 9 whichever one you looked at last month, and along the discussion you had with Walt, if you look at that 10 safety functions, required safety functions there in 11 the box, if one were to lay this out more logically I 12 think you could get closer. Of course you wouldn't 13 14 have this simpler presentation.

15 If you take this transcript and look at 16 your long discussion here for the last 10 minutes, 17 maybe that's the basis for trying to put together a 18 white paper and that would really help. If you're 19 laying out this logic and writing (audio interference) 20 pictures, you know, so people could see it and talk 21 about it, it would help.

22 MR. RECKLEY: Okay. Yes, it was a 23 suggestion last time and it's a good one. We will try 24 to do that.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

I don't know what form it would be in. We

(202) 234-4433

25

1

2

3

4

	88
1	are going to have to explain this in the Statement of
2	Considerations and other documents that we need to
3	prepare.
4	And so, to a degree we start to work on
5	that, which we need to, such a white paper could be a
6	vehicle.
7	CHAIRMAN BLEY: Yeah. I think so because
8	I, you know, this is kind of a key to at least the
9	language and much of the rest and at least to me it's
10	I know you want to be able to reflect this back and
11	show that we're doing many of the same things, but it
12	if your basis in 53, and I think it mostly is,
13	risk-informed, then these kind of arbitrary
14	distinctions don't work too well for me, anyway, you
15	know. It's the extent of a particular system's impact
16	on meeting the overall station performance of
17	retaining the radionuclides that's the real key and
18	they seem artificial.
19	We can't solve it here, so we can't
20	solve it very well or help you with that, something
21	coherent written down to work from.
22	MR. RECKLEY: Yeah. And one of the key
23	things that it might be subtle, but one of the key
24	things that drives this structure, which was a
25	decision at some point to maintain, was safety-related
	1

(202) 234-4433

	89
1	designation, Appendix B application, tech spec
2	control, that kind of a structure.
3	If you go back and, you know, we had these
4	discussions not recently, to be honest, because we had
5	them a long time ago and kind of internally decided on
6	this approach.
7	But if you go back and I know, Dennis,
8	you are very familiar, something like NUREG-1860
9	basically said let the risk-informed insights that you
10	get from the assessments determine what special
11	treatment is needed.
12	And special treatment can be graded and
13	you really may not need such things as the
14	designation, because you can let the system drive the
15	special treatment.
16	And that could include something all the
17	way to the application of NQA1 down to some graded
18	approach and not have these designations built in.
19	We did decide, for good or bad, that we
20	were going to keep this structure with safety-related
21	designations and application of the high level quality
22	assurance in NQA1, Appendix B. And that is really
23	driving, to a large degree, this structure in the
24	tiers.
25	So, as we go forward, you will continually
I	I

(202) 234-4433

	90
1	see that and, again, that can be a point of discussion
2	as we go through the iterations.
3	CHAIRMAN BLEY: I think so far some of
4	these things aren't separable. Tech specs are in the
5	first tier, but special treatment, which is laid out
6	in the tech specs, is second tier.
7	I mean, I just I have trouble feeling
8	this the real separability of these things.
9	MEMBER KIRCHNER: Dennis, if I might, I
10	have the same problem, Bill. That's why I suggested
11	something a little more serial.
12	I mean, going back to just your comments,
13	you know, the whole idea of risk-informed and such as
14	a top-level approach would suggest that the let me
15	just not to rebuild your viewgraph in real-time,
16	but give you an example in my own limited mind about
17	how I would approach this, the control of frequency in
18	consequences rather than being in second tier, I would
19	have it up at the top of the first tier above normal
20	operations. And then you go, you get normal
21	operations, unplanned events and so on.
22	And likewise, to me, having defense-in-
23	depth in the second tier just, as a former designer,
24	is just anathema to me. I mean, defense-in-depth
25	ought to be built into these safety functions. So,
I	I

(202) 234-4433

	91
1	that's what I meant be "serial."
2	Just as Dennis said, you would have tech
3	specs and then special treatment and license programs
4	would be part of the design features and programmatic
5	controls it.
6	I don't want I'm just not convinced you
7	need the second tier to address 182 and 161 and then
8	trying to split them to line up with each of those
9	raise, at least for me, some artificialities of what
10	you really intend, which is a more holistic approach
11	rather than an either/or kind of set of buckets to
12	work through.
13	CHAIRMAN BLEY: Maybe your next slide will
14	help us some.
15	MR. CORRADINI: Bill, can I ask one a
16	different question, though, because, Bill, you used an
17	example that I thought was interesting.
18	You said that if I had the reactor to be
19	small enough thermal output, then perhaps what you
20	define as "first tier" would automatically mean that,
21	and the only thing that would be controlling is what
22	you call "second tier." That implies that everything
23	fits in the same under the same umbrella.
24	Could you not have a parallel path that if
25	something if some design is small enough I don't
I	

(202) 234-4433

	92
1	even know what "small" is, but is small enough that
2	you would actually have a more restrictive
3	categorization kind of like the NPUF rule that you
4	have only allowable releases of 1 rem offsite.
5	And, therefore, with small machines,
6	whatever "small" is, you have a more deterministic
7	approach, but it's much simpler.
8	I'm what's troubling me is and,
9	again, I said this last time, but I'll just repeat
10	briefly, this as the size of the design gets
11	smaller, this becomes a really complicated overload of
12	regulation on something that ought to be very simple.
13	So, I guess I was asking there might be
14	a parallel way to do this if something if somebody
15	can and the parallel way might actually be more
16	restrictive.
17	It might be or essentially the second
18	tier might be the restrictive tier to do the
19	regulation upon.
20	I'm using the NPUF rule as an example
21	because I am not even sure if it's been approved
22	yet by the Commission.
23	But when we reviewed that a few years ago,
24	that essentially looked upon things in a manner that
25	was more deterministic.
	I

(202) 234-4433

	93
1	MR. RECKLEY: Yeah, for the decisions that
2	were being made under that rule, but yeah, as we
3	get into this next design and analysis, let's I
4	think we'll revisit this again and again. So, I
5	your comment, Mike, is one we're hearing from others
6	as well.
7	I would caution that if you go back to the
8	integrated slide, even the 1 rem number is for
9	evacuation, right?
10	And so, you have to look at what the
11	safety margins are being applied to to see even what
12	the right dose number might be if it was to be used as
13	a criterion.
14	And as we talk about and this might be
15	today or definitely in future meetings what is the
16	flexibility that people foresee if you want to focus
17	in on micro-reactors, there is an argument to be had
18	that the relaxations that are being sought in a whole
19	host of areas for those the possible deployment of
20	micro-reactors puts even additional onus on making
21	sure the design is to the highest standard that a
22	systematic approach, whether it be PRA or some other
23	systematic approach, has made very clear that the
24	risks are appropriate because the deployment models go
25	beyond and we may not need to evacuate the local
ļ	I

(202) 234-4433

	94
1	population. It goes even further than those potential
2	relaxations.
3	So, we get into that, I think, in the next
4	section. Let's go on, if we can, to slide 21 and
5	we'll talk about some of the feedback, which is
6	similar to the feedback we're getting here.
7	Let's start with the first bullet. Some
8	people say get rid of the second tier. The thing we
9	heard last time was from ACRS committee members
10	was, again, clarify the two tiers. We continually
11	hear them on this.
12	Going forward we hope to clarify it.
13	You'll see language in a few weeks when we release an
14	iteration.
15	But, as I mentioned, our expectation is
16	right now in order to make this differentiation
17	between the regulatory treatment across all of the
18	subparts, we continue to grasp onto this concept and
19	maybe want to give it one more shot in the next
20	iteration to see if we can provide additional
21	explanation and understanding of that.
22	Go ahead, Dennis.
23	CHAIRMAN BLEY: One thing that does come
24	together for me, but you know, see how it relates to
25	the discussion in the proposed rule (audio
Į	I

(202) 234-4433

1 interference) today, and it eludes me a little bit, is the distinction that we see in Part 52 with Tier 1 2 3 being the fixed things that you essentially have to 4 (audio interference) change to -- to the license to change. And Tier 2 still requires things you have to 5 have that using your tools of this management at the 6 7 plant you can change on your own, subject to the 8 inspection looking, you know, later by the staff. 9 That makes sense to me, but I -- I'll 10 leave it at that. MR. RECKLEY: Okay. And, again, we think 11 that would hopefully -- we're hoping, as we build this 12 out, that that construct would stay and that what we 13 14 call the "first tier" would align with Tier 1. 15 If there's something that is keeping the 16 dose less than 25 rem and the licensee is proposing to 17 make a change to it, that would require prior NRC And we get into this in the Operations 18 approval. 19 section. If it is less than that, for instance, it 20 is some of the equipment or programs that are aimed 21 primarily, let's say, at beyond design-basis events 22 and meeting the QHOs, then the applicant would have 23 24 the ability to change those on their own and include 25 them in an update. So, that general construct, we

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

95

	96
1	think, will stay.
2	We have to, as we work and put all the
3	pieces together, see if it does, but the initial
4	thinking is that it that construct you've described
5	should stay.
6	CHAIRMAN BLEY: Right. And this is
7	something you can't see now. If you did follow the
8	LMP and you came up with your licensing basis events,
9	those high consequence, higher frequency, the things
10	that under our current thinking might be beyond
11	design-basis would no longer be because they would
12	shift into the design-basis events that are covered
13	under Tier 1.
14	We kind of missed that here because we're
15	not seeing a practical application with this.
16	MR. RECKLEY: True. True. So, going
17	under that third sub-bullet there under the second
18	tier, there's some discussion of even if you keep two
19	tiers, whether the health objectives are the
20	appropriate metric, and some discussion about maybe
21	the development of an alternative metric to it to
22	the QHOs; or even if the QHOs are included, whether
23	they are put into the terms of the specific numbers of
24	the frequencies that we used in the first iteration.
25	So, again, one of the comments that we've received.
I	1

(202) 234-4433

	97
1	We do and this is similar, I think, to
2	the comment from Walt have a comment that as
3	opposed to saying the applicant is required to
4	identify the fundamental to identify safety
5	functions, to actually include the fundamental safety
6	functions, the ones we've been talking about, into the
7	rule proper, again, we're reiterating on that.
8	One of the things that goes into our
9	thinking, I mentioned one already, the need to address
10	inventories or source terms within the plant that are
11	different than the reactor core.
12	And then the other possible wrinkle is
13	that we're still holding open the possibility that
14	fusion energy systems would be also addressed within
15	Part 53.
16	And they would obviously have different
17	safety functions supporting the retention of
18	radionuclides within that type of a facility.
19	So, if we go down then to slide 22, one of
20	the big comments from our last meeting is the
21	potential to address chemical hazards or non-
22	radiological hazards. That was a good comment. We
23	currently have that under review looking at fuel cycle
24	facilities and other areas to determine how we would
25	address non-radiological hazards.
ļ	I

(202) 234-4433

	98
1	Another comment from external stakeholders
2	was to do away with, as well as reasonably achievable,
3	requirements in Part 53 and our reference to them in
4	Part 20.
5	Some members in our last discussion with
6	this subcommittee actually expressed the view to keep
7	ALARA. We're working on that iteration.
8	But for now, given the long history of
9	including "as well as reasonably achievable" in our
10	regulatory structure, our leaning is to maintain it.
11	MEMBER PETTI: So, Bill, I don't remember
12	recall reading the industry comments on that. To
13	me, one of the arguments for leaving it is that the
14	greatest risk for some of these facilities may be to
15	the workers themselves and less to the public.
16	And so, this allows at least a focus
17	there, you know, to recognize that it that a
18	distribution of risk, if you will, is different and
19	this gives it that high-level visibility.
20	MR. RECKLEY: And I know it's been, you
21	know, we summarize things here. Even the ALARA
22	discussion varies between stakeholders and what they
23	have proposed.
24	No one has proposed, as a operating
25	philosophy, doing away with it. It's just where if
ļ	I

(202) 234-4433

	99
1	and where and how it's captured in the regulations.
2	MEMBER PETTI: So, help me understand
3	that. Is there I mean, is there subtlety in the
4	legal sense? If it's in, you know, a different part
5	of a rule, they have to in Part 20?
6	I saw that later but they said, oh,
7	they're not throwing away ALARA. They just don't want
8	it over here. It's okay to be over there.
9	I mean, tactically, does that change
10	something?
11	MR. RECKLEY: It has a potential, I think.
12	When we included it in Subpart B as kind of a primary
13	factor to consider and then something we would carry
14	through all of the subparts, one of the areas of
15	concern was the degree to which ALARA is then brought
16	into the design process. And a designer would be held
17	to showing how the design meets an ALARA concept.
18	So, it is tricky in that something like
19	ALARA is accomplished by all the things we continually
20	put together in our discussions.
21	It's part of the design, it's part of
22	programmatic controls, and it's even part of the human
23	element associated with operations.
24	And so, when we break out an area like
25	design and say design in combination with programmatic
I	1

(202) 234-4433

	100
1	features needs to support ALARA, there is a concern
2	about how that would be implemented.
3	So, I understand where the concern is
4	coming from. I don't have a perfect solution to that
5	concern.
6	But from my perspective, as you've
7	mentioned, both in terms of occupational and public
8	releases, as well as reasonably achievable, the design
9	process has always been an element.
10	So, I how this would actually work, I
11	mean, we when we're interacting with stakeholders,
12	you have to and I would do the same if I were in
13	their boat. They have to not only look at what the
14	requirement is, but how might it be interpreted, how
15	might an inspector look at them and say, show me where
16	you meet this requirement. So, that's part of the
17	concern.
18	Then the last bullet, protection of plant
19	workers. Again, there was some concern about having
20	it up in Subpart B as kind of a primary objective of
21	the whole Part 53 effort.
22	And there was also some concern that we
23	were cutting and pasting and potentially paraphrasing
24	things from Part 20.
25	So, our preliminary thought is to keep
I	1

(202) 234-4433

	101
1	protection of plant workers much along the lines,
2	Dave, as you were mentioning. It's always been
3	important.
4	For some designs the and actually even
5	for existing plants if you look up societal dose,
6	protection of the workers are probably higher than the
7	public. That will be even more so potentially for
8	some designs.
9	So, we're proposing to keep it and but,
10	to avoid confusion, we can refer to Part 20 as opposed
11	to paraphrasing.
12	So, that is the feedback we've received on
13	Subpart B. If you want to stay here for a second or
14	we can jump into how this gets reflected in the design
15	and analysis subpart.
16	MEMBER KIRCHNER: Just a quick, minor
17	point, Bill. This is Walt Kirchner.
18	When chemical releases, there is the
19	distinct possibility of having mixed releases with
20	some designs, and that makes things like your earlier
21	diagram in terms of returning the fission product
22	barriers and overall meeting the safety objectives
23	perhaps much more difficult.
24	So, it's just not chemical releases as a
25	chemical release. There's the distinct possibility of
ļ	I

(202) 234-4433

	102
1	mixed releases and then interaction of the chemicals
2	with the environment or that would be of concern,
3	fire and other hazards.
4	MR. RECKLEY: Okay. Yes, thank you.
5	Yeah. And, again, we're looking
6	MEMBER KIRCHNER: I wasn't trying to make
7	this more complicated
8	MR. RECKLEY: Right. No.
9	MEMBER KIRCHNER: but if it's a
10	chemical that's carrying a fuel, that becomes a much
11	more difficult proposition.
12	MR. RECKLEY: Right. And you're looking
13	at both the radiological toxicity and the chemical
14	toxicity and, yeah, it's more complicated across the
15	board.
16	So, we are looking at, again, using the
17	fuel cycle facilities that face some of these
18	challenges as well.
19	It might be or probably will be more
20	complicated, in a reactor sense, because you have a
21	wider set of radionuclides involved and you have at
22	least, depending on some designs, a wider set of
23	chemical hazards involved. And then, as Walt just
24	brought up, the potential mixing of the two. So, as
25	if we didn't have enough on the plate, but we agree
	I

(202) 234-4433

	103
1	that it needs to be addressed.
2	So, any other mentions or we're starting
3	on Subpart C?
4	(Pause.)
5	MR. RECKLEY: Let's go on, then, to slide
6	23. Okay. All we're setting up here is its context
7	in the general layout of our Part 53 structure.
8	We go on then to 24, just a kind of a
9	preview of what we'll be discussing. This is the
10	sections as they're currently laid out, the overall
11	design objectives, the design criteria for meeting the
12	first tier safety criteria, meeting the second tier
13	safety criteria, currently have a criteria for
14	protection of plant workers and, in this version, some
15	related design requirements. Then we get into the
16	analysis section, the categorization and special
17	treatment of equipment.
18	Going on then to slide 25. This, I think,
19	will be an area where we can have some really
20	meaningful discussion.
21	The application of analytical safety
22	margins to operational flexibilities, and this really
23	relates to some of the discussions we've already been
24	having in the relationship to micro-reactors in
25	particular, perhaps, in terms of simplifying possible
ļ	I

(202) 234-4433

	104
1	approaches and so forth in design, quality assurances
2	related to design, and then some interface activities.
3	So, before we get in, I just it might
4	be subtle, but the kind of language that we're using
5	here as we go down in terms of level of detail is
6	we're starting off with the safety criteria.
7	We talked about those under Subpart B.
8	Those are currently in the iterations, the 25 rem
9	number from 50.34 and the QHOs for the second tier.
10	So, those are the safety criteria.
11	Then we say under Subpart B, you have to
12	identify safety functions to meet those criteria.
13	Then we say you need to identify design features,
14	human actions and programmatic controls to meet the
15	safety functions.
16	So, if the safety function is heat
17	removal, a design feature might be the reactor cavity
18	cooling system.
19	And then you would have human actions and
20	programmatic controls to meet that to support that
21	design feature.
22	The next level down and what we start to
23	talk about under this section, Subpart C, Design and
24	Analysis, we introduce the term "functional design
25	criteria," which is to take the design feature that's
	I

(202) 234-4433

	105
1	being used to support a safety function and actually
2	laying out what characteristics does that design
3	feature need to perform its job.
4	So, that's kind of the language we used.
5	I know it can get lost in the discussion. So, I
6	thought I would start off with at least trying to say
7	this is how we're using these terms.
8	MEMBER BROWN: Bill, what slide are you
9	on? I've got you're on 24; aren't you?
10	MR. RECKLEY: Actually, I was just laying
11	that out before we go on to
12	MEMBER BROWN: Oh, I'm sorry.
13	MR. RECKLEY: the next discussion.
14	MEMBER BROWN: Alright. Thank you.
15	MR. RECKLEY: So, it's just kind of
16	background. Yeah, sorry. I should have had that on
17	a slide, but I didn't have that structure.
18	But even in the table of contents you're
19	seeing things like "functional design criteria" or
20	the "functional design criteria," that's the
21	terminology we use. So, sorry about that, Charlie.
22	If we go down, then I guess we can get
23	into the first specific subpart section, which is 400,
24	on the design objectives for this subpart.
25	And so, basically just kind of, in general
l	I

(202) 234-4433

	106
1	terms, saying the objective of this section, or
2	subpart, is to establish the overall design
3	objectives, tying them back to the safety criteria and
4	the identification of safety functions from Subpart B;
5	and to require that the design features that are
6	identified, when combined with the associated
7	programmatic controls, provide reasonable assurance
8	that the safety criteria, either the tier first
9	tier or second tier safety criteria are met.
10	And we'll talk about that as we talk about
11	the specific sections. So, that's the overall
12	objective of this subpart.
13	We go down then next to 410. This is
14	maybe this would have been a better place to have the
15	discussion I was having on the terminology, but this
16	then Sections 410 and 420 are basically requiring
17	that functional design criteria be established for
18	those design features.
19	So, this is going to be things like heat
20	removal rates and, you know, the actual things that
21	are needed to define what a design criteria what a
22	design feature needs to have in order to fulfill its
23	function.
24	MEMBER BROWN: Bill?
25	MR. RECKLEY: Yes, Charlie.
	I

(202) 234-4433

	107
1	MEMBER BROWN: 410 this is a question
2	on terminology that I got lost on when I was looking
3	at it.
4	410 starts the title "Functional Design
5	Criteria for First Tier Safety Criteria." Then A is
6	"Functional Design Criteria," virtually a repetition
7	and you go through the rest of it.
8	In 420, you say "functional design
9	criteria for second tier safety," but you start off
10	with "design features."
11	Is there a distinction between first tier
12	and second tier that you don't need "functional design
13	criteria" down in the text?
14	You switched over the terminology of
15	"design features" whereas you used in A and B of 410
16	"functional design criteria" within the A and B
17	itself, and I was wondering if there is a distinction
18	that I lost.
19	MR. RECKLEY: It might be an inconsistent
20	way we've laid these out, which would be you know,
21	we will take that comment and look for consistency,
22	but 420 does require, later in the paragraph, for
23	functional design criteria to be defined for each
24	design feature used to meet the second tier.
25	It is perhaps very confusing, as you point
ļ	

(202) 234-4433

	108
1	out, that we didn't keep the same sentence structure,
2	but the intent is it's the same.
3	MEMBER BROWN: I just if you look at
4	410, Item A says, functional design criteria must be
5	defined for each design feature.
6	420 doesn't start off by saying,
7	functional design criteria must be provided for each
8	design feature. It the terminology is just flipped
9	around. That's all I we ought to be consistent.
10	I'm just hoping I didn't lose the
11	technical understanding. That's what I was worried
12	about.
13	MR. RECKLEY: Yeah. I mean, for example,
14	under 420 B, but we don't do it until the middle of
15	the paragraph, we do say, functional design criteria
16	must be defined for each design feature relied on to
17	demonstrate compliance with the second tier safety
18	group.
19	MEMBER BROWN: I got it.
20	MR. RECKLEY: But your point is well
21	taken. By having them in different places, it can be
22	confusing. So, we'll look at that.
23	The intent was the same. We may have
24	it's just the way we did the sentence structure.
25	MEMBER BROWN: "Design features," to me,
	1

(202) 234-4433

	109
1	are things you put in place to meet functional design
2	criteria and it seems like the first tier just
3	reversed the way we were operating them.
4	So, that's all I I'll stop and you can
5	deal with that.
6	MR. RECKLEY: Yeah. We will look at the
7	language. Thank you.
8	CHAIRMAN BLEY: Can I get in a chance to
9	
10	MR. RECKLEY: No, no. That's fine.
11	CHAIRMAN BLEY: In Subpart B, or in any of
12	the other subparts, do you anywhere lay out the thing
13	you told us earlier that Tier 1 are things you have
14	made a a change to the licensing basis to change,
15	and Tier 2 are things that could be done by the
16	licensee.
17	MR. RECKLEY: What you are seeing not
18	yet. That will get reflected in the future subparts
19	like on licensing and the control of licensing and
20	even, to some degree, under operations.
21	CHAIRMAN BLEY: Okay.
22	MEMBER BROWN: Yeah, Dennis, I did not
23	equate the second tier to the Part 52 Tier 1 and Tier
24	2 they way you said it.
25	CHAIRMAN BLEY: And the last time either,
	I

(202) 234-4433

	110
1	but I think Bill's made clear that's the intent.
2	MEMBER BROWN: Okay. That might ought to
3	be hopefully it should be reflected earlier rather
4	than later because I thought this Tier 2 stuff here in
5	Part 53 was like Tier 1 stuff, but just of a little
6	lesser importance, but didn't allow the applicant to
7	change it on his own.
8	That was the way I read this, so I lost
9	that distinction.
10	CHAIRMAN BLEY: The other thing I was
11	going to ask, because I think I heard this, there
12	isn't a distinction between Tier 1 and Tier 2 that
13	Tier 1 you have to do, Tier 2 you ought to do. These
14	are all requirements that have a different level of,
15	maybe, oversight.
16	MR. RECKLEY: That's right.
17	MR. CORRADINI: But the oversight is not
18	specified here.
19	MR. RECKLEY: Yeah. And that's the
20	difficulty of trying to in my novel analogy, trust
21	me, we'll get to that in Chapter 8. You're looking at
22	Chapter 2.
23	MEMBER BROWN: Yeah, but why shouldn't
24	Part B make that distinction since it's the overall
25	safety objectives?
	I

(202) 234-4433

	111
1	Why shouldn't that make the distinction
2	between first tier and second tier the way you just
3	phrased it?
4	MR. RECKLEY: Again, once we put it all
5	together, hopefully it will be people will be able
6	to see it in total and understand how the pieces fit
7	together.
8	But once we do that, if it makes more
9	sense from a clarity standpoint to have some of this
10	discussion under Subpart B, we can certainly look at
11	that.
12	But, again, the thinking was that you
13	start off at this high level and you make everything
14	consistent with it and hopefully when we get into the
15	licensing area, we can remain consistent, but it all
16	derives from these higher level principles.
17	And so, the licensing process is would
18	be driven by its relation to this higher level
19	discussion, not the other way around, was what we were
20	hoping.
21	CHAIRMAN BLEY: So, we're not doing
22	Subpart B today, but one last comment on that.
23	MR. RECKLEY: Yes.
24	CHAIRMAN BLEY: The thing that got me
25	started off wrong, if you will, is 53.22, the safety
ļ	1

(202) 234-4433

	112
1	functions when we read that and then immediately go
2	into first tier safety criteria and it felt like there
3	should be a link between the safety functions and the
4	two tiers of safety criteria, but there are not. And
5	that really set me astray, I think.
6	MR. RECKLEY: Okay. And, again, it's a
7	challenge to put this together. To be honest, one of
8	the things that we did do is switch around the order.
9	So, safety functions now follow the design criteria
10	the first tier/second tier safety criteria.
11	(Simultaneous speaking.)
12	MR. RECKLEY: I know. So, let me see.
13	MEMBER BROWN: As opposed to Dennis making
14	the last comment in that relation, when I go back and
15	I look at Part B, I hate to say this, when you talk
16	about the first tier safety criteria, they all seem to
17	be firmly rooted in limiting things to, like, the 0.1
18	rem for this or the 25 rem for that, et cetera, et
19	cetera. That's in the first tier.
20	When you get to the second tier in Part B,
21	it starts it talks about those same things.
22	However, you throw in the "as well as reasonably
23	achievable" and you throw in well, maybe the
24	economics get thrown into this and you may not have to
25	do anything if it costs too much.
ļ	I

(202) 234-4433

	113
1	That seemed to be a really big difference
2	between Tier 1 and 2 the second tier and first tier
3	in Part B.
4	And it makes it certainly makes the
5	second tier safety criteria seem, well, if it costs
6	too much, they're not important. I'll leave you with
7	that for future
8	MR. RECKLEY: And in terms of the normal
9	operations, that is clear because the whole discussion
10	of ALARA includes a cost element.
11	So, that's
12	MEMBER BROWN: I got that. It's just
13	MR. RECKLEY: and that's intentional
14	and that is the flexibility that is provided by the
15	two tiers. We've been talking about what's the
16	difference. That is it's a large difference.
17	The numbers are lower, the performance
18	goals are significantly lower than 100 millirem, but
19	it also includes the ability to consider costs in the
20	assessment.
21	And that is generally aligning with the
22	whole concept of adequate protection, which means you
23	have to provide it and we don't care how much it
24	costs.
25	And the second tier, which goes to a
	I

(202) 234-4433

	114
1	different part of the Atomic Energy Act and that part
2	of the act that we've traditionally employed primarily
3	for backfit analysis where a risk threshold and
4	considering cost implications are allowed.
5	So, again, I think it fits not only within
6	Part 53, but it fits with how we've generally operated
7	over the years.
8	MEMBER BROWN: Well, my only thought if I
9	had 53.200 talks about safety objectives. That
10	paragraph would have been ideal at the end if you had
11	said, within that we've established two tiers; one
12	like this and the other one with the ALARA, et cetera,
13	et cetera. So it instead of having to root it out,
14	that's all.
15	MR. RECKLEY: Okay.
16	MEMBER BROWN: It's tough to figure it out
17	as opposed to having a quick statement of how you've
18	divided it up.
19	You divided it up by having the two
20	separate sections and hopefully people can figure out
21	what the difference is.
22	I'll quit now. I'm sorry.
23	MR. RECKLEY: No, no, no, you know,
24	clarity is the goal here. And so, these kind of
25	observations on how we might structure it and
ļ	I

(202) 234-4433

115 discussions like this where we're not really changing 1 what the technical requirements might be, but just 2 trying to make them more clear are good comments. 3 4 So, we will go back and look at how we would put this together. 5 6 MEMBER BROWN: Okay. I am not objecting 7 to the approach. This is just а matter of 8 understanding it. Until we had it today, I didn't quite put 9 10 all that together until I went back again and reread Part B again. 11 MR. RECKLEY: Okay. 12 MEMBER BROWN: It just took me a while. 13 14 MR. RECKLEY: Okay. 15 MEMBER PETTI: I think the thing that I'm taking away is if -- I know it's hard. This is worse 16 17 than writing a novel -- is to somehow embed succinctly a rationale in the rule without it getting, you know, 18 19 overly wordy. Because that's what people are tripping on 20 because there's not a rationale that they can easily 21 access to understand, you know, why the flow is the 22 way the flow is. 23 24 MR. CORRADINI: Yeah. And, in fact, Bill, I think the way you said it in explaining to Charlie 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	116
1	was probably the most succinct way that I hear about
2	it relative to there is a risk threshold and a cost
3	threshold for the second tier requirements that don't
4	exist for the first tier. At least that's what I
5	heard you say.
6	MEMBER BROWN: That's excellent, Mike.
7	Thank you. Bill's explanation then was very clear.
8	Put it in Part B 53.200.
9	MR. RECKLEY: Okay. Thank goodness you
10	guys take transcripts. We'll go back to see how that
11	was said and we'll try to do better.
12	So, the note here was turning also to
13	just to point out there are parallel activities and,
14	at some point, your subcommittee will start to hear
15	about these other activities like the technology-
16	inclusive content application and advanced reactor
17	content application, two very similar activities, that
18	are looking to address not only the traditional
19	content of application, but also where we might
20	improve in terms of performance-based approaches to
21	regulation.
22	And the reason that's brought up on this
23	slide is historically one of the areas of concern is
24	how much of the initial licensing review is associated
25	with things like ALARA and the design aspect in
ļ	I

(202) 234-4433

117 1 conformance with -- to Appendix I of Part 50 and so forth. 2 3 And we are thinking and developing some 4 guidance, there's actually even been draft language 5 put out, in terms of content of application where some of this can adopt a more performance-based approach 6 7 and move some of the review from the initial design to 8 a performance-based element. 9 So, it is just a note that there's other 10 activities underway and that note is especially as it relates to ALARA in the first sub-bullet of the second 11 So, with that, I think we can go to slide 28. 12 tier. 13 MEMBER PETTI: Just a question on 27. 14 MR. RECKLEY: Yes. 15 I'm struggling with just MEMBER PETTI: 16 the English, "design features and functional design 17 criteria are determined through analysis." Are you meaning that the design features 18 19 are validated that they meet the functional design criteria, analysis is used to validate the design 20 features meet the functional design criteria? 21 MR. RECKLEY: Oh, thanks, Dave. Actually 22 that's a -- I was trying to make a distinction in both 23 24 for the first tier and the second tier that for normal 25 operations ultimately you can have a performance

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	118
1	measure actually related to the release of effluence.
2	And, from a regulatory perspective, we can
3	come back and say we didn't look at your design in as
4	much detail as we may have historically, but we can
5	tell right away you're not meeting the performance
6	goals set out apparently set out in Appendix I to
7	Part 50, which is, you know, a couple millirem per
8	year.
9	Therefore, there's a performance-based
10	approach that can be taken for normal ops and showing
11	that you meet the 25 rem number or the QHOs, that's
12	done by analysis.
13	You can bring in performance-based
14	elements, but that it's not, per se, a measurable
15	parameter. It's you're showing compliance through the
16	analysis that you do.
17	Is that more clear?
18	MEMBER PETTI: Okay. And then just the
19	second question on the functional design criteria. In
20	some guidance, you'd point them potentially to the
21	advanced reactor design criteria as examples of
22	criteria that are associated with safety functions?
23	MR. RECKLEY: Yeah. They could bring in
24	Reg Guide 1.232 as an example of how they are meeting
25	safety functions.
ļ	I

(202) 234-4433

	119
1	And the advanced reactor design criteria
2	does go a little beyond design functions and starts to
3	talk about design features and even functional design
4	criteria. So, the but that so, yes, they could
5	refer to that.
6	We haven't looked exactly where the ARDC
7	how far they go in terms of the functional design
8	criteria. That's a it's a good observation.
9	We'll go back and look to see if the at
10	what level does the ARDC go down to.
11	MEMBER PETTI: Alright.
12	MR. RECKLEY: Okay.
13	CHAIRMAN BLEY: Bill?
14	MR. RECKLEY: Yes, Dennis.
15	CHAIRMAN BLEY: To me, it feels like we're
16	just back from the break, but I expect many of you
17	back on the east coast are ready for lunch and this is
18	where we had it scheduled.
19	Although we were just really getting into
20	Subpart C, we are (audio interference) slides at this
21	point. So, this could be a good place.
22	If anybody wants to say anything about
23	that, do it. Otherwise, I'm going to declare a lunch
24	break now.
25	(Pause.)
l	I

(202) 234-4433

	120
1	CHAIRMAN BLEY: We're going to recess for
2	lunch for one hour. Be back at five after 12:00 here,
3	five after 2:00 out where those of you in the east
4	are. We are now in recess.
5	(Whereupon, the above-entitled matter went
6	off the record at 1:06 p.m. and resumed at 2:05 p.m.)
7	CHAIRMAN BLEY: Okay. We are now back in
8	session. I've heard from one member, so I know we
9	have a quorum for the subcommittee.
10	Bill, before I turn it back to you, two
11	quick questions. One for now, and one for two slides
12	from now.
13	The first one is Ron said you had found
14	that old DOE paper. If you have something more recent
15	that you folks are hanging your hat on, or something
16	you've written, we'd be interested in seeing that.
17	And the other one, you know, the
18	functional design I'm sorry, the design
19	requirements of Section 440, there's a way that I
20	think I've seen elsewhere and it seems odd to me a
21	little, but maybe it's common, that says the system
22	shall be designed using generally accepted consensus
23	codes and standards wherever applicable.
24	Is that "wherever applicable" language
25	common? It seems like it's just begging people to
ļ	I

(202) 234-4433

	121
1	say, well, it doesn't apply.
2	So, on those two things, I'll turn it back
3	to you. Whenever it's convenient, maybe you can
4	address them.
5	Bill?
6	MR. RECKLEY: Thank you, Dennis. Yeah,
7	I'll get to that when we talk on the consensus codes
8	and standards.
9	I'll look for the DOE handbook. It seems
10	like that's the general time frame back in 2012, I
11	think, or whatever edition that was.
12	We can talk later. Something else out of
13	the general construct of the DOE orders handbook and
14	standards that we had raised to stakeholders actually
15	in the first meetings when we were talking about the
16	design criteria, that we still are searching to see if
17	it might have a role, is the use in the DOE
18	terminology and approach of a new mitigated event and
19	whether that might be a vehicle to, I think, as Mike
20	Corradini and others have suggested, it may be as a
21	way to greatly simplify matters in the DOE approach.
22	And it's been reflected in seismic design
23	criteria and in ANS 2.26 as well that if you can do an
24	unmitigated event and show it is below certain
25	thresholds, then you can, in the seismic design
	I

(202) 234-4433

	122
1	category, take that into account in both your design
2	of the structure and even what seismic hazard to
3	consider and we're still trying to toy with that.
4	Part of the issue and, again, this is
5	where if there's anybody with knowledge otherwise,
6	part of our hesitancy in exploring that further is we
7	have not seen any literature that even micro-reacttors
8	would show that an unmitigated event would be below
9	the thresholds that people are interested in, whether
10	it be the 1 rem number, or perhaps even lower,
11	depending on what relief they're seeking.
12	But I'll just drop that as a bug and if
13	anybody has insights, we'll probably come to a point
14	in a couple slides from now where that might be
15	brought into the discussion.
16	So, we've talked about this slide. Again,
17	the requirement being to come up with the functional
18	design criteria for any design feature for the
19	unplanned events for both the first tier and the
20	second tier.
21	So, in our first iteration that was
22	released, we kept or we had a design requirement in
23	this subpart to look at the protection of plant
24	workers in both the Part 20 upper limits, firm limits,
25	and then also the ALARA requirements in Part 20.
ļ	I

(202) 234-4433

	123
1	As the note says, there's been some
2	discussion from stakeholders. We have slides at the
3	end of this subpart.
4	And, I'm sorry, Dennis, one thing I did
5	want to mention, the siting subpart is less
6	complicated an actually has fewer exchanges. And so,
7	the time we have allotted for that is probably more
8	generous than it needs to be.
9	And so, if it's okay, I think we can
10	extend this design and analysis discussion a little
11	past the agenda time frame because we can make up for
12	it in the siting subpart.
13	CHAIRMAN BLEY: Yeah. That's what it
14	looked to me as well. So, okay.
15	MR. RECKLEY: So, as I mentioned here,
16	there has been some stakeholder feedback on whether we
17	include the protection of plant workers and how much
18	it's included within the design requirements that
19	we've defined. So, that will be a matter we can
20	discuss as we go into future iterations.
21	MEMBER KIRCHNER: Bill, this is Walt
22	Kirchner.
23	It would seem to me that referencing 10
24	CFR Part 20 is appropriate so that you don't have
25	inconsistencies, but having functional design criteria
I	I

(202) 234-4433

	124
1	for protection of plant workers seems to make sense
2	here to me at this point in terms of flushing out
3	design criteria.
4	I'm tempted to ask, or just make a note,
5	that this recent event at NIST, which I have to admit
6	I'm not well-informed on, but where workers evidently
7	were exposed, would suggest that this kind of criteria
8	belongs here.
9	MEMBER PETTI: So, yeah, my concern
10	we've struggled with this in the fusion program.
11	Tritium control in a fusion mission, or any mission,
12	has a lot of tritium. You could do it with bubble
13	suits or you can put glove boxes around lots of
14	equipment. One is an administrative sort of control,
15	the other is an engineering design control.
16	And the push was obviously for the
17	engineering design control. Yes, it costs more money,
18	but it was a surer way to protect the LOCAs. And
19	given the inventories involved, just the historical
20	precedence at Savannah River and other places that
21	dealt with tritium was that that's what we should do,
22	but putting it here makes me think about an
23	engineering solution instead of purely an
24	administrative solution. So, I think it's correct
25	there.
I	I

(202) 234-4433

	125
1	MR. RECKLEY: Okay. Thank you.
2	MEMBER KIRCHNER: It's also consistent
3	with the past advanced reactor policy statements
4	where, you know, less reliance on programmatic
5	administrative controls and more reliance on, you
6	know, design features is one of my take-aways from the
7	advanced reactor policy statements.
8	MR. RECKLEY: Thank you, Walt. That's
9	just what I was about to also observe that it is
10	consistent with the overall agency position that it's
11	best to do it in the design process as opposed to rely
12	on programmatic or human actions in other areas. So,
13	again, we're considering this both in wording and the
14	overall resolution of public comments.
15	We can go on to slide 29.
16	CHAIRMAN BLEY: Bill?
17	MR. RECKLEY: Yes, Dennis.
18	CHAIRMAN BLEY: I agree with my colleagues
19	on this one (audio interference) operating in a
20	facility or (audio interference) performance (audio
21	interference) administrative controls that are (audio
22	interference) source of problems that (audio
23	interference).
24	But we had talked with you folks and
25	decided we didn't really have any key points at which
Į	

(202) 234-4433

	126
1	a letter from the Committee was necessary until we get
2	(audio interference). But if there are any areas,
3	this one just pops in my head, where a letter would be
4	useful, we can always do that. So, go ahead.
5	MR. RECKLEY: Okay. And, you know, there
6	will be decision points throughout the process. Like
7	I said, we're preparing our next iteration that will
8	include some changes to both Subparts B and C, and in
9	some areas a conscious decision not to make changes.
10	And then we'll see what, you know, what
11	the feedback is from stakeholders both external, ACRS,
12	and then also we have to run all this through
13	internal.
14	So, there may be points where a position
15	needs to, you know, a flag needs to be planted or
16	whatever.
17	I think the next iteration in the
18	discussions right after that would be would
19	probably be the point for that.
20	And this slide, Section 440, goes to
21	Dennis' question about the language of design features
22	used in generally accepted consensus codes and
23	standards and, you're right, in the language we say
24	"where applicable."
25	One of the reasons we feel it necessary to
I	I

(202) 234-4433

	127
1	put that in is, in some cases, there may not be
2	consensus codes in standards or an applicant might
3	choose not to use them.
4	In which case, they would have to make a
5	they would have to make all of the arguments that
6	would otherwise be resolved through the referencing of
7	the consensus code and standard.
8	But the primary reason we put in "wherever
9	applicable," at least for my first draft, was there
10	will be plenty of places where for advanced reactor
11	design to at least for some number of years there may
12	not be consensus codes and standards available.
13	CHAIRMAN BLEY: I suggest we use more
14	explicit language so it's clear what you mean.
15	MR. RECKLEY: Okay. We'll look at that.
16	MEMBER BROWN: I have another comment on
17	that.
18	We talk about consensus codes and
19	standards. Is that inclusive of current NRC Reg
20	Guides, interim staff guidance, branch technical
21	positions, et cetera, like that or this is in the
22	stuff segueing in from the commercial world?
23	It seems to me kind of I mean, in my
24	particular area, the I&C has you're going to need
25	instrumentation, going to need controls, you're going
I	I

(202) 234-4433

	128
1	to need protection systems of some sort.
2	The NRC guidance and requirements that you
3	have today, the Reg Guides are pretty are virtually
4	technology neutral and even plant characteristic-type
5	neutral. They can be whatever you want them to be,
6	but their guidance is certainly applicable.
7	So, you don't even mention the NRC
8	standard regulatory guides and other documents,
9	NUREGs, et cetera.
10	MR. RECKLEY: And what we do mean here is
11	those things that are set by standards development
12	organizations. So, IEEE, ANS, ASME, et cetera.
13	We don't mention NRC guidance in the rule,
14	but would certainly hope and we're looking now in
15	a number of areas where existing guidance might be
16	available to use to help show compliance with some of
17	the requirements here or even one level down from what
18	this rule language is going.
19	Once you were to determine, for example,
20	in the area of I&C, once you were to determine that
21	there will be a design feature associated with I&C and
22	then you can set functional design criteria for what
23	it needs to deliver in terms of timing and accuracy
24	and so forth, then it might very well be that there's
25	an existing Reg Guide that would support a particular
	I

(202) 234-4433

	129
1	design or approach.
2	So, we don't refer to it, but we would
3	certainly hope that some of that material would be
4	relevant and usable once you get down into the design
5	of a specific system, for example.
6	MEMBER BROWN: Well, the NUREG the new
7	design DRG will be NUREG-800 Chapter 7 if it ever
8	gets to that point. A new edition or separate. It
9	embodies the framework from within which you would
10	develop your design. And how you can hope that maybe
11	somebody will decide that that's useful doesn't seem
12	to make a whole lot of sense to me.
13	MR. RECKLEY: In any case, that's a good
14	example of and we don't typically mention our own
15	guidance within the real language, but that guide is
16	developed in the same time frame as we're doing this
17	activity.
18	So, that would be a good example where we
19	certainly hope that guidance would help people meet
20	the requirements when they are looking at the role of
21	I&C in the design.
22	MEMBER BROWN: So, you're telling me the
23	existing 50 and 52 Part 50 and 52, all the existing
24	rules don't have any reference at all to NRC?
25	MR. RECKLEY: I'll say the number of rules
ļ	I

(202) 234-4433

	130
1	that refer to Reg Guides or any kind of guidance
2	documents is rare.
3	I think maybe the ASME code case Reg Guide
4	is mentioned in the rule, but very few Reg Guides are
5	mentioned in rules because it usually goes the other
6	way around. The Reg Guide is developed to show how
7	you comport with the rule.
8	MEMBER BROWN: That's disturbing.
9	MR. RECKLEY: Okay. Going on then but,
10	by the way, the reason we want to do this is it's
11	encouraged by Congress, and also even within NEMA,
12	they continue to encourage the maximum use of
13	consensus codes and standards.
14	And so, we did this the reason we say
15	"generally accepted," is here is one area and the text
16	box is highlighting the potential issue, is that we
17	didn't want to be really specific because one of the
18	comments we're getting from stakeholders is I think
19	somebody mentioned in the QA area, might it be
20	possible to use ISO standards?
21	In other areas, if there are either ISO
22	standards, even potentially standards from other
23	countries or entities that are generally accepted,
24	might this rule make it easier to apply those
25	consensus codes and standards instead of the
l	I

(202) 234-4433

	131
1	traditional references to specific standards like ASME
2	and, to some degree, IEEE.
3	So, that's something we'll be talking
4	about as we go forward and exactly the language. And,
5	Dennis, I made a note on our language there.
6	So, the next one is just overall design
7	requirements in oh, I'm sorry. Yeah, on the next
8	bullet, the materials must be qualified for their
9	service conditions over the plant lifetime and have an
10	element or code requirement embedded. Its safety and
11	security must be considered together.
12	That's coming out of the advanced reactor
13	policy statement. I'll get to that. That's an area
14	we're getting comments on.
15	CHAIRMAN BLEY: I really like that, Bill.
16	I'm glad you said that.
17	MR. RECKLEY: Okay. Then the last one
18	here is if we're looking at the language to this,
19	what this one was intended to do was capture the code
20	requirement in 50.43(e) that basically says when
21	you're bringing forth the engineering approach, it has
22	to be proven by a combination of analysis, test
23	programs, the potential use of a prototype plant and
24	operating experience.
25	I think the way we worded it initially it
	I

(202) 234-4433

	132
1	maybe lost a little of its tie with that requirement
2	in 50.43(e), but that's the objective here.
3	So, any questions on that?
4	MEMBER PETTI: Yeah. This is Dave.
5	Were there concerns with the second bullet
6	or the fourth bullet, because you, quote, qualified.
7	I mean, there's an EQ requirement in the regs or in
8	the guidance.
9	This is pretty basic stuff, right, to
10	assure to come to an adequate assurance of safety
11	finding.
12	MR. RECKLEY: We didn't get much reaction
13	to the word "qualified." But the reason we ask the
14	question when we put it out is because, like a lot of
15	terms, it has its definition in the dictionary and
16	then it has maybe the history of what "qualification"
17	has met and the amount of work that goes into some
18	qualification activities.
19	But, again, in terms of stakeholder
20	feedback it did not seem to, at least preliminarily,
21	initiate any response.
22	MEMBER PETTI: That's good. Okay.
23	MR. RECKLEY: Alright. I think we can go
24	on to 30. This is
25	CHAIRMAN BLEY: There was a fair amount
I	I

(202) 234-4433

	133
1	during the Gen IV project, the initial Gen IV project,
2	focusing on security by design. It's almost a
3	parallel to your discussion about admin versus design
4	fixes for (audio interference) people.
5	But it made a lot of sense to a lot of
6	people, that that's a preferred approach and it can
7	very much make it easier to ensure that security is
8	well covered (audio interference).
9	MR. RECKLEY: When we get to stakeholder,
10	we'll kind of go over that, but the biggest comment or
11	issue was not that they didn't recognize it as a good
12	practice, but whether it should be in the rule.
13	And if it wasn't done by the design
14	process, could it be compensated for on the other end?
15	Everybody, I think, would acknowledge it's not the
16	most efficient or desirable way to do it, but couldn't
17	it be done by just adding guns, gates, and guards if
18	it wasn't done at the design.
19	So, this is, you know, another one of
20	those areas we have to look at and say, how much do we
21	want to put good practice into the requirements?
22	As we go through the iterations and
23	looking at comments, that's an area we'll have to kind
24	of make a judgment on.
25	CHAIRMAN BLEY: Okay. And I (audio
	I

(202) 234-4433

	134
1	interference) two things. I am convinced it's cheaper
2	in the long run, by a long shot. And, two, although
3	we do exercises, we haven't really tested the guns,
4	guards and gates security issues and I hope we don't.
5	MR. RECKLEY: Well, obviously we put it in
6	there. So, we had a similar thought when we put it
7	in. So, I think this slide in Section 450 is one
8	we'll end up talking a fair amount on.
9	In the iteration that you have that's
10	publicly available, the analysis in Section 450 can be
11	broken down into first, it starts off with the
12	requirement that there will be a probabilistic risk
13	assessment forum. And there's been a little reaction
14	to that, but not black-white arguments.
15	The second bullet is where a lot of the
16	discussion has focused in that we not only said that
17	a PRA needs to be done, but then we basically said
18	that the PRA is going to support the design and the
19	overall analysis effort by being used to pick
20	licensing basis events, classifying the equipment and
21	human actions, evaluating defense-in-depth and just as
22	a kind of central element of the design and licensing
23	approach and the analytical approach.
24	MEMBER MARCH-LEUBA: So, let me break in.
25	This is Jose. You knew I was going to break in on
	I

(202) 234-4433

	135
1	this slide, right?
2	I just want to put on the record just a
3	little bit, if not a little much, of a simpler logic
4	in this approach.
5	It would be great if the PRA was actual
6	systematic search of everything that can possibly go
7	wrong in the plant, but it is not.
8	It is by necessity, by a scientific
9	method, it is incomplete and this is not hypothetical.
10	It just happened last year when the last reactor was
11	certified. The thing is the two limiting events
12	(unintelligible). So, it's not hypothetical. It
13	happens. And the way people think and the way the
14	human mind works, you ignore events. Okay?
15	And it's even more, because what the risk
16	analysts do to generate a fault tree is identify all
17	the components and ask the system engineer what
18	happens if Valve No. 27 fails? And the guy comes back
19	and says, eh, nothing because I have 28 that backs it
20	up. So, then that's how you build a tree.
21	With fault opinions, at best an Excel
22	calculation, and then you use those opinions, those
23	ideas of the design engineers, to identify what events
24	are important and you analyze those events properly
25	afterwards. You just confirm what the system
I	

(202) 234-4433

	136
1	engineers thought based on the Excel calculations.
2	So, and this is what I mean, ACRS is on
3	the record, in a letter, saying that you should use
4	PRA, of course, to identify the basis events, but you
5	should also try to do more systematic and try to
6	understand what could possibly go wrong. Because what
7	I've seen happen is you start with the standard review
8	plan events and start removing the ones that don't
9	apply to your plant, but don't add any.
10	So, the rule should, in my opinion, be
11	much more strict and emphasize the fact that
12	identifying the design-basis events is crucial. That
13	if you follow if you're going to spend enough time
14	doing this and enough peer review and a lot of time on
15	it trying to identify what could possibly go wrong,
16	you will miss something. Every time we have a
17	significant accident is because somebody missed
18	something. Okay?
19	I put it on the record. You don't need to
20	defend it.
21	CHAIRMAN BLEY: Okay. But some of us need
22	to offer a comment. I agree with Dr. March-Leuba's
23	final conclusion. We need a thorough process to
24	identify these things, whether it's supporting PRA or
25	some other approach.
	1

(202) 234-4433

	137
1	There's probably been more work done in
2	the PRA area on identifying ways to do that although
3	it's not listed here in what you have for these in
4	the rule language here or in the PRA standard or
5	guidance document. It's necessary and there are a
6	number of very useful approaches that have been used.
7	Mr. Carl Fleming was at our meeting on PRA
8	standards a few months back and provided us a rather
9	nice package of papers that delve into some of those
10	methods. We've mentioned them in several of our
11	letter reports.
12	So, I'm agreeing that it really ought to
13	be emphasized, I think, in the rule, but that search
14	has to be very thorough and creative and not just
15	picking out previous lists especially for these new
16	designs.
17	The comment about how people decide
18	failure modes and what goes in fault trees just isn't
19	the way it's done. So, I'll leave it at that.
20	But I agree it would be really good to
21	beef up the description of how we search for these.
22	Because even if you don't do PRA, you've got to find
23	them and that's the place we slip up, I think.
24	MEMBER KIRCHNER: Bill, this is Walt
25	Kirchner.
ļ	I

(202) 234-4433

	138
1	MR. RECKLEY: Yeah.
2	MEMBER KIRCHNER: You know, I had the
3	language open at the same time as you're showing your
4	viewgraph and my concern, to add on to Dennis'
5	comments and indirectly also respond to my colleague
6	Jose's comments, is this says you must do a PRA.
7	And, again, going back to very early this
8	morning, Mike Corradini's comments, you know, if
9	there's going to be a graded approach, can't we allow
10	that someone would do and I'll just use some
11	terminology probably incorrectly a hazard analysis
12	for a much smaller system and start with that and use
13	that as a basis for defining licensing basis events
14	and then subsequently SSCs and so on in this process.
15	It looks like it's a mandatory requirement
16	you will do a PRA as the as I read the language
17	right now.
18	MR. CORRADINI: This is Corradini. I
19	guess I agree with Walt.
20	The "must" part bothered me and the detail
21	bothered me. So, I'm curious what the staff felt that
22	required a "must."
23	CHAIRMAN BLEY: I'm going to jump in, too,
24	because I disagree not in principle, but in words,
25	with the last two comments.
I	I

(202) 234-4433

I like having "must" in here. 1 But as I said earlier, you need some pretty thorough guidance 2 implements a PRA depending on 3 on how one the 4 complexity of the design and the -- I'll go back to 5 the language we borrowed from the DOE earlier, the material at risk and the damage ratio kind of idea of 6 7 it should be scalable. if 8 Ι still call it а "PRA" it's

probabilistic and looking at risk.

MR. CORRADINI: So, Dennis, I think we're saying the same thing. I guess there's other tools or -- I mean, I'm not an expert. So, you're really the expert in terms of this, but it just struck me that this was very prescriptive. Almost too prescriptive.

15 CHAIRMAN BLEY: It does three things. It 16 searches for and identifies the scenarios, what can go 17 wrong; it identifies how likely those are; and it 18 identifies what the consequences -- or the range of 19 consequences on each one would be. And if you do 20 those three things, that's a PRA.

Now, he has a lot of guidance on how you do one for a large, complex facility. We need some guidance on how you simplify that for smaller systems (audio interference).

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

So, yeah, I do think we're saying the same

(202) 234-4433

25

9

	140
1	thing, but in different ways.
2	MEMBER KIRCHNER: On the topic of
3	Dennis, I'm trying to I'm thinking back to the
4	existing Reg Guides which were really tailored for
5	PRAs for the existing fleet. Very comprehensive.
6	Very detailed.
7	Is there some way in this language that we
8	can I agree with you, I'm just wondering what the
9	expectation would be and I don't even want to raise
10	this, but I'll mention it uncertainty for advanced
11	concepts in the results of a PRA, but is there some
12	way that one could capture what you just said, Dennis,
13	in the language helping Bill so that my first
14	reaction is they're asking for PRA like you have for
15	the existing fleet and you really probably are going
16	to have great difficulty doing that so, I mean,
17	informing it with the kind of data that we have for
18	the existing design.
19	So, is there some way in this regulatory
20	language that it okay, keep the word "must," but
21	the PRA then is defined as you very clearly defined
22	it.
23	MR. RECKLEY: And this is Bill
24	CHAIRMAN BLEY: They just needed the
25	guidance to go with it.
	I

(202) 234-4433

	141
1	MR. RECKLEY: Right. And what we're
2	working on now is we got the non-light water reactor
3	PRA standard just issued and the staff is reviewing
4	that.
5	And that will be an opportunity to look
6	and see within our guidance and what exists already
7	within the standard for making sure, I think, what
8	everybody is saying.
9	If you're going to require a PRA, make
10	sure the PRA is simple if the machine is simple. If
11	you have few things to break, then your trees should
12	reflect that you have a few things to break.
13	The reason light water reactor PRAs are
14	extensive and complicated is they have a lot of moving
15	parts and the parts interplay with each other.
16	A break on the secondary side provides
17	immediate feedback to the primary side. So, the
18	interrelationships and the complexity is what drives
19	the PRAs to be as extensive as they are, but Dennis
20	can weigh in he's, again, the expert here or
21	I'll ask Marty Stutzke to weigh in.
22	But we've come back and tried to say we
23	think the nature of PRAs are that simple machines will
24	or can have simple PRAs, but, Dennis or Marty, if you
25	want to weigh in?
	I

(202) 234-4433

	142
1	MEMBER MARCH-LEUBA: I want to weigh in a
2	moment.
3	What I was saying, is if you are going to
4	do a PRA, you better do a good PRA. It's not
5	laughable, I mean, because the last PRA we saw,
6	according to all the experts, was the best PRA ever
7	performed for this hazard configuration, an order of
8	magnitude, still missed the two limiting events.
9	That's my point, that over-relying just
10	because you spend ten man-years and you fill up 700
11	pages of cap trees (phonetic) doesn't mean you got
12	them all. It's the basis of the scientific method.
13	You cannot prove a negative. Okay.
14	MEMBER BALLINGER: But that's the nature
15	of any of these designs, you know? I mean, are we
16	hung up on the we've got, in our mind, a definition
17	of "PRA" that's very tied to light water reactors.
18	If you were to go out to the I don't
19	know oil and gas industry and tell them what is a
20	PRA, first they probably wouldn't you know, you
21	would get a different definition. It's just a risk
22	assessment of the system. And if you want to make the
23	EPZ the site boundary, you got to somehow demonstrate
24	that Part 20, you know, dose limits are met and a risk
25	assessment is one way to do it. Call it a PRA if you
I	1

(202) 234-4433

	143
1	want. I don't know.
2	MEMBER REMPE: So, I'm curious still on
3	why the staff said you must have a PRA. I, again, am
4	thinking about what I've been reading about Part 50
5	and 52 alignment and the staff tied it to the severe
6	accident policy statement.
7	And if you go back to the severe accident
8	policy statement, it doesn't say you have to do a PRA
9	well, it says you need to use risk methods.
10	They basically say again what everyone
11	else is saying here today about that they realize that
12	some designs aren't really suited for a full PRA as we
13	think of for a large light water reactor.
14	They talk about that, you know, if you
15	with the complexity and as you go further in the
16	licensing process, what might be more suitable.
17	So, those kind of what drove you to
18	decide we've got to do a PRA?
19	MR. RECKLEY: And I'll break it into two
20	elements. Again, the first and the second bullet.
21	The requirement our thoughts on requiring a PRA are
22	that it seems a logical continuation and evolution of
23	the risk-informed approach that saw a requirement for
24	a PRA added to Part 52 and the discussion that went on
25	at that time.
I	I

(202) 234-4433

	144
1	And, at that time, the PRA was required
2	and everyone is looking at it for insights. We have
3	an SRP Chapter 19 to look for those insights.
4	It also includes, as you mentioned, the
5	that chapter looks at the severe accident design
6	features and that were added as a result of the
7	severe accident policy statement.
8	The NRC has built this not only the
9	NRC. The nuclear industry and the NRC have built this
10	infrastructure starting in the '70s that I'll
11	acknowledge freely there are other risk assessment
12	tools.
13	The one that was selected by the nuclear
14	industry and the NRC is the PRA. And so, it just
15	seems a logical evolution of that process to require
16	the PRA to be performed.
17	And, again, the first bullet requiring a
18	PRA is consistent with Part 52 and it's consistent
19	with what's going to be put into Part 50. So, having
20	a PRA doesn't seem that controversial.
21	The second bullet is what generated more
22	response, was that you would actually use the PRA,
23	which when we did this iteration, seemed again like
24	the logical evolution.
25	Part 52 said, you'll have a PRA and you'll
ļ	I

(202) 234-4433

	145
1	use it for insights for a design that continued to be
2	based largely on a deterministic approach of the
3	general design criteria and related regulations.
4	And so, our initial thought was, okay,
5	we're just going to take this step. This is an
6	evolution in risk-informed approaches.
7	We will not only require the PRA to be
8	performed, which is current requirements, we're going
9	to actually require it to be used in the theory that
10	it's actually a more systematic approach than the
11	deterministic way of saying, pick some reactivity
12	events, pick some loss of heat transfer events, some
13	pick some loss of inventory events and use those.
14	I'm sorry, I didn't mean that to come across as it
15	probably just did.
16	That is a systematic approach and it's a
17	fine approach, but, just as Jose was mentioning, it's
18	as good as an approach as how you execute it. It can
19	either be very good, or it can be haphazard, depending
20	on the events you pick and the discipline that you put
21	into it.
22	But our thinking at the time, and as we
23	get into comments later on, the use of the PRA in the
24	design process is a comment we got and it's one that
25	the next iteration we expect will take a step back
ļ	

(202) 234-4433

Í	146
1	from saying the PRA is the primary design tool in
2	terms of picking your licensing basis events and
3	classifying the equipment and other things.
4	MEMBER REMPE: So, are you closing off the
5	option of having a worst case or maximum hypothetical
6	event? The second bullet seems to be that you might
7	be doing that.
8	I get that you need to justify the maximum
9	hypothetical event having some sort of risk method to
10	say you've systematically gone through possible
11	challenges and you've picked the worst case, but I'm
12	kind of wondering if the second bullet doesn't kind of
13	close off that option for potential applicants.
14	MR. RECKLEY: And that's been the
15	observation and why we're looking to probably change
16	that in the next iteration.
17	MEMBER REMPE: Oh, again, I'd really like
18	to tie this to what's going to be done with Part 50/52
19	alignment. Like, some guidance would be very helpful
20	that emphasizes risk methods more.
21	MR. RECKLEY: Right.
22	MEMBER REMPE: But, again, I guess we'll
23	have to see what you come up with.
24	MR. RECKLEY: Well, and, again and that
25	will be a point of discussion. We have one way to do
I	1

(202) 234-4433

147 1 this through the licensing modernization and Reg Guide 1.233, NEI 18-04. So, we have one way to do this 2 3 that's been established. 4 Miqht there be additional quidance 5 developed either by industry or staff to say here's another possible approach, that will be something we 6 7 talk about as we continue through this process. 8 CHAIRMAN BLEY: Bill, two points. One, 9 over the last 30 years there have been developed a 10 number of very useful tools developed by people doing nuclear plant PRAs, some developed by the chemical 11 12 industry, some from aerospace. In any case, a large number of tools that 13 14 help you be more systematic, more complete in 15 identifying, I'll call them, "initiating events and scenarios." 16 There is no current quidance I'm aware of 17 in either of the PRA standards, or in NEI 18-04, or in 18 19 any of the NRC quidance documents on how to do that systematic search, you know, starting with a blank 20 sheet of paper and not being biased by everything 21 that's been done before. 22 I think you really need that guidance. 23 24 This is -- we've suggested that several times already and will probably do it more thoroughly in the future. 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	148
1	The second point is this seems one more
2	place that if that you could save yourself a lot of
3	trouble if you'd get some white papers started that
4	will eventually become part of the statement of
5	consideration defining and justifying the Tier 1/Tier
6	2 stuff, talking about what do you mean by a PRA, what
7	kinds of PRAs could be done, but how can this process
8	be simplified?
9	I still look at it on various levels of
10	depth and the one I think you always got to do very
11	thoroughly is the identification of initiating events
12	and scenarios, what can go wrong.
13	And then, two, how do you figure out the
14	likelihood event and how do you figure out the
15	consequences? Those you can scale according to things
16	about the design.
17	And I think if you had white papers on
18	those, it would help a lot. And eventually I think
19	they ought to be part of the SSC and that same sort of
20	thinking could be reflected over in 50/52.
21	MR. RECKLEY: Okay. Thank you.
22	Again, this might be the part or place to
23	throw in the the other area, again, that we've
24	raised and I've not gotten much traction on is when
25	people say "maximum hypothetical," if that's
ļ	I

(202) 234-4433

	149
1	equivalent to unmitigated as it's used in the DOE
2	standards and in the other guidance documents like
3	ANS-2.26.
4	I mean, we also are looking to see where
5	infrastructure might be in place and guidance already
6	exists such that we could just adopt something like an
7	ANS or a DOE standard. So, I'll just leave it there.
8	The issue that often arises with maximum
9	hypothetical is if one picks hypothetical to be non-
10	realistic and that starts to approach for me the
11	unmitigated approach that DOE takes, one can make
12	those arguments.
13	But what often creeps in is that it's not
14	necessarily unrealistic but a probabilistic argument
15	enters into the discussion.
16	And in my view, for example, maximum
17	hypothetical or unmitigated are, by their nature, set
18	out to be conservative to prove a point.
19	And if you can prove that point, then
20	things can be greatly simplified, but that differs
21	from a maximum credible accident where a frequency is
22	being introduced into the argument of and so, maybe
23	to Dennis' point, in such white papers we would have
24	to make a clear distinction between maximum
25	hypothetical or bounding or unmitigated events and
I	I

(202) 234-4433

	150
1	maximum credible events where frequency is being
2	introduced based on the some either initiating
3	event frequency or reliability of equipment. So
4	but those are the challenges we look at.
5	So, again, we are considering we've
6	gotten considerable feedback on this and we are
7	looking in the next iteration to make some adjustments
8	in recognition. Many of the comments are similar to
9	what we're hearing here today.
10	MR. CORRADINI: So, Bill, just one last
11	question because maybe you said it and I missed it,
12	but this requirement, does the PRA have to be
13	qualified based on some standard?
14	MR. RECKLEY: Yeah. It goes down to the
15	next one that we would consider it meeting either the
16	for light water reactor designs, the light water
17	reactor standard that reflects Reg Guide 1.200 and all
18	the related work or the recently issued non-light
19	water reactor standard which is currently under NRC
20	review.
21	Or if it didn't, then they would have to
22	justify some other approach, but the hope and the
23	thought was that, again, we have that infrastructure
24	for those two major technologies, non-light water
25	reactors and light water reactors.
l	I

(202) 234-4433

	151
1	MEMBER MARCH-LEUBA: What I think we were
2	saying, or at least I was saying on this regard, is
3	there is no logical vision to include the use of the
4	maximum hypothetical, what you call the mitigated.
5	If for one of these small, super-safe
6	reactors you can live with it, why do the rest?
7	MR. RECKLEY: And, again, I don't know
8	that we would have strong disagreement. Our look at
9	the literature is we're not sure there's such a
10	machine exists.
11	MEMBER MARCH-LEUBA: Well, you just have
12	to analyze it and see if it does.
13	MEMBER PETTI: Yeah. I know of one that
14	I think meet that definition.
15	MR. RECKLEY: Okay. Anyway, so we're
16	looking at that. Again, if anybody has any thoughts
17	or experience especially for us on or to me,
18	anyway, the unmitigated approach, the assessment of
19	unmitigated events and whether that could be used in
20	this context, the attractiveness of that is there's
21	already a considerable infrastructure built around
22	that that we might be able to use.
23	So, I guess it's
24	MEMBER PETTI: Bill, just a question on
25	the two years.
ļ	

(202) 234-4433

	152
1	Is that something that comes from one of
2	the standards, Y2?
3	MR. RECKLEY: It's another area we got
4	comments on, but especially the word "upgraded." We
5	were thinking to require it to be updated and assessed
6	every two years.
7	Marty, weigh in. Under 50.74, I think, is
8	that the current requirement or is the current
9	requirement four years, but at some periodicity.
10	So, we pick two years. That generally
11	goes with kind of once you enter the operational
12	phase, that these assessments should be done
13	periodically. I don't think there's
14	MEMBER KIRCHNER: This is Walt. Just to
15	help you a little, I thought your facility safety
16	program was going to utilize an updated PRA at
17	frequent intervals to kind of offset, you know,
18	whether you had inspectors and all the rest.
19	MR. RECKLEY: Yeah. That would be part of
20	it. And then there would also be on the assumed, at
21	least in this construct that we proposed in the first
22	iteration, the notion was especially when you get into
23	the second tier requirements that you would be having
24	to look at the reliability of the equipment, the
25	actual operating history, and making sure that the
	I

(202) 234-4433

	153
1	things you had set up in the PRA for meeting the QHOs
2	in the second tier were actually being satisfied.
3	So, you're going to have to run that
4	through the PRA on some periodic basis. We picked two
5	years. That's a traditional number for updating
6	licensing documents and so forth.
7	I'll have to go back and look what the
8	existing requirement is in 50.74, I think it is.
9	MS. VALLIERE: It's 50.71, Bill, and it's
10	four years in Part 50.
11	MR. RECKLEY: Thank you. Four years.
12	MS. VALLIERE: Yes.
13	MR. RECKLEY: Okay. So, the logic from
14	shortening it from four to two was the increased role
15	of the PRA and the need to really continue to validate
16	that you're meeting the second tier.
17	MR. CORRADINI: So, Bill, can I ask
18	another question? I'm sorry I'm putting you on the
19	spot, but I'm sure you've got staff colleagues that
20	can help you.
21	Is it fair to say the way you guys are
22	discussing this, that the MHA is a thing of the past
23	and everything's got to be an MCA? And, therefore,
24	you must do some sort of risk analysis to show that
25	you've bounded all the potential scenarios?
	I

(202) 234-4433

MR. RECKLEY: No, I don't think that's what we're trying to say. The use of an MHA, which, by the way, is not a tool we've used on the power reactor side, but the use of an MHA could still be used especially to simplify the analysis that one would do.

The logic here would be you need to do a PRA and look at all of -- systematically look at what can go wrong, as Dennis was saying.

10 And if you were able to show through the Image A -- or through that collection of events that 11 12 could simplify the analysis by looking you at something that bounded them all -- and I'll use a 13 14 simple example and don't take it too far, but let's 15 say back on that first slide where you had a damage 16 ratio, that you had a fuel farm that basically could 17 say there will be no relief below temperature X. Okay? 18

And I go through all of the events and look at what can go wrong with this plant and then say of all of those events, I can bound it by saying I'll take away, you know, everything but radiation to the air -- and that's a maximum hypothetical -- and I still show I'm under the temperature at which damage ratio is basically zero.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

7

8

9

	155
1	Then I could argue I've looked
2	systematically at what can go wrong, I took a
3	conservative approach to assessing the consequences of
4	a maximum hypothetical accident and I've assessed it
5	and there are no consequences.
6	CHAIRMAN BLEY: And you have taken a
7	conservative approach to the likelihood. You've
8	assumed it's going to happen.
9	MR. RECKLEY: Right.
10	CHAIRMAN BLEY: So, really those three
11	pieces kind of work. My hang-up it's not a hang-
12	up. My claim is that you always got to do a detailed
13	search for the scenarios.
14	Maximum hypothetical or maximum credible
15	can't be proved if you've got the worst one unless you
16	can show that you've really thought through those
17	things.
18	MR. CORRADINI: But then, Dennis, I think
19	you're kind of saying, in essence, what I said, which
20	is the concept of an MHA can only be identified once
21	you've essentially gone through some sort of search of
22	what could happen, what is the likelihood of it
23	happening, and what are potential consequences in
24	bounding those consequences with a I won't call it
25	"simple," but with a bounding analysis.
	I

(202) 234-4433

1 CHAIRMAN BLEY: With a bounding analysis. And if you don't do that first part, you might be 2 3 missing something very energetic that happens right 4 next to this thing that sets it all in motion and 5 would create much broader consequences than you would normally get to that thing you thought was maximum 6 7 hypothetical. 8 That's why you have to look to what can go 9 wrong. 10 MR. RECKLEY: Yeah. And the other, you know, the other part from a practical standpoint as we 11 look at this, is, you know, maximum hypothetical is a 12 qood -- I mean, it's a plausible approach to show that 13 14 there's no consequences to the public health and 15 safety, but --16 CHAIRMAN BLEY: In use for research 17 reactors, too, though. MR. RECKLEY: Right. And it has some 18 19 history in the research arena. The -- but the notion that you're going to thereby greatly simplify the 20 analysis done for the machine overall, I would ask 21 people to really think if that's true. 22 In this day and age if you won't be 23 24 looking at failure modes in effect of every component to support the commercial aspect of the deployment of 25

> **NEAL R. GROSS** COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	157
1	these machines, it's kind of easy for the NRC,
2	perhaps, to say, well, the MHA bounds and therefore
3	it's okay.
4	But if you don't think that any customer
5	is going to say, whether there's a health effect or
6	not, how often are components going to fail that kicks
7	this thing offline, I my personal think is that's
8	going to happen in any case.
9	And so, for all of the work to say you
10	don't need to do a PRA, are you just taking it out of
11	the regulatory arena but it's going to have to be done
12	anyway?
13	And so, the conservatism you piled onto
14	the licensing side, in theory, to save doing the PRA,
15	you don't save at all anyway because you're going to
16	have to do the PRA to show that this thing is going to
17	have a reliability greater than the 40 or 50 percent
18	that the light water reactor capacity factors showed
19	for the first 10 or 15 years.
20	So, you know what I mean? I think you
21	need to take a realistic view of the whole landscape
22	and be kind of realistic about are you really saving
23	by arguing that you don't need to do a more complete
24	assessment of not only failure modes, in effect, but
25	the actual probabilities that will go ultimately into
I	1

(202) 234-4433

	158
1	giving some kind of estimate on the reliability of the
2	reactor as a whole.
3	But anyway, now I'm starting to preach.
4	So, I better shut up because I'm going beyond my realm
5	here.
6	MEMBER REMPE: Bill, I agree. I used to
7	work for a company many, many years ago and they did
8	economic risk as well as safety risk assessments.
9	I think the answer that might come back is
10	that the regulators should only be concerned about
11	safety and let the buyer beware and look at the
12	economic risk assessment.
13	Again, there's a lot of cost with the QA
14	required for the regulator, right? So, perhaps, you
15	know, you may be right, but I just kind of wonder. I
16	can see why it would
17	MR. RECKLEY: And I do and that's why
18	I say I was going off the rails there, but because
19	I see the difference between a regulatory
20	responsibility and what the but I just the
21	argument that a lot of money gets saved one way or
22	another is my point.
23	I'm not sure that argument really is all
24	that compelling, but that's not for us to decide in
25	the end. You're exactly right, Joy.
ļ	1

(202) 234-4433

	159
1	So, anyway, all that said, we're likely to
2	get some relief in this area, when we get down a
3	couple slides, to show the feedback and what we expect
4	to do in the next iteration.
5	Someone brought up that we use for the
6	analytical conforms to analytical generally accepted
7	methods and standards. That would include the PRA
8	standards.
9	The next bullet, the codes, you'd have to
10	go through an appropriate validation and verification
11	to qualify the codes. I don't think that's very much
12	in argument.
13	The next to the last bullet we did throw
14	in some things. We did not weren't sure got
15	captured and we just wanted to have a placeholder.
16	Fire protection obviously very important.
17	Aircraft impact assessments under the Part 50 and 52
18	regulations.
19	And the specific events that were
20	addressed most recently, the Fukushima-related
21	mitigation of selected beyond design-basis events.
22	And then I wanted to get into another
23	important element because I'm not sure it's been clear
24	that the analysis, the licensing basis events as we've
25	talked about them above and then the rest of 53.450,
	I

(202) 234-4433

	160
1	we would say the analysis of those events one
2	acceptable way to do that would be, as we've endorsed
3	in Reg Guide 1.233 on licensing modernization, which
4	is those assessments of events are using out of NEI
5	18-04 kind of best estimate approaches and then
6	assessing the uncertainties of frequencies and
7	consequences. That would be one way to do it.
8	But the other thing that's in NEI 18-04
9	methodology and we were proposing to require also in
10	Part 53 was the specific assessment of a design-basis
11	accident, which is done using only safety-related
12	crediting only safety-related equipment, using perhaps
13	more traditional analytical approaches, a bit more
14	conservative than codes might be to do the thermal

hydraulic assessments under the PRA.

And here's where we tie this kind of back to Subpart B that it's the design-basis accident that's really being used to judge the first tier safety criteria.

This is the assessment from which you're getting the confirmation that there's no conservatively assessed using only safety-related equipment even that would trip the 25 rem at the exclusionary boundary threshold.

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

MEMBER MARCH-LEUBA: And how do you choose

(202) 234-4433

15

25

	161
1	the DVAs?
2	MR. RECKLEY: Well, the DVAs would come
3	out of the overall assessment licensing basis event
4	that under and I'll give you two answers.
5	NEI 18-04 describes one way to do that,
6	which is you derive them out of the design-basis event
7	category as well as looking at potential high
8	consequence beyond design-basis events, but the
9	primary element is to pick them out of the design-
10	basis event category at NEI 18-04.
11	Or especially as we get into the
12	alternative we'll be building in, they could be picked
13	by some other systematic approach and that might be
14	picked up in some kind of other standard.
15	Going back to the way it was done for
16	light water reactors, you could pick it out of ANS
17	51.1 and 52.1, for example, for PWRs and BWRs, would
18	tell you what your design-basis accident is.
19	So, if there is some other methodology
20	that's developed that has included a kind of
21	systematic approach to it, when we get down to the
22	next iteration, I think we would say that we'd be open
23	to such an approach.
24	MEMBER MARCH-LEUBA: Yeah, but shouldn't
25	the rule I mean, a specific variable of the
I	

(202) 234-4433

	162
1	licensing basis events, which don't mean anything
2	because the DVAs are the ones under control, and then
3	the DVAs we don't specify how to do it?
4	MR. RECKLEY: Well, the current language
5	used is the 10 to the minus 4 frequency of the
6	underlying event frequencies, again, consistent with
7	what we endorsed in Reg Guide 1.233.
8	One of the discussions as we go forward is
9	if you want to separate the approach of selecting
10	events from such a frequency oriented approach, a PRA
11	approach, then we'll have to perhaps come up with
12	other approaches.
13	Although, even 51.1 and 52.1 for the
14	current structure basically tied those or had any
15	relationship between the DVAs and frequencies.
16	But as the current language that we have
17	for 53.450(e) talks about picking the design-basis
18	accidents from the event sequences with a frequency on
19	the order of 10 to the minus 4.
20	MR. CORRADINI: That's an upper bound.
21	That one piece of language you just quoted confused me
22	in Subpart E.
23	MR. RECKLEY: Yeah. I mean, under and
24	I should have had it open, but under LMP, for example,
25	they're selected from the event sequences ranging from
ļ	I

(202) 234-4433

	163
1	10 to the minus 2 to 10 to the minus 4, plus
2	accounting for the uncertainty.
3	So, a 95th percentile event down to 10 to
4	the minus 4.
5	MR. CORRADINI: Okay. Because alright.
6	So, the way you just said it here isn't the way I read
7	the English in Subpart E.
8	MR. RECKLEY: Okay.
9	MR. CORRADINI: Because in there it says,
10	with an upper bound frequency less than 1 in 10 to the
11	minus 4.
12	So, the way you just said it in explaining
13	it to me makes perfect sense. It's just the way it's
14	worded in the subpart confused me. Sorry.
15	MR. RECKLEY: Yeah. No, no. And I find
16	it very difficult to write and we adopted later on
17	we adopted using the frequencies and then saying
18	accounting for uncertainties as opposed to trying to
19	I think the reason I put in "less than 10 to the
20	minus 4" was the assumption that you'd have to account
21	for uncertainties, but that
22	MR. CORRADINI: Okay.
23	MR. RECKLEY: It might be more clear and
24	I think we've tried to adopt it later on where we just
25	are more clear and then say, plus accounting for
	I

(202) 234-4433

	164
1	uncertainties.
2	MR. CORRADINI: Okay. No, that helps,
3	Bill. Sorry to butt in there.
4	MR. RECKLEY: No, no.
5	MEMBER REMPE: Before you leave this
6	slide, when I was studying up for this meeting with
7	respect to this thing about enhancing the guidance, I
8	think that Section 2.3.1 of Reg Guide 1.174 might be
9	a good place to add some additional words because
10	there they already talk about the fact that although
11	you need to look at all the plant operating modes and
12	hazards groups, that it's also not necessary to have
13	a PRA of such scope. A qualitative treatment could be
14	sufficient for some applications and designs.
15	And so, that's a good starting place that
16	you might want to consider for beefing up the
17	guidance.
18	MR. RECKLEY: Okay. Thank you.
19	Alright. If we can go to slide 31, so a
20	couple notes. So, as we develop the next alteration,
21	as I had mentioned a couple times, I got allowing an
22	alternative risk-informed systematic approach to PRA
23	for the determination of licensing basis event, safety
24	classification, and evaluating defense-in-depth.
25	That is a comment we've received from some
l	I

(202) 234-4433

	165
1	of the members today. It's also something we got from
2	public stakeholders. So, that's something we'll
3	address in the next iteration.
4	There was some discussion in the next
5	iteration I'll try to clarify a little bit. The lower
6	or the higher frequency events, the anticipated
7	operational occurrences, I'd have to agree the
8	existing language that we have in the first iteration
9	is probably a little light on the anticipated
10	operational occurrence end. So, we've tried to
11	clarify that.
12	And then something out of our meeting with
13	this subcommittee in January is the discussion in your
14	lessons learned letter about end states.
15	And so, we will look the PRA non-
16	light water reactor PRA standards talks about
17	analyzing events to define end state. So, we can
18	capitalize on that discussion within the PRA standard.
19	And then for the design-basis accidents,
20	the one we were just talking about within 53.450 on
21	analysis, at that point we can't even talk about a
22	safe, stable end state for the design-basis accident.
23	So, per the discussion we had in January
24	and in looking at that discussion, I think we can
25	address that in the next iteration.
l	I

(202) 234-4433

	166
1	So, any discussion with that? If not, we
2	can go to slide 32 and the safety categorization.
3	(Pause.)
4	MR. RECKLEY: So, the definitions that we
5	would propose, and somebody had brought up earlier the
6	definition, so we would look, and we have in 53.460,
7	the need to categorize equipment and human actions.
8	And the first one is what equipment
9	what human actions are relied upon to address the
10	design-basis accidents and meet the first tier safety
11	criteria? And those would be termed "safety-related."
12	Then the non-safety-related, but safety-
13	significant, would capture those things that are
14	needed to provide or fulfill the second tier safety
15	criteria of meeting the QHOs.
16	And or are considered risk significant
17	within the probabilistic risk assessment using the
18	value from the PRA standard.
19	And it's actually consistent with NEI 18-
20	04 that it be one percent of the cumulative plant
21	risk.
22	As we look at revising, in the next
23	iteration, the role of the PRA and categorizing the
24	events and categorizing the equipment, this is an area
25	that we'll have to look into because the non-safety-
I	I

(202) 234-4433

	167
1	related, but safety significant, would not necessarily
2	it wouldn't work to quote the PRA if you weren't
3	requiring the PRA to be used for this purpose. And
4	so, we'll look, in the next iteration, to maybe modify
5	that language.
6	CHAIRMAN BLEY: But have you thought about
7	how deep you go on some of these? Let's say you have
8	a design we'll make up something that might be a
9	little silly, but it's happened in some other cases
10	you have a design for which one of your design-basis
11	accidents relies on this particular system.
12	This particular system from your from
13	a hydraulics analysis and other things shows that you
14	need one train to operate, but you've built four
15	trains in.
16	Are all the components in all four trains
17	safety-related? Is it one train? Is it one plus one?
18	And if you do something like that, then it gets really
19	confusing going on to the other cases or if you stayed
20	with if you went with risk-significant, it would be
21	clear.
22	MR. RECKLEY: Yeah, that that would
23	have to be developed as people look at a possible
24	alternative.
25	The guidance that's available for at least
	I

(202) 234-4433

one approach, which is that described in NEI 18-04, would basically say your single train can be safetyrelated and then -- depending on the nature of the designs.

5 It was more clear when you talk about If you talk -- even under LMP if you talk 6 passive. 7 about having an active system, whether you could get 8 by with an assessment that one of -- one train of a 9 two-train active system would be differentiated in safety classification gets a little fuzzy because you 10 would have to look at -- you'd really look at the 11 reliability of the system 12 actual to make that determination. 13

But the basic structure of the -- of NEI 15 18-04 that enabled us to address things like single 16 failure criteria and -- if you're not using the PRA 17 and you are proposing an alternate approach, then that 18 question of things like single failure criterion would 19 have to be answered within that approach. Maybe I'll 20 just leave it with that.

So, I can't give you a definitive answer because it would depend on a number of things, whether it was passive or active and so forth, but -- and we have a slide later on even if we introduce the term "inherent," that may be one additional complication,

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

1

2

3

4

169 1 but the -- one of the reasons we were writing the first iteration the way we did is because we had an 2 available guidance document that answered questions 3 4 like single failure criteria. 5 So, Ι probably didn't answer your question, Dennis, but --6 7 MEMBER KIRCHNER: Bill, this is Walt I'm -- just a little clarification on that 8 Kirchner. 9 I would ask for. I thought the traditional definition of 10 "safety-related" was those SSCs. It did not include 11 human actions. 12 And certainly the advanced policy 13 - -14 advanced reactor policy statements have always pointed 15 to less reliance on human actions. So, one would expect, you know, longer 16 17 time constants, inherent feedback, passive mechanisms. I'm a little concerned about what you mean 18 19 by "human actions" other than pushing the scram button or activating TFAS (phonetic) and so on. 20 MR. RECKLEY: And what you're seeing is a 21 bit of a trailer for what's yet to come. 22 The reason included human actions in this discussion is 23 we 24 because we're looking ahead to that segment of the operation subpart that I mentioned earlier where we 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

start to really look at what are the role of the human actions and where there will be distinctions between what's done by a licensed operator, what might be allowed by a non-licensed staff, and the possibility that you'd have no staff at all. And so, the fact that we're kind of looking at this as an integrated approach requires us,

8 we thought, and why we included it in here, to bring 9 this forward even into the analysis to say that when you're doing the analysis under this subpart, 10 the analysis under 53.450, is also likely to be supporting 11 your staffing discussions under Subpart H and it has 12 to be reinforced that whatever analysis you've done 13 14 under 450 in this construct is showing that the -whatever the role of the people might be is going to 15 16 carry forward.

17So, for light water reactors the operators18have roles that they have to take during the course of19a design-basis accident. It might be in the later20stages, but most designs have a role for operators.21That would get reflected in Subpart H on22staffing to say, oh, a human being is being relied

Therefore -- and the "therefore" we have yet to write, but in traditional, therefore, that's

upon to meet that 25 rem criterion in the first year.

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

23

	171
1	going to be a licensed operator. That action is going
2	to have to be modeled and simulated and trained and,
3	et cetera, et cetera.
4	If, on the other hand, 53.450 analyses can
5	show that people serve no role, then that might
6	support the concept of operations that would be
7	required in Subpart H on the role of personnel.
8	So, the reason that it includes human
9	actions, you're right, we don't traditionally call
10	human action a safety-related thing, but we're looking
11	forward to how this will translate into Subpart H.
12	MEMBER KIRCHNER: Yeah, I get that. I
13	just wonder if that this introduces lowers the
14	expectations.
15	I mean, traditionally what we've done in
16	Chapter 15 analyses is you rely on the SSCs, they're
17	classified as safety-related and it's pretty much
18	hands off and you do the accident analysis to
19	demonstrate that you can meet the regulatory I
20	mean, sooner or later it ties to the dose offsite, but
21	basically there are a lot of surrogate regulations for
22	the LWRs.
23	And I'm just I'm I see where you're
24	going with it. I just would expect of an advanced
25	reactor that, at least for the design-basis accidents,
	I

(202) 234-4433

	172
1	human intervention would not be a requirement. That's
2	old-fashioned thinking, I'm sure.
3	MR. RECKLEY: It's an element of the
4	advanced reactor policy statement to try to minimize
5	human actions.
6	The question to us is always how to build
7	that into the requirements and whether it's whether
8	that is something that all designers will choose to
9	do.
10	We're trying to leave open to the designer
11	throughout this subpart that they have choices to
12	make.
13	Do they want the operational cost of
14	licensed operators? And is that more economic in the
15	long-term than putting in design features to try to
16	show you don't need them?
17	That is something we're not trying to
18	decide. We're trying to support either decision. So,
19	that's where we are in developing the
20	MEMBER KIRCHNER: Yeah. But I guess, for
21	me, this would be something that would be more second
22	tier, the human factor.
23	In your first tier, I guess, I would see
24	the definition of "safety-related" restricted to the
25	SSCs needed to form your what you call your primary
I	I

(202) 234-4433

	173
1	safety functions.
2	MR. RECKLEY: Right. I guess that may be
3	saying the same thing, but from the other direction.
4	Do I think it's likely that most advanced reactor
5	developers can show they don't need a human to meet
6	the 25 rem first tier criteria? I would hope so.
7	But we'll put it in there and then it will
8	be up to them to show that they don't actually need
9	human intervention.
10	MEMBER REMPE: So, I thought Walt was
11	going to go a different direction with his questions
12	because we were involved in an activity not too long
13	ago where it appears that an operator was required for
14	recovery to put the reactor in a safe, stable state
15	and the there was not really any documentation to
16	support it or what would happen if an operator didn't
17	act as expected.
18	And so, it sounds to me like you're
19	actually going to require some more documentation
20	about operator actions if they're needed, which I was
21	wondering if some of the stakeholders were concerned
22	about that.
23	MR. RECKLEY: We didn't hear too much.
24	But after you pointed it out, then we might hear next
25	round.
ļ	I

(202) 234-4433

	174
1	(Laughter.)
2	MEMBER DIMITRIJEVIC: I have a question
3	about your third category, non-safety-significant.
4	Can safety-related things be in that
5	category?
6	MR. RECKLEY: No. That's the that's
7	really the remaining category for which the only
8	expectation for non-safety-significant SSCs would be
9	commercial-grade equipment and whatever restrictions
10	a designer or licensee wanted to put on it for their
11	own reasons not really nothing beyond commercial-
12	grade being built into the safety assessment.
13	MEMBER DIMITRIJEVIC: So, my question is
14	here you're not using any risk insights, right, to
15	classify your conformance?
16	MR. RECKLEY: It depends on what the
17	approach would be. Under one acceptable method, which
18	is the NEI 18-04 method, risk insights are integral to
19	the determination especially of the non-safety-
20	related, but safety-significant category.
21	That is going to be those events that are
22	coming out of the PRA as being needed to support
23	findings related to the NRC safety goal, as an
24	example.
25	MEMBER DIMITRIJEVIC: I think it's a very
I	I

(202) 234-4433

	175
1	small category in the current PRAs. It's a much
2	bigger category is safety-related, non-safety-
3	significant components. And this is what the most of,
4	you know, 50.69 is about, but you don't have this
5	category here.
6	So, you know, this category of non-safety-
7	related or safety-significant is a very small
8	category. So I'm just surprised that you have
9	actually the biggest category, which this NEI guide
10	and 50.69 devotes a lot of things deserves special
11	treatment, reduction is a category where you have
12	safety-related but not risk-significant component.
13	MR. RECKLEY: The logic there is that that
14	process in 50.69, in general, comes out of a
15	historically very deterministic approach to the
16	classification and then overlaying a risk assessment
17	and finding that there were many safety-related SSCs
18	that, from the PRA's point of view, weren't really
19	contributing as much as expected to the risk argument.
20	And so, there was a category basically
21	created to address that and lower the expectation on
22	that set or subset of safety-related equipment.
23	Going into a new design the thought is
24	that a reactor designer will not over-classify
25	equipment such that you then have a category of

(202) 234-4433

	176
1	safety-related but not safety-significant.
2	So, that was the reason that we even omit
3	this because it can be avoided from the initiation of
4	the design.
5	MEMBER DIMITRIJEVIC: So, it's a different
6	safety classification than we are to use now. That's
7	what will take care about this category. That's what
8	you are saying.
9	MR. RECKLEY: Yeah. The definition the
10	definition of "safety-related" should limit the amount
11	of equipment going into that category.
12	So, there should not be in our view,
13	there should not be as much over-classification as
14	might had been done in the earlier days of the
15	operating fleet.
16	MEMBER DIMITRIJEVIC: Alright. Thank you.
17	MEMBER KIRCHNER: Just an observation,
18	Bill. Are you going to reconcile this set of
19	definitions, these three bullets, with your colleagues
20	who are doing 10 CFR 50 and 52?
21	I think it would help immensely because
22	then when it comes to Reg Guides, we won't have the
23	four boxes that we often see as the kind of the
24	framework in the Reg Guides. So, getting this
25	simplified across the board would be certainly useful.
I	I

(202) 234-4433

	177
1	But I wanted to go back to Dennis and say,
2	Dennis, did you say non-safety-related but risk-
3	significant would be preferred?
4	CHAIRMAN BLEY: Preferred to what? I'm
5	not sure you're going way back in whatever I said.
6	My own thoughts in this area are that
7	safety-related is a holdover from the time of kind of
8	guessing what was going to be important and slapping
9	a classification on it.
10	Now that we have a risk assessment to pin
11	that down, the things that are risk-significant are
12	the things that ought to be treated as we always
13	treated safety-related and we shouldn't arbitrarily
14	declare anything safety-related, from where I stand.
15	Now, what they're doing because they're
16	going to have a PRA up front, they're going to know
17	what's important and they're going to develop their
18	own design-basis accident, the things that go into
19	that category are, you know, kind of meets what Bill
20	was saying before.
21	It's going to be self-regulated such that
22	almost anything that meets their label of "safety-
23	related" will also be risk significant or is likely to
24	be risk significant.
25	So, I'm kind of okay with where they're
ļ	I

(202) 234-4433

	178
1	going. It's just I would have done it differently.
2	MR. RECKLEY: Okay. If we go, then, to 33
3	we've had this discussion somewhat, special treatment.
4	And this will be established that, you know, it has to
5	provide appropriate confidence.
6	The safety-related stuff we've already
7	talked about, it will fall under Appendix B. It would
8	fall under the existing PRA requirements defined under
9	Appendix B.
10	It would fall under technical
11	specifications and so forth. So, special treatment as
12	it's applied to safety-related will look much the way
13	it currently is described for the operating fleet.
14	The big change really will be the kind of
15	expansion of the discussion of special treatment for
16	non-safety-related but safety-significant SSCs and
17	making sure that they will perform as they're assumed
18	to perform under the right service conditions, under
19	the appropriate environmental conditions, and that
20	they're available and reliable as it's been modeled in
21	showing that they meet the second tier safety
22	criteria, which is currently proposed to be the QHO.
23	So, it's really the expansion of those
24	requirements in order to allow us to take more credit
25	for those, that category of equipment and the
	I

(202) 234-4433

performance of those functions to meet the QHOs that then supports going forward in some of the other areas that we'll talk about.

4 And then as Walt brought up human actions, 5 thought even here to start to bring in the we discussion of human actions more so than what you'll 6 7 see in current regulations under Part 50, for example, 8 to start to build the argument that would be possibly 9 used in the later subparts on staffing levels, on the 10 development of concept of operations, which would actually be more definitive in terms of this is the 11 role of people in meeting the safety objectives. 12

13 If we go to 34, this is an area I thought 14 we would probably have a fair amount of discussion on. 15 And I think we're okay still on time, but I will try 16 to speed it up a little bit.

But the -- this is where the flexibility for advanced reactors starts to be introduced and this was our attempt to say how you can capture that.

And it's through the analysis that would 20 show you're meeting some threshold, some target that's 21 designer 22 been established by the that's more restrictive than what would otherwise be required. 23 24 And the margin you gain from showing you

meet a lower threshold is the avenue to get relief in

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

1

2

3

some other area.

1

180

2	So, the easiest one to explain, because
3	we're all familiar with it, is you run through your
4	licensing basis events. The expectation is most
5	advanced reactor designers will try to show that, at
6	the fence, they don't exceed the 1 rem in a month or
7	1 rem in 96 hours and, therefore, they can justify an
8	emergency planning zone that collapses to the site
9	fence or at least much closer to the site fence.
10	So, how is that arrived at? That's
11	arrived at picking 1 rem, which is more restrictive
12	than showing you meet either the than you would
13	show by the through meeting the QHOs and
14	establishing a more restrictive criteria.
15	And then the requirement, as it's written
16	in 470, is once you do that the goal of the
17	requirement in 470 is once you do that, that becomes
18	your new design standard that you have to show you
19	continue to meet because this has been one of the
20	questions of how once I set that and now I set things
21	in motion for the next 20 years and I do system
22	changes, I do power uprates, I do whatever, how do I
23	maintain the fact that I justify that I don't exceed

planning that has to be maintained throughout the life

1 rem at the site and, therefore, don't need emergency

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

24

25

	181
1	of the facility or I have to have an option of
2	bringing emergency planning back into the possible
3	overall framework for that facility.
4	So, 53.470 is the avenue by which we're
5	trying to do that. And I know it's only a paragraph,
6	but it's a critical paragraph within Part 53 because
7	it's, again, saying I can establish more restrictive
8	goals.
9	And with the margin that I get from that,
10	I can trade it off against requirements that are most
11	likely going to be in Subpart H under Operations.
12	This is how I'm going to do siting, maybe
13	more flexibility in siting, more flexibility in
14	emergency planning, perhaps more siting more
15	flexibility in security, more flexibility in staffing.
16	And so, with that, I'll just kind of open
17	it up for discussion again because, from my
18	perspective, this is we've talked about advanced
19	reactors and how you can get some of the flexibility
20	that's been expected and this was our vehicle to try
21	to do that.
22	Dennis?
23	CHAIRMAN BLEY: Yeah. I was waiting to
24	see if somebody had discussion. And this is probably
25	a good place for a break.
I	I

(202) 234-4433

	182
1	Do you think so, Bill?
2	MR. RECKLEY: Yeah, that's fine. And,
3	again, maybe during the break people will think about
4	this because this it goes to some of the earlier
5	discussions as well.
6	I mean, this idea that and this is
7	built on the fact that you do the analysis and from
8	the analysis you get the relief.
9	There's been, even today, some discussion
10	of isn't there a shortcut to even do less analysis?
11	So, we would have to work such an approach into this
12	construct.
13	I'll admit it's not currently there, but
14	whatever people wanted to do through the shortcut, you
15	also have to show, through that simplified assessment,
16	that you're confident that you're going to be
17	justifying all the relief that is being expected in
18	these other areas.
19	So, I'll kind of leave that as a thought
20	for people to consider during the break.
21	CHAIRMAN BLEY: Okay. That sounds good.
22	It's about 10 minutes till. Let's take a 20-minute
23	break. Come back at 10 after what is this back
24	east? Anyway, come back in 20 minutes.
25	(Whereupon, the above-entitled matter went
I	I

(202) 234-4433

	183
1	off the record at 3:48 p.m. and resumed at 4:10 p.m.)
2	CHAIRMAN BLEY: The question and 53.470
3	appears to be linked to the Tier 2 stuff and in the
4	pardon?
5	MR. RECKLEY: Take us back to where you
6	were, if you would. This seems a little hard to parse
7	I guess for me.
8	MEMBER REMPE: Bill, if you're talking,
9	you're on mute.
10	MR. RECKLEY: Oh, there we go. Sorry
11	about that. It is difficult because it's the attempt
12	at trying to make this flexible and yet integrated so
13	in the bowtie figure of how you might capitalize on
14	the assessments that are done under 53.450. And to
15	use them to justify operating flexibility and so, as
16	Dennis mentioned, basically you're the, an applicant
17	would be setting up an alternative threshold that's
18	more restrictive than the regulations.
19	And then the goal of 53.470 is to just
20	maintain those. Once that decision is made to make
21	sure that all of the analysis and then all of the
22	subsequent programmatic controls are in place, to
23	maintain it.
24	The actual trading off of the margin will
25	be reflected in the later Subparts and again, the
ļ	

(202) 234-4433

	184
1	example would be emergency planning where it can be
2	shown that the doses are less than one rem over the
3	time period.
4	You can use that to justify an alternate
5	emergency planning zone in siting, you could do the
6	dose calculation and if you meet the revised threshold
7	you could revise the population density guidance from
8	500 people per square mile out to 20 miles to some
9	lesser distance.
10	And we're looking to how that might
11	actually then also go into the concept of operations
12	and the possible justification of reduced staffing and
13	other areas, security and other areas.
14	We might be able to use that same logic
15	and so, again, it's a short paragraph but the intent
16	of it is to explicitly allow the tradeoff and then set
17	the requirements in place to maintain them after that
18	tradeoff is made.
19	MEMBER CORRADINI: So Bill, this is
20	Corradini, can I ask the question a little
21	differently? If this weren't explicitly written, that
22	still would be allowed it just wouldn't be explicit.
23	If they were to follow the, your
24	discussion about one rem at the boundary, that
25	allowed, that could allow them to do this. This just
ļ	

(202) 234-4433

	185
1	makes it an explicit opportunity. That's where I'm
2	confused. I thought this flexibility always existed.
3	MR. RECKLEY: It does both. It highlights
4	the opportunity and then it puts in place the
5	requirements to maintain it.
6	MEMBER CORRADINI: I got it now. I got it.
7	CHAIRMAN BLEY: So if I design my plant to
8	be more robust then I can cut some of my margins in
9	other areas but this requires me to keep, maintain
10	that robustness?
11	MR. RECKLEY: Right. Or to revisit how
12	you were trading off the margins.
13	CHAIRMAN BLEY: Sure. So, if I do that
14	because this is Tier 2, if I'm beginning to get where
15	you're headed with that, this is Tier 2 so, if I
16	decide to rebalance those margins, I have the freedom
17	to do that. Now you might come in and audit me on it
18	but it's something I can do on my own?
19	MR. RECKLEY: As we develop the Subparts,
20	yeah. Keeping in compliance, yes. You'll have the
21	inherent flexibility. The notion of not including
22	Tier 1 is that those things are not intended to have
23	flexibility.
24	CHAIRMAN BLEY: Right.
25	MR. RECKLEY: You will always meet Tier 1
	I

(202) 234-4433

	186
1	and you'll always meet it basically the same way.
2	There is no tradeoff of emergency planning in Tier 1
3	for example or any other criterion.
4	It's also based on an individual dose
5	number versus, well I won't get into that. So
6	CHAIRMAN BLEY: Another thing that would
7	be very helpful to have explained then in the SOCs or
8	early in some kind of whitepaper.
9	MR. RECKLEY: Okay. Seeing no other
10	activity at the moment, we'll finish out the design
11	section in the next 10 or 15 minutes and then get into
12	siting. The, yeah, if we go to the next slide.
13	The quality assurance for design was
14	basically just Criterion III from Appendix B, which is
15	the Criterion related design activity.
16	And again, we brought in that it would
17	comply with generally accepted consensus codes and
18	standards of which we've already identified in QA one
19	as being one of those.
20	One of the discussions that we will have
21	going forward is if other consensus codes and
22	standards like the ISO standards might also fulfill
23	that expectations.
24	MEMBER PETTI: So, Bill, do you see a gap
25	analysis or something in the future with when we
I	I

(202) 234-4433

	187
1	compare Appendix B to these other quality standards
2	and see if they really do cover all the bases?
3	Because I've heard different, I've heard
4	people steeped in this stuff tell me that ISO in no
5	way comes up to the level of NQA-1 Appendix B.
6	MR. RECKLEY: And the NRC did its study
7	and it varies by which criterion and activity you're
8	looking at but other places have taken, this is
9	stretching my memory here, which is not a good thing.
10	But there's been a nuclear component added
11	on to some of the ISO standards to kind of fulfill
12	MEMBER PETTI: Ah, okay.
13	MR. RECKLEY: where some of those gaps
14	exist. So, it's not clear you could take the most
15	general of the ISO standards and simply say, I will
16	follow that but there has been activity to supplement
17	them to make them more amenable to the nuclear
18	community if you will.
19	Is my understanding. But yes, somebody
20	would have to show that the consensus codes and
21	standards that they're referencing actually fulfills
22	the underlying desire and provides the confidence
23	that's provided.
24	One thought in breaking Appendix B up into
25	its associated areas was that might be a little easier

(202) 234-4433

	188
1	to show for a particular activity like design versus
2	showing some collection of ISO standards meets the
3	equivalent of NQA-1 in its totality.
4	But we'll see as we get into additional
5	interactions. But
6	MEMBER KIRCHNER: Bill, this is Walt.
7	Having looked at this a while back and I have to admit
8	it's a while back, I would say something along the
9	lines that David just suggested that the simple ISO
10	9000 would not come quite up to measure with the
11	totality of NQA-1.
12	I would also even suggest that of the
13	DOE's QA standard, which is derivative from NQA-1 and
14	after a fashion. The danger I see in breaking down
15	things like this is that yes, you'd have section in
16	NQA-1 that's design controlled.
17	But there are many other aspects to NQA-1
18	that support your ability to maintain that design
19	control. It's things as simple as records. So, it's
20	a little, if you pick and choose from Appendix B, be
21	careful because it's the integrated, all 18 sections
22	of NQA-1 that as a whole that really, you know, give
23	you the total effect.
24	Whereas, just picking and choosing
25	criteria from Appendix B may not, maybe necessary but
l	

(202) 234-4433

189 1 not complete. You see where I'm going with this? I do and it is something 2 MR. RECKLEY: we're looking at and as we take the concept as I 3 4 mentioned earlier, we're not exactly wedded to this 5 breaking apart. It was a notion. you 6 But when see Appendix Ε on 7 construction, which is primarily quality assurance, we really ran into something exactly what you're saying 8 9 because what do you do with the requirements for 10 audits and things that go beyond that particular activity and are really aimed at the QA program 11 overall. 12 And so, it's a point well taken and we're 13 14 looking at it. We'll see kind of, taking this 15 attitude of wait and see once we get it all together and if it makes sense that's fine or if it makes more 16 17 sense to put it back together. The way we're doing it, it's easy to also 18 19 put back together if that's decided that's the best 20 way. MEMBER BALLINGER: This is Ron, the ISO 21 standard that you're talking about is 19443, which I 22 have and it's pretty extensive. 23 24 MR. RECKLEY: And again, for certain activities the comparison is probably easier. I'm not 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	190
1	versed in the ISO numbering scheme and even the
2	content. So, but today's point yeah, somebody would
3	have to do that assessment. The last time the NRC did
4	it, it was, I think 10 or 15 years ago.
5	MEMBER BALLINGER: Yeah, this standard was
6	issued in, around 2018.
7	MR. RECKLEY: Okay. So, that's really all
8	I had on that one. If we can go to 36.
9	MEMBER PETTI: Just one more question.
10	MR. RECKLEY: Sure, Dave.
11	MEMBER PETTI: That's come up. In terms
12	of the ASME code to use, would an ASME accept a
13	Section 8 vessel instead of a Section 3 vessel if for
14	some reason the material was unique or the inability
15	to get an N stamp.
16	It is a code in standard, it is accepted
17	in many places but it's not, you know, it's not the
18	nuclear part of the code. Is that a hard rule on
19	that?
20	MR. RECKLEY: I'm not going to give you a
21	straight yes, no answer. We'll look into that and it
22	would depend on really the technology and what was
23	being derived from the reference to that code.
24	MEMBER PETTI: Okay.
25	MR. RECKLEY: I can say I don't think
I	1

(202) 234-4433

	191
1	we'll necessary rule it out but we would have to look
2	and see what was in that division and make a judgement
3	on what was being provided.
4	MEMBER PETTI: Okay.
5	MR. RECKLEY: Okay. If we can
6	MEMBER DIMITRIJEVIC: How sorry, this
7	is Vesna. How about the PRA code? The PRA now, they
8	been using design. Is it going to be applicant's
9	up in addition to PRA standard.
10	MR. RECKLEY: The PRA itself, our thinking
11	is would be governed the PRA standard. So, either the
12	light water or non-light water reactor standard and
13	then the assessments that are built into that
14	standard, the independent reviews and so forth.
15	MEMBER DIMITRIJEVIC: All right.
16	MR. RECKLEY: So, if we can go then to
17	Slide 36. There's a section on interfaces that we'll
18	probably build in to all the Subparts just to try to
19	reinforce that they all have to fit together.
20	If we go on into 37, this is one of the
21	things we put out to stakeholders when we released
22	this Subpart as a question and that is, the treatment
23	of inherent features, basically those things that are
24	governed by physics without either a need to activate
25	or have an active or a passive engineered system to
ļ	I

(202) 234-4433

192 1 provide and whether it would be useful to have additional discussion and guidance. 2 And it might help to go on then to 38, 3 4 which is Slide 38. This is Idaho National Lab, kind 5 of figure that basically goes through that for any design you have basically the same concept we were 6 7 talking about before. You have an inventory, you have a number 8 of barriers and traditionally you have originally for 9 large light water reactors, for the most part you had 10 active engineered features to do things like maintain 11 cooling of the cladding. 12 Then pressure relief to maintain 13 the 14 pressure boundary and containment cooling systems to maintain the reactor building in the final barrier. As 15 you move forward in time you started to have passive 16 17 systems to perform those roles. And then at the bottom is just the concept 18 19 that it is possible to have for some designs and some technologies and some power levels the ability to 20 perform those functions using inherent features. 21 Like reactivity feedback or heat removal 22 that might depend only on conduction and radiation and 23 24 not need a circulation path perhaps and so, as most of you are aware, as we moved from active to passive 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	193
1	there were was a lot of guidance written.
2	A lot of thought that went into moving
3	from active to passive and just the question is if we
4	are to be moving from passive to inherent, what
5	additional guidance, what other discussions would be
6	needed to support to moving in that direction? You
7	MEMBER MARCH-LEUBA: What's the difference
8	between passive and inherent? And haven't we been
9	taking credit for all this reactivity for bad, we take
10	credit for it all the time?
11	MR. RECKLEY: No, not exactly, Jose. What
12	they're proposing here, I believe, is that the
13	negative temperature coefficient of a solid moderator
14	is a shutdown mechanism. And so, I don't need
15	MEMBER MARCH-LEUBA: If you're over
16	MEMBER KIRCHNER: Yes, but not if you cool
17	down.
18	MEMBER PETTI: Well, if you cool down
19	super low but I'm just talking about it turns it
20	around so, do I have to have, you know, two
21	MEMBER MARCH-LEUBA: So, does void
22	fraction in a boiler, I mean, if you overheat a
23	boiling water reactor it will produce voids and it
24	will shut down. It will maintain k-effective one
25	eventually, is what everyone of this is going to do.
Į	1

(202) 234-4433

	194
1	This is part of the analysis. It's part of your
2	effected margins.
3	(Simultaneous speaking.)
4	MEMBER KIRCHNER: Bill, to the extent that
5	people take credit for these inherent or passive
6	features, it would seem to me the logic that would be
7	applied would be similar to what you discussed a few
8	slides earlier about trading off analytical safety
9	margin.
10	So that you would have to demonstrate that
11	this is maintained over the lifetime of the plant. In
12	other words, you know, as you go through a burnup
13	cycle the negative temperature of coefficients may
14	change.
15	As you go through leaving a plant operate
16	for 40 years we may have, I'll make something up, you
17	may have CRUD deposition on a boundary that is
18	passably cooled and that reduces the cooling rate.
19	So, you know, it erodes the, over time the
20	performance that you had been credited for in the
21	initial analysis. So, it seems to me, these things
22	should be encouraged but they would have to be, how
23	should I say it, maintained over the lifetime of the
24	plant.
25	You would have to have, I don't know if
I	I

(202) 234-4433

	195
1	tech specs is the right vehicle for doing that you
2	would have to be able to demonstrate that those
3	credited features over the lifetime of the plant would
4	still, you know, provide the desired performance.
5	MEMBER MARCH-LEUBA: Yeah, I don't think
6	the reactivity from that is going to degrade with what
7	lies instead. The problem I have actually, I have an
8	aversion to this, the first year replaces General
9	Design Criterion-27, thou shall have a shutoff
10	mechanism, that keeps the reactor shutdown, meaning k-
11	effective less than one.
12	By controlling the heat rate. Meaning
13	that as long as you increase the heat rate a little
14	bit you will get a reactivity feedback and you will
15	maintain k-effective of one no matter what happens
16	under any conditions.
17	That's not the same thing as GDC-27. I
18	only think that you need to consider having a GDC-27
19	to the Tier 1 safety criteria. Shutdown of a reactor
20	must be a fundamental principle.
21	Being able to shut it down and not letting
22	it run out, run off when the temperatures was high
23	because you got activity feedback, it's not the same
24	as shutting down.
25	MEMBER PETTI: So, Jose, just to give you

(202) 234-4433

	196
1	a comparison, I don't know if you know this, the
2	pebble bed reactor in China, the small one, HTR-10,
3	they shut it down by shutting the circulator off,
4	letting the temperature rise, very tiny rise. And
5	then the temperature coefficient brings it down and
6	then xenon builds in.
7	MEMBER MARCH-LEUBA: That's correct. All
8	of the gas cool reactors do that.
9	MEMBER PETTI: Well all, lots a solid
10	moderator and I think we're going to see a lot of
11	different in innovative solid moderators come out in
12	the micro-reactor space beyond a graphite.
13	And they all tend to have this behavior
14	and it's just something that we haven't looked at, you
15	know, in the U.S., solid moderators besides graphite
16	haven't been plenty since the 70s.
17	MEMBER MARCH-LEUBA: But this is a backup
18	for the shutdown system.
19	MEMBER PETTI: No. This is where, this is
20	the key issue is that some designers I know want to
21	say that is their primary, that it's a safety
22	function. It's how they're going to implement the
23	safety function and then they'll use the LMP in the
24	second system, the rods in essence become that middle
25	category of the three in the characterization.
	I

(202) 234-4433

	197
1	MEMBER KIRCHNER: Yeah. But, Dave, you
2	know, sooner or later that system cools down and you
3	need the rods to effect a, as Jose is saying, a
4	positive shutdown.
5	MEMBER PETTI: For sure
6	(Simultaneous speaking.)
7	MEMBER PETTI: function of the five in
8	terms of what power level it backs to, all that stuff.
9	MEMBER MARCH-LEUBA: And then our lessons
10	been learned that you have to analyze the transient to
11	its logical completion. In one reactor like this it
12	might be three months.
13	But you're leaving the reactor hot for a
14	while, eventually it's going to cool down and you're
15	going to return to power. You're not taking it to a
16	safe and a stable condition.
17	It might be acceptable. It's really great
18	that they have it but you are in a degrading, a
19	continuously degrading condition. You're
20	(Simultaneously speaking.)
21	MEMBER PETTI: Yeah, but what if
22	MEMBER MARCH-LEUBA: the rods.
23	MEMBER PETTI: But we just allowed a
24	design because they didn't violate SAFDLs to go
25	through a very similar approach.
I	

(202) 234-4433

198 1 MEMBER MARCH-LEUBA: Yeah. No, it's okay but we consider that, that's a defense-in-depth. 2 Ι 3 don't know, so --4 (Simultaneous speaking) MEMBER PETTI: All I'm saying is that they 5 could --6 7 MR. RECKLEY: So anyway --8 MEMBER BROWN: Not all of us agreed with. 9 So again, I'll leave this MR. RECKLEY: 10 maybe, because we posed it as a question, we're not Yes, such features to some 11 proposing an answer. degree have been built in before. 12 But as Dave is suggesting, the question 13 14 is, as they become the front defense mechanisms, what 15 additional quidance would we need and what, you mentioned some of the concerns. 16 17 What we're posing to stakeholders is, to what degree are proposing this that such that we need 18 19 to develop quidance to make sure that if you're crediting an inherent feature, you're staying within 20 the boundary conditions in which you're confident that 21 that behavior is guaranteed. 22 Both within things like 23 physical 24 conditions, temperatures and so forth, then over the life of the facility, all of the questions that you 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	199
1	raised.
2	So again, this question we're posing and
3	based on the feedback it might be another area where
4	guidance might be developed.
5	If we also need to look at the rule
6	language to support it, that might be another thing
7	that we talk about in a future iteration.
8	So, just so we can do design, I think
9	we'll go on to the public comments. Most of these
10	I've already talked about
11	MEMBER MARCH-LEUBA: Before you go there
12	on that line, the problem I'm having, I put myself
13	with my hat as reactor designer with this rule is that
14	you having so much flexibility that I don't know what
15	you're approving and you're not approving.
16	I'm going to either be very concerned
17	about it and not believe you want to approve or yes,
18	think you want to approve and go see, bring it around
19	and see if you approve it.
20	The guidance doesn't tell me if I can do
21	this or not and this is not the only, I mean, there
22	are many where you say well, bring us a proposal and
23	we'll look it.
24	In other words, the rule does not forbid
25	you from bringing a proposal but doesn't tell you what
	I

(202) 234-4433

	200
1	to proposal needs to satisfy, which leaves me with a
2	lot of licensing uncertainty.
3	Yes, put it on the record. I know you
4	don't want to prescript it but there is a perfectly
5	good alternative, which is using exemptions when you
6	want to get out of the rule. As it is, I don't know
7	what you want me to do.
8	MR. RECKLEY: Okay, thank you. So, let's,
9	so again, I've talked about most of these in terms of
10	the comments and even given the hint at the direction
11	we're going.
12	The discussion of occupational dose, we
13	talked about the need to continue the discussion on
14	generally accepted in terms of Consensus Codes and
15	Standards.
16	I mentioned there was a suggestion that
17	security could be put off and be addressed by the
18	overall security program and not included within the
19	design activities, within this Subpart. Going on to
20	Slide 40.
21	A lot of discussion and we had it here
22	today, very similar discussions of not using the PRA
23	for the purpose of selecting your licensing basis
24	events and safety classifications.
25	That the PRA should complement the safety
ļ	

(202) 234-4433

	201
1	review, allow more, allow other approaches. Some
2	discussion that even the PRA itself should be
3	optional.
4	One issue that's come up kind of as a
5	continuing theme is our discussion all along in the
6	rulemaking plan, and even before the rulemaking plan,
7	was that we would use the guidance in Reg Guide 1.233,
8	the NEI 1804 methodology as one acceptable way for
9	this rule to be, to meet this rule.
10	And one of the comments, again a recurring
11	a theme has been, the rule may lean too much in that
12	direction. That it might actually end up requiring or
13	not allowing any other approach or requiring the use
14	of LMP.
15	And so, that's one of the areas where
16	we're looking trying to strike the balance to maybe
17	provide alternative but as we've said all along to
18	maintain that methodology is one acceptable way to
19	meet this rule.
20	That was, you know, from our perspective
21	that's why we undertook that initiative back when we
22	were doing LMP. We said we foresaw it being used for
23	what is now Part 53, so, you know, it was part of the
24	rationale for everything we've done in the last three
25	or four years.
I	1

(202) 234-4433

	202
1	So, we want to maintain that. At the same
2	time, we're hearing those that are complaining or
3	observing that maybe we're precluding other methods.
4	So, as we prepare the next iteration, we'll look at
5	alternate approaches. Maybe more deterministic
6	approaches.
7	Then another discussion about consistency
8	with IAEA or other regulator's approaches that look at
9	PRAs somewhat differently and build them into the
10	regulatory structure somewhat different than what we
11	had proposed here. So
12	CHAIRMAN BLEY: Bill?
13	MR. RECKLEY: Yes?
14	CHAIRMAN BLEY: As I read information from
15	various sources, a lot of this emphasis on developers
16	seems to be that they really are hoping for
17	consistency in regulation internationally so that they
18	can sell these things in many different places without
19	doing a full, you know, review everyplace they go.
20	Does that seem what they're after to you?
21	MR. RECKLEY: Yeah, that's the comment on
22	the international frameworks. That, to the degree we
23	can try to either be consistent with or at least that
24	whatever we put into this rule doesn't require
25	starting all the way over from scratch to go to
l	

(202) 234-4433

	203
1	another approach.
2	It is the desire. So, again, it's
3	something we're looking at and trying to do. We're
4	aware of this kind of issue and desire even before.
5	I think we've talked to you before about
6	having agreements with CNSC, the Canadian Nuclear
7	Safety Commission and kind of looking at our
8	approaches.
9	Because there are a number of potential
10	applicants that would look at both countries and then
11	obviously were involved in IAEA and some other
12	activities. So, yes. We're trying to do that.
13	Going on to 41. Some other observations
14	has been that defense-in-depth, while it's a good
15	philosophy should be addressed somewhere other than
16	incorporating it into the regulations.
17	Or, maybe and/or the guidance we could
18	clarify, what would be a defense-in-depth analysis
19	when either you're using an approach other than
20	licensing modernization that includes a methodology
21	for a defense-in-depth.
22	Or reflecting the decision, the discussion
23	we just had when there's a reliance on inherent
24	features, what additional measures might be taken for
25	defense-in-depth above those provided by the IAEA.
ļ	I

(202) 234-4433

	204
1	What would be considered an inherent feature?
2	So, those are the, kind of discussion
3	points. Think we have one more slide, 42. So, that's
4	really the discussion and a summary of the feedback
5	we've gotten on Subpart C.
6	I think I can get through Subpart D
7	deciding one in the allotted time here. Largely
8	because Subpart D will look very familiar. We are
9	largely, we're not proposing dramatic changes to what
10	goes into the siting considerations.
11	But any last-minute discussion on Subpart
12	C, the design and analysis Subpart?
13	CHAIRMAN BLEY: No. But just a quick note
14	from me. We wrote a letter a year and a half ago on
15	your draft SECY paper on siting considerations for
16	advanced reactors, went with you toward option three.
17	Do you, in your opinion, is what you have in here
18	pretty well consistent with that?
19	MR. RECKLEY: Yes. In so, and the
20	language is the same. Actually, in our proposed
21	Subpart D the language is pretty much the same as the
22	existing language in part 100 and therefore the
23	methodology and flexibility that would come with the
24	options that we describe in SECY-20-45 would be
25	available under this.

(202) 234-4433

	205
1	But we didn't mention it specifically but
2	it would be available because it was written to this
3	language that comes out of Part 100. I'll talk about
4	that as we, when we talk on the population slide.
5	CHAIRMAN BLEY: Okay, good.
6	MEMBER BROWN: This is Charlie. I did
7	have one comment or maybe it's a question, I'm not
8	sure which. This is on Slide 41, about the defense-in-
9	depth required when you've got physics or inherent
10	features.
11	That it always disturbs me a little bit
12	when we think maybe DID is not required when some
13	unknown accident progression that nobody envisions all
14	of sudden rearranges, disturbs the inherent and/or the
15	physics-based feature.
16	A lot of stuff we don't know that we found
17	out later when we're doing designs, we're not familiar
18	with. So, I hope NRC is not compromising and leaving
19	I thought incorporating DID into the overall
20	thought process was the right way to do it. I hope
21	you don't throw that out. It's just my observation.
22	MR. RECKLEY: Yeah, this comes into play
23	specifically under our defense-in-depth proposal. We
24	had a requirement that no single element be credited,
25	I mean not be relied upon.

(202) 234-4433

	206
1	And so, this question kind of comes in the
2	context of, well what if you have some inherent
3	feature, do you really need to back it up and again?
4	The comment was coming in the context of
5	the DID requirement that we included in the first
6	iteration that included the sentence, no single
7	feature shall be totally relied upon, words to that
8	effects.
9	MEMBER BROWN: Did you eliminate that in
10	your, did we not see the original version?
11	MR. RECKLEY: You saw the original
12	version. We're working on evaluating comments to see
13	if we might change anything in that regard.
14	MEMBER BROWN: If you decide to throw out
15	defense-in-depth you ought to explicitly address it
16	with us.
17	MR. RECKLEY: Oh, we will. When we come
18	in a future meeting, probably the March meeting if we
19	have one set up in March. We'll be bringing any
20	revisions we made to B and C in light of ongoing
21	discussion.
22	And then, as I said, these are going to be
23	continually iterated because we continue to get
24	comments, we continue to learn as we develop future
25	Subparts that something needs to be changed to make it
	I

(202) 234-4433

	207
1	work.
2	And so, this will be dynamic all the way,
3	well, logically, I mean, it'll probably be dynamic all
4	the way through the process. But at least until we
5	start to get the package together in the Fall.
6	We'll be constantly iterating. Hopefully,
7	converging so that each iteration is making less and
8	less changes, just tweaks. But yes, we would probably
9	come to you at the next meeting with any changes we're
10	thinking about for B and C, Subparts B and C.
11	MEMBER BROWN: Okay, thank you.
12	MR. RECKLEY: And then as Dennis has
13	pointed out, anytime you see us going in the wrong
14	direction, you can, you have an option then of saying
15	hey, maybe this is something that needs to come before
16	the full Committee.
17	(Simultaneous speaking.)
18	CHAIRMAN BLEY: I would say it happened
19	years ago, as recently as maybe 10 years ago is
20	everybody knew what defense-in-depth meant but you
21	didn't find in the rules and it essentially meant
22	something different to everybody.
23	I think the work that was done by the
24	staff on putting together the NUREG
25	MR. RECKLEY: Yeah, the knowledge
	I

(202) 234-4433

	208
1	management.
2	MEMBER KIRCHNER: Yeah, KM009.
3	CHAIRMAN BLEY: was really useful and
4	I'd hate to see it disappear. I mean, what we got
5	here is, when, it's essentially a fill the gap, as
6	Charlie was in saying in another set of words.
7	It takes care of, it helps cover our
8	uncertainty in identifying the areas where we have
9	uncertainty and making sure we have sufficient
10	defense-in-depth to support those areas is really
11	important.
12	It was one place I thought NEI, 19-04, 20-
13	04 on the LMP did a really, the best job I've seen of
14	explaining how you bring all of the quantitative and
15	qualitative ideas together to really decide how much
16	defense-in-depth you need.
17	Twenty years ago, we'd gone so far
18	anything anybody wanted they just said defense-in-
19	depth and we had no control of it. Pushing it aside
20	doesn't make much sense to me. I think refining it a
21	little bit here is important. But, you know, again,
22	it's one member.
23	MR. RECKLEY: Yeah, and I want to go
24	ahead. I'm sorry, Walt.
25	MEMBER KIRCHNER: Yeah, I was going to
l	I

(202) 234-4433

	209
1	jump in, Dennis, and say that or suggest that, and
2	Mary Drouin's work has a short list of considerations
3	and this second bullet is bothersome to me as it
4	probably is to Charlie.
5	I mean, I can't, I'm an advocate of these
6	advanced designs with inherent safety features and so
7	on but maintaining multiple fission product barriers
8	is just, you know, you can't, you have to have a
9	reasonable balance.
10	And you can't overly depend on one design
11	attribute. So, some, I, like Dennis said, I would
12	hope you do not drop this.
13	I think there's a way in your rulemaking
14	to very concisely in a paragraph outline what you mean
15	by defense-in-depth. So that would-be applicants have
16	at least a conceptual idea of what you are, what you
17	mean by DID as pertains to 10CFR 53.
18	MR. RECKLEY: Okay, thank you. And I
19	don't want exaggerate that stakeholders are not, are
20	wanting to do away with defense-in-depth or even in
21	some of the previous discussions as low as reasonably
22	achievable.
23	Or even the safety code policy statement
24	for those commenting about that, the question comes
25	down what do we incorporate into the regulation, what
I	1

(202) 234-4433

	210
1	stays as policy and philosophy and what gets
2	incorporated.
3	So, we saw this largely as an opportunity
4	to look at the policy statements that were done over
5	the last 30 or 40 years and there was a reason they
6	were adopted as policy statements as opposed to trying
7	to incorporate some of that into Part 50.
8	But given we're starting from scratch our
9	thought was this is an opportunity to take what the
10	Commission has said is important and important enough
11	to write down in a policy statement and actually
12	incorporate it into the, kind of the infrastructure of
13	the rule.
14	But again, that'll be something that as we
15	go through the iterations, we'll work out what
16	actually gets incorporated into the rule and what
17	might be addressed by guidance documents or remain as
18	Commission policy.
19	MEMBER KIRCHNER: Well, didn't you state
20	that defense-in-depth is policy or a philosophy, would
21	it not fit in, Bill, in your Part B?
22	MR. RECKLEY: Oh
23	MEMBER KIRCHNER: Or you would make a, let
24	me use the word policy statement about defense-in-
25	depth and describe what you mean by it and then, you
I	I

(202) 234-4433

	211
1	know, then you can look for either in the design
2	section, Part C or you can look at it in the, I forget
3	which letter is operations, where you do defense-in-
4	depth through tech specs or administrative and
5	programmatic controls.
6	MR. RECKLEY: Right. So again, I think
7	we're all-in agreement. We put it in there in the
8	first place. Maybe I should just cut to the chase,
9	expect it to stay there.
10	But we are listening to the nuances as
11	well, so there's, you know, the big question of
12	whether to keep it or not and then there's the
13	secondary questions of if it's kept, exactly how it
14	reads and what, is there opportunities to maybe
15	improve how it's written.
16	So, we're leaning at this point, in terms
17	of the next iteration, we're leaning towards the
18	latter, changing the wording a little bit but keeping
19	the overall thought as you read it the first time.
20	So, getting into siting, again, I'm hoping
21	I can get through this relatively quickly. Because
22	it's largely not introducing major changes. The way
23	it fits into the analysis and so forth, changes a
24	little bit.
25	But we've talked about that in the past
I	I

(202) 234-4433

	212
1	so, going on to 44, there's a 53.500, just a you
2	can go onto the next one if you will, 45. There's a
3	general requirement mentioning why, in the biggest
4	picture why we have siting considerations.
5	And it's basically to identify the threat
6	or the hazards that the site introduces to the plant
7	and then vice versa, the threats that the site
8	introduces to the environment.
9	So, looking at in both directions, that's
10	always been the general approach to the siting
11	requirements. The one thing that does get introduced
12	here, although it's not a dramatic change, I don't
13	believe, is the introduction and the tying of the
14	siting to the Subpart B first and second tier safety
15	criterion.
16	And we'll talk about that in large part on
17	the next Slide 46. So, the first part of that
18	discussion is what threat does the environment pose to
19	the plant. That's generally referred to as external
20	hazards.
21	The approach is that SSCs needed to meet
22	the first tier need to be designed to withstand
23	natural phenomena and manmade hazards up to the
24	design-basis external hazard level. And that's a
25	phrase that's taken out LMP NEI 18-04.
ļ	I

(202) 234-4433

And basically, it's the same thing we do 1 now, safety-related equipment needs to be designed to 2 3 withstand an external hazard level up to the design-4 basis earthquake, the design-basis flood, design-basis 5 wind loading. That is basically comparable to what we're 6 7 doing now. We did add the second sub-bullet, which is a bit of a change but I don't think it's a dramatic 8 9 change in that we adopted the seismic numbers of 1 in 10 100,000 years. With added margin to address uncertainties 11 to be a standard that would be used for all external 12 The guidance now, there's a bit of a range 13 hazards. 14 from hazard to hazard that's been introduced in terms 15 of the frequency and the probability of exceedance and so forth from hazard to hazard. 16 17 So that's basically again, is what we do now for safety-related SSCs and it reflects, again, 18 19 the approach in NEI 18-04 in terms of applying the design-basis external hazard level. 20 We did maintain a specific requirement for 21 the safe shutdown earthquake ground motion and that 22 again, reflects the current requirement including the 23 24 establishment of the minimum .1g value.

So again, nothing really being introduced

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

25

Í	214
1	in Part 53 that's a departure from where we are now or
2	have been recently anyway. If we go onto 47. This is
3	a new requirement and it actually goes beyond current
4	requirements.
5	And that is, given you have a PRA that one
6	needs to do, the analysis required under 53.450, which
7	is the PRA, needs to address external hazard
8	frequencies and related SSC fragilities related to
9	those hazards within the PRA to the degree that's
10	possible.
11	And so, we're just trying to build in
12	looking forward that the external event PRAs would be
13	done. At the same time, we recognize the state of the
14	art might not be there for all hazards quite yet. Any
15	thoughts or questions on that?
16	MEMBER BROWN: Yeah, just I had forgotten
17	something so, I need you to refresh me. One of the
18	statements in 53.10, if I can make my picture big
19	enough to read it, was that they need to design or
20	address a range of estimated external hazard
21	frequencies to once in 100,000 years.
22	Is that standard on number? 100,000
23	sounds, how can anybody ever believe what you're
24	talking about?
25	MR. RECKLEY: That's the current number in

(202) 234-4433

	215
1	
2	MEMBER BROWN: Okay.
3	MR. RECKLEY: the seismic approach.
4	MEMBER BROWN: Okay. I'm not as familiar
5	with the overall seismic stuff. That's why I asked
6	the question. All right. Sounds ridiculous to me,
7	but.
8	MR. RECKLEY: Well actually is the seismic
9	arena, given the ability to look at historical data,
10	that's why they've been able to do that and I'll ask
11	Dennis or somebody or Marty to please jump in, I'm not
12	a PRA expert.
13	But at least in geologic history you can
14	track things like that and so, you do have some
15	ability to look at earthquakes. There are other
16	hazards where you may not have the ability to
17	construct such an approach and that's why the ability
18	to do probabilistic hazard analysis in some other
19	areas is more challenging.
20	(Simultaneous speaking.)
21	MEMBER BROWN: The Mineral Springs
22	earthquake was kind of a surprise up here into the
23	North Anna, near North Anna so, I don't know, I never
24	saw an analysis of that but
25	MEMBER KIRCHNER: Charlie, actually you
ļ	

(202) 234-4433

	216
1	can do a good job on the seismic, as Bill said. The
2	thing, surprisingly, it's things like meteorology
3	where we have only a 100-year history.
4	So, there it becomes more difficult to
5	construct the 1 in 100,000 event but certainly in the
6	seismic area, there's good geologic basis for what
7	they've been able to extract there.
8	MEMBER BROWN: Well, I'd like to see
9	somebody show that the one that occurred, that the
10	North Anna and Mineral Springs area in Virginia was
11	outside the 100, once in 100,000 years.
12	CHAIRMAN BLEY: It was not, Charlie. It
13	wasn't
14	MEMBER KIRCHNER: It was not, yeah. It
15	was within it.
16	MEMBER BROWN: So it, so they didn't meet
17	the metric then? It shouldn't have happened in other
18	words?
19	MR. RECKLEY: Well no, actually the
20	opposite. The North Anna plant was designed for that,
21	it exceeded a little bit but in some frequency ranges,
22	I think. But again, Marty can weigh in.
23	But by and large the plant was already
24	designed for that or very nearly that level of a
25	seismic event.
I	I

(202) 234-4433

	217
1	MEMBER BROWN: Okay, thank you. I learn
2	something all the time.
3	MR. RECKLEY: Okay. So, then we can go on
4	to 48, I think. This is again just the need to
5	characterize the site and to gather data on
6	meteorology, the geology, seismology, all of the -
7	ologies in order to understand the site.
8	What would happen if radioactive material
9	were to escape in terms of how would it be transported
10	in air, how would it be transported in water. Again,
11	nothing, this was largely just taken from the existing
12	requirement in Part 100.
13	And it makes a certain amount of sense. I
14	don't think we got any significant feedback that you
15	don't need to characterize the site.
16	You can go on to 49, I guess before we
17	leave site characterization, the potential model and
18	this is, when you get into the micro-reactor realm and
19	if the thought is these are being fabricated in
20	factories and being deployed, whether the degree to
21	which they would take bounding approaches to these
22	external hazards and then be able to also in this area
23	basically say they're compatible with this, you know,
24	this range of sites such that you could minimize some
25	of these evaluations.
I	I

(202) 234-4433

	218
1	Along with the general discussion of
2	manufacturing licenses, something we want to
3	understand from the industry and other stakeholders on
4	exactly what is the model and what would Part 53 need
5	to address in terms of this kind of a deployment if
6	that's being contemplated, so
7	CHAIRMAN BLEY: Bill?
8	MR. RECKLEY: Yes, Dennis.
9	CHAIRMAN BLEY: This jumped off the page
10	at me because we've been looking at something that
11	came up because of concerns about where micro-reactors
12	in particular might get sited as the NRC has now
13	developed the Reg Guide on volcanology, in case it's
14	too close to volcanos.
15	And you don't mention that one in your
16	list here and it came up particularly for some of the
17	new reactors. Seems like you ought to have it in
18	there.
19	MR. RECKLEY: Yeah, it would be addressed
20	in the external hazards that needs to be identified.
21	You're probably right. We can certainly add that. I
22	don't, again, we lifted this largely out of Part 100,
23	one could say geology includes volcanology but maybe
24	we'll add specifically. It's definitely
25	CHAIRMAN BLEY: You've actually done a Reg
I	I

(202) 234-4433

	219
1	Guide on it recently.
2	MR. RECKLEY: Yeah, no, and its,
3	volcanology, volcanos have always been included in the
4	list of external hazards one needs to assess. It's,
5	the NUREG Guide or Draft Reg Guide is just going into
6	more detail on how to do that assessment. But yeah,
7	okay. Good point.
8	If we can go to 49, yeah, 49. This gets
9	into, Dennis, what you were saying and it's also an
10	area where we got some feedback in this area on the
11	population-related siting considerations.
12	We were looking at it as we developed SECY
13	20-0045 on alternatives to population density and so,
14	we're awaiting the Commission to make a decision on
15	that SECY paper.
16	And so, we didn't go much further than
17	that paper. What we've included here would allow that
18	flexibility but we didn't go much further than that.
19	So, what 53.530 talks about is the
20	definition of both the exclusion area boundary and the
21	low population zone using the existing criteria, 25
22	rem for two hours for the EAB or over the course of
23	the event for the low population zone.
24	Some of the comments were to replace those
25	with the site boundary. This goes again, to whether
I	I

(202) 234-4433

	220
1	Part 53 should continue to allow a future advanced
2	reactor to meet the same criteria that existing plants
3	have or should we, for example, prohibit any plant
4	that would exceed 25 rem dose at the site boundary.
5	Our current approach is to try to support
6	the flexibility that advanced reactors can have an
7	exclusionary boundary and low population zone defined
8	as the site boundary if that's where, if they can show
9	that the dose does not exceed 25 rem.
10	So, it's setting up the equivalency, the
11	site boundary is the site boundary, it's the
12	exclusionary boundary, it's the low population zone
13	boundary.
14	But if there are advanced reactors that,
15	for whatever reason would be designed and have the
16	potential for the 25 rem offsite, thereby they're also
17	going to set up that they're going to need emergency
18	planning offsite, that that flexibility be provided.
19	So, it comes down to trying to allow
20	flexibility. So, the current language that we used
21	here allows the exclusionary boundary and low
22	population zone to collapse.
23	It also allows, if anyone were so to
24	choose, to keep with the existing system. So that was
25	the logic of using the existing language. The
ļ	I

(202) 234-4433

	221
1	MEMBER BROWN: Bill.
2	MR. RECKLEY: Yes?
3	MEMBER BROWN: Go ahead, I'll wait until
4	you're done.
5	MR. RECKLEY: No, no. Well, I was going
6	on to the next slide.
7	MEMBER BROWN: Oh, okay. I just want to
8	make sure I understand it. Effectively there's a
9	fence around the site most of the time of some sort.
10	A physical barrier around the site.
11	MR. RECKLEY: Right.
12	MEMBER BROWN: So, this would, if they
13	took advantage of this because they meet the 25 rem
14	that means somebody could have their backyard up
15	against the site boundary? Is that correct?
16	MR. RECKLEY: Yes. That the, usually the
17	way it is set up is you have a site boundary then
18	beyond the site boundary out to, typically about a
19	half a mile you have the exclusionary boundary where
20	the licensee has the ability contractually to control
21	people within that boundary.
22	MEMBER BROWN: Yeah, but you said you're
23	waiving that.
24	MR. RECKLEY: It could collapse if they
25	can show that the 25 rem won't exceed the 25 then
I	1

```
(202) 234-4433
```

	222
1	you're right, you would not need an additional half a
2	mile distance or even any distance
3	MEMBER BROWN: Somebody could build a
4	house right next door to the boundary if they meet
5	this requirement?
6	MR. RECKLEY: That's right.
7	MEMBER BROWN: So, wouldn't there be some
8	other physical safety concerns relative to people that
9	do that that have ulterior motives?
10	MR. RECKLEY: Yeah. As we get, then
11	there's another
12	MEMBER BROWN: Safety, you know, physical
13	safety issues, you know what I'm talking about.
14	MR. RECKLEY: Yes. And actually, as we
15	get into the security arena there's another zone, the
16	owner-controlled area that is set up for security
17	reasons.
18	Sometimes, traditionally they might
19	overlap with some of these radiological areas just
20	because it made sense for an owner-controlled area and
21	an exclusionary boundary to line up.
22	But there is another consideration of
23	where people live and that is in the security realm
24	under the owner-controlled area.
25	And if were to be, if it were to make
l	I

(202) 234-4433

	223
1	sense from a security standpoint to have people not
2	having their backyard at the fence, then that would be
3	another way but for reasons other than radiological to
4	have them be at a distance.
5	MEMBER BROWN: Yeah, I just wanted to make
6	sure there was still, is the safety or the owner-
7	controlled boundary part of these Part 53
8	considerations or not?
9	MR. RECKLEY: It may be when we get to the
10	security program, which would be under Subpart H.
11	MEMBER BALLINGER: So then, in order to
12	avoid having to have evacuation plans and all that
13	stuff, you just simply build the plant where the fence
14	is out to the point where you don't exceed the 25 rem?
15	MR. RECKLEY: You could do that.
16	MEMBER KIRCHNER: But the PAGs, Ron, are
17	one rem.
18	MR. RECKLEY: Yeah, that's different than
19	emergency planning and having evacuation plans, which
20	as Walt said, is one rem.
21	MEMBER BALLINGER: Okay, well then that
22	just makes it a little further out. 1 over R-squared.
23	MR. RECKLEY: In theory, one could do
24	that.
25	MEMBER BALLINGER: Well, the Seabrook
ļ	I

(202) 234-4433

	224
1	Plant up here just simply sold a lot of their land
2	right up to the boundary and now there's a giant
3	shopping center and the access road to the plant goes
4	through the parking lot for the shopping center. You
5	don't even know it's there.
6	MR. RECKLEY: So, again, I would just
7	weigh in, this is basically the current requirement.
8	And the EAB and the LPZ, the low population zone,
9	exclusionary, have always been defined in terms of
10	these dose values. So, this is the existing
11	requirement.
12	MEMBER REMPE: Bill, before you leave this
13	slide or if you, I'm not sure if you're done with your
14	sentence. Did you have another comment?
15	MR. RECKLEY: No, I did not.
16	MEMBER REMPE: Okay. So, on this last
17	item, it sounds like, again, I've seen this before,
18	that you're assuming a single release from an event
19	and as I recall the gas reactor has circulated, if it
20	had a LOCA, there's a circulating activity release.
21	And then you might later heat up and you'd
22	have additional releases coming out that might be more
23	substantial. So, is a release the word you want to
24	use in the second bullet?
25	MR. RECKLEY: The actual language is, I
I	I

(202) 234-4433

	225
1	think, refers to the worst case. The worst two hours,
2	and in the low population zone if over the period, the
3	whole period of the release, which would be including
4	the PUF and the subsequent release.
5	MEMBER REMPE: Okay. So, what if there's
6	a design that's, because again you've got this, it's
7	the release associated with an event is basically what
8	I'm trying to be clear about and I hope the language
9	is clear.
10	Because I thought when I looked at it, in
11	an earlier section they talked about a single plume.
12	We want to make sure that it's recognized you could
13	have more than one release associated with an event.
14	MR. RECKLEY: Right. And keep in mind
15	also that, for Part 53, when we talk about a plant it
16	includes multi-units and so, not only could you have
17	different timing of different releases from a unit,
18	you could have different timing from different units
19	and you could have different timing in the case of an
20	external event from different inventories associated
21	with different units, so.
22	MEMBER REMPE: And I thought that was the
23	response you gave me back but I thought the language
24	I saw here still kind of talks like it's a single
25	release.
ļ	I

(202) 234-4433

	226
1	MR. RECKLEY: Okay, that, we'll look at
2	that language and make sure it's clear that this is
3	looking in total and reinforces, again, one difference
4	for Part 53 is, it's multi sources, multi units.
5	And as you're saying, potential different
6	time frames. So, we'll look at that language and make
7	sure that in our copying it over from Part 100 we
8	didn't inadvertently lose the continuity of that
9	requirement.
10	Anything else on EABs and low population
11	zones? If not, we can go to Slide 50, which is
12	talking about the population center distance. This is
13	an existing requirement as well.
14	And it does start to get into the
15	relevance of SECY 20-0045 on population densities.
16	And just as a remainder, the low population, I mean,
17	the population center distance is currently defined as
18	the, you take the low population zone boundary.
19	So, traditionally that's been a number of
20	a couple miles and it's one and a third so, just one
21	way to think about it easily, if the low population
22	zone is three miles, the population center distance,
23	which is the distance between the plant and the
24	nearest population center of 25,000 people could not
25	be any smaller than four miles.
I	I

(202) 234-4433

227 1 And that was just developed in the, you know, all of this was developed in the, kind of early 2 3 davs. The NUREG-0396, the whole setting up of the 4 emergency planning programs and so the multiplying by 5 one and а third was just а way to add some 6 conservatism, make sure things like emergency plans 7 could be effectively done and to site them away from somewhere where that might become an issue in the 8 9 value of 25,000 where the population center was 10 selected way back in the, it was probably in the 1960s, I guess. 11 So, we actually maintained that but as we 12 talked about in SECY 20-0045, if you're collapsing the 13 14 low population zone to the fence then you basically 15 have a low population zone distance of zero and one and a third. 16 17 You don't, this doesn't come into play unless you have a dose of 25 rem at some distance from 18 19 The last bullet on the slide, reactor the plant. sites should be located away from very densely 20 populated centers. 21 And this is more or less the way the rule 22 It's one of the more general-worded rules 23 is worded. 24 that you'll find, even including that sentence where population, low population densities are generally 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	228
1	preferred.
2	This is where we addressed in SECY 20-0045
3	that instead of 500 people per square mile as the
4	population density out to a distance of 20 miles, we
5	would introduce a, or potentially introduce if the
6	Commission approves it, a consequence-oriented formula
7	where our recommendation, as Dennis mentioned, was
8	that the distance would be out to twice the distance
9	at which you get one rem dose to an individual over a
10	period of a month.
11	And so, it's roughly twice the emergency
12	planning zone distance, I mean, the, yeah, the
13	emergency planning zone. But that is what we
14	recommended. So instead of 20 miles, it could be a
15	smaller number.
16	But there still would be a limit on
17	population density. If there was a dose off site
18	exceeding one rem and if there were no doses off site
19	that exceeded one rem, then the only population-
20	related requirement that comes into play is that
21	reactor sites should be relocated away from densely
22	populated centers, which is defined as 25,000.
23	And so, the interpretation in SECY 20-0045
24	is, if you have no dose exceeding one rem off site,
25	you could be located almost anywhere except for in a
I	I

(202) 234-4433

	229
1	population center of greater than 25,000 people.
2	And so, that is the way this carries out
3	and this is what we brought into Part 53. As we'll
4	talk about, some stakeholders want that even further
5	relaxed but our current language in this iteration is
6	as I described it. So, questions on the population-
7	related?
8	MEMBER BALLINGER: This is Ron. It looks
9	to me that most of this rule is assuming as a
10	practical matter that the plant that you're going to
11	install is going to generate electricity.
12	What about a plant that you want to
13	install that's just going to generate heat for use in
14	processing?
15	MR. RECKLEY: There's nothing in the rule
16	that we foresee that is totally dependent on the end
17	product. For example, whether it be electricity or
18	process heat. The
19	MEMBER BALLINGER: But if you plunk this
20	thing down in the middle of a site where they're doing
21	mining and there's a lot of workers and things like
22	that, does that make a difference?
23	MR. RECKLEY: Well, the way we have
24	currently constructed it, as it's described in SECY
25	20-0045, is that a reactor could support those

(202) 234-4433

	230
1	activities because those areas are usually population
2	centers of less than 25,000 people.
3	If you start to talk about process heat
4	being district heating or process heat in an
5	industrial facility that is also in a densely
6	populated center, this could become a restriction.
7	So, one of the things again we would be
8	interested to hear from stakeholders is, if the 25,000
9	is going to become if they see 25,000 as an
10	obstacle to actually deploying these reactors as they
11	envision, might we need to look again to see if that
12	is a needed limitation?
13	Right now, we didn't do the assessment
14	because we didn't, we're not changing current
15	requirements. But if the thought was to put advanced
16	reactors into more densely populated centers, what
17	would need to be considered?
18	And what limitations would come with that?
19	That's a question. Since we didn't propose it, we
20	didn't need to come up with a justification. But if
21	it is going to be proposed, what would be the
22	argument?
23	So, I'll leave it there if there are
24	people with thoughts or concerns on that aspect of
25	whether we should go further in terms of flexibility
	I

(202) 234-4433

	231
1	in siting.
2	MEMBER PETTI: So, Bill, this is all
3	depending on that document that you presented to us
4	that's not yet approved, right?
5	MR. RECKLEY: Yes. I mean
6	MEMBER PETTI: Is that just, you know, a
7	time constant for the bureaucracy and the gears to
8	move or there is a chance that somehow higher up the
9	chain people that don't like and you have to, might
10	have to and rewrite this?
11	MR. RECKLEY: I mean, where it is right
12	now is for the Commission to consider. It's made it
13	through the process and it's with the Commission, so.
14	MEMBER BALLINGER: What document is that?
15	Excuse me, I'm sorry.
16	MR. RECKLEY: This is SECY 20-0045.
17	MEMBER BALLINGER: Oh, okay. I have it.
18	Thanks.
19	MR. RECKLEY: So, I don't know the answer,
20	David, as to what the Commission might decide. I
21	mean, if they, if the Commission were to decide just
22	to deny that SECY paper altogether and just stick with
23	the current requirement, the guidance, the key part
24	is, everything we've adopted up to this point is in
25	accordance with the existing guidance, existing rules.

(202) 234-4433

232 1 It's just the quidance that we were proposing to provide additional flexibility 2 by 3 shrinking the 20 miles. If the Commission were to 4 decide to maintain 20 miles at 500 people per square 5 mile, that would, you know, that would have an impact on the deployment models. 6 7 CHAIRMAN BLEY: I'll just mention that we wrote a letter on this in late 2019 and briefed the 8 9 Commission on this sometime after that so, we've gotten our input to the Commission. 10 MR. RECKLEY: Yeah. I mean, from the 11 staff's point of view in writing Part 53, the question 12 is really at this point, whether to go beyond the 13 14 flexibility that's afforded by both the existing rules and the quidance documents including the potential for 15 additional flexibility in SECY 20-0045. 16 17 Again, some stakeholders are saying it should be opened up more than this. We will see what 18 19 arguments are brought forth to possibly support that 20 argument. You know, it's always brought up so, I 21 might as well, you know, just pose it as a question to 22 the Committee, you know, it's always brought up, do we 23 24 want to revisit Ravenswood, right? Ravenswood was the boiling water reactor 25

> NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

(202) 234-4433

	233
1	proposed, I'll get my rivers wrong. Anyway, it was in
2	the middle of New York City, East River or Hudson
3	River. So, in a very populated place.
4	Would we want to go as far as to say there
5	are no requirements related to siting and population
6	and a reactor can make a case based on its consequence
7	assessments and be placed anywhere.
8	You know, that would be the question. The
9	long-standing policy of the Commission has been as
10	it's stated here, areas of low population away from
11	very densely populated centers.
12	If there's an argument that should no
13	longer be the position based on an analysis of
14	advanced reactors or potentially micro-reactors in
15	particular, should we, in Part 53, ask the Commission
16	to change that policy I guess, would be the question.
17	We're not proposing to do that. You guys
18	can think about it. You'll see this again as we go
19	through the iterations and as you see the total
20	package. I'll leave it then as a question because
21	we're at the end of the time. But I only have like a
22	couple more slides.
23	So, if we could do 51, we talked about the
24	interfaces. Basically, every subpart will have a
25	reminder of its interfaces with others.
ļ	1

(202) 234-4433

	234
1	Obviously, external hazards goes back to
2	things like 53.540 on, I mean, I'm sorry, 450 on the
3	analysis and safety classification and so forth.
4	And applicants would have to also address
5	all the environmental requirements in Part 51. So, if
6	we go to 52, Slide 52. Some of the public comments I
7	already mentioned.
8	Specifically use of the site boundary as
9	the EAB and low population zone specifically as
10	opposed to, I suppose allowing the EAB and LPZ of
11	being outside the site boundary.
12	The comment I just made, that there's some
13	observation by some stakeholders that the safety
14	criteria does away with the need to worry about
15	population centers, population densities and so forth.
16	And sort of the last bullet there is a
17	notion that, and this goes to some of the other
18	discussion of maximum hypothetical accident and so
19	forth, it is impossible to just show that a particular
20	design is impervious to external hazards or some
21	subset of external hazards and therefore, not need to
22	do any additional analysis, any additional
23	characterizations of a site and so forth. And with
24	that, I go to the last slide, which is just questions.
25	CHAIRMAN BLEY: No, but you brought up
I	1

(202) 234-4433

	235
1	something I'd mentioned to my colleagues on the
2	Committee. If anybody is entertaining this idea that,
3	forgetting about what happened at Ravenswood is a good
4	idea, I'd suggest reading the chapter on Ravenswood in
5	Dave Oklin's book that all of you have access to. But
6	it might be something to talk about at a later time,
7	not now.
8	Any comments from the Committee? If not,
9	I'd like to get the public line open, so we could
10	entertain public comments and then I'll come back to
11	the Committee. While we're waiting for the line to
12	open
13	MR. DASHIELL: Public line is open for
14	comments.
15	CHAIRMAN BLEY: I see he's still signed
16	in. Thank you, Thomas. If there's anybody in the
17	public that would like to make a comment, please
18	identify yourself and make your comment. Any public
19	comments?
20	MR. DRAFFIN: Yes, this is Cyril Draffin
21	from the U.S. Nuclear Industry Council. We appreciate
22	the effort that you've done today in terms of raising
23	issues.
24	We spend a lot of time thinking about the
25	topics and thinking about how these technologies can
l	

(202) 234-4433

	236
1	be developed and used and I think it's healthy to have
2	a dialogue.
3	And we look forward to the iteration as
4	people think about what makes sense, provide safety
5	and also enables this to be a transformative part that
6	the industry and others can rely upon. So, we
7	(Simultaneous speaking.)
8	CHAIRMAN BLEY: Thank you very much. I'm
9	sorry, I thought
10	MR. DRAFFIN: coming fast and we will
11	continue to try to be supportive of the NRC.
12	CHAIRMAN BLEY: Okay. Thank you very much
13	for your comment. We appreciate it. Anyone else?
14	All right, hearing none, Thomas, can we close the
15	outside line?
16	MR. DASHIELL: Outside line is closing.
17	CHAIRMAN BLEY: And now I'd ask members,
18	I'd first state that I don't see a reason yet to go to
19	the full Committee and consider writing a letter. But
20	if anyone disagrees, bring it up. Anyone like to add
21	something to your questioning today? Of the members
22	of the Committee? Well, thank you.
23	I have a couple things I wanted to mention
24	right here at the end. Bill, I don't know if when you
25	see it might be possible. So, let me start at a
	1

(202) 234-4433

	237
1	different point.
2	It's becoming clear to me from the
3	discussions today that the emphasis on flexibility and
4	what that does to the brevity of the language and the
5	rule, to me makes the Statement of Considerations or
6	whitepapers that would precede the development of
7	Statements of Considerations.
8	And the associated guidance documents,
9	really essential integral elements with the rule and
10	I don't see how we can evaluate the rule language
11	absent the SOC and key guidance documents.
12	Bill, when you talked about some of these
13	things, the story was really pretty good. I don't
14	know if you were talking from draft white papers
15	yourself or speaking extemporaneously, if it's the
16	latter, I suggest you get the transcript and see what
17	you said.
18	And I again, say that would be a good
19	starting point. Part 100.23 does mention volcanos so,
20	I say you need to do that here too.
21	I'd also ask, whenever it's possible, it
22	would be really good to schedule a discussion with us
23	on the development and structure of guidance. What's
24	going to be in the guidance documents, what kind of
25	documents do you envision, what things beyond what we
l	I

(202) 234-4433

	238
1	currently have.
2	And likewise, as you begin to develop any
3	white papers that would support the SOC, bringing
4	those to us and letting us see it would be very
5	helpful. I guess that's all I wanted to say.
6	So, thanks to everyone. Bill, it was a
7	heroic day for you. You should be tired, have a good
8	weekend. Thank you very much for the presentation and
9	all of the discussion. And at this point, I think the
10	meeting comes to a close. We are adjourned.
11	(Whereupon, the above-entitled matter went
12	off the record at 5:38 p.m.)
13	
14	
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	
25	
I	



Protecting People and the Environment

ACRS Future Plant Designs Subcommittee

10 CFR Part 53 "Licensing and Regulation of Advanced Nuclear Reactors"

Subparts C and D Preliminary Proposed Rule Language

February 18, 2021




- 9:30 AM 9:35 AM Opening Remarks
- 9:35 AM 9:40 AM Staff Introduction
- 9:40 AM 1:00 PM 10 CFR Part 53 Subpart C Design and Analysis Requirements
- 1:00 PM 2:00 PM Lunch
- 2:00 PM 3:00 PM 10 CFR Part 53 Subpart C Design and Analysis Requirements (continued)
- 3:00 PM 5:30 PM 10 CFR Part 53 Subpart D Siting Requirements

5:30 PM – 6:00 PM Discussion



NRC Staff Plan to Develop Part 53





NRC Staff Engagement Plan

ACRS Interactions


	Stakeholder Interactions								
	Framework	Safety Criteria	Design	Siting	Construction	Operations	Decommissionin g	Licensing	General/Admin
Sept 20							9		
Nov 20									
Dec 20									
Jan 21									
Feb 21									
Mar 21									
Apr 21									
May 21									
Jun 21									
Jul 21	Consolidated Technical Sections								
Aug 21									
Sept 21	Consolidated Technical Sections								
Oct 21									
Nov 21				Consolid	lated Rulemaking	Package			
Dec 21									
Jan 22				A	CRS Full Commit	ttee			
Feb 22									
Mar 22									
Apr 22									
May 22			Dra	aft Proposed Rul	emaking Packag	e to the Commis	sion		
Jun 22									
Jul 22									
Aug 22									
Sept 22									
Oct 22									

Concept/Introduction
Discussion
Interim Staff Resolution



First Principles


Recent NRC activities related to advanced reactors (e.g., functional containment performance criteria, possible changes to emergency planning & security, and DG-1353) recognize the limitations of existing LWR-related guidance, which requires a return to first principles such as fundamental safety functions supporting the retention of radionuclides



See: SECY-18-0096, "Functional Containment Performance Criteria for Non-Light-Water-Reactors," and INL/EXT-20-58717, "Technology-Inclusive Determination of Mechanistic Source Terms for Offsite Dose-Related Assessments for Advanced Nuclear Reactor Facilities"



Integrated Approach (NRC Activities)



Note that a goal of the current effort is to build from the Licensing Modernization Project and have that guidance (NEI 18-04, RG 1.233) be one acceptable way of meeting the requirements to be developed and incorporated into Part 53



Subpart A – General Provisions

- Scope
- Definitions
- Interpretations
- Written Communications
- Employee Protection
- Completeness and Accuracy of Information
- Specific Exemptions
- Deliberate Misconduct
- Combining licenses; elimination of repetition
- Jurisdictional Limits
- Attacks and Destructive Acts
- Information Collection Requirements: OMB Approval



- Safety Objectives
- Safety Functions
- First Tier Safety Criteria
- Second Tier Safety Criteria
- Licensing Basis Events
- Defense in Depth
- Protection of Plant Workers



- Design Objectives and Design Features
- Functional Design Criteria for First Tier Safety Criteria
- Functional Design Criteria for Second Tier Safety Criteria
- Functional Design Criteria for Protection of Plant Workers
- Design Requirements
- Analysis Requirements
- Safety Criteria and Special Treatment
- Application of Analytical Safety Margins to Operational Flexibilities
- Design Control Quality Assurance
- Design and Analyses Interfaces



Subpart D – Siting

- General Siting
- External Hazards
- Site Characteristics
- Population-Related Considerations
- Siting Interfaces
- Environmental Considerations



Subpart E – Construction and Manufacturing

- Scope and Purpose
- Part 1 Construction
 - (a) Management and Control
 - (b) Construction Activities
 - (c) Inspection and Acceptance
 - (d) Communication
- Part 2 Manufacturing
 - (a) Management and Control
 - (b) Manufacturing Activities
 - (c) Fuel Loading
 - (d) Communication
 - (e) Transportation
 - (f) Acceptance and Installation at the Site



- Transition from Construction/Manufacturing to Operations
- Part 1 Maintaining Capabilities and Reliabilities of Safety Related and Safety Significant Equipment
 - Design Features and Programs for Normal Operations (53.220(a) Criteria)
 - Design Features and Programs for Normal Operations (53.220(b) ALARA Criteria
 - Configuration Management for Safety-Related Design Functions
 - Technical Specifications
 - Configuration Management for Safety-Significant Design Functions
 - Special Treatment (e.g., Reliability Assurance)
 - Maintenance, Repair and Inspection Programs
 - Quality Assurance
 - Aging Management Programs
 - Design Control
 - Facility Safety Program



- Part 2 Establishing and Maintaining Appropriate Staffing
 - Concept for Operations
 - Identifying Role of Personnel in Meeting First Tier Safety Criteria
 - Identifying Role of Personnel in Meeting Second Tier Safety Criteria
 - Requirements for Licensed Personnel
 - Staffing
 - Training
 - Medical Requirements
 - Licensing (Applications, Examinations, Licenses)
 - Requirements for Non-Licensed Personnel (Graded based on roles)
 - Staffing
 - Training
 - Other Requirements



- Part 3 Radiation Protection
- Part 4 Emergency Preparedness
- Part 5 Security Programs
- Part 6 Preparing for and Transitioning to Decommissioning



- Termination of power reactor licenses (transition from operation to possession-only license)
- Financial assurance for decommissioning
- Transition to unrestricted use...



Subpart H – Licensing

- General
- Siting
 - Site Suitability Reviews
 - Limited Work Authorizations
 - Early Site Permits
- Design
 - Conceptual Design Reviews?
 - Standard Design Approvals
 - Design Certifications
 - Manufacturing Licenses
 - Manufacturing, Transportation, Deployment
- Site & Design
 - Construction Permit
 - Operating License
 - Combined Licenses
- Appendix A (Content Table)



Subpart I – Maintaining Licensing Basis

- Amendments to a license
 - Application (review?)
 - Public notice and consultations
 - Issuance
- Updating FSAR
 - Including PRA
- Revocation, suspension, modification of license for cause
- Retaking SNM
- Commission order for operation after revocation
- Suspension and operation in war or national emergency, (50.54(d))
- Backfitting and Issue Finality
- Information requests (50.54(f))



Subpart J – Administrative and Reporting

- Common standards
- Selective implementation (relationship to Parts 50, 52)
- Reporting
- Notifications (50.72, 50.73)
- Financial Qualifications
- Creditor Regulations
- Enforcement
- US/IAEA
- Bankruptcy (50.54(cc))
- Property insurance (50.54(w))
- Liability / Price Anderson

- Water pollution control act (50.54(aa))
- National emergency, can deviate from TS (50.54(dd))
- Share SNM and byproduct material between units (50.54(ee))
- Need to address FEMA deficiencies (50.54(gg))
- Receipt of aircraft threat (50.54(hh))
- ASME (50.55(a)) & quality standards (50.54(jj))
- SNM (50.54(b)-(d))
- Antitrust (50.54(g))
- Subject to laws & regulations (50.54(h))




Recap of Subpart B Safety Criteria

- Safety Objectives
 - Reasonable assurance of adequate protection
 - Additional measures to minimize danger to life and property
- Safety Functions
 - Primary safety function is to limit the release of radioactive materials from the facility
 - Additional supporting functions must be defined
- First Tier Safety Criteria
 - Normal operations (§ 20.1301)
 - Licensing basis events (§§ 50.34(a)(1)(ii)(D) & 52.79(a)(1)(vi))
- Second Tier Safety Criteria
 - Normal operations (Performance objectives for liquid and gaseous effluents (10 CFR Part 50, Appendix I))
 - Licensing basis events (Safety Goals)
- Licensing Basis Events
- Defense in Depth
- Protection of Plant Workers



Subpart B Flowchart





Part 53 Subpart B Stakeholder Feedback

- Second Tier Safety Objectives
 - Proposal by some stakeholders to eliminate second tier
 - Some ACRS Subcommittee members supported revisiting the two tier framework to clarify requirements
 - Staff Proposed Iteration: Maintain second tier to provide clarity on regulatory treatment (e.g., special treatment for safety significant SSCs)
 - Proposal by some stakeholders to not use QHOs as second tier
 - Staff Proposed Iteration: Maintain use of QHOs as logical riskinformed criteria. Industry may develop guidance for analysis section to support other risk-informed (but perhaps more deterministic) approaches to support finding that QHOs are satisfied.
- Safety Functions
 - Proposal by some stakeholders to explicitly cite fundamental safety functions
 - Staff Proposed Iteration: Maintain mention of fundamental safety functions as examples to maintain technology-inclusive framework (with potential use for technologies such as fusion energy systems and multiple source terms within plants)



Part 53 Subpart B Stakeholder Feedback Cont'd

- Non-Radiological Hazards
 - Some ACRS Subcommittee members noted inclusion of non-radiological hazards should be considered, such as chemical releases
 - Staff Proposed Iteration: Under consideration by the Working Group
- As Low as Reasonably Achievable (ALARA)
 - Proposal by some stakeholders to exclude ALARA requirements for normal effluents or occupational exposures
 - Some ACRS Subcommittee members favored retaining ALARA requirements in subpart B
 - Staff Proposed Iteration: Maintained requirements for normal operations and occupational exposures to be ALARA
- Protection of Plant Workers
 - Proposal by some stakeholders to exclude occupational dose from Part
 53 or to confine to reference to Part 20
 - Some ACRS Subcommittee members favored retaining occupational dose limits.
 - Staff Proposed Iteration: Revised to reference Part 20



Part 53 General Layout

- Subpart A, General Provisions
- Subpart B, Technology-Inclusive Safety Objectives
- Subpart C, Design and Analysis
- Subpart D, Siting
- Subpart E, Construction and Manufacturing Requirements
- Subpart F, Requirements for Operation
 - Facility Safety Program
- Subpart G, Decommissioning Requirements
- Subpart H, Applications for Licenses, Certifications and Approvals
- Subpart I, Maintaining and Revising Licensing Basis Information
- Subpart J, Reporting and Administrative Requirements



- § 53.400 Design Objectives and Design Features
- § 53.410 Functional Design Criteria for First Tier Safety Criteria
- § 53.420 Functional Design Criteria for Second Tier Safety Criteria
- § 53.430 Functional Design Criteria for Protection of Plant Workers
- § 53.440 Design Requirements
- § 53.450 Analysis Requirements
- § 53.460 Safety Categorization and Special Treatment



- § 53.470 Application of Analytical Safety Margins to Operational Flexibilities
- § 53.480 Design Control Quality Assurance
- § 53.490 Design and Analysis Interfaces



- Design Objectives and Design Features
 - Establishes the overall design objectives by referring to the underlying safety criteria and the identification of safety functions.
 - Design features must be provided such that, when combined with associated programmatic controls and human actions, there is reasonable assurance the safety criteria will be met.



§§ 53.410 & 53.420 – Functional Design Criteria

- First Tier Safety Criteria
 - Effluents during normal operation do not result in a dose to an individual member of the public exceeding 100 millirem.
 - Design features and functional design criteria for unplanned events are determined through analyses.
- Second Tier Safety Criteria
 - Doses from effluents during normal operation are as low as reasonably achievable (ALARA).
 - Design features and functional design criteria for unplanned events are determined through analyses.

Note that performance-based approaches for Part 53 safety criteria for normal operations are being discussed as part of the advanced reactor content of applications project (ARCAP). Performance-based approaches for licensing basis events are being incorporated into sections on analyses and programmatic controls within Subpart F (Operations).



- Functional Design Criteria for Protection of Plant Workers
 - Functional design criteria must be defined for each design feature relied upon to demonstrate compliance with occupational dose limits provided in Subpart C to 10 CFR Part 20.
 - Functional design criteria must be defined for each design feature to ensure that plant SSCs achieve occupational doses as low as is reasonably achievable.

Note that inclusion of requirements for protection of plant workers within Part 53 is a topic of ongoing discussions related to Subpart B (Technology-Inclusive Safety Objectives)



- Design features must use generally accepted consensus codes and standards
- Materials must be qualified for their service conditions over plant lifetime
- Safety and security must be considered together
- Design features must be demonstrated capable of accomplishing safety functions without adverse effects to other safety features
 - Analysis
 - Test programs
 - Prototype testing
 - Experience

Note that preliminary rule language refers to "generally accepted consensus codes and standards" and materials being "qualified" for their service conditions. These terms are topics for discussion. Resolution may include rule language, discussions within rulemaking package, and/or developing guidance documents.



- Probabilistic risk assessment (PRA)
 - Performed to identify potential failures, degradation mechanisms, susceptibility to hazards, other risks to safety functions
 - Used to determine licensing basis events (LBEs), classify safety significance and human actions, evaluate defense in depth, assess other challenges to plant safety
 - Conforms with generally accepted methods, standards, and practices
 - Maintained and upgraded every two years
- Analytical codes must be qualified for range of conditions for which they are used
- Analyses must assess fire protection, aircraft impacts, and mitigation of select beyond design basis events (BDBEs)
- Analyses must include design basis accidents (DBAs)



- Note that possible changes being considered for next iteration as a result of interactions with public stakeholders and ACRS
 - Allowing alternative risk-informed, systematic approaches to the PRA for activities such as determining licensing basis events, safety classification, and evaluating defense in depth
 - Clarifying that licensing basis events range from anticipated operation occurrences to very unlikely event sequences.
 - Addressing that analyses must be performed from event initiation to defined end state (e.g., safe stable end state for design basis accidents)



§ 53.460 – Safety Categorization and Special Treatment

- Safety Related (SR)
 - SSCs and human actions relied upon to function in response to design basis accidents
- Non-Safety Related but Safety Significant (NSRSS)
 - SSCs and human actions that perform a function that is necessary to achieve adequate defense-in-depth or are classified as risk significant
 - Failure contributes 1% or more to cumulative plant risk
 - Would cause a licensing basis event to exceed safety criteria
- Non-Safety Significant (NSS)
 - SSCs not warranting special treatment

Note that criteria for NSRSS my change to address an iteration that supports alternatives to a PRA categorizing SSCs



§ 53.460 – Safety Categorization and Special Treatment


- Special treatment
 - Must be established to provide appropriate confidence that the SR and NSRSS SSCs will perform under the service conditions and with the reliability assumed in the required analysis to provide reasonable assurance of meeting the safety criteria
- Human actions
 - Must be capable of being reliably performed under the postulated environmental conditions present and be addressed by programs to provide confidence that those actions will be performed as assumed in the required analysis



§ 53.470 – Application of Analytical Safety Margins to Operational Flexibilities

- Allows adoption of more restrictive criteria to obtain safety margin for application to other areas
- Requires use of a design goal to ensure analysis, design features, and programmatic controls are established to support analytical margins

Note that this provision would support integrated approach historically discussed for use in justifying alternatives in areas such as emergency preparedness and population-related siting considerations





- Establishes quality assurance requirements for design and analysis activities
- Derived from Criterion III in Appendix B to 10 CFR Part 50
- QA program must conform with generally accepted consensus codes and standards

Note that preliminary rule language refers to "generally accepted consensus codes and standards". This term is a topic for discussion. Resolution may include rule language, discussions within rulemaking package, and/or developing guidance documents.



§ 53.490 – Design and Analysis Interfaces

- Requires applicants and licensees to identify, control, and maintain interfaces between design and analyses activities and other activities
 - For example, configuration controls in Subpart F and the proposed facility safety program



Other Possible Topics for Discussion

A topic for possible discussion is the consideration and treatment of inherent design features. An inherent design feature is one where the safety function is achieved through natural processes governed by the physical laws without reliance on the activation or operation of supporting active or passive systems. It may be helpful to develop guidance on how inherent design features are credited in analyses, verified and validated, and considered under safety classification and special treatment provisions of this Subpart.



Other Possible Topics for Discussion (Cont'd)




Figure 3-6. Elements of safety design approach incorporated into *Plant Capability Defense-in-Depth*.



Key Public Comments on Subpart C Design and Analyses

- Occupational dose should not be included in Part 53.
- Need additional discussion on the term "generally accepted" as applied to consensus codes and standards
- Security should be assessed against NRC performance requirements, not required to be assessed within design processes.



Key Public Comments on Subpart C Design and Analyses

- Do not make PRA an implicit requirement for LBE selection, SSC classification, DID determinations
 - PRA insights should complement the safety review
 - Use of PRA should be optional if other risk-informed analyses are appropriate to use
 - Preliminary rule text for is supported by RG 1.233 implementation, but not supported by an applicant using a deterministic approach to classify SSCs
 - Deterministic approaches for some aspects may be appropriate and should not be excluded (allow combination of risk-informed and deterministic analyses)
- International regulatory frameworks have risk-informed approaches that certain vendors may choose to pursue
 - Part 53 should accommodate such approaches (i.e., IAEA SSR-2/1 and markets with dual-DSA/PSA requirements)



Key Public Comments on Subpart C Design and Analyses

- DID is important in supporting an adequate safety case for both LMP and non-LMP applications, but is best addressed in guidance rather than regulations.
- In guidance, NRC should clarify what DID analysis is required when physics or inherent features of a design have already resolved or removed the potential for releases of large amounts of radioactivity



Subpart C, Design and Analysis

Discussion



Part 53 General Layout

- Subpart A, General Provisions
 Subpart B, Technology-Inclusive Safety Objectives
- Subpart C, Design and Analysis
- Subpart D, Siting Requirements
- Subpart E, Construction and Manufacturing Requirements
- Subpart F, Requirements for Operation
 - Facility Safety Program
- Subpart G, Decommissioning Requirements
- Subpart H, Applications for Licenses, Certifications and Approvals
- Subpart I, Maintaining and Revising Licensing Basis Information
- Subpart J, Reporting and Administrative Requirements



- § 53.500 General Siting
- § 53.510 External Hazards
- § 53.520 Site Characteristics
- § 53.530 Population-related Considerations
- § 53.540 Siting Interfaces
- § 53.550 Environmental Considerations



- Overall siting considerations
 - Consider site in combination with design features and programmatic controls to satisfy first and second tier safety criteria.
 - Identify and assess external hazards and site characteristics that could contribute to initiation, progression, or consequences of licensing basis events.
 - Address potential adverse impacts on nearby environs as a result of normal operations or potential accidents.



- Structures, systems, and components (SSCs) needed to meet first tier safety criteria must be designed to withstand natural phenomena and man-made hazards.
 - SSCs designed to withstand hazards up to design basis levels.
 - Design basis external hazard levels must address hazards occurring with both routine frequency and up to 1 in 100,000 years, with added margin.
- Geologic and seismic factors must be considered to determine Safe Shutdown Earthquake Ground Motion (SSEGM).
 - SSEGM is level of seismic activity at which SSCs must remain functional.
 - The SSEGM for the site is determined considering the results of the geological, seismological, and engineering characteristics of a site and its environs.



- Analyses required by § 53.450 must address external hazard frequencies and related SSC fragilities.
 - Analyses (including beyond design basis events) must assess external hazards in order to meet second tier safety criteria.
 - Functional design criteria and programmatic controls must be established to maintain performance of SSCs relied upon to meet safety criteria.



 Meteorological, geological, seismological, topographical, hydrological, and other characteristics of the site and surrounding area that could affect radioactive material escape should be identified, estimated, and considered in the analyses required by Subpart C (Design and Analysis).



- Every site must have an exclusion area, low population zone, and provide a population center distance as defined in § 53.120. Offsite radiological consequences estimated by analyses required by § 53.450 are used to define:
 - Exclusion area such that any individual on the boundary for any two hour period following a release would not receive more than 25 rem total effective dose equivalent (TEDE).
 - Low-population zone such that any individual on the boundary following a release would not receive more than 25 rem TEDE.



§ 53.530 – Population-related considerations (cont.)

- Offsite radiological consequences estimated by analyses required by § 53.450 are used to define:
 - Population center distance that must be at least one and one-third times the distance from the reactor to the outer boundary of the low population zone.
 - Reactor sites should be located away from very densely populated centers. Areas of low population density are, generally, preferred.



§§ 53.540 & 53.550 – Siting Interfaces and Environmental Considerations

- External hazards and site characteristics must be addressed by design features, programmatic controls, and supporting analyses to demonstrate compliance with first and second tier safety criteria.
- Applicants must demonstrate compliance with environmental protection regulations in accordance with 10 CFR Part 51.



Key Public Comments on Subpart D Siting Requirements

- Scope of required site characteristics and associated analyses should be first informed by risk/safety profile of the facility, and then the specific site, as necessary.
- Use of site boundary to replace EAB and LPZ
- Performance-based focus of safety criteria obviates need for considering distance to population center (i.e., prescriptive Section 53.530 not necessary)
- Consider higher level requirements to allow flexibility
 - Characteristics of the site that have a significant impact on the ability to meet the safety criteria (examples, e.g., seismology, rather than prescriptive)
 - Locate detailed expectations in guidance (e.g., seismic hazard)



Part 53 Rulemaking

QUESTIONS?





Acronyms and Abbreviations

ACRSAdvisory Committee on Reactor SafeguardsALARAAs low as reasonably achievableARCAPAdvanced Reactor Content of Applications ProjectBDBEBeyond design-basis eventCFRCode of Federal RegulationsDBADesign-basis accidentDIDDefense-in-DepthDSADeterministic Safety AnalysisEABExclusionary Area BoundaryF-CFrequency – ConsequenceFEMAFederal Emergency Management Agency		
ARCAPAdvanced Reactor Content of Applications ProjectBDBEBeyond design-basis eventCFRCode of Federal RegulationsDBADesign-basis accidentDIDDefense-in-DepthDSADeterministic Safety AnalysisEABExclusionary Area BoundaryEPEmergency preparednessF-CFrequency – ConsequenceFEMAFederal Emergency	ACRS	-
Applications ProjectBDBEBeyond design-basis eventCFRCode of Federal RegulationsDBADesign-basis accidentDIDDefense-in-DepthDSADeterministic Safety AnalysisEABExclusionary Area BoundaryEPEmergency preparednessF-CFrequency – ConsequenceFEMAFederal Emergency	ALARA	As low as reasonably achievable
CFRCode of Federal RegulationsDBADesign-basis accidentDIDDefense-in-DepthDSADeterministic Safety AnalysisEABExclusionary Area BoundaryEPEmergency preparednessF-CFrequency – ConsequenceFEMAFederal Emergency	ARCAP	• • • • • • • • • • • • • • • • • • • •
DBADesign-basis accidentDIDDefense-in-DepthDSADeterministic Safety AnalysisEABExclusionary Area BoundaryEPEmergency preparednessF-CFrequency – ConsequenceFEMAFederal Emergency	BDBE	Beyond design-basis event
DIDDefense-in-DepthDSADeterministic Safety AnalysisEABExclusionary Area BoundaryEPEmergency preparednessF-CFrequency – ConsequenceFEMAFederal Emergency	CFR	Code of Federal Regulations
DSADeterministic Safety AnalysisEABExclusionary Area BoundaryEPEmergency preparednessF-CFrequency – ConsequenceFEMAFederal Emergency	DBA	Design-basis accident
EABExclusionary Area BoundaryEPEmergency preparednessF-CFrequency – ConsequenceFEMAFederal Emergency	DID	Defense-in-Depth
EPEmergency preparednessF-CFrequency – ConsequenceFEMAFederal Emergency	DSA	Deterministic Safety Analysis
F-CFrequency – ConsequenceFEMAFederal Emergency	EAB	Exclusionary Area Boundary
FEMA Federal Emergency	EP	Emergency preparedness
	F-C	Frequency – Consequence
	FEMA	

FSAR	Final Safety Analysis Report
IAEA	International Atomic Energy Agency
LBE	Licensing Basis Event
LMP	Licensing Modernization Project
LPZ	Low Population Zone
LWR	Light-water Reactor
NEI	Nuclear Energy Institute
NRC	U.S. Nuclear Regulatory Commission
NSRSS	Non-Safety Related but Safety Significant
NSS	Non-Safety Significant
OMB	Office of Management and Budget
ONT	Other New Technologies
PRA	Probabilistic Risk Assessment



Acronyms and Abbreviations

PSA	Probabilistic Safety Assessment
QA	Quality assurance
QHO	Quantitative health objective
SAR	Safety Analysis Report
SMR	Small Modular Reactor
SR	Safety-related
SSCs	Structures, systems, and components
SSEGM	Safe Shutdown Earthquake Ground Motion
TEDE	Total Effective Dose Equivalent
TS	Technical Specifications