

- (2) Exelon Generation pursuant to the Act and 10 CFR Part 70, to receive, possess and use at any time special nuclear material as reactor fuel, in accordance with the limitations for storage and amounts required for reactor operation, as described in the Final Safety Analysis Report, as supplemented and amended;
- (3) Exelon Generation pursuant to the Act and 10 CFR Parts 30, 40, and 70 to receive, possess and use at any time any byproduct, source and special nuclear material as sealed neutron sources for reactor startup, sealed sources for reactor instrumentation and radiation monitoring equipment calibration, and as fission detectors in amounts as required;
- (4) Exelon Generation pursuant to the Act and 10 CFR Parts 30, 40 and 70, to receive, possess and use in amounts as required any byproduct, source or special nuclear material without restriction to chemical or physical form, for sample analysis or instrument and equipment calibration or associated with radioactive apparatus or components.
- (5) Exelon Generation pursuant to the Act and 10 CFR Parts 30 and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of the facility.

C. This renewed operating license shall be deemed to contain and is subject to the conditions specified in the following Commission regulations in 10 CFR Chapter I:

Part 20, Section 30.34 of Part 30; Section 40.41 of Part 40; Section 50.54 and 50.59 of Part 50; and Section 70.32 of Part 70. This renewed license is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect and is also subject to the additional conditions specified or incorporated below:

(1) Maximum Power Level

The licensee is authorized to operate the facility at steady state reactor core power levels not in excess of 1850 megawatts (thermal).

(2) Technical Specifications

The Technical Specifications contained in Appendix A, which is attached hereto, as revised through Amendment No. 245, is hereby incorporated into this license. Exelon Generation shall operate the facility in accordance with the Technical Specifications.

(3) Deleted

Renewed License No. DPR-63

Amendment No. ~~191 through 210, 211, 213, 214, 215, 216, 217, 218, 220, 222, 223, 224, 225, 227, 229, 231, 233, 234, 236, 237, 239, 240, 241, 243, 244, 245~~

~~Correction Letter Dated August 7, 2012
Correction Letter Dated March 17, 2015
Correction Letter dated July 29, 2016~~

LIMITING CONDITION FOR OPERATION

- c. If Specifications 3.3.4 a and b are not met, the reactor coolant system temperature shall be reduced to a value less than 215°F within ten hours.

SURVEILLANCE REQUIREMENT

- c. In accordance with the Surveillance Frequency Control Program, a representative sample of instrument-line flow check valves will be tested for operability.