

### Enclosure 3

Summary of proprietary markings and minor clarifications for Draft SE of ANP-10344P, Revision 0,  
“Framatome Best-Estimate Enhanced Option III Methodology”

| Change Number | Page Number | Line Number/s | Comment   |
|---------------|-------------|---------------|---|
| 1.            | 1           | 17            | Change Estimate to estimate   |
| 2.            | 3           | 121           | Change “channel DR” to “ICO FoM”  |
| 3.            | 3           | 142           | Remove extraneous “the”   |
| 4.            | 6           | 244           | Remove extraneous “Regulatory Requirements Summary.”  |
| 5.            | 9           | 379           | Change “channel MCPR” to “ICO FoM”  |
| 6.            | 10          | 443           | Clarify by changing to ICO FoM  |
| 7.            | 10          | 453           | Clarification language requested. Change “from the initial steady-state”  |
| 8.            | 11          | 484-485       | Remove extraneous text to [[ ]]   |
| 9.            | 11          | 502-503       | Language clarified to reflect stage 3 analysis, [[ ]]   |
| 10.           | 12          | 528           | Language clarified to reflect stage 3 analysis, :reduction instead of change  |
| 11.           | 12          | 532           | Change “ICO” to “channel”   |
| 12.           | 12          | 539           | Change “ICO” to “channel”   |
| 13.           | 12          | 568           | Change “MCPR responses” to “FoMs”   |
| 14.           | 13          | 579           | Corrected typo  |
| 15.           | 18          | 834           | Clarification language requested to allow other means   |
| 16.           | 19          | 872           | Corrected typo “the” instead of “these”   |
| 17.           | 22          | 1012          | Correction typo to generic BEO-III methodology  |
| 18.           | 25          | 1157-1162     | Clarification language requested to allow either AURORA-B or COTRANSA2  |
| 19.           | 25          | 1171-1173     | Remove extraneous text to [[ ]]   |
| 20.           | 27          | 1237-1238     | Change “MCPR response” to “FoM”   |
| 21.           | 27          | 1241          | Change “MCPR” to “FoM”  |
| 22.           | 30          | 1399          | Clarified language “across all exposures”   |
| 23.           | 32          | 1476          | Corrected typo 8 not 9  |
| 24.           | 33          | 1557-1559     | Framatome interprets this to mean that reduced initial flow and artificial destabilization can be used to establish an oscillatory final statepoint that demonstrates the 95/95 period remains above T <sub>min</sub> . |
| 25.           | 35          | 1654-1655     | Additional reference to COTRANSA2 approved methodology to address item 18.  |
| 26.           | Throughout  | -             | Information that should be marked as Proprietary is highlighted in <b>Yellow</b> .  |

1 **DRAFT SAFETY EVALUATION FOR FRAMATOME INC.**

2  
3 **TOPICAL REPORT ANP-10344P, REVISION 0**

4  
5 **“FRAMATOME BEST-ESTIMATE ENHANCED OPTION III METHODOLOGY”**

6  
7 **EPID L-2019-TOP-0046**

8  
9 **PROJECT NO. 728**

10  
11 **DOCKET NO. 99902041**

12  
13  
14 **1.0 INTRODUCTION**

15  
16 Framatome Inc. (Framatome) submitted Topical Report (TR) ANP-10344P, “Framatome Best-  
17 Estimate Enhanced Option III [(BEO-III)] Methodology,” to the U. S. Nuclear Regulatory  
18 Commission (NRC) on October 31, 2019 (Ref. 1). This TR is intended to support analysis of  
19 stability for boiling water reactors (BWRs).  
20

21 Following stability events that occurred at BWRs during the late 1980s (Ref. 2) and early 1990s  
22 (Ref. 3), in response to NRC staff concerns, the industry made a number of improvements to  
23 analytical methods, plant hardware, and plant operations. Among these improvements were  
24 algorithms and associated analytical methods intended to allow detection and suppression of  
25 oscillatory behavior, while avoiding unnecessary reactor trips. The BEO-III methodology  
26 described in ANP-10344P builds upon these industry efforts and the subsequent evolution of  
27 Framatome’s methods for analyzing stability.  
28

29 In particular, Framatome’s BEO-III methodology is similar to a plant-specific BEO-III approach  
30 that the NRC staff has previously reviewed in a plant-specific license amendment to support a  
31 transition to ATRIUM 11 fuel at the Brunswick Steam Electric Plant (Brunswick). This plant-  
32 specific methodology is documented in TR ANP-3703P, “BEO-III Analysis Methodology for  
33 Brunswick Using RAMONA5-FA” (Ref. 4). The NRC staff found the plant-specific methodology  
34 for Brunswick to be acceptable as documented in Section 3.6, “Stability Analysis Using Plant-  
35 Specific Best-Estimate Option III (BEO-III) Approach,” of its safety evaluation (SE) dated  
36 March 6, 2020 (Ref. 5).  
37

38 The description of the generic BEO-III stability methodology summarized in this SE is based  
39 primarily upon Framatome’s TR ANP-10344P, and a supporting response to a request for  
40 additional information (RAI) dated November 30, 2020 (Ref. 6).  
41

42 **2.0 REGULATORY EVALUATION**

43  
44 The generic BEO-III methodology was developed to support a demonstration of BWR licensees’  
45 compliance with requirements governing stability in General Design Criteria (GDC) 10 and 12 in  
46 Title 10 of the *Code of Federal Regulations* (CFR) Part 50, Appendix A, “General Design  
47 Criteria for Nuclear Power Plants.”  
48

49 Criterion 10, “Reactor design,” requires that “The reactor core and associated coolant, control,  
50 and protection systems shall be designed with appropriate margin to assure that specified

51 acceptable fuel design limits are not exceeded during any condition of normal operation,  
52 including the effects of anticipated occurrences.”

53  
54 Criterion 12, “Suppression of reactor power oscillations,” requires that “The reactor core and  
55 associated coolant, control, and protection systems shall be designed to assure that power  
56 oscillations that can result in conditions exceeding specified acceptable fuel design limits are not  
57 possible or can be reliably and readily detected and suppressed.”

58  
59 **3.0 TECHNICAL EVALUATION**

60  
61 3.1 Overview and Relationship to Previous Stability Methodologies

62  
63 The applicant’s proposed generic BEO-III methodology makes use of Framatome’s  
64 RAMONA5-FA code (Ref. 7), which has been previously approved for stability calculations as  
65 part of the Option III (Ref. 8) and Enhanced Option-III (EO-III) methodologies (Ref. 9). The  
66 Option III methodology determines the delta-critical power ratio (CPR) response during  
67 anticipated oscillations by performing an analysis consisting of three primary components:

- 68
- 69 • The first component consists of determining the minimum critical power ratio (MCPR)  
70 margin that exists prior to the onset of oscillations. This is a plant- and cycle-specific  
71 determination that is based on the plant response to a two recirculation pump trip  
72 (2RPT), as well as during steady-state operation at reduced flow conditions.  
73
  - 74 • The second component of the calculation determines to a 95/95 statistical tolerance limit  
75 the largest oscillation amplitude expected prior to oscillation suppression for a given  
76 plant configuration using analytically prescribed oscillation power range monitor (OPRM)  
77 response signals with assumed statistical distributions for oscillation growth rate,  
78 oscillation mode, and other relevant parameters.  
79
  - 80 • The third component of the calculation uses the Delta over Initial Versus Oscillation  
81 Magnitude (DIVOM) correlation to conservatively compute the delta-CPR response  
82 associated with this 95 percent probability with 95 percent confidence (95/95) oscillation  
83 amplitude. The DIVOM correlation is developed based on the MCPR response  
84 calculated by RAMONA5-FA during simulated oscillations of growing amplitude, starting  
85 from assumed conditions representative of the plant following a two recirculation pump  
86 trip.  
87

88 This approach of dividing the calculation process into three separate components introduces  
89 significant conservatism into the calculation of operating limit MCPR (OLMCPR) values. For  
90 example, because the statistical analysis component does not use best-estimate RAMONA5-FA  
91 calculations to determine the core response during growing oscillations, the assumption is made  
92 that the oscillations grow with a constant decay ratio (DR) from the time of oscillation inception  
93 until suppression. Depending on statistical sampling, the constant DR value can be well  
94 above 1.0. However, assuming a DR value significantly above 1.0 from the time of oscillation  
95 inception is conservative. In a realistic recirculation pump trip (RPT) event, the oscillation  
96 growth rate will begin at 1.0 at oscillation inception and gradually increase over time. This is  
97 due to the gradually decreasing core inlet temperature throughout the event, as well as changes  
98 in the recirculation pump driving flow that may continue into the early portion of the oscillations.  
99 These initially slower-growing oscillations increase the likelihood that sufficient successive  
100 oscillation counts will be recorded by the period-based detection algorithm (PBDA) prior to the

101 oscillations exceeding the amplitude setpoint. Accordingly, the Option III and EO-III assumption  
102 of using a fixed oscillation DR leads to a conservatively high hot channel oscillation amplitude.  
103 Another conservatism lies in the process of calculating the DIVOM slope, which determines the  
104 MCPR response of fuel assemblies in the core under oscillatory conditions in a bounding (rather  
105 than best-estimate) manner.

106  
107 The EO-III methodology employs the same process as Option III for determining the core MCPR  
108 response during anticipated oscillations. However, EO-III also calculates the limiting growth or  
109 | DR for individual channel oscillations (ICOs) in the core. [ [

110  
111  
112 | [ ] The existence of ICOs simultaneously with  
113 whole-core oscillations invalidates the assumptions of the DIVOM relationship and is unsuitable  
114 under these conditions. Therefore, in conjunction with the normal DIVOM approach, EO-III  
115 implements a scram region, known as the channel instability exclusion region, to ensure that the  
116 power will be suppressed before ICOs may develop.

117  
118 BEO-III discards the three-step approach used in Option III and EO-III. Instead, BEO-III  
119 performs cycle-specific best-estimate RAMONA5-FA evaluations in which the entire event,  
120 including the initiating pump trip and subsequent growth of oscillations, is explicitly modeled.  
121 | The event MCPR response and ~~channel DR~~ ICO FoM are then determined to a 95/95 tolerance  
122 limit to ensure adequate safety limit MCPR (SLMCPR) protection. These 95/95 values are  
123 determined by performing a set of statistical trials in which physical modeling parameters are  
124 randomly varied according to appropriate uncertainty distributions.

125  
126 By explicitly modeling the plant and core response to the potentially limiting RPT events,  
127 explicitly treating uncertainties through a statistical process, and directly calculating the MCPR  
128 response from the oscillations that develop, many of the conservatisms inherent in the  
129 three-step approach of Option III and EO-III are avoided. Best-estimate assumptions are made  
130 for most of the modeling aspects of BEO-III; however, in some specific areas, Framatome made  
131 conservative assumptions to ensure that the BEO-III predictions remain bounding with respect  
132 to the safety criteria.

133  
134 Many of the underlying modeling aspects of the BEO-III methodology remain the same relative  
135 to Option III and EO-III. However, this is the first NRC review of a generic methodology in which  
136 RAMONA5-FA is used within a statistical framework to determine the MCPR response and  
137 associated uncertainty during stability events. Therefore, the NRC staff focused its review on  
138 determining the acceptability of the new modeling features that were added to RAMONA5-FA,  
139 as well as the acceptability of the statistical approach to ensure that the safety limits are met  
140 during any anticipated oscillations in operating BWRs.

141  
142 | A plant-specific BEO-III methodology for ~~the~~ Brunswick described in ANP-3703P (Ref. 4) was  
143 previously reviewed by the NRC staff and approved for Brunswick over an operating domain  
144 that includes Maximum Extended Load Limit Line Analysis Plus (MELLLA+) (Ref. 5). The  
145 Brunswick plant-specific BEO-III methodology is similar or identical to the generic BEO-III  
146 methodology in ANP-10344P in many respects. The main difference between the two methods  
147 is that for Brunswick, a separate post-processing step was necessary to simulate the behavior  
148 of the proprietary stability algorithm of a different fuel vendor. The generic version of the BEO-  
149 III methodology in ANP-10344P is based on the PBDA, and the additional post-processing step  
150 used in the Brunswick application is not necessary. Consequently, the NRC staff's review of the

151 generic BEO-III methodology in ANP-10344P builds upon the previous review of the Brunswick  
152 plant-specific BEO-III methodology, focusing especially on areas where differing approaches  
153 were employed.

### 154 155 3.2 Regulatory Requirements Summary 156

157 As discussed in Section 2.0 of this SE, GDC 10 and 12 of Appendix A to 10 CFR Part 50 require  
158 that specified acceptable fuel design limits (SAFDLs) not be exceeded under normal operation  
159 or anticipated operational occurrences (AOOs). The relevant SAFDL for stability events is the  
160 SLMCPR.

161  
162 The applicant identified two figures of merit (FoMs) that were used to demonstrate compliance  
163 with GDC 10 and 12:

- 164  
165 • Core MCPR at the time of oscillation suppression, referred to hereafter as the “core  
166 MCPR FoM”
- 167  
168 • Verification that ICOs do not invalidate the assumption that the reactor protection system  
169 can detect and suppress the oscillations prior to violation of the SAFDLs, referred to  
170 hereafter as the “ICO FoM”

171  
172 Framatome evaluated the core MCPR based on simulated oscillation suppression times using  
173 the PBDA. The specific manner in which the core MCPR and ICO FoMs were assessed in the  
174 context of the statistical analysis is provided in Section 7.0, “BEO-III Cycle-Specific Analyses,”  
175 of ANP-10344P, as evaluated below in Section 3.7, “BEO-III Cycle-Specific Analyses.”

### 176 177 3.3 Scenario Identification 178

179 The applicant identified a 2RPT from the minimum flow condition at rated power within the  
180 extended flow window (EFW)<sup>1</sup> operating domain to be the limiting event for the stability analysis.  
181 This limiting event identification is consistent with previous plant-specific applications of  
182 Option III and EO-III. Pump trip events may lead to instability due to a large reduction in core  
183 flow rate combined with a relatively modest reduction in power, which moves the core toward  
184 the upper left (low-flow, high-power) corner of the power-flow operating map. These conditions  
185 promote unstable oscillations.

186  
187 In particular, the 2RPT event from the lowest flow at rated power is expected to be the most  
188 limiting pump trip event because it starts from operation at the highest control rod line, which  
189 results in the highest power level, and therefore, the most unstable condition following the RPT.

190  
191 However, there exists a possibility that other events may be limiting, depending on the specific  
192 conditions at the plant. The proposed methodology also analyzes a 2RPT from the lowest-flow  
193 point at rated core power within the MELLLA domain with the minimum allowed feedwater (FW)  
194 temperature under FW heater out-of-service (FWHOOS) conditions. A lower FW temperature  
195 gives higher core inlet subcooling, which is destabilizing. Note that FWHOOS is not allowed  
196 during EFW operation. Therefore, this initial operating condition in the MELLLA domain may be

---

<sup>1</sup> Note that the EFW terminology used by Framatome is comparable to the MELLLA+ terminology used by GE-Hitachi.

197 more limiting than the operating condition in the EFW domain due to the core inlet temperature  
198 difference.  
199

200 The methodology also evaluates a 1RPT event starting from the highest power level under  
201 single-loop operation (SLO) conditions. This may be a limiting event because it results in flow at  
202 natural circulation conditions similar to the 2RPT event. **[[**

203  
204 **]]**

205  
206 As stated in Section 7.2, "BEO-III Calculation Procedure," of ANP-10344P, the applicant  
207 proposes to evaluate all three of these pump trip scenarios **[[**

208  
209 **]]** The NRC staff has high confidence that the limiting stability  
210 event will be one of these three events based on past experience and consistency with previous  
211 applications of Option III and EO-III. Therefore, the analysis of these three events in plant-  
212 specific applications is appropriate and sufficient. For scenarios which are non-limiting by a  
213 significant margin above normal cycle variation, the applicant also proposes to **[[**

214  
215 **]]** The NRC staff's evaluation of this proposal is given in Section  
216 3.7.2, "BEO-III Calculation Procedure."

### 217 3.4 Evaluation Model Requirements

218  
219  
220 RAMONA5-FA is currently approved for DIVOM analyses within the Option III and EO-III  
221 methodologies. These DIVOM analyses involve calculation of the system stability response  
222 starting from natural circulation conditions after the pump trip has completed. These analyses  
223 must be able to accurately calculate the MCPR response as a function of oscillation amplitude  
224 as the oscillations grow. However, the magnitude of oscillations that occur before they are  
225 suppressed by a trip, is determined separately from the RAMONA5-FA calculations in these  
226 previous methodologies.

227  
228 The BEO-III methodology is used to determine **[[** **]]** the MCPR  
229 response during unstable oscillations, as in the Option III and EO-III methodologies. Therefore,  
230 the evaluation model requirements<sup>2</sup> related to the growth of oscillations and associated MCPR  
231 response are the same for BEO-III as in these previous methodologies.  
232

233 However, unlike the Option III and EO-III methodologies, the BEO-III RAMONA5-FA analyses  
234 start from normal operating conditions and explicitly model the RPT and associated core inlet  
235 flow and temperature response. Therefore, accurate modeling of the time-dependent plant  
236 response following a RPT is required for BEO-III as well. Another difference is that BEO-III  
237 implements the PBDA algorithm directly into RAMONA5-FA in order to simulate the OPRM  
238 response and PBDA trip generation time for the time-dependent RAMONA5-FA 3D power  
239 distribution. This requires that the PBDA algorithm be properly implemented, in order to  
240 accurately determine trip times and resulting MCPR values for a given plant-specific application.  
241 The applicant developed a phenomena identification and ranking table (PIRT) to determine  
242 which model uncertainties are important in determining the core MCPR FoM and the ICO FoM  
243 as defined in Section 2.0, "Regulatory Requirements Summary," of ANP-10344P (Ref. 1),

---

<sup>2</sup> Note that the term "evaluation model requirements" is used in the sense specified in RG 1.203, which describes the evaluation model development and assessment process (i.e., EMDAP).

244 | ~~“Regulatory Requirements Summary.”~~ This table summarizes all the relevant phenomena and  
245 | provides an importance ranking with respect to each FoM. The NRC staff evaluated the BEO-III  
246 | PIRT in detail due to its importance in determining the evaluation model requirements for  
247 | BEO-III, as well as in defining the uncertainty parameters included in the statistical uncertainty  
248 | analysis performed for BEO-III.

249 |  
250 | Based on its review of the BEO-III PIRT, the NRC staff finds that the applicant identified all  
251 | significant parameters that are relevant to the FoMs and that appropriate importance rankings  
252 | were assigned to each of them. The applicant considered not only phenomena that impact the  
253 | neutronic and thermal-hydraulic dynamics of the core during oscillations, but also phenomena  
254 | that impact the plant and vessel response following a RPT. The NRC staff determined these  
255 | phenomena and their rankings to be consistent with the current state of understanding of BWR  
256 | oscillations. In order to make this determination, the NRC staff reviewed PIRTs developed  
257 | under the guidance of the NRC in 2001 (Ref. 10) and 2011 (Section 5 of Ref. 11), more recent  
258 | NRC-published studies of ATWS-I scenarios (Ref. 12) and (Ref. 13), and other available  
259 | sources of information from open literature or internal NRC experience based on reviewing  
260 | ATWS-I methodologies.

261 |  
262 | The NRC staff also compared the BEO-III PIRT to the ATWS-I PIRT presented in ANP-10346P  
263 | (Ref. 14). Although the FoMs are not identical, the NRC staff expected that many of the same  
264 | phenomena would be identified in both PIRTs due to the similarity of the two applications. This  
265 | was found to be the case, as all relevant phenomena in the ATWS-I PIRT were considered in  
266 | the BEO-III PIRT as well. Furthermore, the importance of these phenomena was indicated as  
267 | the same or higher in BEO-III relative to ATWS-I, which is consistent with the NRC staff's  
268 | expectations.

269 |  
270 | Additional Potentially Significant Phenomena

271 |  
272 | The NRC staff further identified two phenomena that were dispositioned as being of low  
273 | importance in the BEO-III PIRT, but which the NRC staff considered to have a potentially  
274 | significant impact for stability. Additionally, in some cases, these parameters were included in  
275 | the AURORA-B AOO statistical sampling for non-pressurization transients, which uses similar  
276 | methods as BEO-III. These phenomena are:

- 277 |  
278 | • [[  
279 | ]]

280 |  
281 | [[

282 |  
283 |  
284 |  
285 | ]] The NRC staff finds that this assumption is conservative [[

286 |  
287 |  
288 |  
289 | ]] Therefore, the NRC staff finds this treatment of [[  
290 | ]] to be acceptable and finds that no ~~statistical sampling~~ of this parameter is needed.

291 |  
292 | [[

293 |



294  
295  
296  
297  
298  
299  
300  
301  
302  
303  
304  
305  
306  
307  
308  
309  
310  
311  
312  
313  
314  
315  
316  
317  
318  
319  
320  
321  
322  
323  
324  
325  
326  
327  
328  
329  
330  
331  
332  
333  
334  
335  
336  
337  
338  
339  
340  
341  
342  
343

]]

The NRC staff issued RAI-2 to obtain additional justification for [[  
]] as low importance, considering its physical relevance to stability dynamics. In particular, this [[  
]] may have a stronger impact on global oscillations than on regional oscillations. This is because the total flow rate outside the core remains nearly constant for regional oscillations but not for global oscillations. Therefore, plant or cycle applications which are global- or mixed-mode-limited could exhibit a greater sensitivity to these parameters than regional-limited applications such as the MELLLA+ sample problem.

In the RAI response, Framatome analyzed the behavior for [[

]] As noted above, the impact on regional oscillations is expected to be even less. Therefore, the NRC staff finds that the disposition of [[  
]] as low importance, and its exclusion from statistical sampling is acceptable.

Because of its consistency with the NRC staff's understanding of BWR stability and the similarity to previous stability PIRTs, the NRC staff finds the BEO-III PIRT presented in ANP-10344P to be acceptable for generic application.

#### Core Flow and Power Uncertainty

The total core flow rate and total core power were dispositioned as being of high importance in the BEO-III PIRT. The NRC staff issued RAI-7 to obtain additional justification for their exclusion from statistical sampling.

In the RAI response, the applicant [[

]]

The NRC staff agrees that the standard BEO-III approach may often be conservative in practice; however, it is difficult to ensure conservatism for all plants and cycle designs, particularly if the limiting exposure points occur when the nominal flow rate is at or near the minimum allowed value.

The NRC staff examined additional results in RAI-7 for a case that assumed a minimum flow and maximum power, [[



344  
345  
346  
347  
348  
349  
350  
351  
352  
353  
354  
355  
356  
357  
358  
359  
360  
361  
362  
363  
364  
365  
366  
367  
368  
369  
370  
371  
372  
373  
374  
375  
376  
377  
378  
379  
380  
381  
382  
383  
384  
385  
386  
387  
388  
389  
390  
391  
392  
393

]]

The SLO [[

]]

In its RAI response, the applicant also justified that operating flow and power uncertainties are accounted for when determining the SLMCPR. The NRC staff finds that the impact of power and flow uncertainties is partially, but not fully, accounted for via the SLMCPR calculation. In particular, the SLMCPR calculation does not fully account for these uncertainties' impact on the growth rate and magnitude of oscillations (and therefore the hydraulic conditions in the core at a given point in time) during the transient.

However, in Section 3.7.2 of this SE, the NRC staff concluded that the approach of [[

]]

Considering that [[

]]

and the significant conservatism inherent in the ~~channel-MCPR~~ ~~ICO~~ FoM calculation approach, the NRC staff concludes with high confidence that the BEO-III predictions will remain conservative overall, in the absence of flow and power uncertainty sampling, provided that the minimum flow rate and maximum power MELLLA+ point is used for all calculations. Therefore, the NRC staff finds the treatment of core flow and power uncertainties to be acceptable considering the overall balance of conservatisms in the generic BEO-III methodology.

### 3.5 Method Adaptations for BEO-III

The version of the RAMONA5-FA code used for BEO-III is identical to that used in the approved EO-III and Option III methodologies, with several exceptions that are discussed and evaluated in the following sections of this evaluation.

#### 3.5.1 Fuel Rod Models

394 Fuel rod modeling impacts the thermal energy stored in the fuel rod and the heat that reaches  
395 the cladding surface and coolant during thermal-hydraulic oscillations. Therefore, the BEO-III  
396 model must adequately determine the initial condition of the fuel rod, the change in fuel rod  
397 conditions following the initiating event (e.g., 2RPT), and the change in fuel rod conditions  
398 during growing oscillations up until oscillations are suppressed by a scram.  
399

400 For the BEO-III methodology, [[

401  
402 ]] In the SE for ANP-10346P  
403 (Ref. 15), the NRC staff concluded that the [[ ]] fuel rod model acceptably  
404 simulates fuel behavior under the full range of conditions expected for ATWS-I.  
405

406 Limiting ATWS-I events, such as 2RPT, are identical to stability events except that the ATWS-I  
407 events are not terminated by a reactor scram. Therefore, the ATWS-I methodology must  
408 determine the fuel rod behavior under the same conditions as for BEO-III, as well as under  
409 larger-amplitude oscillations in the absence of scram. Therefore, the same evaluation given in  
410 the SEs for ANP-10346P (Ref. 15) and the plant-specific license amendment for Brunswick  
411 (Ref. 5) can be used to justify the fuel rod model in the generic BEO-III methodology.  
412 Additionally, the experimental benchmarking performed for BEO-III indicated no observable bias  
413 that would indicate a deficiency in the fuel rod modeling. For these reasons, the NRC staff finds  
414 that the [[ ]] fuel rod model is acceptable in both RAMONA5-FA and STAIF.  
415

### 416 3.5.2 Radial Power Deposition Distributions in Fuel Pellets

417  
418 The radial distribution of power deposition in the fuel pellets affects the fuel temperature  
419 distribution and the rate of heat reaching the cladding and coolant as a function of time during  
420 stability events. [[

421  
422 ]] Therefore, the NRC staff finds the radial power deposition  
423 distribution model, which was found to be acceptable for [[ ]] is acceptable for BEO-III  
424 as well.  
425

### 426 3.5.3 Period-Based Detection Algorithm Model

427  
428  
429 Framatome implemented the PBDA included in the Boiling Water Reactor Owners Group  
430 (BWROG) Long-Term Stability Solutions Option III solution (Ref. 16) and (Ref. 17) within  
431 RAMONA5-FA to determine the time of scram during the simulated oscillations. The NRC staff  
432 reviewed Section 5.3, "Period-Based Detection Algorithm Model," of the TR and concluded that  
433 the PBDA was implemented properly into RAMONA5-FA and provides appropriate PBDA trip  
434 times and corresponding MCPR values, provided that the PBDA settings employed in the  
435 calculations are consistent with those of the plant being analyzed. RAMONA5-FA calculates trip  
436 times based on the PBDA only; application of BEO-III to a plant with a detect and suppress  
437 (D&S) algorithm other than PBDA would therefore extend beyond the scope of the generic  
438 BEO-III method being approved in the present SE.  
439

440 3.5.4 Multi-Stage Analysis

441  
442 As in the Brunswick plant-specific methodology, the generic BEO-III methodology employs a  
443 “multi-stage analysis” approach to determine both the core MCPR and the ICO FoM for a given  
444 statistical case. Due to its importance, the multi-stage analysis was a focus of significant  
445 attention during the NRC staff’s review. Details and the staff’s evaluation of each stage of the  
446 multi-stage approach are provided below.

447  
448 **[[**

449  
450  
451  
452  
453  
454  
455 **]]**

456  
457 The NRC staff evaluated **[[** to determine its ability to adequately determine **[[**  
458 **]]** as It of core oscillations during the limiting stability events. The  
459 NRC staff determined that the limiting stability events were simulated in a realistic manner,  
460 accounting for all important physics. **[[**

461  
462  
463  
464  
465  
466  
467  
468  
469 **]]** The NRC staff finds that these best-estimate calculations were performed in an  
470 acceptable manner and are suitable for use **[[**

471  
472 **]]**

473  
474 **[[**

475  
476  
477  
478  
479  
480  
481  
482  
483  
484  
485  
486 **]]**

487  
488 The NRC staff reviewed the **[[** **]]** and finds that it is  
489 an acceptable means of determining **[[**

490  
491  
492  
493  
494  
495  
496  
497  
498  
499  
500  
501  
502  
503  
504  
505  
506  
507  
508  
509  
510  
511  
512  
513  
514  
515  
516  
517  
518  
519  
520  
521  
522  
523  
524  
525  
526  
527  
528  
529  
530  
531  
532  
533  
534  
535  
536  
537  
538  
539

[[

]]

]] The NRC staff issued RAI-5 to obtain specific information on the criteria that will be used for this determination. In the RAI response, Framatome specified that the Stage 3 analysis [[

]]

The NRC staff finds this approach to be acceptable because [[

]]

In the RAI-5 response, the applicant also provided [[

]]

The BEO-III methodology calculates [[

]] Therefore,  
]]

the NRC staff finds that this calculation approach provides an acceptable approximation of [[

540  
541 | Figure 5-1, [[

542  
543  
544  
545  
546  
547  
548 | ]]. The example in Figure 5-1 provides added confidence that this  
549 | is true, and therefore that the Stage 3 results are reliable and accurate.

550  
551 | In RAI-1, the NRC staff requested a plot of core pressure drop [[

552  
553  
554  
555  
556  
557  
558  
559  
560 | ]]. Thus, the NRC staff finds that [[  
561 | ]]. is acceptable.

562  
563 | An evaluation of expected [[ ]]. compared to the Stage 3 approach is  
564 | given in Section 3.7.2 of this SE. In that section, the NRC staff found the Stage 3 approach of  
565 | [[ ]]. to provide a conservative calculation of [[  
566 | ]].

567  
568 | Based on these evaluations, the NRC staff finds that the core and ICO MCPR-FoMs responses  
569 | are adequately determined by the multistage analysis process.

### 570 571 | 3.6 Code Validation and Model Uncertainties

572  
573 | Section 6.0, "Code Validation and Model Uncertainties," of ANP-10344P describes the  
574 | determination of neutronic and thermal-hydraulic modeling uncertainties applicable to the  
575 | BEO-III statistical analysis, as well as the benchmarking of these models to measured data.

#### 576 577 | 3.6.1 Model Uncertainties

578  
579 | Table 7-3, "Sampled Parameters for ~~BEO-III~~ BEO-III ATRIUM 11 Statistical Analyses," of  
580 | ANP-10344P lists the parameters that were statistically sampled in the BEO-III licensing  
581 | analyses. In Table 7-2, "Disposition of High and Medium-Ranked Phenomena," of ANP-10344P,  
582 | the applicant provided a disposition of each high- and medium-ranked parameter including  
583 | justification for the exclusion of certain medium-ranked parameters from the statistical sampling.

584  
585 | In its evaluation of the AURORA-B AOO evaluation model in ANP-10300P (Ref. 18), which uses  
586 | a similar statistical approach as BEO-III, in response to an RAI from the NRC staff, Framatome  
587 | also included medium-ranked parameters in the statistical sampling. This was because the  
588 | combined effect of the medium-ranked parameters on the final 95/95 result was considered  
589 | large enough to warrant their inclusion, even if the impact of individual medium-ranked

590 parameters may be relatively small. Based on this precedent, the NRC staff considered both  
591 high- and medium-ranked parameters in its evaluation. For parameters which were included in  
592 the statistical sampling, the NRC staff evaluated whether the sampling approach appropriately  
593 accounted for uncertainties. For parameters which were excluded from the statistical sampling,  
594 the NRC staff evaluated whether their exclusion was justifiable by having no significant impact  
595 on the FoMs.

596  
597 All phenomena with high importance to either the MCPR FoM or the ICO FoM (or both) were  
598 included in the statistical sampling. Of the remaining phenomena, eight were assigned medium  
599 importance for at least one FoM. Four of these were selected by the applicant for inclusion in  
600 the set of sampled parameters:

- 601  
602 | • [[  
603 | •  
604 | •  
605 | • ]]

606  
607 The applicant provided justification for excluding the remaining four medium-ranked  
608 phenomena:

- 609  
610 | • [[  
611 | •  
612 | •  
613 | • ]]

614  
615 Uncertainties of Sampled Parameters

616  
617 Parameters listed under [[ ]] were  
618 assigned uncertainties based on [[ ]]. The modeling uncertainty of each parameter  
619 is determined based on comparison to measured data, [[ ]].

620  
621  
622  
623  
624  
625 ]] Because of these considerations, the NRC staff  
626 finds that these parameter uncertainties [[ ]] are  
627 acceptable for use in BEO-III.

628  
629 The approach for determining parameter uncertainties in the BEO-III methodology includes  
630 [[ ]]

631  
632  
633  
634  
635 ]] The NRC staff reviewed the new  
636 uncertainty methods and determined that they remain within the spirit of the approved methods  
637 in AURORA-B AOO. [[ ]]

638 ]] Therefore, the NRC

639 staff finds the methods used to determine uncertainties for all sampled parameters to be  
640 acceptable.

641  
642 [[ ]] uncertainties were derived based  
643 on experimental void fraction data from the FRIGG and KATHY facilities. The FRIGG  
644 experiments included legacy geometric designs, while the KATHY experiments included  
645 benchmarking of ATRIUM-10 and ATRIUM 10XM fuel bundles. The [[ ]]  
646 uncertainty was determined based on experimental pressure drop data from  
647 KATHY for ATRIUM-10, ATRIUM 10XM, and ATRIUM 11 fuel. The ATRIUM-10 and  
648 ATRIUM 10XM designs include part-length-fuel rods, mixing vane grids, and prototypic  
649 axial/radial power distributions, which are reasonably representative of the design features in  
650 ATRIUM 11.

651  
652 A sufficient degree of thermal-hydraulic compatibility with previous fuel types is a requirement  
653 for introducing new fuel types. The NRC staff notes that bundle thermal-hydraulic parameters,  
654 including pressure drop and void fraction distributions, depend primarily on bulk quantities such  
655 as bundle hydraulic diameter and are relatively insensitive to mild variations in the configuration  
656 of flow paths within the bundle. Therefore, the NRC staff finds it acceptable [[ ]]

657  
658 | [[ ]] Note that Section 4.0,  
659 "Limitations and Conditions," of this SE provides the NRC staff's position on potential application  
660 of BEO-III to new fuel types beyond ATRIUM 11.

661  
662 [[ ]]  
663  
664  
665  
666  
667 | [[ ]] The NRC staff  
668 finds this approach to be acceptable because [[ ]]  
669 | [[ ]]  
670

671 [[ ]]  
672 | [[ ]] Realistic modeling of reactor noise is important  
673 for stability calculations because it strongly affects the onset time and initial magnitude of  
674 oscillations as the core becomes unstable. The model used to define this random noise,  
675 including the values of parameters used to define the noise amplitude, as well as its temporal  
676 characteristics, [[ ]]  
677 | [[ ]] it is expected  
678 to provide a realistic representation of the actual noise in terms of the distribution of amplitude  
679 and frequency ranges within the noise signal. Additionally, the noise parameters to be used for  
680 BEO-III analyses are consistent with those used for the validation cases, which provides  
681 confidence that the BEO-III analyses will produce accurate results consistent with the good  
682 experimental agreement demonstrated in ANP-10344P.

683  
684 However, the random nature of noise means that the results will differ depending on [[ ]]  
685 | [[ ]] This may impact oscillation onset timing to some  
686 degree, but the most significant effect is the possibility of PBDA resets due to the chaotic effects  
687 of the applied noise. Such resets can significantly impact the PBDA trip time in each statistical



688 trial, and therefore, impact the final 95/95 FoMs. This chaotic effect is not a shortcoming of the  
689 model but a realistic representation of actual PBDA behavior in the plant.

690  
691 To ensure that the final MCPR determination accounts for this noise-induced variability, the  
692 applicant has [[

693  
694  
695  
696 ]] Therefore, the NRC staff finds the inclusion of [[  
697 ]] to be acceptable. The NRC staff has determined that

698 [[

699  
700  
701  
702 ]]  
703

704 Medium-Importance Phenomena Excluded from Sampling

705  
706 The following medium-ranked parameters were omitted from the statistical sampling in the  
707 ANP-10344P methodology:

- 708  
709 • [[  
710 •  
711 •  
712 • ]]  
713

714 The exclusion of these phenomena is discussed in the following paragraphs.

715  
716 [[

717  
718  
719  
720  
721  
722  
723  
724  
725  
726  
727  
728  
729  
730  
731  
732 ]]  
733

734  
735 The NRC staff reviewed [[ ]] modeling approach and finds it  
736 acceptable that MICROBURN-B2 contains sufficient modeling fidelity to accurately predict [[

737

738  
739  
740  
741  
742  
743  
744  
745  
746  
747  
748  
749  
750  
751  
752  
753  
754  
755  
756  
757  
758  
759  
760  
761  
762  
763  
764  
765  
766  
767  
768  
769  
770  
771  
772  
773  
774  
775  
776  
777  
778  
779  
780  
781  
782  
783  
784  
785  
786  
787

]] The NRC staff finds that this impact is small enough that this parameter may be excluded from the BEO-III [[ ]] without significant adverse impact on the final FoMs.

[[

]]

| In Section 6.9, [[ ]] of ANP-10344P, the applicant applied [[

]] The NRC staff finds that [[

]]

In addition to the impact of bypass flow rate on the thermal-hydraulic stability of the core, the NRC staff considered the impact of bypass voiding and its effect on OPRM miscalibration. At low core flow rates, particularly those characteristic of pump trip events, the bypass exhibits an especially low-flow rate, which can lead to boiling in the upper portion of the bypass due to direct gamma heating and neutrons slowing down in the bypass. The resulting void formation in the bypass reduces the sensitivity of the local power range monitors, which leads to error in the measured local power level and resulting miscalibration of the OPRM signal.

| In its review of the EO-III methodology (Ref. 19), the NRC staff concluded [[

]]

Because BEO-III relies on the same D&S algorithm as EO-III, based on relative OPRM amplitude signals, the same conclusion applies, and [[ ]] are necessary to account for OPRM miscalibration.

Note that average power range monitor (APRM) miscalibration due to bypass voiding does impact the channel stability exclusion region of EO-III, as discussed in the SE for ANP-10262PA (Ref. 19). However, BEO-III does not calculate an exclusion region on the power-flow map; instead, the impact of ICOs is evaluated within the multistage analysis supporting BEO-III implementation. This does not involve detection of ICOs using plant hardware, and therefore the miscalibration of APRMs and/or OPRMs due to bypass voiding is not relevant for this

788 | determination. [[  
789 | ]] Note also that the impact of core power and flow uncertainties was discussed in  
790 | Section 3.4, "Evaluation Model Requirements," and that [[

791 |  
792 | ]]

793 |  
794 | [[  
795 | ]] In Section 6.11, [[ ]] of  
796 | ANP-10344P, the applicant indicated that [[

797 |  
798 |  
799 |  
800 |  
801 |  
802 |  
803 | ]] Therefore,  
804 | the NRC staff finds that [[ ]] can be acceptably excluded from  
805 | the [[ ]]

806 |  
807 | The recirculation pump coastdown behavior affects the time required for the core flow rate to  
808 | decrease to natural circulation conditions following a pump trip. If this time is sufficiently long,  
809 | the elevated flow rates may delay the onset and early growth behavior of oscillations. This  
810 | could cause a significant change in oscillation period from one oscillation to the next; if this  
811 | change is large enough, the PBDA might not identify subsequent oscillations correctly, which  
812 | may cause the PBDA successive oscillation counts to reset, resulting in a possible delay in the  
813 | eventual PBDA trip signal timing.

814 |  
815 | [[

816 |  
817 |  
818 |  
819 |  
820 |  
821 |  
822 |  
823 |  
824 |  
825 |  
826 | ]]  
827 | Because of this possibility, the NRC staff issued RAI-10 to obtain additional justification for the  
828 | exclusion of the pump coastdown uncertainty from the statistical analysis. [[

829 |  
830 |  
831 |  
832 |  
833 |  
834 | ]]

835 |  
836 | The NRC staff finds this approach to be acceptable [[

837 |

838  
839  
840  
841  
842  
843  
844  
845  
846  
847  
848

]]

Table 1: Modeling Parameters Included in the BEO-III Statistical Analysis

| Category | Parameter | PIRT Importance |
|----------|-----------|-----------------|
| ]]       |           | ]]              |

849  
850  
851

3.6.2 Impact of Core Oscillation Mode

852 Certain system phenomena may impact which core oscillation mode occurs (global, regional, or  
853 mixed) and/or may have a stronger impact on the FoMs under one mode compared to the other.  
854 As part of its review, the NRC staff considered whether the appropriate phenomena were  
855 included in the statistical sampling to accurately predict the oscillation mode and the impact on  
856 the FoMs for all expected plant conditions.

857  
858 **[[**Having higher bundle powers in the radial center of the core promotes in-phase oscillations,  
859 while having higher powers toward the periphery promotes out-of-phase oscillations due to the  
860 impact on the out-of-phase mode subcriticality. **[[**

861  
862  
863  
864  
865  
866  
867  
868  
869  
870  
871

872  
873  
874  
875  
876

877 **]]** The **[[** **]]** was evaluated in Section 3.4 of this  
878 SE and its exclusion from statistical sampling was found to be acceptable. The **[[**  
879 **]]** are included in the statistical sampling.

880  
881  
882

Based on these findings, the NRC staff has determined that the appropriate phenomena were included in the methodology to accurately predict the oscillation mode and resulting impact on the FoMs, under all anticipated operating conditions.

884

### 885 3.6.3 Additional Code Validation

886

887 The validation of RAMONA5-FA against KATHY void fraction and pressure drop data is  
888 discussed and evaluated in the previous section. Additional experimental benchmarking was  
889 performed against measured stability data. These include KATHY stability tests, KATHY  
890 dryout/rewet tests, linear reactor stability benchmarks, and a nonlinear reactor stability  
891 benchmark. The tests encompass a wide range of conditions that provide sufficient coverage of  
892 the expected core conditions during anticipated oscillations at BWRs.

893

894 These stability benchmarks were also performed for the generic RAMONA5-FA ATWS-I  
895 methodology described in ANP-10346PA (Ref. 15). The benchmarks include experimental  
896 validation for the onset of oscillations, growth of oscillations, occurrence of dryout, and  
897 post-dryout behavior. In its review of ANP-10346PA, the NRC staff concluded that the  
898 RAMONA5-FA ATWS-I code demonstrated close agreement with the measured data and that  
899 this benchmarking was sufficient to justify the use of the RAMONA5-FA ATWS-I code for  
900 ATWS-I applications.

901

902 The BEO-III methodology analyzes the same physical phenomena as the ATWS-I methodology,  
903 with the exception of not treating post-dryout behavior. The NRC staff reviewed the  
904 benchmarking results for the BEO-III version of RAMONA5-FA and determined that the  
905 agreement with measured data was comparable to what was observed for RAMONA5-FA  
906 ATWS-I and that the agreement remains acceptable. Statistical trials were also performed to  
907 determine upper 95/95 bounds for DRs, frequencies, and other results across these  
908 benchmarks when relevant statistical parameters were considered. The statistical perturbations  
909 led to a reasonable degree of variation in the calculated results, and in the majority of cases the  
910 95/95 DR results bounded the experimental data, which is expected. Overall, RAMONA5-FA  
911 tended to predict [[

]] However, as discussed in its review of

912 ANP-10346PA, this apparent bias in [[ ]] did not lead to an  
913 unacceptable discrepancy in [[ ]]. The  
914 NRC staff finds that the applicant's BEO-III methodology, including treatment of uncertainties, is  
915 acceptable because its modeling result for the stability response and dryout occurrence during  
916 anticipated instability events is consistent with the measured data.  
917

918

### 919 3.6.4 Timestep Size and Nodalization

920

921 Spatial and temporal discretization may impact the stability behavior predicted by system  
922 thermal-hydraulic codes such as RAMONA5-FA. It is often found that increasing the timestep  
923 size leads to increased oscillation DRs, regardless of oscillation mode due to reduction in  
924 numerical damping. Increasing the number of axial nodes in the core may have a similar effect  
925 by reducing the numerical damping, as well as increasing the spatial resolution. However,  
926 increasing the number of axial nodes in the vessel is only expected to have a significant effect  
927 on numerical damping for in-phase modes. This is because the total core flow rate, and  
928 therefore, the flow rate in the vessel nodes, is essentially constant during out-of-phase  
929 oscillations. In either case, vessel nodalization may also impact the core inlet subcooling by  
930 affecting the transport of fluid energy through the vessel as the FW temperature decreases  
931 during the event.  
932

933

934 The NRC staff issued RAI-3 to request sensitivity studies on timestep size and vessel  
935 nodalization. The intent of this RAI was to obtain assurance that potential changes in  
936 discretization would not have an undue impact on calculated FoMs or change the sensitivities to  
937 statistical parameters.

938

939 In the RAI response, [[

940

941

942

943 ]] No clear trend was observed with

944 respect to timestep size.

945

946 For the vessel nodalization study, [[

947

948

]]

949

950 | The range of the impact on core MCPR and ICO results is [[

951

952  
953  
954  
955  
956  
957  
958  
959  
960  
961  
962  
963  
964  
965  
966  
967  
968  
969  
970  
971  
972  
973  
974  
975  
976  
977  
978  
979  
980  
981  
982  
983  
984  
985  
986  
987  
988  
989  
990  
991  
992  
993  
994  
995  
996  
997  
998  
999  
1000  
1001

[[ ]] provides sufficient justification for the NRC staff to conclude that the “base” vessel nodalization and timestep size parameter values used in ANP-10344P are acceptable for BEO-III analyses.

Core nodalization could potentially impact the BEO-III results as well for similar numerical damping considerations as mentioned above, as well as an impact related to resolving void fraction gradients in the bottom portion of the channel. A sensitivity study on core nodalization was not requested by the NRC staff in its review of Framatome’s BEO-III methodology. However, such a study was performed for the ATWS-I methodology (Ref. 15), [[ ]]. For ATWS-I, a trend of [[ ]]. For ATWS-I, a trend of [[ ]] was observed. However, the “base nodalization” of [[ ]] axial core nodes was found to be acceptable due to the good agreement it provided with the measured data, whereas [[ ]]. Because [[ ]], the NRC staff expects a similar trend would be observed for BEO-III and the same conclusions would apply. Furthermore, the vessel nodalization study, in particular, and the timestep size study performed for BEO-III, would be expected to impact the solution in a similar way as a core nodalization study, at least in terms of the impact on numerical diffusion. Therefore, the NRC staff finds sufficient justification to conclude that the base axial nodalization of [[ ]] nodes for the BEO-III methodology is acceptable.

### 3.7 BEO-III Cycle-Specific Analyses

#### 3.7.1 Statistical Methodology

The impact of code uncertainties on the 95/95 core MCPR and ICO results was evaluated by the applicant using a statistical process based on non-parametric order statistics. This is a well-established Monte Carlo-based statistical method, and implementations of this method have been approved by the NRC staff in the past, for example, in the AURORA-B AOO TR (Ref. 18). This method involves the following steps:

1. selection of a set of model parameters that is expected to provide the largest impact on the 95/95 results,
2. determination of applicable uncertainty values for these variables,
3. execution of a series of statistical trials using random perturbations of these variables within RAMONA5-FA, and
4. determination of the 95/95 results for the FoMs derived from these calculations.

The selection of largest-impact parameters was performed based on the BEO-III PIRT provided in Section 4.2, “PIRT Summary,” of ANP-10344P. The applicant defined high probability as [[ ]] at least 95 percent of the population with 95 percent or greater confidence (95/95). The NRC staff has accepted use of the 95/95 criterion in numerous past reviews as providing sufficient confidence that safety limits and other regulatory criteria are satisfied.



1002 In practice, the 95/95 value for each FoM is determined by sorting the FoM results from all  
1003 statistical trials at a given exposure point and event condition. Then, the  $N_{th}$  most limiting FoM  
1004 value is selected, where  $N$  is the acceptance number corresponding to a simultaneous upper  
1005 tolerance limit with at least 95 percent probability coverage at a 95 percent confidence level for  
1006 the predetermined statistical sample size. For BEO-III, the consequences of the limiting stability  
1007 event(s) are determined to be acceptable if [[ ]] with  
1008 95 percent probability at 95 percent confidence. This means that if [[ ]]

1009 ]]  
1010 The applicant noted that the required sample size for a given acceptance number is dependent  
1011 upon the number of parameters being treated simultaneously. The NRC staff finds the  
1012 statistical approach proposed for the Brunswick-specific generic BEO-III methodology  
1013 appropriately ensures

1014 [[ ]]  
1015 ]]  
1016 Based on its review, the NRC staff finds that the same overall statistical approach proposed in  
1017 BEO-III was previously used in the approved AURORA-B AOO TR (Ref. 18). This statistical  
1018 approach based on non-parametric order statistics provides a broad framework for determining  
1019 the impact of code uncertainties on relevant FoMs, independent of the actual modeling details  
1020 and FoMs specific to each application. Therefore, the NRC staff finds the proposed use of  
1021 non-parametric order statistics to be acceptable for use in BEO-III, provided that the method is  
1022 implemented appropriately to the BEO-III analyses.

1023 ]]  
1024 To determine the appropriateness of the implementation, the NRC staff verified that the  
1025 individual RAMONA5-FA calculations were performed in an acceptable manner. The  
1026 calculations realistically modeled the system response during the entire event progression from  
1027 the initiating pump trip until oscillation suppression, and the most limiting potential stability  
1028 events were considered, as discussed in Section 3.3, "Scenario Identification," of this SE.  
1029 Furthermore, input assumptions, including the timestep size and nodalization, were found to be  
1030 acceptable, as discussed in Section 3.6 of this SE.

1031 ]]  
1032 Additionally, the NRC staff determined that the FoMs – both the core MCPR FoM and the ICO  
1033 FoM, were selected appropriately within the BEO-III framework to ensure compliance with  
1034 GDCs 10 and 12. In the absence of ICOs, the core MCPR FoM determines the limiting MCPR  
1035 response in the core during oscillations. The ICO FoM is used to ensure that any ICOs that  
1036 may occur during such events will not lead to a more limiting MCPR response, and therefore,  
1037 challenge the SLMCPR. Core oscillations and ICOs are the two fundamental types of  
1038 oscillatory phenomena in BWRs that may challenge the SLMCPR during anticipated stability  
1039 events. The inclusion of these two FoMs allows the methodology to provide adequate  
1040 assurance that the safety criteria are met for all anticipated oscillation types.

1041 ]]  
1042 In summary, the applicant proposed an acceptable non-parametric order statistics process,  
1043 applied this process to suitable stability analysis calculations, determined statistical parameters  
1044 and uncertainties appropriately, and established acceptable FoMs to ensure that relevant safety  
1045 limits are not violated. Thus, the NRC staff finds the statistical methodology proposed by the  
1046 applicant is acceptable, provided that an appropriate calculation procedure is used to apply it to  
1047 plant- and cycle-specific analyses. The calculation procedure is evaluated in the following  
1048 section to confirm this condition is satisfied by the applicant.

1049 ]]  
1050 3.7.2 BEO-III Calculation Procedure

1051  
1052 Section 7.2 of ANP-10344 defines a calculation procedure that will be used on a cycle-specific  
1053 basis to determine that stability events will not challenge the SLMCPR. A sample ATRIUM 11  
1054 equilibrium cycle analysis using this procedure was provided in ANP-10344P, Section 9.0,  
1055 "ATRIUM Equilibrium Cycle Sample Application."  
1056

1057 Definition of Statepoints  
1058

1059 The ANP-10344P, Section 7.2, calculation procedure defines the statepoints to be analyzed.  
1060

1061 [[

1062  
1063  
1064  
1065  
1066  
1067  
1068

1069 ]]

1070 definition of exposure points to be acceptable [[

1071 ]]

1072  
1073

1074 [[

1075 ]]

1076 This is consistent with the previous methodologies and the  
1077 NRC staff finds it remains acceptable for BEO-III. However, [[

1078

1079 ]]

1080 The NRC staff finds this acceptable because  
1081 [[ ]]

1082 ]]

1083 The calculation procedure includes an [[

1084

1085 ]]

1086 The NRC staff finds the proposed  
1087 ]]

1088 Equilibrium Cycle Sample Application," of this SE.

1089 The calculation procedure proposes that three events [[

1090

1091 ]]

1092  
1093

- 1094 1. a two-pump trip from rated power at the lowest licensed core flow with nominal rated  
1095 subcooling (EFW event),
- 1096 2. a two-pump trip from rated power at the lowest licensed core flow that allows FWHOOS,  
1097 with increased subcooling corresponding to the minimum allowed FW temperature  
1098 (MELLLA FWHOOS event), and
- 1099 3. a single-pump trip from the highest power under SLO, with nominal subcooling (SLO  
1100 event).

1101 [[

1102

1103

1104

]]

1105 The NRC staff expects the most limiting event in terms of final MCPR margin to be one of these

1106 three events, and inclusion of these events [[ ]]

1107 is consistent with Option III and EO-III. In general, oscillations will grow faster, and therefore,

1108 may exhibit the largest delta-MCPR response at the time of trip, at higher rod lines. The EFV

1109 event provides the highest allowable rod line at rated power and is likely to be the most limiting

1110 event. However, the growth rate of oscillations also increases with core inlet subcooling, so the

1111 MELLA FWHOOS event shall be analyzed as well, as indicated in ANP-10344P Section 7.2.

1112 The SLO event is included because this case provides a smaller decrease in flow rate during

1113 the event, and therefore, a smaller initial increase in MCPR margin, relative to the TLO

1114 operating points. This may compensate for the slower oscillation growth rate expected for this

1115 case.

1116

1117 The stability characteristics and dynamic system response may change somewhat across

1118 typical reload cycles, but at least to a reasonable degree, such changes would be expected to

1119 have a similar impact on the results for all three events. [[

1120

1121

1122

1123

]] to be acceptable.

1124

1125 The NRC staff issued RAI-4 to request the description and justification for the process used to

1126 determine whether a BEO-III analysis remains bounding when actual cycle operation deviates

1127 significantly from the intended cycle design. In response, the applicant discussed its existing

1128 process for addressing deviations in cycle operation, starting with an assessment of whether the

1129 deviations are minor (i.e., negligible impact) or whether additional analyses are necessary to

1130 ensure the cycle licensing limits remain valid. Such analyses may include [[

1131 ]]

1132 to ensure that the cycle analyses remain bounding. This is determined based on criteria defined in the reload safety analysis report, considering the impact on [[

1133 ]]

1134 affecting AOOs as well as stability analyses in particular. In the event that actual cycle

1135 operation is not expected to be protected by established operating limits, Framatome uses

1136 historic operating data and the projected depletion to end of cycle to establish new appropriate

1137 operating limits.

1138

1139 The NRC staff reviewed the information presented and finds this process for addressing

1140 unanticipated operating cycle changes to be reasonable and consistent with general industry

1141 practice. However, the representativeness of the specific historical operating data and depletion

1142 projections that may be used to address unanticipated operating cycle changes in future cycles

1143 is beyond the scope of the present review. In accordance with Generic Letter 88-16, "Removal

1144 of Cycle-Specific Parameter Limits from Technical Specifications," and subject to the provisions

1145 of 10 CFR 50.59, "Changes, tests and experiments," applicants typically perform cycle-specific

1146 core reload analyses without prior NRC staff review. By the same token, modifications to cycle-

1147 specific reload analyses to address unanticipated operating cycle changes may also be

1148 performed without prior NRC staff review if the provisions of 10 CFR 50.59 are satisfied. The

1149 NRC staff notes that changes made by applicants under the 10 CFR 50.59 process are subject

1150 to oversight through the NRC's inspection program. Therefore, the NRC staff finds that the

1151 applicant will appropriately address unanticipated changes and the cycle-specific BEO-III  
1152 analyses will remain bounding or will be updated to appropriately account for unanticipated  
1153 variations in cycle operation.

1154  
1155 | In addition, ANP-10344, Section 7.2, specifies that the RAMONA5-FA [[  
1156  
1157 |  
1158 | ]]. The NRC staff finds this acceptable  
1159 because lower core flow rates promote more unstable oscillations; hence, this approach  
1160 conservatively accounts for the differences between [[

1161  
1162 | ]]  
1163

#### 1164 Confirmation of SLMCPR Protection

1165  
1166 Under the procedure in ANP-10344P, Section 7.2, the OLMCPR is confirmed to protect the  
1167 SLMCPR if [[

1168  
1169  
1170  
1171 |  
1172 |  
1173 |  
1174  
1175  
1176  
1177  
1178 | ]] the methodology finds that the existing  
1179 OLMCPR is adequate to protect against postulated core oscillations. Otherwise, the OLMCPR  
1180 must be modified [[ ]] to protect the SLMCPR, or additional  
1181 actions such as modification of the cycle design are required.

1182  
1183 ICOs are significantly more likely for pump trips starting from the EFW domain, as these  
1184 oscillations typically only occur deeper into the unstable region (upper left corner) of the  
1185 power-flow map relative to core-wide oscillations. In the generic EO-III methodology, which is  
1186 approved for EFWs (e.g., the EFW operating domain), ICOs were precluded by establishing a  
1187 channel instability exclusion region. This was done because ICOs lead to a breakdown of the  
1188 relationship between delta-MCPR and oscillation magnitude (i.e., DIVOM), which forms a  
1189 central component of that methodology. Thus, it was determined that the methodology could  
1190 not be guaranteed to protect the SLMCPR in the presence of ICOs.

1191  
1192 Hypothetically, a similar philosophy for ICOs could have been adopted in BEO-III by  
1193 [[

1194  
1195  
1196  
1197 | ]]  
1198

1199 The SLMCPR must be protected in the presence of full-core oscillations, ICOs, or both modes  
1200 at once. [[

1201  
1202  
1203  
1204  
1205  
1206  
1207  
1208  
1209  
1210  
1211  
1212  
1213  
1214  
1215  
1216  
1217  
1218  
1219  
1220  
1221  
1222  
1223  
1224  
1225  
1226  
1227  
1228  
1229  
1230  
1231  
1232  
1233  
1234  
1235  
1236  
1237  
1238  
1239  
1240  
1241  
1242  
1243  
1244  
1245  
1246  
1247  
1248  
1249  
1250

]] This could occur, hypothetically, by constructive interference depending on the timing and location of both modes in the core.

The applicant provided a discussion in Section 5.4.1, "Basis for the Independent Channel Oscillation," and Section 8.1, [[ ]] of ANP-10344P [[ ]]

]] The applicant discussed [[ ]]

]]

This discussion agrees with the NRC staff's understanding of the underlying stability phenomena and is further supported by the illustrative study provided in Section 5.4.1 of ANP-10344P. In this study, [[ ]]

]] Although this is only one example for a particular BWR core and operating condition, it provides added confidence to the expectation that the multistage analysis approach is conservative.

Based on the discussions and illustrative example provided in ANP-10344P, the NRC staff concludes that the Stage 3 analysis will produce a conservative result for the ICO ~~MCPR~~ responseFoM. The Stage 3 calculation [[ ]]

]] Therefore, the NRC staff finds the ICO ~~MCPR~~-FoM calculation method in ANP-10344P to be acceptable.

As evaluated above, the ANP-10344P methodology sufficiently ensures that the SLMCPR will not be violated when considering the possibility of full-core oscillations, ICOs, and the potential combination thereof. Thus, the NRC staff finds that the calculation procedure in ANP-10344P provides an acceptable means of demonstrating SLMCPR protection during all anticipated oscillation modes in the current fleet of BWRs.

Minimum Oscillation Period

1251 Plant-specific D&S algorithms based on the PBDA define a time period lower limit ( $T_{min}$ ); any  
1252 oscillations which have oscillation periods lower than this limit will not be identified as  
1253 oscillations by the D&S algorithm. Therefore, such D&S algorithms cannot be assured to  
1254 provide SLMCPR protection against such oscillations if they occur.

1255  
1256 The BEO-III calculation procedure in Section 7.2 includes an analysis of a 1RPT scenario from  
1257 the EFW operating point (lowest allowed flow rate at rated power), in order to provide assurance  
1258 that no anticipated oscillations will have a period below  $T_{min}$ . This is determined by comparing  
1259 the 95/95 lowest oscillation period to  $T_{min}$ , in order to account for calculation uncertainties. The  
1260 1RPT calculation will [ [

]]

1261  
1262  
1263 The oscillation period decreases with increasing flow rate; however, the DR also decreases with  
1264 increasing flow rate. Therefore, considering progressively lower final flow rates, the lowest  
1265 period is expected to occur at the flow rate at which the DR first exceeds 1.0. The NRC staff  
1266 issued RAI-8 to obtain clarification on the approach to be used for the 1RPT analysis. In the  
1267 response to RAI-8a, Framatome clarified that the EFW operating point (lowest allowed flow rate  
1268 at rated power) would be used for the 1RPT minimum oscillation period analysis in all plant-  
1269 specific applications. Based on the NRC staff's experience, the 1RPT event from the lowest-  
1270 flow point of the EFW domain provides a reasonable approximation of this limiting condition, as  
1271 it will result in lower oscillation periods than a 2RPT event from the same statepoint, provided  
1272 that the 1RPT results in unstable oscillations at all. Therefore, the NRC staff finds this initial  
1273 statepoint acceptable.

1274  
1275 As discussed in the response to RAI-8b, in the event that the 1RPT from the EFW statepoint  
1276 does not result in unstable oscillations, Framatome will [ [

]] Therefore, the NRC staff finds this an

1284 acceptable method for ensuring that no anticipated oscillations will have a time period less than  
1285  $T_{min}$ .

### 1287 3.7.3 Backup Stability Protection Calculation Procedure

1288  
1289 In the event that the OPRM system is unavailable, backup stability protection (BSP) is used to  
1290 ensure that core oscillations that may violate the safety limits will not occur. The BSP approach  
1291 will be provided based on established BWROG definitions (Ref. 20) that have been used in  
1292 previously approved Framatome stability methods (Ref. 9). The BSP curves will be evaluated  
1293 using STAIF, a previous version of which was approved for calculating stability boundaries (Ref.  
1294 21) and is further used in previous stability methodologies such as EO-III (Ref. 9).

1295  
1296 The version of STAIF used in the current methodology differs from the approved version only in  
1297 the fuel models used. The BEO-III STAIF code uses the same [ [ fuel rod  
1298 models as the BEO-III RAMONA5-FA code. These fuel models were found to be acceptable for  
1299 both codes in Section 3.5.1, "Fuel Rod Models," of this SE. Because of this, and because BEO-

1300 III does not impose any other changes to the BSP implementation, the NRC staff finds the  
1301 implementation of BSP in ANP-10344P to be acceptable.

1302

### 1303 3.8 Identification of Major Conservatism

1304

1305 Section 8.0, "Identification of Major Conservatism," of ANP-10344P describes inherent  
1306 conservatism in the methodology. One of the listed conservatisms relates to the [[  
1307 ]], which was evaluated in Section 3.7.2 of this SE.

1308

1309 Another listed conservatism is the use of the SLMCPR as a proxy SAFDL for stability events.  
1310 The applicant discusses that recent large-amplitude oscillation data from the KATHY facility  
1311 suggest that large cladding temperature excursions during oscillations are associated with a  
1312 failure of the cladding outer surface to rewet, which happens later than the onset of boiling  
1313 crisis. This would mean that the CPR-based fuel failure criterion used in the current and  
1314 previous stability methodologies is conservative. These failure-to-rewet data and associated  
1315 models were evaluated for the ATWS-I methodology of ANP-10346P. However, their use in the  
1316 context of stability applications is beyond the scope of the current review, and the proposed  
1317 BEO-III methodology uses conventional CPR-based fuel failure criteria.

1318

1319 The additional listed conservatisms regarding the [[  
1320 ]], have been addressed in previous sections  
1321 of this evaluation. The NRC staff concludes that the BEO-III methodology employs a  
1322 combination of best-estimate and conservative assumptions such that the final calculation of  
1323 stability margins remains conservative overall.

1324

### 1325 3.9 ATRIUM 11 Equilibrium Cycle Sample Application

1326

#### 1327 Sample Equilibrium Cycle Results

1328

1329 Sample BEO-III results for an ATRIUM 11 equilibrium cycle at a large BWR/3 plant were  
1330 provided for illustration purposes in Section 9.0, "ATRIUM 11 Equilibrium Cycle Sample  
1331 Application," of ANP-10344P. For this sample cycle calculation, SLMCPR protection was  
1332 successfully demonstrated for all three events. The FWHOOS was highly non-limiting, with a  
1333 95/95 core MCPR result of [[ ]]. The EFW 2RPT event and the SLO event produced  
1334 comparable 95/95 core MCPR values [[ ]]. However, an  
1335 OLMCPR of [[ ]] was used for all three cases, which appears to be a simplifying assumption  
1336 in this sample analysis. In typical applications, the OLMCPR is expected to be significantly  
1337 higher for SLO than for the TLO EFW conditions (as in the 2RPT event). If this were accounted  
1338 for, the EFW 2RPT would likely have been the most limiting event by a significant margin, which  
1339 aligns with the applicant's expectations as stated in Section 7.2.

1340

1341 | [[

1342

1343

1344

1345

1346

1347

1348



1349  
1350  
1351  
1352  
1353  
1354  
1355  
1356  
1357  
1358  
1359  
1360  
1361  
1362  
1363  
1364  
1365  
1366  
1367  
1368  
1369  
1370  
1371  
1372  
1373  
1374  
1375  
1376  
1377  
1378  
1379  
1380  
1381  
1382  
1383  
1384  
1385  
1386  
1387  
1388  
1389  
1390  
1391  
1392  
1393  
1394  
1395  
1396  
1397  
1398

]]

Based on the trends observed in the sample MELLLA+ cycle and on the NRC staff's understanding of cycle-dependent stability behavior, the 5 percent MCPR and 15 percent channel DR criteria are expected to capture the most limiting 95/95 exposure points with high confidence. This is especially true considering that both nominal and biased nominal parameters are analyzed, providing even more complete coverage of the expected trends with respect to exposure.

The NRC staff issued RAI-9 to determine whether the applicant intends to use the specific pre-filter approach provided in Section 9.0 on a generic basis or whether other approaches could be used. In the RAI response, the applicant clarified that this specific approach, including [[ ]]] is intended for generic use. Because of the high likelihood of selecting the most limiting exposure points, the NRC staff finds the pre-filter process described in Section 9.0 to be acceptable for use on a generic basis.

However, although it is highly likely that this [[ ]]] will identify the most limiting 95/95 exposure point, the trend in 95/95 limiting MCPR versus exposure could differ somewhat from the trends in the [[ ]]] performing the statistical analyses on the reduced set of exposure points, the applicant should inspect the 95/95 results for these exposure points. If trends are observed which indicate that the most limiting exposure point(s) may be outside the analyzed range of exposures, additional exposure points should be analyzed until reasonable assurance is attained that the limiting exposure point is analyzed.

Minimum Oscillation Period

A 1RPT analysis from the EFW statepoint was run for the sample cycle to ensure that all anticipated oscillations have period values above  $T_{min}$ , as discussed in Section 3.7.2 of this SE. For this sample application, the 1RPT event remained stable. [[ ]]]

1399 |  
1400 |  
1401 |  
1402 |                   ]] This successfully demonstrates that all anticipated oscillations will occur within  
1403 | the PBDA stability detection limits for this sample application.  
1404 |

1405 | [[

1406 |  
1407 |  
1408 |  
1409 |   ]] As a result, the NRC staff  
1410 | would find this to be an acceptable means of determining the minimum oscillation period in  
1411 | plant-specific applications, in the situation where the unadjusted 1RPT event remains stable.  
1412 |

1413 | **4.0     LIMITATIONS AND CONDITIONS**

1414 |  
1415 | Section 11.0, "Limitations and Conditions," of ANP-10344P included a list of eight proposed  
1416 | limitations and conditions. Proposed conditions 2, 6, 7, and 8, and the plant-specific component  
1417 | of condition 3, are consistent with the limitations and conditions imposed for the plant-specific  
1418 | BEO-III methodology in the approved Brunswick ATRIUM 11 fuel transition license amendment  
1419 | (Ref. 5). Proposed condition 4 as well as the component of condition 3 related to other noise  
1420 | methods was evaluated in Section 3.8, "Identification of Major Conservatism," of this SE. After  
1421 | review, the NRC staff finds the application of these conditions to be acceptable and appropriate,  
1422 | with the exception of proposed conditions 6 and 7, which are not necessary for the current  
1423 | evaluation. These two conditions were applied to the Brunswick review because they  
1424 | addressed topics which were not directly discussed in the Brunswick ATRIUM11 license  
1425 | amendment but only in RAIs and their responses; the NRC staff included these conditions in its  
1426 | SE to ensure acceptable treatment of these issues. However, in the generic BEO-III TR,  
1427 | Framatome modified the description of the methodology to ensure these issues will be  
1428 | acceptably addressed. Therefore, no additional conditions in this SE are required for these  
1429 | issues.  
1430 |

1431 | Proposed condition 1 relates to potential future changes to or replacement of MICROBURN-B2  
1432 | as the core simulator and is appropriate because it ensures that changes to core simulator  
1433 | methods would be subject to technical review by the NRC staff.  
1434 |

1435 | Proposed condition 5 relates to potential future changes to the RAMONA5-FA code. While the  
1436 | NRC staff agrees that substantive model changes affecting the BEO-III analysis would require  
1437 | prior review by the NRC staff, the NRC staff does not agree with the applicant's referencing of  
1438 | 10 CFR 50.59 with respect to changes made to fuel vendors' codes or analysis methods. In  
1439 | fact, such application appears beyond the scope of the regulation, considering that 10 CFR  
1440 | 50.59(b) states that "[t]his section applies to each holder of an operating license issued under  
1441 | this part or a combined license issued under [P]art 52 of this chapter...." Moreover, because an  
1442 | assessment of methodology changes with respect to the criteria listed 10 CFR 50.59(c) may in  
1443 | general lead reactor licensees to different conclusions for different licensed facilities, there is no  
1444 | obvious means for a fuel vendor to make a singular judgment on behalf of all potentially affected  
1445 | licensees concerning the need for prior NRC staff review of a given methodology change. While  
1446 | the NRC staff does not directly regulate vendor modifications to analytical codes, changes to  
1447 | codes in general have the potential to affect evaluation models approved by the NRC staff.  
1448 | Therefore, the NRC staff has included a revised version of the applicant's proposed condition 5

1449 that is based upon the principle of maintaining the BEO-III methodology as described in the  
1450 submittals the NRC staff has reviewed and which form the basis for the conclusions expressed  
1451 in the present SE.

1452  
1453 Framatome's proposed conditions for ANP-10344P address all stability-related conditions in the  
1454 Brunswick ATRIUM 11 fuel transition SE with the exception of Brunswick BEO-III conditions 1  
1455 and 5. Brunswick BEO-III condition 1 requires that the [ ]

1456  
1457 [ ] In ANP-10344P, the applicant provided additional detail on the Stage  
1458 3 [ ]

1459 [ ] were defined by  
1460 Framatome in the RAI-5 response, and the NRC staff's evaluation is given in Section 3.5.4 of  
1461 this SE. Therefore, Brunswick BEO-III condition 1 does not need to be captured in the  
1462 limitations and conditions for the generic BEO-III methodology.

1463  
1464 Brunswick BEO-III condition 5 relates strictly to the use of the confirmation density algorithm as  
1465 the D&S algorithm at Brunswick. This is a plant-specific issue which is not relevant to  
1466 applications of BEO-III on a generic basis. Plant-specific applications which rely on PBDA as  
1467 the D&S algorithm may use RAMONA5-FA and the built-in PBDA implementation to determine  
1468 appropriate trip times using the plant-specific PBDA settings. Any plant-specific applications  
1469 which rely on D&S algorithms other than PBDA are beyond the scope of this SE and would  
1470 require a separate licensing action.

1471  
1472 Therefore, the conditions proposed by the applicant in Section 11.0 of ANP-10344P are  
1473 acceptable, with the modification discussed above to proposed condition 5, and with proposed  
1474 conditions 6 and 7 being removed as unnecessary for the generic methodology. Framatome  
1475 has appropriately addressed the conditions from the Brunswick plant-specific BEO-III  
1476 application in this generic application. Furthermore, additional conditions 6 through 9-8 have  
1477 been imposed to address additional issues which were identified during the NRC staff's review  
1478 of the generic BEO-III methodology described in ANP-10344P.

#### 1479 Application of BEO-III to New Fuel Types

1480  
1481  
1482 ANP-10344P provides sample MELLLA+ results using ATRIUM 11 fuel; however, the applicant  
1483 did not restrict application of the methodology to current fuel types. The NRC staff issued RAI-6  
1484 to obtain information on the applicant's intended process to apply BEO-III to new fuel types  
1485 beyond ATRIUM 11. In the RAI response, Framatome discussed that the same approach will  
1486 be used as for previous fuel introductions. This includes a review to determine whether current  
1487 RAMONA5-FA modeling capabilities can adequately model the new fuel design features. If so,  
1488 the existing modeling capabilities are considered appropriate [ ]

1489  
1490 [ ] The NRC staff has determined that this approach remains  
1491 applicable for BEO-III because it will ensure that the necessary additions to RAMONA5-FA are  
1492 properly identified and incorporated with the introduction of new fuel types and that all physical  
1493 phenomena necessary for accurate stability prediction will be appropriately updated to reflect  
1494 the behavior of the new fuel type. Application of BEO-III to new fuel types is acceptable under  
1495 this existing fuel development process. Through its existing regulatory processes, including  
1496 inspection and review of licensing actions, the NRC staff retains appropriate oversight of vendor  
1497 determinations concerning methods applications to new fuel products. Therefore, no additional  
1498 limitation and condition is necessary to address this topic in the present SE.

1499  
1500  
1501  
1502  
1503  
1504  
1505  
1506  
1507  
1508  
1509  
1510  
1511  
1512  
1513  
1514  
1515  
1516  
1517  
1518  
1519  
1520  
1521  
1522  
1523  
1524  
1525  
1526  
1527  
1528  
1529  
1530  
1531  
1532  
1533  
1534  
1535  
1536  
1537  
1538  
1539  
1540  
1541  
1542  
1543  
1544  
1545  
1546  
1547  
1548

Gap Conductance Sensitivity

The SE for ANP-10346P imposed a limitation that the gap sensitivity study must be repeated or otherwise justified for a transition to new fuel designs. As discussed in Section 3.5.1 of this SE, the fuel rod model impacts the thermal energy stored in the fuel rod and the heat that reaches the cladding surface and coolant during thermal-hydraulic oscillations. The gap width and associated gap conductance are important parameters in determining the dynamic thermal performance of the fuel during stability events.

New fuel designs, with changes to fuel geometry or materials, could potentially have different sensitivity to gap conductance than current fuel designs. Therefore, the NRC staff imposed the aforementioned limitation for ANP-10346P to ensure that the impact of gap conductance uncertainty for new fuel designs can be readily accommodated by the available margins in operator action time for ATWS-I events, and therefore that the ATWS-I consequences would remain acceptable.

However, such a limitation is not necessary for BEO-III because **[[** **]]** and the resulting impact on the BEO-III FoMs, will be accounted for by the BEO-III methodology. Through its existing regulatory processes, including inspection and review of licensing actions, the NRC staff retains appropriate oversight of this issue. Therefore, no limitation is necessary with regard to gap sensitivity.

Limitations and Conditions

1. MICROBURN-B2 is an integral component in the BEO-III methodology. Application of a new core simulator requires review and approval by the NRC.
2. Selected settings and modeling options, including core and vessel nodalization and time step control parameters, shall be defined consistently with the validation basis presented in Section 6.0.
3. **[[** **]]**
4. **[[** **]]**
5. Framatome must continue to use existing regulatory processes for any code modifications made to the RAMONA-5FA code. The existing regulatory processes do not allow changes to the RAMONA5-FA code that would substantively alter the BEO-III methodology, as described in ANP-10344P and supporting RAI responses, which the

1549 NRC staff relied upon as the basis for the finding of acceptability in this SE, without prior  
1550 NRC review and approval.

1551  
1552 6. Plant-specific applications shall justify whether the recirculation pump coastdown  
1553 behavior will have a significant impact on the final MCPR for the specific plant and  
1554 conditions being analyzed. If so, the uncertainties in the recirculation pump coastdown  
1555 response should be included in the statistical analyses or otherwise accounted for.

1556  
1557 7. If the 1RPT EFW event remains stable, additional analyses are required using **[[**  
1558 **]]** to ensure that the lowest oscillation period  
1559 remains above  $T_{min}$  under any anticipated conditions.

1560  
1561 8. After applying the **[[**  
1562 **]]** If trends are observed which indicate that the most limiting exposure point(s)  
1563 outside the analyzed range of exposures, additional exposure points should be  
1564 analyzed until reasonable assurance is attained that the limiting exposure point is  
1565 analyzed.  
1566

1567

## 1568 **5.0 CONCLUSIONS**

1569

1570 Based upon its review, the NRC staff finds that the generic BEO-III calculation procedure in  
1571 ANP-10344P provides an acceptable means of determining licensing basis SLMCPR protection  
1572 during anticipated stability events for the operating BWR fleet. As discussed in the foregoing  
1573 evaluation, the NRC staff's conclusion relies upon the applicant adhering to the limitations and  
1574 conditions enumerated above in Section 4.0 of this SE.

1575

## 1576 **6.0 REFERENCES**

1577

- 1578 1. Framatome, Inc., "ANP-10344P, Framatome Best-Estimate Enhanced Option III  
1579 Methodology," October 31, 2019 (ADAMS Package Accession No. ML19308A119)
- 1580  
1581 2. U.S. NRC, "Bulletin 88-07: Power Oscillations in Boiling-Water Reactors (BWRs)," June 15,  
1582 1988.
- 1583  
1584 3. U.S. NRC, "Information Notice No. 92-74: Power Oscillations at Washington Nuclear Power  
1585 Unit 2," November 10, 1992.
- 1586  
1587 4. Duke Energy, "Brunswick, Units 1 and 2, Request for License Amendment Regarding  
1588 Application of Advanced Framatome Methodologies," Appendix 15a / 15b, ADAMS  
1589 Accession No. ML18284A395, October 11, 2018.
- 1590  
1591 5. U.S. NRC, "Brunswick Steam Electric Plant, Units 1 and 2 – Issuance of Amendment Nos.  
1592 299 And 327 to Revise Technical Specification 5.6.5b to Allow Application of Advanced  
1593 Framatome ATRIUM 11 Fuel Methodologies (EPID L-2018-LLA-0273)," ADAMS Accession  
1594 No. ML20073F186, March 6, 2020.
- 1595  
1596 6. Framatome, Inc., "Response to Request for Additional Information Regarding ANP-10344P,  
1597 Revision 0, 'Framatome Best-Estimate Enhanced Option III Methodology'," November 30,  
1598 2020 (ADAMS Package Accession No. ML20338A164).

- 1599  
1600 7. AREVA NP Inc., Licensing Topical Report EMF 3028P-A, Volume 2, Revision 4,  
1601 "RAMONA5-FA: A Computer Program for BWR Transient Analysis in the Time Domain:  
1602 Theory Manual," dated June 3, 2013 (ADAMS Accession No. ML13155A493).  
1603  
1604 8. AREVA NP Inc., Publication of BAW-10255PA, Revision 2, "Cycle-Specific DIVOM  
1605 Methodology Using the RAMONA5-FA Code," dated May 21, 2008 (ADAMS Accession No.  
1606 ML082820002 (Non-Public)).  
1607  
1608 9. Framatome, Inc., "ANP-10262(NP), Rev. 0, Enhanced Option III Long Term Stability  
1609 Solution," dated January 31, 2006 (ADAMS Accession No. ML060330650).  
1610  
1611 10. U.S. NRC, NUREG/CR-6743, "Phenomenon Identification and Ranking Tables (PIRTs) for  
1612 Power Oscillations Without Scram in Boiling-Water Reactors Containing High Burnup Fuel,"  
1613 dated September 30, 2001 (ADAMS Accession No. ML012850300).  
1614  
1615 11. U.S. NRC, "Applicability of TRACE/PARCS to MELLLA+ BWR ATWS Analyses –  
1616 Revision 1," dated November 18, 2011 (ADAMS Accession No. ML113350073).  
1617  
1618 12. U.S. NRC, NUREG/CR-7179, "BWR Anticipated Transients Without Scram in the MELLLA+  
1619 Expanded Operating Domain, Part 1: Model Development and Events Leading to Instability,"  
1620 dated June 30, 2015 (ADAMS Accession No. ML15169B064).  
1621  
1622 13. U.S. NRC, NUREG/CR-7180, "BWR Anticipated Transients Without Scram in the MELLLA+  
1623 Expanded Operating Domain, Part 2: Sensitivity Studies for Events Leading to Instability,"  
1624 dated June 30, 2015 (ADAMS Accession No. ML15169A168).  
1625  
1626 14. AREVA NP Inc., Report ANP-10346NP, Revision 0, "ATWS-I Analysis Methodology for  
1627 BWRs Using RAMONAS-FA," dated December 15, 2017 (ADAMS Accession No.  
1628 ML17355A233).  
1629  
1630 15. Framatome, Inc., "ANP-10346P-A, Revision 0, 'ATWS-I Analysis Methodology for BWRs  
1631 Using RAMONA5-FA'," ADAMS Accession No. ML20034E952, October 31, 2019.  
1632  
1633 16. Boiling Water Reactor Owners Group, "NEDO-31960-A, 'BWR Owners' Group Long-Term  
1634 Stability Solutions Licensing'," November 1995.  
1635  
1636 17. Boiling Water Reactor Owners Group, "NEDO-31960-A, Supplement 1, 'BWR Owners'  
1637 Group Long-Term Stability Solutions Licensing'," November 1995.  
1638  
1639 18. Framatome, Inc., "ANP-10300NP-A, Rev. 1, AURORA-B: An Evaluation Model for Boiling-  
1640 Water Reactors; Application to Transient and Accident Scenarios," dated January 31, 2018  
1641 (ADAMS Accession No. ML18186A181).  
1642  
1643 19. U.S. NRC, "Final Safety Evaluation by the Office of Nuclear Reactor Regulation Topical  
1644 Report (TR) ANP-10262(P), Revision 0, "Enhanced Option III [EO-III] Long Term Stability  
1645 Solution" AREVA NP, Inc.," ADAMS Accession No. ML081270214, May 21, 2008.  
1646  
1647 20. A. Chung, "Backup Stability Protection (BSP) for Inoperable Option III Solution," July 17,  
1648 2002.

1649  
1650 | 21. Siemens Power Corporation, "EMF-CC-074(P)(A), Volume 4, Revision 0, "BWR Stability  
1651 | Analysis – Assessment of STAIF with Input from MICROBURN-B2", ADAMS Accession  
1652 | No. ML090750216, August 2000.

1653  
1654 | ~~21.~~22. ANF-913(P)(A) Volume 1 Revision 1 and Volume 1 Supplements 2, 3 and 4,  
1655 | "COTRANSA2: A Computer Program for Boiling Water Reactor Transient Analyses,"  
1656 | Advanced Nuclear Fuels Corporation, August 1990.

1657  
1658  
1659 | Principal Contributors: A. Wysocki (ORNL)  
1660 | J. Lehning

1661  
1662 | Date: February 16, 2021  
1663