


|   |   |                          |
|---|---|--------------------------|
| SEABROOK STATION<br>UPDATED FINAL SAFETY<br>ANALYSIS REPORT | Foundation Cross-Section for Electrical Duct Banks, Manholes, and<br>Service Water Piping |                          |
|   | Rev. 16   | Figure 2.5-50 Sh. 1 of 2 |




SEABROOK STATION  
UPDATED FINAL SAFETY  
ANALYSIS REPORT

Foundation Cross-Section for Electrical Duct Banks, Manholes, and  
Service Water Piping


Rev. 16

Figure 2.5-50 Sh. 2 of 2



|   |                |               |
|---|----------------|---------------|
| SEABROOK STATION<br>UPDATED FINAL SAFETY<br>ANALYSIS REPORT | Offsite Borrow |               |
|   |                | Figure 2.5-51 |





Offsite Borrow Compaction Test Results – Typical Winter  
 Period



NOTES: (1) Results shown correspond to all field density tests on Offsite Borrow placed in various safety-related areas of the plant site during Feb. 1978, Feb. 1979, March 1979, Jan. 1980, Feb. 1980, and Feb. 1981. Field density tests were performed according to ASTM D2922-71. A one-point compaction test was done for each field density test.

(2) All layers were compacted to at least 95% of ASTM D1557-70 compaction. If the measured degree of compaction for any layer was less than 95%, the layer was recompact and retested until adequate compaction was achieved. Only the final compaction result for each layer was plotted in this figure.

(3) The total number of test results used to prepare the histogram is 41.





NOTES: (1) Results shown correspond to all field density tests on Offsite Borrow placed in various safety-related areas of the plant site during April and May for both 1978 and 1979. Field density tests were performed according to ASTM D2922-71. A one-point compaction test was done for each field density test.

(2) All layers were compacted to at least 95% of ASTM D1557-70 compaction. If the measured degree of compaction for any layer was less than 95%, the layer was recompact and retested until adequate compaction was achieved. Only the final compaction result for each layer was plotted in this figure.

(3) The total number of test results used to prepare the histogram is 51.


|  |   |               |
|--|---|---------------|
| <b>SEABROOK STATION<br/>UPDATED FINAL SAFETY<br/>ANALYSIS REPORT</b> | <b>Offsite Borrow Compaction Test Results – Typical Spring<br/>Period</b> |               |
|  | <b>Figure</b>   | <b>2.5-53</b> |




NOTES: (1) Results shown correspond to all field density tests on Offsite Borrow placed in various safety-related areas of the plant site during August 1 through 15 of 1979. Field density tests were performed according to ASTM D2922-71. A one-point compaction test was done for each field density test.

(2) All layers were compacted to at least 95% of ASTM D1557-70 compaction. If the measured degree of compaction for any layer was less than 95%, the layer was recompact and retested until adequate compaction was achieved. Only the final compaction result for each layer was plotted in this figure.

(3) The total number of test results used to prepare the histogram is 69.




|  |   |               |
|--|---|---------------|
| <b>SEABROOK STATION<br/>UPDATED FINAL SAFETY<br/>ANALYSIS REPORT</b> | <b>Offsite Borrow Compaction Test Results – Typical Summer<br/>Period</b> |               |
|  | <b>Figure</b>   | <b>2.5-54</b> |





NOTES: (1) Results shown correspond to all field density tests on Offsite Borrow placed in the Revetment area shown on the site plan during Sept., Oct., Nov. 1977 and May, June, July 1978. Field density tests were performed according to ASTM D1922-71. A one-point compaction test was done for each field density test.

(2) All layers were compacted to at least 95% of ASTM D1557-70 compaction. If the measured degree of compaction for any layer was less than 95%, the layer was recompact and retested until adequate compaction was achieved. Only the final compaction result for each layer was plotted in this figure.

(3) The total number of test results used to prepare the histogram is 9.










NOTES: (1) Results shown correspond to all field density tests performed on Tunnel Cuttings in safety-related areas of the plant site. These areas were N10160-10220+, E5290-5360+ (August 13-26, 1981) and N10140-10210+, E5420-5550+ (September 11, 1980-May 20, 1981). Field density tests were performed according to ASTM D2922-71. A one-point compaction test was done for each field density test.

(2) All layers were compacted to at least 95% of ASTM D1557-70 compaction. If the measured degree of compaction for any layer was less than 95%, the layer was recompact and retested until adequate compaction was achieved. Only the final compaction result for each layer was plotted in this figure.

(3) The total number of test results used to prepare the histogram is 52.



|  |  |               |
|--|--|---------------|
| <b>SEABROOK STATION<br/>UPDATED FINAL SAFETY<br/>ANALYSIS REPORT</b> | <b>Tunnel Cuttings Compaction Test Results</b> |               |
|  | <b>Figure</b>                                  | <b>2.5-57</b> |




**LEGEND**

- Unconfined Compressive Strength after 7 days of curing
- Unconfined Compressive Strength after 28 days of curing
- ▲ Unconfined Compressive Strength after 90 days of curing

**NOTE:**

Results shown correspond to all safety-related SAND-CEMENT placed within the plant site, which was placed in a 10-ft-wide service water pipe trench excavated in rock, centerline N9774, between E6250 and E6430 during the period February 16 to March 29, 1978. Tests performed according to ASTM C39-74. Ref. Table 2.5-17.

|   |                          |        |
|---|--------------------------|--------|
| SEABROOK STATION<br>UPDATED FINAL SAFETY<br>ANALYSIS REPORT | Sand-Cement Test Results |        |
|   | Figure                   | 2.5-58 |



**LEGEND**

- Unconfined Compressive Strength after 7 days of curing
- ▲ Unconfined Compressive Strength after 28 days of curing
- Unconfined Compressive Strength after 90 days of curing

**NOTE:**  
 Results shown are for all tests of FILL CONCRETE placed under the containment mat, Unit 2, during the period May 24-November 11, 1978. Tests performed according to ASTM C39-71.

|   |                            |        |
|---|----------------------------|--------|
| SEABROOK STATION<br>UPDATED FINAL SAFETY<br>ANALYSIS REPORT | Fill Concrete Test Results |        |
|   | Figure                     | 2.5-59 |

Backfill Concrete Test Results


**LEGEND**


- Unconfined Compressive Strength after 7 days of curing
- ▲ Unconfined Compressive Strength after 28 days of curing
- Unconfined Compressive Strength after 90 days of curing

**NOTE:**  
 Test results shown are typical for BACKFILL CONCRETE placed in various safety-related areas of the plant site during the period May 30, 1978 to October 30, 1980. Tests performed according to ASTM C39-71.


**NOTE:**  
 These test results pertain to BACKFILL CONCRETE placed around the outer walls of the following safety-related structures on the dates indicated:

| Structure                  | Date of Pour                       |
|----------------------------|------------------------------------|
| Waste Processing Bldg.     | May 30, 31, 1978                   |
|                            | December 19, 1979                  |
|                            | October 30, 1980                   |
| Diesel Gen. Bldg., Unit 1  | March 23, 27, 1979                 |
|                            | May 4, 8, 22, 23, 24, 29, 30, 1979 |
| Fuel Storage Bldg., Unit 1 | September 21, 25, 1979             |
|                            | March 12, 1980                     |
| Primary Aux. Bldg., Unit 1 | May 16, 18, 1979                   |
| Service Water Pumphouse    | January 4, 1980                    |
|                            | July 14, 1980                      |
| Containment Bldg., Unit 1  | June 4, 28, 1979                   |
|                            | July 3, 6, 1979                    |
| Control Bldg., Unit 1      | March 8, 1979                      |
|                            | June 1, 1979                       |








|   |                 |               |
|---|-----------------|---------------|
| SEABROOK STATION<br>UPDATED FINAL SAFETY<br>ANALYSIS REPORT | Tunnel Cuttings |               |
|   |                 | Figure 2.5-61 |



|   |   |               |
|---|---|---------------|
| SEABROOK STATION<br>UPDATED FINAL SAFETY<br>ANALYSIS REPORT | Overall View of Foundation Excavations, Looking East from<br>Unit 2 toward Unit 1 |               |
|   |   | Figure 2.5-62 |



|   |  |               |
|---|--|---------------|
| SEABROOK STATION<br>UPDATED FINAL SAFETY<br>ANALYSIS REPORT | Foundation Excavation for Service and Circulating Water<br>Pumphouse Looking North |               |
|   |  | Figure 2.5-63 |





**NOTE :**



PEAKS OF SOME OF THE PROCTORS OVER THE 100% SATURATION LINE ARE DUE TO MATERIAL HAVING HIGHER SPECIFIC GRAVITY.

|   |  |               |
|---|--|---------------|
| SEABROOK STATION<br>UPDATED FINAL SAFETY<br>ANALYSIS REPORT | Summary Plot of Compaction Curves for Tunnel Cuttings<br>(March to September 1979) |               |
|   |  | Figure 2.5-64 |





|   |   |               |
|---|---|---------------|
| SEABROOK STATION<br>UPDATED FINAL SAFETY<br>ANALYSIS REPORT | Summary Plot of Compaction Curves for Offsite Borrow<br>(June to December 1979) |               |
|   |   | Figure 2.5-65 |





**NOTATION**

- H = Depth of wall below grade, ft.
- $\gamma_1$  = Buoyant Unit Weight, use 62.5 pcf for offshore borrow
- $\gamma_s$  = Saturated Unit Weight, use 125 pcf for offshore borrow
- $\gamma_w$  = Unit Weight of water, use 62.5 pcf
- q = Live Load Surcharge = 500 psf minimum
- $q_f$  = Fixed or Permanent Surcharge, psf (where applicable)
- $K_A$  = Coefficient of Active Earth Pressure, use  $K_A = 0.30$
- $K_h$  = Coefficient of Dynamic Earth Pressure, use  $K_h = 0.19$  for SSE,  $K_h = 0.10$  for OBE

**NOTES**

1. A non-rigid wall is defined as a retaining wall which is not supported at the top by floors, etc., and can deflect under earth pressure.
2. Finished plant grade is +20 ft MSL. Design groundwater level is El. +20 ft MSF, (refer to Section 2.5.4.6).
3. See Fig. 2.5-53 for lateral loads on rigid walls.

|  |  |
|--|--|
| <p>SEABROOK STATION<br/>UPDATED FINAL SAFETY<br/>ANALYSIS REPORT</p> | <p>Lateral Loading Diagrams for Nonrigid Walls</p> |
|  | <p>Figure 2.5-66</p>                               |




**NOTATION**

- $H$  = Depth of wall below grade, ft.
- $\gamma_1$  = Buoyant Unit Weight, use 62.5 pcf for offshore borrow
- $\gamma_s$  = Saturated Unit Weight, use 125 pcf for onsite borrow
- $\gamma_w$  = Unit weight of water, use 62.5 pcf
- $q$  = Live Load Surcharge = 500 psf minimum
- $q_f$  = Fixed or Permanent Surcharge, psf (where applicable)
- $K_0$  = Coefficient of At-Rest Earth Pressure, use  $K_0 = 0.5$
- $K_p$  = Coefficient of Passive Earth Pressure, use  $K_p = 3.3$
- $K_D$  = Coefficient of Dynamic Earth Pressure, use  $K_D = 0.28$  for SSE
- $K_D$  = 0.15 for CBE


**NOTES**

1. A rigid wall is defined as a foundation wall supported and effectively restrained by the floors, walls, etc., which cannot deflect under earth pressure.
2. Finished plant grade is +20 ft MSL. Design groundwater level is El. +20 ft MSL (refer to Section 2.5.4.6).
3. See Fig. 2.5-52 for lateral loads on non-rigid walls.

|  |   |
|--|---|
| <p>SEABROOK STATION<br/>UPDATED FINAL SAFETY<br/>ANALYSIS REPORT</p> | <p>Lateral Loading Diagrams for Rigid Walls</p> |
|  | <p>Figure 2.5-67</p>                            |




|   |   |        |
|---|---|--------|
| SEABROOK STATION<br>UPDATED FINAL SAFETY<br>ANALYSIS REPORT | Soil Profile and Finite Mesh Revetment A – Deepest Soil Deposit Cross Section Q-Q |        |
|   | Figure  | 2.5-68 |




NOTES: 1) SEE FIGURE 2.5-41a FOR LOCATION OF SECTION.


2) SEE FIGURE 2.4-43 FOR DETAILS OF REVETMENT STONE.



SETTLEMENT FOR WEDGES LAND 3  
(not to scale)



SETTLEMENT FOR WEDGE 4  
(not to scale)




TRIAL DISPLACEMENT WEDGES  
(not to scale)

- NOTES
- 1) See Figs. 2.5-54 and 2.5-55 for exact geometry of sections analyzed.
  - 2) See Fig. 2.4-23 for details of revetment stone.
  - 3) Displacements for Wedges 2 and 5 were significantly lower than for the other wedges. Therefore, settlements were not analyzed for these wedges.

|   |  |               |
|---|--|---------------|
| SEABROOK STATION<br>UPDATED FINAL SAFETY<br>ANALYSIS REPORT | Trial Wedges and Method of Settlement Analysis Revetment |               |
|   |  | Figure 2.5-70 |

SHEAR MODULUS,  $G_{max}$  (psi)  
 (at shear strain  $\gamma = 10^{-6}$  in/in)



- NOTES: 1. See FSAR text, Subsection 2.5.4.7 for description of method used to backfigure  $G_{max}$  from plate load tests.
2. Curves for  $G_{max}$  vs  $\bar{\sigma}_m$  were generated from the plate load test data using the relationship  $G_{2max} = G_{1max} \sqrt{\sigma_{2m}/\sigma_{1m}}$  with  $G_1$  and  $\sigma_1$  being the plate load test values.
3. Values of  $G$  for shear strain levels greater than  $10^{-6}$  in./in. can be obtained using the average modulus reduction curve for sands presented in Seed and Idriss (1970).
4. Values of  $K_2$  for use in the equation  $G_{max} = 1000 K_2 (\bar{\sigma}_m)^{1/2}$  are shown next to each curve.

|   |  |               |
|---|--|---------------|
| SEABROOK STATION<br>UPDATED FINAL SAFETY<br>ANALYSIS REPORT | Shear Modules at Low Strain Levels for Offsite Borrow and<br>Tunnel Cuttings |               |
|   |  | Figure 2.5-71 |