

PBAPS UFSAR

APPENDIX I - INSERVICE INSPECTION AND TESTING PROGRAMS

Inservice Inspection and Testing Programs describe the operability testing and non-destructive examination (NDE) of Code Class 1, 2, 3 and MC components, pursuant to the requirements of 10CFR50.55a.

The programs are described in specifications and documents transmitted to the NRC.

The Inservice Testing (IST) Program for Peach Bottom Atomic Power Station, Units 2 and 3, details the technical basis and provides the overall description of the activities planned to fulfill the testing requirements of pumps and valves as described by 10CFR50.55a(f), Inservice Testing Requirements.

The Inservice Inspection (ISI) Program for Peach Bottom Atomic Power Station, Units 2 and 3, describes compliance with the requirements of 10CFR50.55a(g), Inservice Inspection Requirements.

The ISI and IST Programs are developed in accordance with the applicable approved Edition(s) of the ASME Code and the NRC Safety Evaluation(s) of the Programs. Changes to the Programs, within the constraints of the Code and 10CFR50, do not represent changes to procedures as described in the SAR.