



Michael J. Yox  
Regulatory Affairs Director  
Vogtle 3 & 4

7825 River Road  
Waynesboro, GA 30830  
706-848-6459

APR 19 2021

Docket No.: 52-025

ND-21-0394  
10 CFR 52.99(c)(1)

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555-0001

Southern Nuclear Operating Company  
Vogtle Electric Generating Plant Unit 3  
ITAAC Closure Notification on Completion of ITAAC Item 2.3.10.12 [Index Number 879]

Ladies and Gentlemen:

In accordance with 10 CFR 52.99(c)(1), the purpose of this letter is to notify the Nuclear Regulatory Commission (NRC) of the completion of Vogtle Electric Generating Plant (VEGP) Unit 3 Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC) Item 2.3.10.12 [Index Number 879]. This ITAAC confirms the retrievability of Liquid Radwaste System safety-related displays in the main control room. The closure process for this ITAAC is based on the guidance described in Nuclear Energy Institute (NEI) 08-01, "Industry Guideline for the ITAAC Closure Process under 10 CFR Part 52," which was endorsed by the NRC in Regulatory Guide 1.215.

This letter contains no new NRC regulatory commitments. Southern Nuclear Operating Company (SNC) request NRC staff confirmation of this determination and publication of the required notice in the Federal Register per 10 CFR 52.99.

If there are any questions, please contact Kelli A. Roberts at 706-848-6991.

Respectfully submitted,

A handwritten signature in black ink that reads "Michael J. Yox".

Michael J. Yox  
Regulatory Affairs Director Vogtle 3 & 4

Enclosure: Vogtle Electric Generating Plant (VEGP) Unit 3  
Completion of ITAAC 2.3.10.12 [Index Number 879]

MJY/RAS/sfr

**To:**

**Southern Nuclear Operating Company/ Georgia Power Company**

Mr. Peter P. Sena III (w/o enclosures)

Mr. D. L. McKinney (w/o enclosures)

Mr. M. D. Meier (w/o enclosures)

Mr. G. Chick

Mr. S. Stimac

Mr. P. Martino

Mr. M. J. Yox

Mr. A. S. Parton

Ms. K. A. Roberts

Mr. C. T. Defnall

Mr. C. E. Morrow

Mr. R. L. Beilke

Mr. S. Leighty

Ms. A. C. Chamberlain

Mr. J. C. Haswell

Document Services RTYPE: VND.LI.L06

File AR.01.02.06

cc:

**Nuclear Regulatory Commission**

Ms. M. Bailey (w/o enclosures)

Mr. M. King

Ms. A. Veil

Mr. C. P. Patel

Mr. G. J. Khouri

Mr. C. J. Even

Mr. B. J. Kemker

Ms. N. C. Coovert

Mr. C. Welch

Mr. J. Gaslevic

Mr. O. Lopez-Santiago

Mr. G. Armstrong

Mr. M. Webb

Mr. T. Fredette

Mr. C. Santos

Mr. B. Davis

Mr. J. Vasquez

Mr. J. Eargle

Mr. E. Davidson

Mr. T. Fanelli

Mr. S. Rose

Ms. K. McCurry

**Oglethorpe Power Corporation**

Mr. R. B. Brinkman

Mr. E. Rasmussen

**Municipal Electric Authority of Georgia**

Mr. J. E. Fuller  
Mr. S. M. Jackson

**Dalton Utilities**

Mr. T. Bundros

**Westinghouse Electric Company, LLC**

Dr. L. Oriani (w/o enclosures)  
Mr. D. C. Durham (w/o enclosures)  
Mr. M. M. Corletti  
Mr. Z. S. Harper  
Mr. J. L. Coward

**Other**

Mr. S. W. Kline, *Bechtel Power Corporation*  
Ms. L. Matis, *Tetra Tech NUS, Inc.*  
Dr. W. R. Jacobs, Jr., Ph.D., *GDS Associates, Inc.*  
Mr. S. Roetger, *Georgia Public Service Commission*  
Mr. R. L. Trokey, *Georgia Public Service Commission*  
Mr. K. C. Greene, *Troutman Sanders*  
Mr. S. Blanton, *Balch Bingham*

U.S. Nuclear Regulatory Commission  
ND-21-0394 Enclosure  
Page 1 of 4

**Southern Nuclear Operating Company  
ND-21-0394  
Enclosure**

**Vogtle Electric Generating Plant (VEGP) Unit 3  
Completion of ITAAC 2.3.10.12 [Index Number 879]**

## **ITAAC Statement**

### **Design Commitment**

12. Safety-related displays identified in Table 2.3.10-1 can be retrieved in the main control room (MCR).

### **Inspections, Tests, Analyses**

Inspection will be performed for retrievability of the safety-related displays in the MCR.

### **Acceptance Criteria**

Safety-related displays identified in Table 2.3.10-1 can be retrieved in the MCR.

## **ITAAC Determination Basis**

An inspection was performed to verify the retrievability of the Vogtle Electric Generating Plant (VEGP) Unit 3 safety-related displays in the MCR. The inspection for retrievability confirmed that the safety-related displays of the parameters identified in Combined License (COL) Appendix C Table 2.3.10-1 (Attachment A) can be retrieved in the MCR.

The inspection was performed in accordance the Unit 3 ITAAC Technical Report (Reference 1) for Liquid Radwaste System (WLS) component indication verifications, and visually confirmed that when each of the safety-related displays identified in Attachment A was summoned at the MCR Protection and Safety Monitoring System (PMS) Visual Display Units (VDUs), the summoned safety-related displays appeared on the PMS VDU.

The Unit 3 ITAAC Technical Report (Reference 1) confirmed that the VEGP Unit 3 safety-related displays listed in Attachment A can be retrieved in the MCR.

Reference 1 is available for NRC inspection as part of the Unit 3 ITAAC 2.3.10.12 Completion Package (Reference 2).

## **ITAAC Finding Review**

In accordance with plant procedures for ITAAC completion, Southern Nuclear Operating Company (SNC) performed a review of findings pertaining to the subject ITAAC and associated corrective actions. This review found there are no relevant ITAAC findings associated with this ITAAC. The ITAAC completion review is documented in the ITAAC Completion Package for ITAAC 2.3.10.12 (Reference 2) and is available for NRC review.

## **ITAAC Completion Statement**

Based on the above information, SNC hereby notifies the NRC that ITAAC 2.3.10.12 was performed for VEGP Unit 3 and that the prescribed acceptance criteria were met.

Systems, structures, and components verified as part of this ITAAC are being maintained in their as-designed, ITAAC compliant condition in accordance with approved plant programs and procedures.

**References (available for NRC inspection)**

1. SV3-WLS-ITR-800879 Revision 0, Unit 3: WLS Safety Related Displays in MCR
2. 2.3.10.12-U3-CP-Rev0, ITAAC Completion Package

**Attachment A**

Excerpted from Combined License Appendix C Table 2.3.10-1

<b>Table 2.3.10-1</b>		
<b>Equipment Name</b>	<b>Tag No.</b>	<b>Safety-Related Display</b>
WLS Auxiliary Building Radiologically Controlled Area (RCA) Floodup Level Sensor	WLS-400A	Yes
WLS Auxiliary Building RCA Floodup Level Sensor	WLS-400B	Yes