



Entergy Operations, Inc.
P.O. Box 756
Port Gibson, Mississippi 39150

Robert Franssen
Site Vice President

10CFR50.59

GNRO-2021/00011

April 19, 2021

ATTN: Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

SUBJECT: Revision of Original Report of 10CFR50.59 and Commitments Change Evaluations – July 1, 2018 through May 21, 2020
Grand Gulf Nuclear Station Unit 1
Docket Number 50-416
License Number NPF-29

REFERENCE: 1) Report of 10CFR50.59 and Commitment Change Evaluations – July 1, 2018 through May 21, 2020 (GNRO-2020/00025)

Dear Sir or Madam:

Pursuant to 10CFR50.59(d)(2) Entergy Operations, Inc. (Entergy) hereby submits a revision of the summary of the approved 10CFR50.59 Evaluations and the Commitment Change Evaluations for the period of July 1, 2018 through May 21, 2020.

Reference 1 is the original submittal of the summary of the approved 10CFR50.59 evaluations and the Commitment Change Evaluations for the period of July 1, 2018 through May 21, 2020. An error was later discovered in the 10CFR50.59 evaluations that were reported as approved, which required this update to the summary.

Attachment 1 contains the 10 CFR 50.59 Evaluation Summary Report and Attachment 2 contains the Commitment Change Evaluation Summary Report.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert Franssen".

Robert Franssen
RF/rws

GNRO-2021/00011

Attachment: 1. 10 CFR 50.59 Evaluation Summary Report
2. Commitment Change Evaluation Summary Report

cc: NRC Region IV - Regional Administrator
NRC Senior Resident Inspector, Grand Gulf Nuclear Station
State Health Officer, Mississippi Department of Health
NRC Project Manager

Attachment 1
10 CFR 50.59 Evaluation Summary Report

Evaluation Number	Summary	Initiating Document
2018-003-R00	CYCLE 22 FUEL RELOAD/COLR Rev 1 (EC 78267)	EC 78267 LBDCR 2018-066
2019-001-00	Installation of In-Line Feedwater Debris Strainers	EC 79003 LBDCR 2019-042
2019-002-00	EC 7278 - Turbine Control Upgrade	EC 72780 LBDCR 2018-076
2019-003-00	EC 81050 - Continuous backfill for RCIC Steam Header LDS	EC 81050
2019-004-00	Condensate Pump and Condensate Booster Pump Low Flow Trip SPV Elimination / EC 82394	EC 82394 LBDCR 2020-032
2019-005-00	Reactor Feed Pump Turbine Low Suction Flow Trip Hardening	EC 81856 LBDCR 2020-038
2019-006-00	Circulating Water Pump Motor Digital Relay Upgrade	EC 82408
2020-001-00	Setpoint Increase for Refuel Platform Hoist Jam for the Auxiliary Hoists	EC 84077 LBDCR 2020-17
2020-002-00	CYCLE 23 FUEL RELOAD/COLR	EC 85716

Attachment 2
Commitment Change Evaluation Summary Report

Commitment Number	Original Commitment	Justification for Change
36142	Grand Gulf Nuclear Station, Unit 1 (GGNS) will follow the generic schedule provided in the industry open phase condition (OPC) initiative. Full implementation will be achieved by 12/31/2017.	<p>In the Rev 2 letter, NEI states a revised implementation date of 12/31/2019 with a minimum of 24 months for completion of the associated monitoring period. Additionally, plants that have not accumulated 24 months of monitoring by December 31, 2019 may extend the monitoring period into 2020.</p> <p>GGNS is updating the commitment in to make use of the extended monitoring period to complete the necessary data collection and implementation of adjustments, tuning and additional design changes to the open phase detection system.</p>