


UFSAR Revision 30.0

| | | |
|----------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|
|  <p style="font-size: small; margin: 0;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revised: 27.0 Table: 14.3.1-1 Page: 1 of 3 |
|----------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|

Plant Operating Range Analyzed by the Best-Estimate Large Break LOCA Analysis for D. C. Cook Unit 1

| | Parameter | Analyzed Value or Range |
|------------|--------------------------------------------------------------------|----------------------------------------------------------------------------------------|
| 1.0 | Plant Physical Description | |
| a) | Dimensions | Nominal |
| b) | Pressurizer location | On an intact loop ¹ |
| c) | Hot assembly location | Anywhere in core ² |
| d) | Hot assembly type ³ | 15x15 Upgrade Fuel with ZIRLO® cladding or Optimized ZIRLO™ cladding, non-IFBA or IFBA |
| e) | Steam generator tube plugging level | ≤ 10% |
| f) | Fuel assembly type ³ | 15x15 Upgrade Fuel with ZIRLO® cladding or Optimized ZIRLO™ cladding, non-IFBA or IFBA |
| 2.0 | Plant Initial Operating Conditions | |
| 2.1 | Reactor Power | |
| a) | Maximum Core power | 3315 MWt |
| b) | Peak heat flux hot channel factor (F _Q) ^{3,4} | ≤ 2.15 |


¹ Analyzing the pressurizer as being located on an intact loop is limiting per Westinghouse methodology.

² 44 peripheral locations will not physically be lead power assembly.

³ In the Westinghouse Reload Safety Analysis Checklist (RSAC) process, this parameter is identified as a key safety analysis parameter that could be impacted by a fuel reload.

⁴ Parameter values affected by evaluation described in Section 14.3.1.6.2

UFSAR Revision 30.0


| | | |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revised: 27.0 Table: 14.3.1-1 Page: 2 of 3 |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|

Plant Operating Range Analyzed by the Best-Estimate Large Break LOCA Analysis for D. C. Cook Unit 1

| | Parameter | Analyzed Value or Range |
|------------|---------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------|
| c) | Peak hot rod enthalpy rise hot channel factor ($F_{\Delta H}$) ^{3,4} | ≤ 1.55 |
| d) | Hot assembly radial peaking factor (P_{HA}) ^{3,4} | $\leq 1.55/1.04$ |
| e) | Hot assembly heat flux hot channel factor (F_{QHA}) ⁴ | $\leq 2.15/1.04$ |
| f) | Axial power distribution (P_{BOT} , P_{MID}) ³ | Figure 14.3.1-2 |
| g) | Low power region relative power (P_{LOW}) ³ | $0.30 \leq P_{LOW} \leq 0.70$ |
| h) | Hot assembly burnup | $\leq 75,000$ MWD/MTU, lead rod ^{2,5} |
| i) | MTC | ≤ 0 at hot full power (HFP) |
| j) | Typical cycle length | 18 months |
| k) | Minimum core average burnup ³ | $\geq 10,000$ MWD/MTU |
| l) | Maximum steady state depletion, F_Q ^{3,4} | 1.90 |
| 2.2 | Fluid Conditions | |
| a) | T_{AVG} ⁴ | $553.7 - 4.1^\circ\text{F} \leq T_{AVG} \leq 575.4 + 5.1^\circ\text{F}$ |
| b) | Pressurizer pressure ⁴ | $2100 - 67$ psia $\leq P_{RCS} \leq 2100 + 67$ psia; $2250 - 67$ psia $\leq P_{RCS} \leq 2250 + 67$ psia |
| c) | Minimum thermal design flow | 88,500 gpm/loop |

⁵ The fuel temperature and rod internal pressure data is only provided up to 62,000 MWD/MTU. In addition, the hot assembly/ hot rod will not have a burnup this high in ASTRUM analyses.


UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revised: 27.0 Table: 14.3.1-1 Page: 3 of 3 |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|

Plant Operating Range Analyzed by the Best-Estimate Large Break LOCA Analysis for D. C. Cook Unit 1

| | Parameter | Analyzed Value or Range |
|------------|----------------------------------------------------|----------------------------------------------------------------------------------------|
| d) | Upper head design | T_{HOT} |
| e) | Pressurizer level (at hot full power) ⁴ | 56.1% of span (High T_{AVG}) 43.4% of span (Low T_{AVG}) |
| f) | Accumulator temperature ⁴ | $60^{\circ}F \leq T_{ACC} \leq 120^{\circ}F$ |
| g) | Accumulator pressure | $599.7 \text{ psia} \leq P_{ACC} \leq 672.7 \text{ psia}$ |
| h) | Accumulator liquid volume | $921 \text{ ft}^3 \leq V_{ACC} \leq 971 \text{ ft}^3$ |
| i) | Minimum accumulator boron | 2228 ppm |
| 3.0 | Accident Boundary Conditions | |
| a) | Minimum safety injection flow ⁴ | Table 14.3.1-4a and 14.3.1-4b |
| b) | Safety injection temperature ⁴ | $70^{\circ}F \leq SI \text{ Temp} \leq 105^{\circ}F$ |
| c) | Safety injection delay ⁴ | 27 seconds (with offsite power) 54 seconds (with LOOP) |
| d) | Containment modeling ⁴ | Figures 14.3.1-3 thru 14.3.1-9 and raw data in Tables 14.3.1-2, 14.3.1-3, and 14.3.1-7 |
| e) | Initial containment pressure | See Table 14.3.1-2 |
| f) | Containment spray initiation delay ⁴ | See Table 14.3.1-2 |
| g) | Deck Fan initiation delay ⁴ | See Table 14.3.1-2 |
| h) | Single failure | Loss of one ECCS train |

UFSAR Revision 30.0

| | | |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|--------------------------------------------------|
|  <small>An AEP Company</small> | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revised: 27.0 Table: 14.3.1-2 Page: 1 of 1 |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|--------------------------------------------------|

Large-Break Containment Data (Ice Condenser Containment)

| | |
|------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------|
| Net Free Volume Distribution Between Upper (UC), Lower (LC), Ice Condenser (IC) and Dead-Ended (DE) Compartments | UC: 729,969 ft ³ LC: 295,258 ft ³ IC: 122,350 ft ³ DE: 60,209 ft ³ |
| Initial Condition Containment Pressure | 14.7 psia |
| Maximum Temperature for the Upper (UC), Lower (LC) and Dead-Ended (DE) Compartments | UC: 100°F LC: 120°F DE: 120°F |
| Temperature Outside Containment | -22°F |
| Initial Spray Temperature at 14.7 psia | 45°F ¹ |
| Maximum Containment Spray Flow Rate ² | 3700 gpm / pump |
| Number of Spray Pumps Operating | 2 |
| Post-Accident Initiation of Spray System ² | 44 sec |
| Post-Accident Initiation of Deck Fans ² | 108 sec |
| Deck Fan Flow Rate | 48,000 cfm / fan |
| Assumed Spray Efficiency of Water from Ice Condenser Drains | 100% |

¹ Due to errors identified with the LOTIC2 containment backpressure calculation, an evaluation was performed assuming a revised initial CTS temperature. See Section 14.3 .1.6.1 for more information.

² Parameter values affected by the evaluation described in Section 14.3.1.6.2.


UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 23</p> <p>Table: 14.3.1-3</p> <p>Page: 1 of 1</p> |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------|

LARGE BREAK CONTAINMENT – HEAT SINKS DATA (ICE CONDENSER CONTAINMENT)

| Wall | Compartment | Area (ft ²) | Thickness (ft) | Material |
|------|-------------|-------------------------|----------------|------------------|
| 1 | UC | 24036. | 0.0329 / 3.2 | steel / concrete |
| 2 | UC | 5993. | 0.0329 / 3.7 | steel / concrete |
| 3 | UC | 2593. | 2.1 | concrete |
| 4 | UC | 17742. | 4.2 | concrete |
| 5 | UC | 4973. | 0.0392 / 13.7 | steel / concrete |
| 6 | UC | 21305. | 0.0091 | steel |
| 7 | UC | 18067. | 0.0196 | steel |
| 8 | UC | 6035. | 0.1070 | steel |
| 9 | UC | 5079. | 0.2300 | steel |
| 10 | UC | 23429. | 0.1284 | steel |
| 11 | LC | 2682. | 0.0218 / 5.3 | steel / concrete |
| 12 | LC | 447. | 5.3 | concrete |
| 13 | LC | 51219. | 6.8 | concrete |
| 14 | LC | 15033. | 0.0200 / 5.40 | steel / concrete |
| 15 | LC | 42353. | 0.0081 | steel |
| 16 | LC | 16886. | 0.0166 | steel |
| 17 | LC | 13778. | 0.0644 | steel |
| 18 | LC | 61214. | 0.1076 | steel |
| 19 | LC | 4529. | 14.04 | concrete |
| 20 | LC | 3439. | 0.1561 | steel |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------|
|  <p style="font-size: small; margin-top: 5px;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revised: 27.0 Table: 14.3.1-4A Page: 1 of 1 |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------|

Minimum Safety Injection Pump (HHSI) and Residual Heat Removal Pump (RHR) Combined Injection Flow

| Pressure (psia) | Original HHSI and RHR Total Injected Flow (gpm) ^{1,2} | Adjusted HHSI and RHR Total Injected Flow (gpm) ^{2,3} |
|-----------------|----------------------------------------------------------------|----------------------------------------------------------------|
| 14.7 | 3219.7 | 3044.9 |
| 34.7 | 2637.8 | 2455.0 |
| 54.7 | 2009.5 | 1802.4 |
| 74.7 | 1520.6 | 1390.3 |
| 94.7 | 1188.2 | 1045.0 |
| 114.7 | 788.0 | 629.3 |
| 134.7 | 267.3 | 259.1 |
| 154.7 | 262.9 | 255.5 |
| 174.7 | 258.5 | 251.9 |
| 194.7 | 254.1 | 248.3 |
| 214.7 | 249.6 | 244.6 |
| 234.7 | 245.0 | 240.8 |
| 254.7 | 240.4 | 237.1 |
| 274.7 | 235.7 | 233.3 |
| 294.7 | 231.0 | 229.4 |
| 314.7 | 226.0 | 225.5 |

¹ The original HHSI and RHR flow corresponds to the analysis results presented in the tables and figures, except for Table 14.3.1-5.

² HHSI and RHR total injected flow values affected by the evaluation described in Section 14.3.1.6.2. See Table 14.3.1-4C.

³ The adjusted HHSI and RHR flow corresponds to the PCT results presented in the Adjusted HHSI and RHR Flow column in Table 14.3.1-5.


UFSAR Revision 30.0

| | | |
|----------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 23 Table: 14.3.1-4B Page: 1 of 1</p> |
|----------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|

MINIMUM CENTRIFUGAL CHARGING PUMP (CCP) INJECTION FLOW

| Pressure (psia) | Total CCP Injected Flow (gpm) |
|--------------------|----------------------------------|
| 14.7 | 283.2 |
| 114.7 | 253.5 |
| 214.7 | 247.3 |
| 314.7 | 247.0 |
| 414.7 | 243.7 |
| 514.7 | 233.4 |
| 614.7 | 214.9 |
| 714.7 | 195.9 |
| 814.7 | 176.3 |
| 914.7 | 155.9 |
| 1014.7 | 134.7 |
| 1114.7 | 112.4 |
| 1214.7 | 88.9 |
| 1314.7 | 63.8 |
| 1414.7 | 36.3 |
| 1514.7 | 9.1 |
| 1614.7 | 0.0 |
| 1714.7 | 0.0 |

UFSAR Revision 30.0

| | | |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|---------------------------------------------------|
|  <small>An AEP Company</small> | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revised: 27.0 Table: 14.3.1-4C Page: 1 of 1 |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|---------------------------------------------------|

Minimum Safety Injection Pump (HHSI) and Residual Heat Removal Pump (RHR) Combined Injection Flow for the Return to NOP/NOT Evaluation

| Pressure (psia) | HHSI and RHR Total Injected Flow at NOP/NOT Conditions (gpm) |
|-----------------|-----------------------------------------------------------------|
| 15.7 | 3099 |
| 19.7 | 2997 |
| 24.7 | 2853 |
| 29.7 | 2707 |
| 34.7 | 2561 |
| 39.7 | 2412 |
| 54.7 | 1928 |
| 74.7 | 1465 |
| 94.7 | 1140 |
| 114.7 | 745 |
| 134.7 | 275 |
| 154.7 | 271 |
| 174.7 | 267 |
| 194.7 | 262 |
| 214.7 | 258 |
| 234.7 | 254 |
| 254.7 | 249 |
| 274.7 | 245 |
| 294.7 | 240 |
| 314.7 | 236 |
| 414.7 | 212 |
| 514.7 | 184 |
| 614.7 | 149 |
| 714.7 | 108 |
| 814.7 | 58 |
| 914.7 | 0 |


UFSAR Revision 30.0

| | | |
|----------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER An AEP Company</p> | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revision: 23 Table: 14.3.1-5 Page: 1 of 1 |
|----------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-------------------------------------------------|

D. C. COOK UNIT 1 BEST-ESTIMATE LARGE BREAK LOCA RESULTS

| Parameter | ASTRUM Result for Original HHSI and RHR Injection Flow Value | ASTRUM Result for Adjusted HHSI and RHR Injection Flow Value | 10 CFR 50.46 Acceptance Criteria |
|-----------------------------------------------------------------------------|---------------------------------------------------------------------------------|---------------------------------------------------------------------------------|-------------------------------------------------|
| 95 th Percentile PCT at the 95- Percent Confidence Level (°F) | 2106 | 2128 | ≤2200 |
| 95 th Percentile LMO at the 95- Percent Confidence Level (%) | 10.0 | 11.1 | ≤17 |
| 95 th Percentile CWO at the 95- Percent Confidence Level (%) | 0.35 | 0.40 | ≤1 |

UFSAR Revision 30.0


| | | |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revised: 29.0 Table: 14.3.1-6 Page: 1 of 1 |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|

Peak Cladding Temperature Including All Penalties and Benefits, Best-Estimate Large Break LOCA (BE LOCA) for D. C. Cook Unit 1

| | | |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------|------------------------------------------------------------------------------------------------------|
| PCT for Analysis-of Record (AOR) | 2128°F | |
| PCT Assessments Allocated to AOR | | |
| <ul style="list-style-type: none"> • Design Input Changes with Respect to Plant Operations • Evaluation of Pellet Thermal Conductivity Degradation and Peaking Factor Burndown • Revised Heat Transfer Multiplier Distribution • HOTSPOT Burst Strain Error • Decay Group Uncertainty Factors Errors • Upflow Conversion | | NOP/NOT ¹ -489°F +404°F -91°F +85°F -29°F +14°F |
| <p>BE LBLOCA PCT for Comparison to 10CFR 50.46 Requirements</p> | <p>2022°F</p> | |

¹ NOP/NOT refers to Unit 1 Return to Normal Operating Pressure and Temperature implemented by EC-52930

UFSAR Revision 30.0


| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p style="text-align: center;">INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revised: 27.0 Table: 14.3.1-7 Page: 1 of 1</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|

Nitrogen Mass and Energy Release Rates¹

| Time (s) | Flow Rate (lb _m / s) |
|----------|---------------------------------|
| 0. | 0. |
| 50. | 0. |
| 50.01 | 236. |
| 70.01 | 236. |
| 70.02 | 0. |
| 1000. | 0. |

¹ Parameter values affected by the evaluation described in Section 14.3.1.6.2. See Table 14.3.1-7A.


UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revised: 27.0 Table:14.3.1-7A Page: 1 of 1</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|

Nitrogen Mass and Energy Release Rates for the Return to NOP/NOT Evaluation

| Time (s) | Flow Rate (lb_m / s) |
|-----------------|---------------------------------------|
| 0 | 0 |
| 44.3 | 0 |
| 44.31 | 254.6 |
| 64.31 | 254.6 |
| 64.32 | 0 |
| 1000.0 | 0 |

UFSAR Revision 30.0


| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p style="text-align: center;">INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revised: 27.0 Table: 14.3.1-8 Page: 1 of 1</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|

Sequence of Events for the Limiting Case¹

| Event | Time (sec) |
|------------------------------|------------|
| Start of Transient | 0.0 |
| Safety Injection Signal | 4.6 |
| Accumulator Injection Begins | 16.0 |
| End of Blowdown | 25.0 |
| Bottom of Core Recovery | 42.5 |
| Accumulator Empty | 49.3 |
| Safety Injection Begins | 58.6 |
| PCT Occurs | 247.0 |
| End of Transient | 500.0 |

¹ The evaluation for the return to NOP/NOT conditions and fuel TCD calculated a new limiting case. See Section 14.3.1.6.2 and Table 14.3.1-8A for more information.


UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revised: 27.0 Table:14.3.1-8A Page: 1 of 1</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|

Sequence of Events for the Limiting Return to NOP/NOT Evaluation Case


| Event | Time (sec) |
|------------------------------|------------|
| Start of Transient | 0.0 |
| Safety Injection Signal | 5.0 |
| Accumulator Injection Begins | 12.0 |
| End of Blowdown | 24.6 |
| Safety Injection Begins | 33.0 |
| Bottom of Core Recovery | 35.2 |
| Accumulator Empty | 46.2 |
| PCT Occurs | 272.0 |
| End of Transient | 500.0 |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------|
|  <p style="font-size: small; margin: 0;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revision: 29.0 Table: 14.3.2-1 Sheet: 1 of 2 |
|-----------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------|

| Plant Input Parameters for Small Break Loss-of-Coolant Accident | |
|------------------------------------------------------------------------|----------------------|
| Core Rated Thermal Power-100% (MWt) | 3304 |
| Peak Linear Power, kW/ft | 15.171 |
| Fuel Type | 15x15 Upgrade Fuel |
| Total Core Peaking Factor, F_Q | 2.32 |
| Hot Channel Enthalpy Rise Factor, $F_{\Delta H}$ | 1.55 |
| Hot Assembly Average Power Factor, P_{HA} | 1.38 ⁽⁴⁾ |
| Thermal Design Flow, gpm/loop | 83,200 |
| Nominal Vessel Average Temperature, °F | 577.4 ⁽¹⁾ |
| Nominal Pressurizer Pressure, psia | 2250 ⁽²⁾ |
| Pressurizer Pressure Uncertainty (psia) | ±67 |
| Minimum Auxiliary Feedwater Flow Rate, lbm/s per SG | 14.68 |
| Steam Generator Tube Plugging (Maximum), % | 10 |
| Initial Accumulator Water Volume, ft ³ | 946 |
| Accumulator Tank Volume, ft ³ /tank | 1350 |
| Accumulator Water Temperature, °F | 130 |
| Minimum Accumulator Cover Gas Pressure (minus uncertainties), psia | 600 |
| Refueling Water Storage Tank Temperature, °F | 105 |
| Nominal Steam Pressure, psia | 848.32 |

UFSAR Revision 30.0

| | | |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|
|  <small>An AEP Company</small> | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revision: 29.0 Table: 14.3.2-1 Sheet: 2 of 2 |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|

| Plant Input Parameters for Small Break Loss-of-Coolant Accident | |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------|
| SI Flow Delay Time, seconds | 54 |
| HHSI Cross-Tie Valve Position | Open (Injection & Cold Leg Recirculation) ⁽³⁾ |
| RHR Cross-Tie Valve Position | Open (Injection) Closed (Cold Leg Recirculation) |
| <p>(1) Analysis supports operation over the range of nominal full-power Tavg values of 553.7°F – 575.4°F.</p> <p>(2) Analysis supports operation at nominal initial pressurizer pressure (without uncertainties) of 2100 psia and 2250 psia.</p> <p>(3) Conservatively modeled HHSI cross-tie valves closed in injection phase.</p> <p>(4) Parameter value affected by the evaluation described in Section 14.3.2.4.1.2. See Table 14.3.2-1a.</p> | |

UFSAR Revision 30.0




**INDIANA MICHIGAN POWER
D. C. COOK NUCLEAR PLANT
UPDATED FINAL SAFETY ANALYSIS REPORT**

Revised: 29
Table: 14.3.2-1a
Page: 1 of 1

| Burnup-Dependent Hot Assembly Average Power Factor (P_{HA}) For Small Break Loss-of-Coolant Accident – Upflow Configuration | |
|------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------|
| Assembly Burnup (MWD/MTU) | P_{HA} Limit without Uncertainty |
| 0 | 1.38 |
| 28,000 | 1.38 |
| 30,000 | 1.250 |
| 60,000 | 1.139 |
| 62,000 | 1.139 |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER</p> <p>D. C. COOK NUCLEAR PLANT</p> <p>UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 29.0</p> <p>Table: 14.3.2-2</p> <p>Page: 1 of 1</p> |
|-----------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------|


Time Sequence of Events for Small Break Loss-of-Coolant Accident⁽⁶⁾

| Event Time (sec) | 1.5-inch | 2-inch | 2.5-inch | 2.75-inch | 3.0-inch | 3.25-inch | 3.5-inch | 3.75-inch | 4.0-inch | 6.0-inch | 8.75-inch |
|--------------------------------------|----------|--------|----------|-----------|----------|-----------|----------|-----------|----------|----------|--------------------|
| Break Initiation | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Reactor Trip Signal | 89.8 | 45.9 | 27.9 | 22.7 | 19.0 | 16.2 | 14.0 | 12.3 | 10.9 | 6.0 | 4.5 |
| S-Signal | 112.8 | 60.9 | 38.2 | 31.6 | 26.8 | 23.2 | 20.3 | 17.9 | 15.7 | 8.4 | 6.7 |
| SI Flow Delivered ⁽¹⁾ | 166.8 | 114.9 | 92.2 | 85.6 | 80.8 | 77.2 | 74.3 | 71.9 | 69.7 | 62.4 | 60.7 |
| Loop Seal Clearing ⁽²⁾ | 2492 | 1341 | 857 | 628 | 516 | 445 | 386 | 390 | 302 | 146 | 30 |
| Core Uncovery ⁽⁴⁾ | N/A | 1897 | 1027 | 1017 | 963 | 780 | 664 | 630 | 602 | 342 | N/A |
| Accumulator Injection | N/A | N/A | 3065 | 2129 | 1707 | 1264 | 1031 | 940 | 823 | 345 | 168 ⁽³⁾ |
| RWST Volume Delivered ⁽⁵⁾ | 2165.6 | 2157.6 | 2145.4 | 2137.8 | 2130.0 | 2120.9 | 2114.4 | 2110.2 | 2106.4 | 2042.8 | 1590.7 |
| PCT Time (BOL) | N/A | 2284.4 | 2684.0 | 2140.6 | 2000.5 | 1483.4 | 1249.3 | 1129.8 | 986.2 | 404.1 | N/A |
| Core Recovery ⁽⁴⁾ | N/A | 6663 | 4032 | 4081 | 3977 | 3840 | 3973 | 4110 | 3404 | 423 | N/A |

Notes:

- (1) SI is assumed to begin 54.0 seconds (SI delay time) after the S-Signal.
- (2) Loop seal clearing is assumed to occur when the steam flow through the broken loop, loop seal is sustained above 1 lbm/s.
- (3) For 8.75-inch break, accumulator injection begins for Loops 2-4 only; Loop 1 (broken loop) accumulator line is the location of the break and assumed to spill to containment.
- (4) The latest point of sustained core uncovery/recovery is reported.
- (5) The analysis assumes minimum usable RWST volume (280,000 gal) delivered via ECCS injection and containment spray before the low level RWST water level signal for switchover to cold leg recirculation is reached.
- (6) See Table 14.3.2-2a for additional evaluation results for Upflow configuration.

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revised: 29 Table: 14.3.2-2a Page: 1 of 1</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------|


Time Sequence of Events for Small Break Loss-of-Coolant Accident – Upflow Configuration

| Event Description | Time (s) | | | |
|--------------------------------------|----------|----------|-----------|-----------|
| | 2.5 inch | 3.0-inch | 3.25 inch | 3.6- inch |
| Break Initiation | 0.0 | 0.0 | 0.0 | 0.0 |
| Reactor Trip Signal | 22.9 | 19.1 | 16.3 | 14.0 |
| S-Signal | 31.6 | 27.0 | 23.3 | 20.3 |
| SI Flow Delivered ⁽¹⁾ | 85.6 | 81.0 | 77.3 | 74.3 |
| Loop Seal Clearing ⁽²⁾ | 625 | 535 | 467 | 388 |
| Core Uncovery ⁽⁴⁾ | 1023 | 646 | 586 | 638 |
| Accumulator Injection ⁽³⁾ | 2032 | 1475 | 1216 | 1016 |
| PCT Time (BOL) | 2051.7 | 1772.3 | 1418.3 | 1223.1 |
| RWST Volume Delivered | 2136.9 | 2126.3 | 2119.5 | 2113.7 |
| Core Recovery ⁽⁴⁾ | 4370 | 4003 | 3786 | 3914 |

Notes:

- (1) SI is assumed to begin 54.0 seconds (SI delay time) after the S-Signal
- (2) Loop seal clearing is assumed to occur when the steam flow through the broken loop, loop seal is sustained above 1 lbm/s
- (3) Applies to all 4 loops
- (4) The latest point of sustained core uncovery/recovery is reported.

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|------------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 29.0 Table: 14.3.2-3 Page: 1 of 1</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|------------------------------------------------------------|


Small Break Loss-of-Coolant Accident Calculations⁽²⁾

| Break Size (in) | 2-inch | 2.5 inch | 2.5 inch | 3.0-inch | 3.25 inch | 3.5 inch | 3.5 inch | 4- inch | 4- inch |
|-----------------------------------------------|--------|----------|----------|----------|-----------|----------|----------|---------|---------|
| PCT (°F) | 968.4 | 1433.4 | 1452.5 | 1584.0 | 1725.0 | 1705.3 | 1517.9 | 1411.2 | 670.6 |
| PCT Time (s) | 2284.4 | 2684.0 | 2140.6 | 2000.5 | 1483.4 | 1249.3 | 1129.8 | 986.2 | 404.1 |
| PCT Elevation (ft) | 11.0 | 11.50 | 11.50 | 11.75 | 11.75 | 11.75 | 11.50 | 11.25 | 11.00 |
| Max. Local ZrO2 (%) | 0.03 | 0.70 | 0.54 | 1.26 | 2.08 | 1.72 | 0.56 | 0.26 | 0.00 |
| Max. Local ZrO2 Elev. (ft) | 11.0 | 11.50 | 11.50 | 11.75 | 11.75 | 11.50 | 11.50 | 11.25 | 11.00 |
| Hot Rod Axial Average ZrO2 (%) ⁽¹⁾ | 0.00 | 0.09 | 0.07 | 0.17 | 0.30 | 0.26 | 0.08 | 0.04 | 0.00 |

Notes:

- (1) The hot rod axial average ZrO2 conservatively represents the core wide average oxidation, since the core wide average ZrO2 thickness will always be less than the corresponding hot rod axial average ZrO2 thickness.
- (2) See Table 14.3.2-3a for additional calculation results for Upflow configuration

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revised: 29 Table: 14.3.2-3a Page: Page 1 of 1</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------|

Beginning of Life Small Break Loss-of-Coolant Accident Calculations – Upflow Configuration

| Item Description | 2.75-inch | 3.0-inch | 3.25-inch | 3.5-inch |
|--------------------------------------------|-----------|----------|-----------|----------|
| PCT (°F) | 1522.9 | 1784.2 | 1771.7 | 1734.8 |
| PCT Time (s) | 2051.7 | 1772.3 | 1418.3 | 1223.1 |
| PCT Elevation (ft) | 11.5 | 11.75 | 11.75 | 11.75 |
| Max Local ZrO ₂ (%) | 1.01 | 2.97 | 2.53 | 1.89 |
| Max Local ZrO ₂ Elev. (ft) | 11.75 | 11.75 | 11.75 | 11.75 |
| Hot Rod Axial Average ZrO ₂ (%) | 0.14 | 0.40 | 0.35 | 0.28 |

Unit 1

UFSAR Revision 30.0



INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT

Revised: 29
Table: 14.3.2-3b
Page: Page 1 of 1


Upflow Configuration Limiting 3.0-Inch Small Break Loss-of-Coolant Accident Burnup Results

| Burnup (MWD/MTU) | 8000 | 8500 ⁽¹⁾ | 9000 ⁽²⁾ | 10000 | 15000 | 50000 ⁽³⁾ | 62000 ⁽⁴⁾ |
|--------------------------------------------------|--------|---------------------|---------------------|--------|--------|----------------------|----------------------|
| PCT (°F) | 1761.1 | 1831.4 | 1796.2 | 1794.6 | 1801.7 | 1776.3 | 1573.0 |
| Max. Local ZrO ₂ (%) | 2.33 | 6.13 | 6.19 | 6.16 | 5.65 | 2.96 | 1.14 |
| Hot Rod Axial Average ZrO ₂ (%) | 0.28 | 0.34 | 0.37 | 0.36 | 0.31 | 0.10 | 0.03 |
| Total Maximum Local Oxidation ⁽⁵⁾ (%) | 4.19 | 8.11 | 8.28 | 8.49 | 9.14 | 14.6 | 15 |

Notes:


- (1) The limiting PCT occurs at the incipient burst point burnup of 8500 MWD/MTU.
- (2) The limiting local transient oxidation and hot rod average oxidation occur at 9000 MWD/MTU.
- (3) P_{HA} burndown would be available at the 50,000 MWD/MTU burnup; however, it is not credited.
- (4) The 62,000 MWD/MTU case credits P_{HA} burndown to meet the maximum local oxidation limit of 17%.
- (5) Includes summation of transient (max. local ZrO₂) and pre-transient oxidation.

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------|
|  <p style="font-size: small; margin-top: 5px;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 25.0 Table: 14.3.2-4 Sheet: 1 of 2</p> |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------|

| Safety Injection Flows Used in the SBLOCA Analysis - Injection Phase (1 CHG pump, 1 HHSI pump, 1 RHR pump - faulted loop injects to RCS pressure – 1.5-inch through 6-inch breaks) | | | | |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------|------------------------|--------|--------|
| RCS Pressure (psia) | Broken Loop (lbm/sec) | Intact Loops (lbm/sec) | | |
| | Loop 1 | Loop 2 | Loop 3 | Loop 4 |
| 14.7 | 188.63 | 158.38 | 175.00 | 159.93 |
| 114.7 | 127.20 | 102.43 | 117.32 | 103.38 |
| 214.7 | 38.89 | 12.50 | 34.37 | 12.50 |
| 314.7 | 37.49 | 12.21 | 33.10 | 12.21 |
| 414.7 | 35.93 | 11.90 | 31.73 | 11.90 |
| 514.7 | 34.30 | 11.57 | 30.26 | 11.57 |
| 614.7 | 32.56 | 11.23 | 28.64 | 11.23 |
| 714.7 | 30.73 | 10.88 | 26.98 | 10.88 |
| 814.7 | 28.80 | 10.54 | 25.22 | 10.54 |
| 914.7 | 26.74 | 10.18 | 23.35 | 10.18 |
| 1014.7 | 24.34 | 9.82 | 21.14 | 9.82 |
| 1114.7 | 21.49 | 9.46 | 18.54 | 9.46 |
| 1214.7 | 18.00 | 9.10 | 15.32 | 9.10 |
| 1314.7 | 13.03 | 8.70 | 10.73 | 8.70 |
| 1414.7 | 10.36 | 8.29 | 8.29 | 8.29 |
| 1514.7 | 9.82 | 7.86 | 7.86 | 7.86 |
| 1614.7 | 9.27 | 7.42 | 7.42 | 7.42 |
| 1714.7 | 8.72 | 6.98 | 6.98 | 6.98 |
| 1814.7 | 8.08 | 6.47 | 6.47 | 6.47 |


UFSAR Revision 30.0

| | | |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|
|  <small>An AEP Company</small> | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revision: 25.0 Table: 14.3.2-4 Sheet: 2 of 2 |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|

| |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Safety Injection Flows Used in the SBLOCA Analysis - Injection Phase (1 CHG pump, 1 HHSI pump, 1 RHR pump - faulted loop injects to RCS pressure – 1.5-inch through 6-inch breaks) |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

| RCS Pressure (psia) | Broken Loop (lbm/sec) | Intact Loops (lbm/sec) | | | |
|------------------------|--------------------------|------------------------|--------|--------|--|
| | Loop 1 | Loop 2 | Loop 3 | Loop 4 | |
| 1914.7 | 7.41 | 5.93 | 5.93 | 5.93 | |
| 2014.7 | 6.72 | 5.38 | 5.38 | 5.38 | |
| 2114.7 | 5.94 | 4.76 | 4.76 | 4.76 | |
| 2214.7 | 5.02 | 4.01 | 4.01 | 4.01 | |
| 2314.7 | 0 | 0 | 0 | 0 | |


UFSAR Revision 30.0

| | | |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|
|  <small>An AEP Company</small> | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revision: 25.0 Table: 14.3.2-5 Sheet: 1 of 2 |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|

**Safety Injection Flows Used in the SBLOCA Analysis – Injection Phase
 (1 CHG pump, 1 HHSI pump, 1 RHR pump – faulted loop CHG flow injects
 to RCS pressure and faulted loop HHSI / RHR flow spills to containment
 (0 psia) – 8.75-inch break)**

| RCS Pressure (psia) | Broken Loop (lbm/sec) | | Intact Loops (lbm/sec) | | |
|------------------------|-----------------------|----------------------|------------------------|--------|--------|
| | Loop 1 CHG | Loop 1 RHR / HHSI | Loop 2 | Loop 3 | Loop 4 |
| 14.7 | 16.34 | 157.03 | 139.36 | 156.01 | 140.26 |
| 34.7 | 16.27 | 215.73 | 126.84 | 99.71 | 127.64 |
| 54.7 | 16.20 | 274.56 | 115.46 | 32.18 | 116.17 |
| 74.7 | 16.13 | 303.81 | 97.04 | 12.90 | 97.63 |
| 94.7 | 16.06 | 323.64 | 72.95 | 12.84 | 73.37 |
| 114.7 | 15.98 | 345.72 | 43.70 | 12.78 | 43.93 |
| 134.7 | 15.91 | 365.86 | 12.73 | 12.73 | 12.73 |
| 154.7 | 15.84 | 365.86 | 12.67 | 12.67 | 12.67 |
| 214.7 | 15.63 | 365.86 | 12.50 | 12.50 | 12.50 |
| 314.7 | 15.25 | 365.86 | 12.21 | 12.21 | 12.21 |
| 414.7 | 14.83 | 365.86 | 11.90 | 11.90 | 11.90 |
| 514.7 | 14.45 | 365.86 | 11.57 | 11.57 | 11.57 |
| 614.7 | 14.03 | 365.86 | 11.23 | 11.23 | 11.23 |
| 714.7 | 13.60 | 365.86 | 10.88 | 10.88 | 10.88 |
| 814.7 | 13.17 | 365.86 | 10.54 | 10.54 | 10.54 |
| 914.7 | 12.73 | 365.86 | 10.18 | 10.18 | 10.18 |
| 1014.7 | 12.29 | 365.86 | 9.82 | 9.82 | 9.82 |
| 1114.7 | 11.83 | 365.86 | 9.46 | 9.46 | 9.46 |
| 1214.7 | 11.38 | 365.86 | 9.10 | 9.10 | 9.10 |


UFSAR Revision 30.0

| | | |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|
|  <small>An AEP Company</small> | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revision: 25.0 Table: 14.3.2-5 Sheet: 2 of 2 |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|

**Safety Injection Flows Used in the SBLOCA Analysis – Injection Phase
 (1 CHG pump, 1 HHSI pump, 1 RHR pump – faulted loop CHG flow injects
 to RCS pressure and faulted loop HHSI / RHR flow spills to containment
 (0 psia) – 8.75-inch break)**


| RCS Pressure (psia) | Broken Loop (lbm/sec) | | Intact Loops (lbm/sec) | | |
|------------------------|-----------------------|----------------------|------------------------|--------|--------|
| | Loop 1 CHG | Loop 1 RHR / HHSI | Loop 2 | Loop 3 | Loop 4 |
| 1314.7 | 10.88 | 365.86 | 8.70 | 8.70 | 8.70 |
| 1414.7 | 10.36 | 365.86 | 8.29 | 8.29 | 8.29 |
| 1514.7 | 9.82 | 365.86 | 7.86 | 7.86 | 7.86 |
| 1614.7 | 9.27 | 365.86 | 7.42 | 7.42 | 7.42 |
| 1714.7 | 8.72 | 365.86 | 6.98 | 6.98 | 6.98 |
| 1814.7 | 8.08 | 365.86 | 6.47 | 6.47 | 6.47 |
| 1914.7 | 7.41 | 365.86 | 5.93 | 5.93 | 5.93 |
| 2014.7 | 6.72 | 365.86 | 5.38 | 5.38 | 5.38 |
| 2114.7 | 5.94 | 365.86 | 4.76 | 4.76 | 4.76 |
| 2214.7 | 5.02 | 365.86 | 4.01 | 4.01 | 4.01 |
| 2314.7 | 0 | 365.86 | 0 | 0 | 0 |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|
|  An AEP Company | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revision: 25.0 Table: 14.3.2-6 Sheet: 1 of 2 |
|-----------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|


| Safety Injection Flows Used in the SBLOCA Analysis - Recirculation Phase (1 CHG pump, 1 HHSI pump, 1 RHR pump - faulted loop injects to RCS pressure – RHR Spray active -1.5 - through 6 inch breaks) | | | | |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------|------------------------|--------|--------|
| RCS Pressure (psia) | Broken Loop (lbm/sec) | Intact Loops (lbm/sec) | | |
| | Loop 1 | Loop 2 | Loop 3 | Loop 4 |
| 14.7 | 36.1 | 32.1 | 31.3 | 32.3 |
| 34.7 | 35.9 | 31.9 | 31.1 | 32.1 |
| 54.7 | 35.7 | 31.7 | 30.9 | 31.9 |
| 74.7 | 35.5 | 31.5 | 30.7 | 31.7 |
| 94.7 | 35.3 | 31.3 | 30.5 | 31.5 |
| 114.7 | 35.0 | 31.1 | 30.3 | 31.3 |
| 134.7 | 34.8 | 30.9 | 30.1 | 31.1 |
| 154.7 | 34.6 | 30.7 | 29.9 | 30.9 |
| 174.7 | 34.3 | 30.5 | 29.7 | 30.6 |
| 194.7 | 34.1 | 30.3 | 29.5 | 30.4 |
| 214.7 | 33.9 | 30.1 | 29.3 | 30.2 |
| 234.7 | 33.6 | 29.9 | 29.1 | 30.0 |
| 254.7 | 33.4 | 29.6 | 28.9 | 29.8 |
| 274.7 | 33.2 | 29.4 | 28.7 | 29.6 |
| 294.7 | 32.9 | 29.2 | 28.4 | 29.3 |
| 314.7 | 32.7 | 29.0 | 28.2 | 29.1 |
| 414.7 | 31.5 | 27.9 | 27.2 | 28.0 |
| 514.7 | 30.2 | 26.7 | 26.0 | 26.8 |
| 614.7 | 28.8 | 25.5 | 24.9 | 25.6 |
| 714.7 | 27.4 | 24.2 | 23.6 | 24.3 |
| 814.7 | 26.0 | 22.9 | 22.3 | 23.0 |
| 914.7 | 24.5 | 21.5 | 21.0 | 21.6 |
| 1014.7 | 22.6 | 19.9 | 19.4 | 20.0 |

UFSAR Revision 30.0

| | | |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|
|  <small>An AEP Company</small> | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revision: 25.0 Table: 14.3.2-6 Sheet: 2 of 2 |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|

| Safety Injection Flows Used in the SBLOCA Analysis - Recirculation Phase (1 CHG pump, 1 HHSI pump, 1 RHR pump - faulted loop injects to RCS pressure – RHR Spray active -1.5 - through 6 inch breaks) | | | | |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------|-------------------------------|---------------|---------------|
| RCS Pressure (psia) | Broken Loop (lbm/sec) | Intact Loops (lbm/sec) | | |
| | Loop 1 | Loop 2 | Loop 3 | Loop 4 |
| 1114.7 | 20.7 | 18.1 | 17.7 | 18.1 |
| 1214.7 | 18.4 | 15.9 | 15.6 | 16.0 |
| 1314.7 | 15.3 | 13.0 | 12.8 | 13.1 |
| 1414.7 | 11.4 | 9.4 | 9.3 | 9.4 |
| 1514.7 | 9.2 | 7.4 | 7.4 | 7.4 |
| 1614.7 | 8.7 | 7.0 | 7.0 | 7.0 |
| 1714.7 | 8.1 | 6.6 | 6.6 | 6.6 |


UFSAR Revision 30.0

| | | |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|
|  <small>An AEP Company</small> | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revision: 25.0 Table: 14.3.2-7 Sheet: 1 of 2 |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|

Safety Injection Flows Used in the SBLOCA Analysis – Recirculation Phase
 (1 CHG pump, 1 HHSI pump, 1 RHR pump –
 faulted loop CHG flow injects to RCS pressure and faulted loop
 HHSI/RHR flow spills to containment (0 psia) – RHR Spray active – 8 5/8 inch break)

| RCS Pressure (psia) | Broken Loop (lbm/sec) | | Intact Loops (lbm/sec) | | |
|---------------------------|-----------------------|----------------------|------------------------|--------|--------|
| | Loop 1 – CHG | Loop 1 – RHR/HHSI | Loop 2 | Loop 3 | Loop 4 |
| 14.7 | 15.4 | 20.7 | 32.1 | 31.3 | 32.3 |
| 34.7 | 15.4 | 39.8 | 31.9 | 12.4 | 32.0 |
| 54.7 | 15.3 | 39.9 | 31.6 | 12.4 | 31.8 |
| 74.7 | 15.3 | 40.0 | 31.4 | 12.3 | 31.5 |
| 94.7 | 15.2 | 40.1 | 31.1 | 12.2 | 31.2 |
| 114.7 | 15.1 | 40.3 | 30.8 | 12.2 | 31.0 |
| 134.7 | 15.0 | 40.4 | 30.6 | 12.1 | 30.7 |
| 154.7 | 15.0 | 40.5 | 30.3 | 12.1 | 30.4 |
| 174.7 | 14.9 | 40.6 | 30.0 | 12.0 | 30.1 |
| 194.7 | 14.8 | 40.8 | 29.7 | 12.0 | 29.9 |
| 214.7 | 14.8 | 40.9 | 29.4 | 11.9 | 29.6 |
| 234.7 | 14.7 | 41.1 | 29.2 | 11.8 | 29.3 |
| 254.7 | 14.6 | 41.2 | 28.9 | 11.8 | 29.0 |
| 274.7 | 14.5 | 41.3 | 28.6 | 11.7 | 28.7 |
| 294.7 | 14.5 | 41.4 | 28.3 | 11.7 | 28.4 |
| 314.7 | 14.4 | 41.6 | 28.0 | 11.6 | 28.1 |
| 414.7 | 14.1 | 42.2 | 26.5 | 11.3 | 26.6 |
| 514.7 | 13.7 | 42.9 | 24.9 | 11.0 | 25.0 |
| 614.7 | 13.3 | 55.9 | 22.6 | 10.7 | 22.6 |
| 714.7 | 12.8 | 57.8 | 19.8 | 10.4 | 19.8 |
| 814.7 | 12.4 | 59.8 | 16.5 | 10.0 | 16.6 |

UFSAR Revision 30.0

| | | |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|
|  <small>An AEP Company</small> | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revision: 25.0 Table: 14.3.2-7 Sheet: 2 of 2 |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|

Safety Injection Flows Used in the SBLOCA Analysis – Recirculation Phase
(1 CHG pump, 1 HHSI pump, 1 RHR pump –
faulted loop CHG flow injects to RCS pressure and faulted loop
HHSI/RHR flow spills to containment (0 psia) – RHR Spray active – 8 5/8 inch break)

| RCS Pressure (psia) | Broken Loop (lbm/sec) | | Intact Loops (lbm/sec) | | |
|---------------------------|-----------------------|----------------------|------------------------|--------|--------|
| | Loop 1 – CHG | Loop 1 – RHR/HHSI | Loop 2 | Loop 3 | Loop 4 |
| 914.7 | 12.0 | 62.2 | 12.7 | 9.7 | 12.7 |
| 1014.7 | 11.6 | 64.3 | 9.3 | 9.3 | 9.3 |
| 1114.7 | 11.1 | 64.3 | 9.0 | 9.0 | 9.0 |
| 1214.7 | 10.7 | 64.3 | 8.6 | 8.6 | 8.6 |
| 1314.7 | 10.2 | 64.3 | 8.3 | 8.3 | 8.3 |
| 1414.7 | 9.8 | 64.3 | 7.9 | 7.9 | 7.9 |
| 1514.7 | 9.2 | 64.4 | 7.4 | 7.4 | 7.4 |
| 1614.7 | 8.7 | 64.4 | 7.0 | 7.0 | 7.0 |
| 1714.7 | 8.1 | 64.4 | 6.6 | 6.6 | 6.6 |

UFSAR Revision 30.0



**INDIANA MICHIGAN POWER
D. C. COOK NUCLEAR PLANT
UPDATED FINAL SAFETY ANALYSIS REPORT**

Revised: 29
Table: 14.3.2-8
Page: Page 1 of 1

Peak Cladding Temperature Including All Penalties and Benefits, Small Break LOCA (SBLOCA) for D. C. Cook Unit 1

PCT for Analysis-of-Record (AOR)

1725°F

PCT Assessments Allocated to AOR

- Upflow Conversion

+107°F

SBLOCA PCT for Comparison to 10 CFR 50.46 Requirements

1832°F

Unit 1

UFSAR Revision 30.0

| | | |
|----------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|------------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 16.1 Table: 14.3.3-1 Page: 1 of 1</p> |
|----------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|------------------------------------------------------------|

**SELECTED INPUT PARAMETERS* USED FOR THE COOK NUCLEAR PLANT
UNITS 1 AND 2 REDUCED TEMPERATURE AND PRESSURE AND RERATING
PROGRAM LOCA FORCES ANALYSIS**

| Input Parameter | Value |
|-------------------------------------|-------------|
| Steam Generator Tube Plugging Level | 15% Uniform |
| Vessel Inlet Temperature | 511.7°F |
| Vessel Outlet Temperature | 582.3°F |
| Loop Flow Rate | 88,500 gpm |
| Reactor Power | 3588 MWt |
| Reactor Coolant System Pressure | 2250 psia |

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 16.4</p> <p>Table: 14.3.4-1</p> <p>Page: 1 of 1</p> |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------|

DONALD C. COOK ICE CONDENSER ANALYSIS PARAMETERS

| | |
|------------------------------------------------------------|-------------------------|
| Reactor Containment Volume (net free volume) | |
| Upper Compartment, ft ³ ⁽¹⁾ | 727,628 |
| Ice Condenser, ft ³ ⁽¹⁾ | 110,520 |
| Lower Compartment (active), ft ³ ⁽¹⁾ | 293,801 |
| Total Active Volume, ft ³ | 1,131,949 |
| Lower Compartment (dead ended), ft ³ | 61,309 |
| Total Containment Volume, ft ³ | Not Applicable |
| Reactor Containment Air Compression Ratio | |
| | 1.42 |
| NSSS Power, MWt | |
| | 3425 |
| Design Energy Release to Containment | |
| Initial blowdown mass release, lbm | 543,885 |
| Initial blowdown energy release, Btu | 338.8 x 10 ⁶ |
| Ice Condenser Parameters | |
| Weight of ice in condenser, lbm | 2.20 x 10 ⁶ |
| Additional System Parameters | |
| Core Inlet Temperature (±5.1 °F), °F | 552.5 ⁽²⁾ |
| Initial Steam Generator Steam Pressure, psia | 858.2 |
| Assumed Maximum Containment Back Pressure, psia | 26.7 |

⁽¹⁾ Reference 36 and 38

⁽²⁾ Includes +4.1°F allowance for instrument error, deadband, and +1°F for cold leg streaming.

This is information utilized in the current containment pressure analysis discussed in Section 14.3.4.1.3.1.

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 19.2 Table: 14.3.4-2 Page: 1 of 1</p> |
|-----------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|------------------------------------------------------------|


DECK LEAKAGE SENSITIVITY

| Break Size | 5 ft ² Deck Leak Air Compression Peak (psig) ¹ | Deck Leakage Area (ft ²) | Spray Flow Rate (gpm) | Resultant Peak Containment Pressure (psig) |
|------------------------------|----------------------------------------------------------------------|--------------------------------------|-----------------------|--------------------------------------------|
| Double ended | 7.8 | 54 | 0 | 12.0 |
| 0.6 double ended | 6.6 | 46 | 0 | 12.0 |
| 3 ft ² | 6.25 | 50 | 0 | 12.0 |
| 8-inch diameter | 5.5 | 56 | 4000 | 12.2 |
| 8-inch diameter | 5.5 | 35 | 2000 | 12.0 |
| 8-inch diameter ² | 5.5 | 56 | 2000 | 11.3 |
| 6-inch diameter | 5.0 | 56 | 4000 | 10.4 |
| 2 1/2-inch diameter | 4.0 | 56 | 4000 | 8.5 |
| 1/2-inch diameter | 3.0 | 50 | 4000 | 3.0 |

¹ The current design basis value for the deck leakage is 7 sq. ft.

² This case assumes upper compartment structural heat sink steam condensation of 8 lb/sec and 30 percent of deck leakage is air.


UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revised: 27.0 Table: 14.3.4-4 Page: 1 of 6</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|

Structural Heat Sink Table

| Upper Compartment | Area (ft ²) | Thickness (ft) | Material |
|-------------------|-------------------------|----------------|------------------|
| Structure 1 | 29,958.25 | | |
| Layer 1 | | 0.001 | Paint (Top Coat) |
| Layer 2 | | 0.0005 | Paint (Primer) |
| Layer 3 | | 0.029741 | Carbon Steel |
| Layer 4 | | 3.0364 | Concrete |
| | | | |
| Structure 2 | 12,571.35 | | |
| Layer 1 | | 0.001 | Paint (Top Coat) |
| Layer 2 | | 0.00275 | Paint (Primer) |
| Layer 3 | | 2.710421 | Concrete |
| | | | |
| Structure 3 | 15,526.8 | | |
| Layer 1 | | 0.001 | Paint (Top Coat) |
| Layer 2 | | 0.00275 | Paint (Primer) |
| Layer 3 | | 2.2728 | Concrete |
| | | | |
| Structure 4 | 1,306.25 | | |
| Layer 1 | | 0.001 | Paint (Top Coat) |
| Layer 2 | | 0.0005 | Paint (Primer) |
| Layer 3 | | 0.209108 | Carbon Steel |
| | | | |


UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revised: 27.0 Table: 14.3.4-4 Page: 2 of 6</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|

Structural Heat Sink Table

| Upper Compartment | Area (ft ²) | Thickness (ft) | Material |
|-------------------|-------------------------|----------------|------------------|
| Structure 5 | 4,207.55 | | |
| Layer 1 | | 0.001 | Paint (Top Coat) |
| Layer 2 | | 0.0005 | Paint (Primer) |
| Layer 3 | | 0.064932 | Carbon Steel |
| | | | |
| Structure 6 | 22,443.75 | | |
| Layer 1 | | 0.001 | Paint (Top Coat) |
| Layer 2 | | 0.0005 | Paint (Primer) |
| Layer 3 | | 0.017572 | Carbon Steel |
| | | | |
| Structure 7 | 24,149.01 | | |
| Layer 1 | | 0.001 | Paint (Top Coat) |
| Layer 2 | | 0.0005 | Paint (Primer) |
| Layer 3 | | 0.010036 | Carbon Steel |
| | | | |


UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revised: 27.0 Table: 14.3.4-4 Page: 3 of 6</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|

Structural Heat Sink Table

| Lower Compartment | Area (ft ²) | Thickness (ft) | Material |
|-------------------|-------------------------|----------------|------------------|
| Structure 8 | 6,734.55 | | |
| Layer 1 | | 0.001 | Paint (Top Coat) |
| Layer 2 | | 0.0005 | Paint (Primer) |
| Layer 3 | | 0.0167 | Carbon Steel |
| Layer 4 | | 1.0103 | Concrete |
| | | | |
| Structure 9 | 14,642.35 | | |
| Layer 1 | | 0.001 | Paint (Top Coat) |
| Layer 2 | | 0.00275 | Paint (Primer) |
| Layer 3 | | 5.8355 | Concrete |
| | | | |
| Structure 10 | 25,872.3 | | |
| Layer 1 | | 0.001 | Paint (Top Coat) |
| Layer 2 | | 0.00275 | Paint (Primer) |
| Layer 3 | | 2.699 | Concrete |
| | | | |
| Structure 11 | 3,214.8 | | |
| Layer 1 | | 0.001 | Paint (Top Coat) |
| Layer 2 | | 0.0005 | Paint (Primer) |
| Layer 3 | | 0.09286 | Carbon Steel |
| | | | |


UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revised: 27.0 Table: 14.3.4-4 Page: 4 of 6</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|

Structural Heat Sink Table

| Lower Compartment | Area (ft ²) | Thickness (ft) | Material |
|-------------------|-------------------------|----------------|------------------|
| Structure 12 | 3,499.8 | | |
| Layer 1 | | 0.001 | Paint (Top Coat) |
| Layer 2 | | 0.0005 | Paint (Primer) |
| Layer 3 | | 0.06918 | Carbon Steel |
| | | | |
| Structure 13 | 12,312.0 | | |
| Layer 1 | | 0.001 | Paint (Top Coat) |
| Layer 2 | | 0.0005 | Paint (Primer) |
| Layer 3 | | 0.013136 | Carbon Steel |
| | | | |
| Structure 14 | 58,073.355 | | |
| Layer 1 | | 0.001 | Paint (Top Coat) |
| Layer 2 | | 0.0005 | Paint (Primer) |
| Layer 3 | | 0.00952 | Carbon Steel |
| | | | |


UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revised: 27.0 Table: 14.3.4-4 Page: 5 of 6</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|

Structural Heat Sink Table

| Ice Condenser | Area (ft ²) | Thickness (ft) | Material |
|--------------------------------------------------|-------------------------|----------------|----------------------|
| Structure 15 | 149,600.0 | | |
| Ice Baskets | | | |
| Layer 1 | | 0.00663 | Steel |
| | | | |
| Structure 16 | 75,865.0 | | |
| Lattice Frames | | | |
| Layer 1 | | 0.0217 | Steel |
| | | | |
| Structure 17 | 28,670.0 | | |
| Lower Support Structure | | | |
| Layer 1 | | 0.0587 | Steel |
| | | | |
| Structure 18 | 3,336.0 | | |
| Ice Condenser Floor | | | |
| Layer 1 | | 0.00275 | Paint |
| Layer 2 | | 0.33 | Concrete |
| | | | |
| Structure 19 | 19,100.0 | | |
| Containment Wall Panels and Containment Shell | | | |
| Layer 1 | | 1.0 | Steel and Insulation |
| Layer 2 | | 0.0625 | Steel Shell |
| | | | |


UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p style="text-align: center;">INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revised: 27.0 Table: 14.3.4-4 Page: 6 of 6</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|

Structural Heat Sink Table

| Ice Condenser | Area (ft ²) | Thickness (ft) | Material |
|-------------------------------------|-------------------------|----------------|----------------------|
| Structure 20 | 13,055.0 | | |
| Crane Wall Panels and Crane Wall | | | |
| Layer 1 | | 1.0 | Steel and Insulation |
| Layer 2 | | 1.0 | Concrete |
| | | | |


UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revised: 27.0 Table: 14.3.4-5 Page: 1 of 1 |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|

Material Property Data

| Upper and Lower Compartments | | |
|-------------------------------------|----------------------------------------------------|-----------------------------------------------------------------|
| Material | Thermal Conductivity (Btu / hr-ft - °F) | Volumetric Heat Capacity (Btu / ft³ - °F) |
| Paint (on concrete) | | |
| Primer | 0.19 | 29.3 |
| Top Coat | 0.19 | 75.0 |
| Concrete | 0.81 | 30.4 |
| | | |
| Paint (on steel) | | |
| Primer | 0.4 | 29.3 |
| Top Coat | 0.4 | 75.0 |
| Steel | 26.0 | 58.8 |
| | | |
| Ice Condenser Compartment | | |
| Material | Thermal Conductivity (Btu / hr-ft - °F) | Volumetric Heat Capacity (Btu / ft³ - °F) |
| Paint (on concrete) | 0.0833 | 28.4 |
| Insulation (on concrete) | 0.2 | 3.663 |
| Concrete | 0.8 | 28.8 |
| | | |
| Insulation (on steel) | 0.15 | 2.75 |
| Steel | 26.0 | 56.4 |

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|------------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revised: 27.0 Table: 14.3.4-6A Page: 1 of 1</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|------------------------------------------------------------|


D. C. Cook Unit 1 DECL Min Containment Energy Accounting - Blowdown

| | Approximate End of Blowdown (10.0 sec) |
|----------------------------------------------|---------------------------------------------------|
| Ice Heat Removal ¹ | 202.99 MBTU |
| Structural Heat Sinks ¹ | 19.96 MBTU |
| RHR Heat Exchanger Heat Removal ¹ | 0.0 MBTU |
| Spray Heat Exchanger ¹ | 0.0 MBTU |
| Energy Content of Sump ² | 204.21 MBTU |
| Ice Melted | 0.668 Mlbm |

¹ Integrated Energy

² Sum of active and inactive sump

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revised: 27.0 Table: 14.3.4-6B Page: 1 of 1 |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------|

D. C. Cook Unit 1 DECL Min Containment Energy Accounting – Melt-Out and Peak Pressure

| | Approximate Time of Ice Melt-Out (~ 12. 91 sec) ¹ | Approximate Time of Peak Pressure (~ 108 s ec) ² |
|-----------------------------------------|-------------------------------------------------------------------------------|------------------------------------------------------------------------------|
| Ice Heat Removal ³ | 576.39 MBTU | 576.39 MBTU |
| Structural Heat Sinks ³ | 123.75 MBTU | 163.27 MBTU |
| RHR Heat Exchanger Removal ³ | 111.22 MBTU | 190.47 MBTU |
| Spray Heat Exchanger ³ | 118.49 MBTU | 204.56 MBTU |
| Energy Content of Sump ⁴ | 549.58 MBTU | 560.49 MBTU |
| Ice Melted | 2.2 Mlbm | 2.2 Mlbm |


¹ Used 7712.9 sec

² Used 10784.2 sec

³ Integrated Energy

⁴ Active Sump


UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revised: 27.0 Table: 14.3.4-7 Page: 1 of 2</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|

| |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <p>Unit 1 Steamline Break Mass / Energy Releases Inside Containment 30% of 3327 MWt NSSS Power, 1.4 ft² Double-Ended Rupture, Failure - MSIV</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------|


| Time (sec) | Mass (lb _m / sec) | Energy (Btu / sec) |
|------------|------------------------------|--------------------|
| 0.0 | 0.0 | 0.000E+00 |
| 0.001 | 9,833 | 1.172E+07 |
| 0.2 | 20,092 | 2.396E+07 |
| 1.0 | 19,499 | 2.327E+07 |
| 2.46 | 18,757 | 2.24J E+07 |
| 2.4601 | 8,928 | 1.068E+07 |
| 4.2 | 8,045 | 9.645E+06 |
| 4.4 | 8,205 | 9.838E+06 |
| 10.0 | 6,741 | 8.105E+06 |
| 12.4 | 6,276 | 7.551E+06 |
| 12.6 | 1,620 | 1.950E+06 |
| 19.8 | 1,290 | 1.553E+06 |
| 26.2 | 1,093 | 1.316E+06 |
| 32.6 | 961.4 | 1.157E+06 |
| 39.0 | 881.7 | 1.061E+06 |
| 45.4 | 835.1 | 1.004E+06 |
| 76.4 | 859.3 | 1.034E+06 |
| 279.8 | 841.1 | 1.012E+06 |
| 281.4 | 826.4 | 9.938E+05 |
| 283.2 | 787.7 | 9.468E+05 |
| 285.0 | 731.1 | 8.783E+05 |
| 288.6 | 553.6 | 6.630E+05 |

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revised: 27.0 Table: 14.3.4-7 Page: 2 of 2</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|


| Unit 1 Steamline Break Mass / Energy Releases Inside Containment 30% of 3327 MWt NSSS Power, 1.4 ft² Double-Ended Rupture, Failure - MSIV | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------|--------------------|
| Time (sec) | Mass (lb _m / sec) | Energy (Btu / sec) |
| 292.2 | 315.1 | 3.744E+05 |
| 292.8 | 281.6 | 3.340E+05 |
| 293.4 | 259.8 | 3.078E+05 |
| 294.0 | 252.8 | 2.994E+05 |
| 294.8 | 259.5 | 3.075E+05 |
| 296.2 | 286.1 | 3.395E+05 |
| 296.8 | 291.0 | 3.454E+05 |
| 301.6 | 282.2 | 3.348E+05 |
| 306.8 | 275.9 | 3.272E+05 |
| 323.2 | 258.4 | 3.062E+05 |
| 329.6 | 247.8 | 2.934E+05 |
| 340.8 | 216.4 | 2.556E+05 |
| 348.0 | 182.5 | 2.149E+05 |
| 361.2 | 103.5 | 1.208E+05 |
| 385.6 | 56.6 | 6.537E+04 |
| 1,800.6 | 56.3 | 6.502E+04 |
| 1,803.2 | 20.6 | 2.374E+04 |
| 1,803.4 | 0.0 | 0.000E+00 |

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revised: 27.0 Table: 14.3.4-8 Page: 1 of 2 |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|


| Unit 1 Steam line Break Mass / Energy Releases Inside Containment 100.34% of 3327 MWt NSSS Power, 0.865 ft² Split Break, Failure - MSIV | | |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------|--------------------|
| Time (sec) | Mass (lb _m / sec) | Energy (Btu / sec) |
| 0.0 | 0.0 | 0.000E+00 |
| 0.2 | 1,549.0 | 1.851E+06 |
| 5.2 | 1,456.4 | 1.743E+06 |
| 5.4 | 1,523.9 | 1.824E+06 |
| 9.6 | 1,648.5 | 1.969E+06 |
| 11.8 | 1,691.6 | 2.019E+06 |
| 14.0 | 1,706.9 | 2.037E+06 |
| 17.8 | 1,694.1 | 2.023E+06 |
| 22.6 | 1,448.0 | 1.735E+06 |
| 25.4 | 1,348.9 | 1.618E+06 |
| 31.2 | 1,196.0 | 1.437E+06 |
| 37.0 | 1,083.1 | 1.303E+06 |
| 42.8 | 995.5 | 1.198E+06 |
| 48.6 | 927.2 | 1.116E+06 |
| 60.2 | 830.4 | 1.000E+06 |
| 71.8 | 769.5 | 9.269E+05 |
| 83.4 | 728.8 | 8.778E+05 |
| 106.6 | 680.9 | 8.200E+05 |
| 129.8 | 661.2 | 7.962E+05 |
| 223.2 | 653.8 | 7.872E+05 |
| 238.0 | 567.5 | 6.829E+05 |
| 243.6 | 518.9 | 6.241E+05 |

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revised: 27.0 Table: 14.3.4-8 Page: 2 of 2</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|

| Unit 1 Steam line Break Mass / Energy Releases Inside Containment | | |
|-----------------------------------------------------------------------------------------|------------------------------------|---------------------------|
| 100.34% of 3327 MWt NSSS Power, 0.865 ft² Split Break, Failure - MSIV | | |
| Time (sec) | Mass (lb_m / sec) | Energy (Btu / sec) |
| 249.2 | 451.8 | 5.428E+05 |
| 254.6 | 368.8 | 4.421E+05 |
| 260.2 | 274.5 | 3.279E+05 |
| 263.0 | 230.4 | 2.745E+05 |
| 265.8 | 192.2 | 2.283E+05 |
| 268.4 | 161.7 | 1.916E+05 |
| 271.2 | 135.3 | 1.599E+05 |
| 274.0 | 114.8 | 1.353E+05 |
| 276.8 | 99.5 | 1.169E+05 |
| 279.6 | 87.4 | 1.025E+05 |
| 281.0 | 82.5 | 9.666E+04 |
| 285.2 | 72.8 | 8.510E+04 |
| 293.4 | 61.6 | 7.180E+04 |
| 299.0 | 58.5 | 6.815E+04 |
| 310.0 | 56.5 | 6.580E+04 |
| 1,800.8 | 55.9 | 6.504E+04 |
| 1,807.6 | 15.6 | 1.794E+04 |
| 1,807.8 | 0.0 | 0.000E+00 |


UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revised: 28.0 Table: 14.3.4-9 Page: 1 of 1</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|

Double-Ended Rupture Steamline Breaks

| Power Level | Break Size | Single Failure | Peak Temperature @ Time |
|-------------|---------------------|--------------------|-------------------------|
| 100.34% | 1.4 ft ² | MSIV | 323.8°F @ 55.57 sec |
| 100.34% | 1.4 ft ² | AFW Runout Control | 323.7°F @ 54.76 sec |
| 70% | 1.4 ft ² | MSIV | 323.8°F @ 12.36 sec |
| 70% | 1.4 ft ² | AFW Runout Control | 323.8°F @ 12.36 sec |
| 30% | 1.4 ft ² | MSIV | 324.3°F @ 12.36 sec |
| 30% | 1.4 ft ² | AFW Runout Control | 324.3°F @ 12.36 sec |
| 0% | 1.4 ft ² | MSIV | 320.9°F @ 131.3 sec |
| 0% | 1.4 ft ² | AFW Runout Control | 320.4°F @ 132.8 sec |
| 0% | 1.0 ft ² | MSIV | 324.5°F @ 265.4 sec |
| 0% | 1.0 ft ² | AFW Runout Control | 324.1 °F @ 140.8 sec |

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|------------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revised: 28.0 Table: 14.3.4-10 Page: 1 of 1</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|------------------------------------------------------------|

Split Steamline Breaks

| Power Level | Break Size | Single Failure | Peak Temperature @ Time |
|-------------|-----------------------|--------------------|-------------------------|
| 100.34% | 0.865 ft ² | MSIV | 324.7°F @ 96.57 sec |
| 100.34% | 0.865 ft ² | AFW Runout Control | 324.5°F @ 95.86 sec |
| 70% | 0.857 ft ² | MSIV | 324.7°F @ 72.43 sec |
| 70% | 0.857 ft ² | AFW Runout Control | 324.5°F @ 111.4 sec |
| 30% | 0.834 ft ² | MSIV | 324.6°F @ 122.9 sec |
| 30% | 0.834 ft ² | AFW Runout Control | 324.3°F @ 116.7 sec |
| 0% | 0.808 ft ² | MSIV | 324.3°F @ 142.8 sec |
| 0% | 0.808 ft ² | AFW Runout Control | 324.5°F @ 119.7 sec |

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------|
|  An AEP Company | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revision: 16.1 Table: 14.3.4-11 Page: 1 of 1 |
|------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------|

LOWER COMPARTMENT TEMPERATURE TRANSIENT CALCULATION RESULTS

| Case | Maximum LC Temp °F | Time T _{max} Sec. | Time Of Containment* | |
|----------------------|-----------------------|-------------------------------|----------------------|------|
| | | | Spray | Fan |
| 0.6 ft ² | 326.1 | 151.39 | 53. | 605. |
| 0.35 ft ² | 325.8 | 322.8 | 59. | 617. |
| 0.1 ft ² | 320.7 | 651. | 106. | 663. |

* Hi-2 Pressure Setpoint used was 3.5 psig.
Relay time used for spray actuation after Hi-2 signal was 45 sec.
Relay time used for fan actuation after Hi-2 signal was 600 sec.

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 16.1</p> <p>Table: 14.3.4-12</p> <p>Page: 1 of 1</p> |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------|

0.35 FT² SPLIT 30% POWER

| Time (sec) | Mass (lb/sec) | Energy (BTU/sec) |
|---------------|------------------|---------------------|
| .1000E-01 | .7970E+03 | .9480E+06 |
| .1000E+01 | .7970E+03 | .9480E+06 |
| .3000E+01 | .7890E+03 | .9388E+06 |
| .5000E+01 | .7820E+03 | .9308E+06 |
| .7000E+01 | .7760E+03 | .7239E+06 |
| .9000E+01 | .7700E+03 | .9169E+06 |
| .1000E+02 | .7680E+03 | .9145E+06 |
| .1300E+02 | .7760E+03 | .9237E+06 |
| .1500E+02 | .7800E+03 | .9284E+06 |
| .1600E+02 | .8960E+03 | .1066E+07 |
| .1900E+02 | .1240E+03 | .1476E+07 |
| 2000E+02 | .7720E+03 | .9195E+06 |
| .2500E+02 | .7090E+03 | .8466E+06 |
| .3000E+02 | .6630E+03 | .7930E+06 |
| .3500E+02 | .6280E+03 | .7520E+06 |
| .4000E+02 | .6010E+03 | .7203E+06 |
| .5000E+02 | .5630E+03 | .6756E+06 |
| .6000E+02 | .5350E+03 | .6425E+06 |
| .7000E+02 | .5140E+03 | .6176E+06 |
| .8000E+02 | .4970E+03 | .5974E+06 |
| .9000E+02 | .4830E+03 | .5808E+06 |
| .1000E+03 | .4700E+03 | .5653E+06 |
| .1200E+03 | .4500E+03 | .5415E+06 |
| .1400E+03 | .4320E+03 | .5200E+06 |
| .1600E+03 | .4160E+03 | .5008E+06 |
| .1800E+03 | .4020E+03 | .4841E+06 |
| .2000E+03 | .3890E+03 | .4685E+06 |
| .2400E+03 | .3650E+03 | .4397E+06 |
| .2800E+03 | .3440E+03 | .4144E+06 |
| .3200E+03 | .3240E+03 | .3904E+06 |
| .3600E+03 | .3060E+03 | .3687E+06 |
| .4000E+03 | .2890E+03 | .3481E+06 |
| .5000E+03 | .2530E+03 | .3046E+06 |
| .6000E+03 | .2230E+03 | .2683E+06 |
| .7000E+03 | .1990E+03 | .2392E+06 |
| .8000E+03 | .1790E+03 | .2150E+06 |
| .9000E+03 | .1620E+03 | .1944E+06 |
| .1000E+04 | .1480E+03 | .1774E+06 |

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 16.1</p> <p>Table: 14.3.4-13</p> <p>Page: 1 of 1</p> |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------|

0.6 FT² SPLIT 30% POWER

| Time (sec) | Mass (lb/sec) | Energy (BTU/sec) |
|---------------|------------------|---------------------|
| .1000E-01 | .1365E+04 | .1624E+07 |
| .1000E+01 | .1365E+04 | .1624E+07 |
| .3000E+01 | .1341E+04 | .1596E+07 |
| .5000E+01 | .1320E+04 | .1572E+07 |
| .7000E+01 | .1302E+04 | .1551E+07 |
| .8000E+01 | .1293E+04 | .1541E+07 |
| .1000E+02 | .1297E+04 | .1545E+07 |
| .1200E+02 | .1298E+04 | .1546E+07 |
| .1300E+02 | .1297E+04 | .1545E+07 |
| .1400E+02 | .1268E+04 | .1513E+07 |
| .1600E+02 | .1196E+04 | .1429E+07 |
| .1800E+02 | .1133E+04 | .1355E+07 |
| .2000E+02 | .1079E+04 | .1292E+07 |
| .2200E+02 | .1033E+04 | .1238E+07 |
| .2400E+02 | .9940E+03 | .1192E+07 |
| .2700E+02 | .9440E+03 | .1133E+07 |
| .3200E+02 | .8800E+03 | .1057E+07 |
| .3600E+02 | .8420E+03 | .1012E+07 |
| .4000E+02 | .8110E+03 | .9754E+06 |
| .4600E+02 | .7740E+03 | .9313E+06 |
| .5000E+02 | .7540E+03 | .9074E+06 |
| .6000E+02 | .7130E+03 | .8584E+06 |
| .7500E+02 | .6680E+03 | .8045E+06 |
| .9500E+02 | .6250E+03 | .7529E+06 |
| .1200E+03 | .5840E+03 | .7036E+06 |
| .1400E+03 | .5570E+03 | .6711E+06 |
| .1800E+03 | .5110E+03 | .6156E+06 |
| .2200E+03 | .4720E+03 | .5685E+06 |
| .2400E+03 | .4530E+03 | .5455E+06 |
| .2600E+03 | .4350E+03 | .5238E+06 |
| .3000E+03 | .4020E+03 | .4838E+06 |
| .3600E+03 | .3600E+03 | .4330E+06 |
| .4200E+03 | .3250E+03 | .3905E+06 |
| .5000E+03 | .2870E+03 | .3445E+06 |
| .5600E+03 | .2680E+03 | .3154E+06 |
| .6000E+03 | .2480E+03 | .2972E+06 |
| .8600E+03 | .1790E+03 | .2136E+06 |
| .9600E+03 | .1610E+03 | .1918E+06 |
| .9800E+03 | .1580E+03 | .1882E+06 |
| .1000E+04 | .1550E+03 | .1846E+06 |

UFSAR Revision 30.0

| | | |
|----------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 16.1 Table: 14.3.4-14 Page: 1 of 1</p> |
|----------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|

KEY PARAMETERS AFFECTING SPLIT STEAM LINE BREAKS

| Variable | Values Used In LOTIC-3 Report | Values for D. C. Cook |
|------------------------------------------|----------------------------------|--------------------------|
| Full Load Steam Pressure (psia) | 1000 | 820 |
| Plant Power (Mwt) | 3425 | 3403 |
| Time Delay to Feedline Isolation (sec) | 15 | ≤9.0 |
| Time Delay to Steam Line Isolation (sec) | 15 | ≤9.0 |

UFSAR Revision 30.0

| | | |
|----------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 17.1 Table: 14.3.4-15 Page: 1 of 2</p> |
|----------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|

STEAM LINE RUPTURE IN STEAM GENERATOR DOGHOUSE

Mass Energy Release Rates Outlet Nozzle Break (Top Break)

| Time (Sec) | Mass Flowrate (lbm/sec) $\times 10^3$ | Energy Flowrate (BTU/sec) $\times 10^6$ |
|------------|------------------------------------------|--------------------------------------------|
| 0.0 | 19.421 | 23.110 |
| 0.042 | 19.421 | 23.110 |
| 0.043 | 13.830 | 16.458 |
| 0.2 | 13.430 | 15.982 |
| 0.45 | 16.630 | 16.239 |
| 0.75 | 26.430 | 19.040 |
| 1.05 | 34.630 | 21.428 |
| 1.9 | 33.350 | 20.358 |
| 2.9 | 31.680 | 19.395 |
| 3.5 | 31.000 | 18.678 |

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revision: 17.1 Table: 14.3.4-15 Page: 2 of 2 |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------|

MAIN FEEDWATER LINE BREAK IN STEAM GENERATOR DOGHOUSE

Mass and Energy Releases (Break at Side of Vessel)

| | <u>Reverse Flow</u> | |
|----------------|---------------------|-----------------------|
| Time (seconds) | Mass Flow (lbm/sec) | Energy Flow (Btu/sec) |
| 0.0 | 8919 | 4.866×10^6 |
| 20.23 | 8919 | 4.866×10^6 |
| 20.24 | 0 | 0 |
| | | |
| | <u>Forward Flow</u> | |
| Time (seconds) | Mass Flow (lbm/sec) | Energy Flow (Btu/sec) |
| 0.0 | 5711 | 2.451×10^6 |
| ∞ | 5711 | 2.451×10^6 |
| | | |
| | <u>Total Flow</u> | |
| Time (seconds) | Mass Flow (lbm/sec) | Energy Flow (Btu/sec) |
| 0.0 | 14630 | 7.317×10^6 |
| 20.23 | 14630 | 7.317×10^6 |
| 20.24 | 5711 | 2.451×10^6 |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revision: 17.1 Table: 14.3.4-16 Page: 1 of 12 |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|

TABLE 14.3.4-16

DOUBLE-ENDED SPRAY LINE BREAK

MASS AND ENERGY RELEASES

(When using this table, add 15% multiplier to mass & energy results.)

| Time (sec) | Mass (lb/sec) | Energy (BTU/sec) |
|---------------|------------------|---------------------|
| .00000 | 0. | 0. |
| .00101 | 1.8429935E+03 | 1.2012554E+06 |
| .00201 | 2.0768869E+03 | 1.3312080E+06 |
| .00302 | 2.0954232E+03 | 1.3410507E+06 |
| .00401 | 2.0943466E+03 | 1.3398926E+06 |
| .00502 | 2.0906198E+03 | 1.3372569E+06 |
| .00600 | 2.0847010E+03 | 1.3334349E+06 |
| .00703 | 2.0776894E+03 | 1.3290038E+06 |
| .00800 | 2.0718446E+03 | 1.3252736E+06 |
| .00901 | 2.0684832E+03 | 1.3229372E+06 |
| .01000 | 2.0667746E+03 | 1.3215515E+06 |
| .01102 | 2.0657651E+03 | 1.3205642E+06 |
| .01200 | 2.0657312E+03 | 1.3202011E+06 |
| .01301 | 2.0710642E+03 | 1.3227266E+06 |
| .01400 | 2.0895916E+03 | 1.3326883E+06 |
| .01505 | 2.1237904E+03 | 1.3513713E+06 |
| .01605 | 2.1428041E+03 | 1.3615888E+06 |
| .01705 | 2.1327342E+03 | 1.3556010E+06 |
| .01804 | 2.1286790E+03 | 1.3530305E+06 |
| .01905 | 2.1408255E+03 | 1.3594780E+06 |
| .02004 | 2.1330134E+03 | 1.3547994E+06 |
| .02108 | 2.1170413E+03 | 1.3456154E+06 |
| .02207 | 2.1196063E+03 | 1.3467887E+06 |
| .02308 | 2.1314002E+03 | 1.3530903E+06 |
| .02400 | 2.1400977E+03 | 1.3576929E+06 |
| .02501 | 2.1475536E+03 | 1.3615802E+06 |
| .02602 | 2.1559827E+03 | 1.3660339E+06 |
| .02707 | 2.1678910E+03 | 1.3724086E+06 |
| .02804 | 2.1768474E+03 | 1.3771613E+06 |
| .02907 | 2.1816274E+03 | 1.3795673E+06 |
| .03009 | 2.1827097E+03 | 1.3799305E+06 |
| .03107 | 2.1841837E+03 | 1.3805245E+06 |
| .03212 | 2.1872679E+03 | 1.3820107E+06 |
| .03301 | 2.1894643E+03 | 1.3830366E+06 |
| .03411 | 2.1903771E+03 | 1.3833149E+06 |

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revision: 17.1 Table: 14.3.4-16 Page: 2 of 12 |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|

TABLE 14.3.4-16

DOUBLE-ENDED SPRAY LINE BREAK

MASS AND ENERGY RELEASES

(When using this table, add 15% multiplier to mass & energy results.)

| Time (sec) | Mass (lb/sec) | Energy (BTU/sec) |
|---------------|------------------|---------------------|
| .03504 | 2.1897285E+03 | 1.3827485E+06 |
| .03607 | 2.1861418E+03 | 1.3805329E+06 |
| .03703 | 2.1786958E+03 | 1.3761844E+06 |
| .03807 | 2.1711481E+03 | 1.3717868E+06 |
| .03906 | 2.1650758E+03 | 1.3682259E+06 |
| .04009 | 2.1587371E+03 | 1.3645103E+06 |
| .04102 | 2.1527706E+03 | 1.3610346E+06 |
| .04212 | 2.1468107E+03 | 1.3575467E+06 |
| .04305 | 2.1432206E+03 | 1.3554088E+06 |
| .04406 | 2.1404771E+03 | 1.3537320E+06 |
| .04510 | 2.1384998E+03 | 1.3524847E+06 |
| .04601 | 2.1374125E+03 | 1.3517571E+06 |
| .04705 | 2.1369632E+03 | 1.3513688E+06 |
| .04809 | 2.1372622E+03 | 1.3514036E+06 |
| .04911 | 2.1379671E+03 | 1.3516676E+06 |
| .05006 | 2.1388546E+03 | 1.3520428E+06 |
| .05108 | 2.1400630E+03 | 1.3525916E+06 |
| .05207 | 2.1411605E+03 | 1.3530872E+06 |
| .05318 | 2.1418610E+03 | 1.3533545E+06 |
| .05404 | 2.1420277E+03 | 1.3533548E+06 |
| .05515 | 2.1419234E+03 | 1.3531771E+06 |
| .05609 | 2.1415416E+03 | 1.3528611E+06 |
| .05711 | 2.1410383E+03 | 1.3524782E+06 |
| .05812 | 2.1409677E+03 | 1.3523442E+06 |
| .05901 | 2.1414214E+03 | 1.3525173E+06 |
| .06004 | 2.1427085E+03 | 1.3531458E+06 |
| .06104 | 2.1448478E+03 | 1.3542536E+06 |
| .06207 | 2.1481439E+03 | 1.3559989E+06 |
| .06303 | 2.1514351E+03 | 1.3577536E+06 |
| .06402 | 2.1550387E+03 | 1.3596806E+06 |
| .06501 | 2.1585740E+03 | 1.3615691E+06 |
| .06604 | 2.1618098E+03 | 1.3632912E+06 |
| .06710 | 2.1647229E+03 | 1.3648345E+06 |
| .06814 | 2.1673799E+03 | 1.3662365E+06 |
| .06905 | 2.1694828E+03 | 1.3673439E+06 |
| .07008 | 2.1716796E+03 | 1.3684953E+06 |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revision: 17.1 Table: 14.3.4-16 Page: 3 of 12 |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|

TABLE 14.3.4-16

DOUBLE-ENDED SPRAY LINE BREAK
MASS AND ENERGY RELEASES

(When using this table, add 15% multiplier to mass & energy results.)

| Time (sec) | Mass (lb/sec) | Energy (BTU/sec) |
|---------------|------------------|---------------------|
| .07111 | 2.1735789E+03 | 1.3694836E+06 |
| .07213 | 2.1750499E+03 | 1.3702354E+06 |
| .07317 | 2.1759218E+03 | 1.3706558E+06 |
| .07412 | 2.1760897E+03 | 1.3706871E+06 |
| .07523 | 2.1755041E+03 | 1.3702969E+06 |
| .07602 | 2.1743802E+03 | 1.3696191E+06 |
| .07705 | 2.1726900E+03 | 1.3686222E+06 |
| .07801 | 2.1708169E+03 | 1.3675296E+06 |
| .07902 | 2.1688239E+03 | 1.3663702E+06 |
| .08006 | 2.1667850E+03 | 1.3651854E+06 |
| .08100 | 2.1651864E+03 | 1.3642490E+06 |
| .08204 | 2.1632686E+03 | 1.3631342E+06 |
| .08306 | 2.1613432E+03 | 1.3620171E+06 |
| .08410 | 2.1593726E+03 | 1.3608757E+06 |
| .08504 | 2.1576149E+03 | 1.3598670E+06 |
| .08603 | 2.1556593E+03 | 1.3587375E+06 |
| .08708 | 2.1538655E+03 | 1.3576993E+06 |
| .08814 | 2.1523767E+03 | 1.3568314E+06 |
| .08915 | 2.1513646E+03 | 1.3562298E+06 |
| .09005 | 2.1510544E+03 | 1.3560230E+06 |
| .09115 | 2.1514210E+03 | 1.3561899E+06 |
| .09214 | 2.1524508E+03 | 1.3567285E+06 |
| .09307 | 2.1540139E+03 | 1.3575665E+06 |
| .09405 | 2.1562098E+03 | 1.3587565E+06 |
| .09504 | 2.1589196E+03 | 1.3602332E+06 |
| .09601 | 2.1619926E+03 | 1.3619135E+06 |
| .09712 | 2.1660659E+03 | 1.3641459E+06 |
| .09811 | 2.1700593E+03 | 1.3663392E+06 |
| .09910 | 2.1743398E+03 | 1.3686932E+06 |
| .10011 | 2.1788810E+03 | 1.3711929E+06 |
| .10505 | 2.1997980E+03 | 1.3827080E+06 |
| .11017 | 2.2084042E+03 | 1.3873725E+06 |
| .11511 | 2.1979605E+03 | 1.3814517E+06 |
| .12010 | 2.1755220E+03 | 1.3688892E+06 |
| .12501 | 2.1516732E+03 | 1.3555705E+06 |
| .13001 | 2.1350205E+03 | 1.3462681E+06 |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 17.1</p> <p>Table: 14.3.4-16</p> <p>Page: 4 of 12</p> |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------|

TABLE 14.3.4-16

DOUBLE-ENDED SPRAY LINE BREAK

MASS AND ENERGY RELEASES

(When using this table, add 15% multiplier to mass & energy results.)

| Time (sec) | Mass (lb/sec) | Energy (BTU/sec) |
|---------------|------------------|---------------------|
| .13501 | 2.1319480E+03 | 1.3445234E+06 |
| .14009 | 2.1415298E+03 | 1.3498034E+06 |
| .14510 | 2.1540075E+03 | 1.3566900E+06 |
| .15015 | 2.1608228E+03 | 1.3604378E+06 |
| .15500 | 2.1603593E+03 | 1.3601520E+06 |
| .16007 | 2.1547404E+03 | 1.3570065E+06 |
| .16515 | 2.1446526E+03 | 1.3513889E+06 |
| .17002 | 2.1327374E+03 | 1.3447619E+06 |
| .17509 | 2.1250311E+03 | 1.3404793E+06 |
| .18010 | 2.1255323E+03 | 1.3407503E+06 |
| .18500 | 2.1307501E+03 | 1.3436315E+06 |
| .19010 | 2.1359241E+03 | 1.3464861E+06 |
| .19507 | 2.1377315E+03 | 1.3474736E+06 |
| .20008 | 2.1357354E+03 | 1.3463523E+06 |
| .21002 | 2.1305966E+03 | 1.3434798E+06 |
| .22009 | 2.1455142E+03 | 1.3517412E+06 |
| .23010 | 2.1609519E+03 | 1.3602792E+06 |
| .24007 | 2.1500994E+03 | 1.3542251E+06 |
| .25001 | 2.1319210E+03 | 1.3441210E+06 |
| .26002 | 2.1212847E+03 | 1.3437534E+06 |
| .27006 | 2.1408201E+03 | 1.3490219E+06 |
| .28015 | 2.1382240E+03 | 1.3475602E+06 |
| .29011 | 2.1219655E+03 | 1.3385282E+06 |
| .30028 | 2.1125694E+03 | 1.3333092E+06 |
| .31011 | 2.1146636E+03 | 1.3344534E+06 |
| .32004 | 2.1134582E+03 | 1.3337664E+06 |
| .33005 | 2.1102424E+03 | 1.3319670E+06 |
| .34002 | 2.1162685E+03 | 1.3352858E+06 |
| .35002 | 2.1252674E+03 | 1.3402496E+06 |
| .36002 | 2.1249488E+03 | 1.3400427E+06 |
| .37007 | 2.1182970E+03 | 1.3363273E+06 |
| .38010 | 2.1179299E+03 | 1.3360961E+06 |
| .39027 | 2.1241025E+03 | 1.3394390E+06 |
| .40003 | 2.1244819E+03 | 1.3396673E+06 |
| .41001 | 2.1157197E+03 | 1.3347842E+06 |
| .42004 | 2.1079031E+03 | 1.3304251E+06 |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 17.1</p> <p>Table: 14.3.4-16</p> <p>Page: 5 of 12</p> |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------|

TABLE 14.3.4-16

DOUBLE-ENDED SPRAY LINE BREAK

MASS AND ENERGY RELEASES

(When using this table, add 15% multiplier to mass & energy results.)

| Time (sec) | Mass (lb/sec) | Energy (BTU/sec) |
|---------------|------------------|---------------------|
| .43006 | 2.1057949E+03 | 1.3292307E+06 |
| .44011 | 2.1038434E+03 | 1.3281221E+06 |
| .45008 | 2.1005501E+03 | 1.3262686E+06 |
| .46002 | 2.1008990E+03 | 1.3264325E+06 |
| .47013 | 2.1046381E+03 | 1.3284716E+06 |
| .48001 | 2.1065466E+03 | 1.3294937E+06 |
| .49011 | 2.1055653E+03 | 1.3289117E+06 |
| .50010 | 2.1065499E+03 | 1.3294210E+06 |
| .51005 | 2.1109307E+03 | 1.3318103E+06 |
| .52014 | 2.1132353E+03 | 1.3330479E+06 |
| .53006 | 2.1104929E+03 | 1.3314882E+06 |
| .54010 | 2.1067324E+03 | 1.3293690E+06 |
| .55002 | 2.1047031E+03 | 1.3282077E+06 |
| .56003 | 2.1025984E+03 | 1.3270031E+06 |
| .57000 | 2.0994619E+03 | 1.3252280E+06 |
| .58000 | 2.0974864E+03 | 1.3240966E+06 |
| .59023 | 2.0978998E+03 | 1.3242862E+06 |
| .60010 | 2.0987566E+03 | 1.3247206E+06 |
| .61005 | 2.0988030E+03 | 1.3247041E+06 |
| .62019 | 2.0998437E+03 | 1.3252383E+06 |
| .63007 | 2.1029363E+03 | 1.3269102E+06 |
| .64009 | 2.1057724E+03 | 1.3284358E+06 |
| .65011 | 2.1063355E+03 | 1.3287028E+06 |
| .66008 | 2.1058521E+03 | 1.3283898E+06 |
| .67006 | 2.1056166E+03 | 1.3282154E+06 |
| .68003 | 2.1048258E+03 | 1.3277315E+06 |
| .69009 | 2.1027606E+03 | 1.3265436E+06 |
| .70006 | 2.1004766E+03 | 1.3252341E+06 |
| .71021 | 2.0994186E+03 | 1.3246041E+06 |
| .72013 | 2.0991217E+03 | 1.3243955E+06 |
| .73018 | 2.0986674E+03 | 1.3240994E+06 |
| .74006 | 2.0987148E+03 | 1.3240815E+06 |
| .75009 | 2.1001279E+03 | 1.3248191E+06 |
| .76008 | 2.1022067E+03 | 1.3259240E+06 |
| .77007 | 2.1038110E+03 | 1.3267654E+06 |
| .78001 | 2.1049477E+03 | 1.3273479E+06 |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 17.1</p> <p>Table: 14.3.4-16</p> <p>Page: 6 of 12</p> |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------|

TABLE 14.3.4-16

DOUBLE-ENDED SPRAY LINE BREAK
MASS AND ENERGY RELEASES

(When using this table, add 15% multiplier to mass & energy results.)

| Time (sec) | Mass (lb/sec) | Energy (BTU/sec) |
|---------------|------------------|---------------------|
| .79005 | 2.1060244E+03 | 1.3278975E+06 |
| .80008 | 2.1065644E+03 | 1.3281484E+06 |
| .81002 | 2.1059659E+03 | 1.3277697E+06 |
| .82003 | 2.1046670E+03 | 1.3270043E+06 |
| .83006 | 2.1036100E+03 | 1.3263731E+06 |
| .84009 | 2.1028557E+03 | 1.3259083E+06 |
| .85013 | 2.1019975E+03 | 1.3253876E+06 |
| .86002 | 2.1012207E+03 | 1.3249123E+06 |
| .87004 | 2.1011387E+03 | 1.3248209E+06 |
| .88001 | 2.1018523E+03 | 1.3251709E+06 |
| .89009 | 2.1029599E+03 | 1.3257378E+06 |
| .90001 | 2.1041960E+03 | 1.3263762E+06 |
| .92003 | 2.1066767E+03 | 1.3276561E+06 |
| .93004 | 2.1070790E+03 | 1.3278333E+06 |
| .94009 | 2.1068436E+03 | 1.3276548E+06 |
| .95015 | 2.1064606E+03 | 1.3273966E+06 |
| .91007 | 2.1055640E+03 | 1.3270867E+06 |
| .96022 | 2.1060345E+03 | 1.3271155E+06 |
| .97001 | 2.1052992E+03 | 1.3266634E+06 |
| .98005 | 2.1042714E+03 | 1.3260489E+06 |
| .99010 | 2.1033853E+03 | 1.3255134E+06 |
| 1.00003 | 2.1030192E+03 | 1.3252670E+06 |
| 1.00015 | 2.1030185E+03 | 1.3252660E+06 |
| 1.01010 | 2.1031598E+03 | 1.3252999E+06 |
| 1.02001 | 2.1036738E+03 | 1.3255407E+06 |
| 1.03002 | 2.1044850E+03 | 1.3259460E+06 |
| 1.04010 | 2.1053738E+03 | 1.3263933E+06 |
| 1.05011 | 2.1060053E+03 | 1.3266987E+06 |
| 1.06006 | 2.1063215E+03 | 1.3268299E+06 |
| 1.07003 | 2.1065103E+03 | 1.3268901E+06 |
| 1.08001 | 2.1065562E+03 | 1.3268717E+06 |
| 1.09002 | 2.1062535E+03 | 1.3266603E+06 |
| 1.10005 | 2.1054973E+03 | 1.3261987E+06 |
| 1.11001 | 2.1045159E+03 | 1.3256120E+06 |
| 1.12004 | 2.1036583E+03 | 1.3250948E+06 |
| 1.13020 | 2.1030886E+03 | 1.3247376E+06 |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revision: 17.1 Table: 14.3.4-16 Page: 7 of 12 |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|

TABLE 14.3.4-16

DOUBLE-ENDED SPRAY LINE BREAK

MASS AND ENERGY RELEASES

(When using this table, add 15% multiplier to mass & energy results.)

| Time (sec) | Mass (lb/sec) | Energy (BTU/sec) |
|---------------|------------------|---------------------|
| 1.14007 | 2.1028399E+03 | 1.3245581E+06 |
| 1.15004 | 2.1028392E+03 | 1.3245158E+06 |
| 1.16002 | 2.1030452E+03 | 1.3245891E+06 |
| 1.17008 | 2.1033358E+03 | 1.3247086E+06 |
| 1.18009 | 2.1036084E+03 | 1.3248175E+06 |
| 1.19008 | 2.1038945E+03 | 1.3249345E+06 |
| 1.20005 | 2.1041572E+03 | 1.3250391E+06 |
| 1.21005 | 2.1041987E+03 | 1.3250213E+06 |
| 1.22004 | 2.1038425E+03 | 1.3247830E+06 |
| 1.23001 | 2.1031332E+03 | 1.3243498E+06 |
| 1.24003 | 2.1022976E+03 | 1.3238470E+06 |
| 1.25007 | 2.1014833E+03 | 1.3233569E+06 |
| 1.26010 | 2.1007977E+03 | 1.3229378E+06 |
| 1.27007 | 2.1002438E+03 | 1.3225929E+06 |
| 1.28000 | 2.0998158E+03 | 1.3223173E+06 |
| 1.29006 | 2.0995386E+03 | 1.3221250E+06 |
| 1.30006 | 2.0993915E+03 | 1.3220048E+06 |
| 1.31013 | 2.0994058E+03 | 1.3219736E+06 |
| 1.32023 | 2.0995298E+03 | 1.3220039E+06 |
| 1.33005 | 2.0995986E+03 | 1.3220040E+06 |
| 1.34003 | 2.0994684E+03 | 1.3218931E+06 |
| 1.35003 | 2.0990790E+03 | 1.3216402E+06 |
| 1.36003 | 2.0984545E+03 | 1.3212564E+06 |
| 1.37021 | 2.0977429E+03 | 1.3208245E+06 |
| 1.38008 | 2.0969880E+03 | 1.3203695E+06 |
| 1.39003 | 2.0962009E+03 | 1.3198970E+06 |
| 1.40007 | 2.0954355E+03 | 1.3194364E+06 |
| 1.41000 | 2.0947605E+03 | 1.3190272E+06 |
| 1.42008 | 2.0941729E+03 | 1.3186648E+06 |
| 1.43000 | 2.0937703E+03 | 1.3184063E+06 |
| 1.44009 | 2.0935338E+03 | 1.3182384E+06 |
| 1.45002 | 2.0933865E+03 | 1.3181211E+06 |
| 1.46007 | 2.0932071E+03 | 1.3179859E+06 |
| 1.47003 | 2.0929094E+03 | 1.3177850E+06 |
| 1.48002 | 2.0924851E+03 | 1.3175144E+06 |
| 1.49013 | 2.0919562E+03 | 1.3171856E+06 |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revision: 17.1 Table: 14.3.4-16 Page: 8 of 12 |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|

TABLE 14.3.4-16

DOUBLE-ENDED SPRAY LINE BREAK

MASS AND ENERGY RELEASES

(When using this table, add 15% multiplier to mass & energy results.)

| Time (sec) | Mass (lb/sec) | Energy (BTU/sec) |
|---------------|------------------|---------------------|
| 1.50005 | 2.0913287E+03 | 1.3168027E+06 |
| 1.51010 | 2.0906026E+03 | 1.3163655E+06 |
| 1.52003 | 2.0897881E+03 | 1.3158794E+06 |
| 1.53000 | 2.0889400E+03 | 1.3153753E+06 |
| 1.54004 | 2.0881300E+03 | 1.3148919E+06 |
| 1.55003 | 2.0874180E+03 | 1.3144632E+06 |
| 1.56002 | 2.0868363E+03 | 1.3141071E+06 |
| 1.57009 | 2.0863657E+03 | 1.3138119E+06 |
| 1.58003 | 2.0859830E+03 | 1.3135658E+06 |
| 1.59008 | 2.0856058E+03 | 1.3133222E+06 |
| 1.60014 | 2.0852041E+03 | 1.3130654E+06 |
| 1.61003 | 2.0847664E+03 | 1.3127889E+06 |
| 1.62002 | 2.0842650E+03 | 1.3124767E+06 |
| 1.63000 | 2.0836788E+03 | 1.3121187E+06 |
| 1.64000 | 2.0829808E+03 | 1.3116980E+06 |
| 1.65005 | 2.0822069E+03 | 1.3112361E+06 |
| 1.66001 | 2.0813530E+03 | 1.3107288E+06 |
| 1.67010 | 2.0805367E+03 | 1.3102429E+06 |
| 1.68013 | 2.0797667E+03 | 1.3097828E+06 |
| 1.69008 | 2.0790890E+03 | 1.3093745E+06 |
| 1.70008 | 2.0784817E+03 | 1.3090042E+06 |
| 1.71005 | 2.0779442E+03 | 1.3086733E+06 |
| 1.72006 | 2.0774536E+03 | 1.3083681E+06 |
| 1.73003 | 2.0769919E+03 | 1.3080787E+06 |
| 1.74005 | 2.0765358E+03 | 1.3077923E+06 |
| 1.75017 | 2.0760313E+03 | 1.3074793E+06 |
| 1.76021 | 2.0754782E+03 | 1.3071398E+06 |
| 1.77003 | 2.0748364E+03 | 1.3067506E+06 |
| 1.78009 | 2.0741177E+03 | 1.3063189E+06 |
| 1.79004 | 2.0733817E+03 | 1.3058784E+06 |
| 1.80001 | 2.0725989E+03 | 1.3054116E+06 |
| 1.81000 | 2.0718428E+03 | 1.3049592E+06 |
| 1.82003 | 2.0711342E+03 | 1.3045334E+06 |
| 1.83004 | 2.0704825E+03 | 1.3041393E+06 |
| 1.84005 | 2.0698712E+03 | 1.3037673E+06 |
| 1.85006 | 2.0693256E+03 | 1.3034315E+06 |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revision: 17.1 Table: 14.3.4-16 Page: 9 of 12 |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|

TABLE 14.3.4-16

DOUBLE-ENDED SPRAY LINE BREAK

MASS AND ENERGY RELEASES

(When using this table, add 15% multiplier to mass & energy results.)

| Time (sec) | Mass (lb/sec) | Energy (BTU/sec) |
|---------------|------------------|---------------------|
| 1.86007 | 2.0688391E+03 | 1.3031290E+06 |
| 1.87004 | 2.0683537E+03 | 1.3028266E+06 |
| 1.88007 | 2.0678600E+03 | 1.3025183E+06 |
| 1.89005 | 2.0673398E+03 | 1.3021967E+06 |
| 1.90017 | 2.0667719E+03 | 1.3018481E+06 |
| 1.91001 | 2.0661520E+03 | 1.3014713E+06 |
| 1.92008 | 2.0654916E+03 | 1.3010717E+06 |
| 1.93007 | 2.0647986E+03 | 1.3006537E+06 |
| 1.94002 | 2.0641131E+03 | 1.3002406E+06 |
| 1.95002 | 2.0634306E+03 | 1.2998286E+06 |
| 1.96004 | 2.0627835E+03 | 1.2994362E+06 |
| 1.97001 | 2.0621900E+03 | 1.2990740E+06 |
| 1.98001 | 2.0616378E+03 | 1.2987343E+06 |
| 1.99001 | 2.0611133E+03 | 1.2984091E+06 |
| 2.00006 | 2.0606351E+03 | 1.2981098E+06 |
| 2.01017 | 2.0601755E+03 | 1.2978210E+06 |
| 2.02002 | 2.0596908E+03 | 1.2975184E+06 |
| 2.03010 | 2.0591909E+03 | 1.2972067E+06 |
| 2.04002 | 2.0586654E+03 | 1.2968812E+06 |
| 2.05018 | 2.0581050E+03 | 1.2965364E+06 |
| 2.06005 | 2.0575012E+03 | 1.2961667E+06 |
| 2.07004 | 2.0568982E+03 | 1.2957985E+06 |
| 2.08009 | 2.0562820E+03 | 1.2954219E+06 |
| 2.09012 | 2.0556887E+03 | 1.2950588E+06 |
| 2.10002 | 2.0551138E+03 | 1.2947052E+06 |
| 2.11010 | 2.0545765E+03 | 1.2943725E+06 |
| 2.12013 | 2.0540837E+03 | 1.2940645E+06 |
| 2.13010 | 2.0536205E+03 | 1.2937729E+06 |
| 2.14019 | 2.0531798E+03 | 1.2934939E+06 |
| 2.15007 | 2.0527452E+03 | 1.2932172E+06 |
| 2.16008 | 2.0523014E+03 | 1.2929356E+06 |
| 2.17003 | 2.0518411E+03 | 1.2926450E+06 |
| 2.18009 | 2.0513588E+03 | 1.2923422E+06 |
| 2.19004 | 2.0508552E+03 | 1.2920279E+06 |
| 2.20009 | 2.0503249E+03 | 1.2916980E+06 |
| 2.21011 | 2.0497884E+03 | 1.2913649E+06 |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 17.1</p> <p>Table: 14.3.4-16</p> <p>Page: 10 of 12</p> |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------|

TABLE 14.3.4-16

DOUBLE-ENDED SPRAY LINE BREAK

MASS AND ENERGY RELEASES

(When using this table, add 15% multiplier to mass & energy results.)

| Time (sec) | Mass (lb/sec) | Energy (BTU/sec) |
|---------------|------------------|---------------------|
| 2.22017 | 2.0492528E+03 | 1.2910321E+06 |
| 2.23014 | 2.0487253E+03 | 1.2907039E+06 |
| 2.24005 | 2.0482384E+03 | 1.2903987E+06 |
| 2.25001 | 2.0477626E+03 | 1.2900986E+06 |
| 2.26009 | 2.0473225E+03 | 1.2898187E+06 |
| 2.27004 | 2.0468923E+03 | 1.2895433E+06 |
| 2.28001 | 2.0465016E+03 | 1.2892908E+06 |
| 2.29005 | 2.0460991E+03 | 1.2890308E+06 |
| 2.30001 | 2.0456898E+03 | 1.2887674E+06 |
| 2.31012 | 2.0452463E+03 | 1.2884848E+06 |
| 2.32007 | 2.0448340E+03 | 1.2882196E+06 |
| 2.33014 | 2.0443954E+03 | 1.2879401E+06 |
| 2.34004 | 2.0439367E+03 | 1.2876484E+06 |
| 2.35001 | 2.0434889E+03 | 1.2873633E+06 |
| 2.36011 | 2.0430542E+03 | 1.2870850E+06 |
| 2.37008 | 2.0426322E+03 | 1.2868139E+06 |
| 2.38012 | 2.0422433E+03 | 1.2865609E+06 |
| 2.39005 | 2.0418693E+03 | 1.2863161E+06 |
| 2.40004 | 2.0415246E+03 | 1.2860877E+06 |
| 2.41008 | 2.0412113E+03 | 1.2858761E+06 |
| 2.42005 | 2.0408975E+03 | 1.2856645E+06 |
| 2.43008 | 2.0406149E+03 | 1.2854698E+06 |
| 2.44013 | 2.0403182E+03 | 1.2852674E+06 |
| 2.45001 | 2.0400192E+03 | 1.2850640E+06 |
| 2.46020 | 2.0397042E+03 | 1.2848514E+06 |
| 2.47007 | 2.0393890E+03 | 1.2846382E+06 |
| 2.48001 | 2.0390787E+03 | 1.2844277E+06 |
| 2.49005 | 2.0387565E+03 | 1.2842108E+06 |
| 2.50017 | 2.0384506E+03 | 1.2840029E+06 |
| 2.51008 | 2.0381551E+03 | 1.2838008E+06 |
| 2.52000 | 2.0378823E+03 | 1.2836107E+06 |
| 2.53003 | 2.0376188E+03 | 1.2834258E+06 |
| 2.54003 | 2.0373717E+03 | 1.2832502E+06 |
| 2.55004 | 2.0371414E+03 | 1.2830827E+06 |
| 2.56007 | 2.0369174E+03 | 1.2829200E+06 |
| 2.57007 | 2.0367206E+03 | 1.2827722E+06 |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revision: 17.1 Table: 14.3.4-16 Page: 11 of 12 |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------|

TABLE 14.3.4-16

DOUBLE-ENDED SPRAY LINE BREAK

MASS AND ENERGY RELEASES

(When using this table, add 15% multiplier to mass & energy results.)

| Time (sec) | Mass (lb/sec) | Energy (BTU/sec) |
|---------------|------------------|---------------------|
| 2.58005 | 2.0365020E+03 | 1.2826116E+06 |
| 2.59008 | 2.0362817E+03 | 1.2824507E+06 |
| 2.60014 | 2.0360644E+03 | 1.2822909E+06 |
| 2.61006 | 2.0358300E+03 | 1.2821214E+06 |
| 2.62001 | 2.0355880E+03 | 1.2819481E+06 |
| 2.63008 | 2.0353598E+03 | 1.2817817E+06 |
| 2.64006 | 2.0351206E+03 | 1.2816095E+06 |
| 2.65009 | 2.0349045E+03 | 1.2814499E+06 |
| 2.66003 | 2.0346896E+03 | 1.2812913E+06 |
| 2.67013 | 2.0344844E+03 | 1.2811382E+06 |
| 2.68004 | 2.0342912E+03 | 1.2809913E+06 |
| 2.69000 | 2.0341169E+03 | 1.2808550E+06 |
| 2.70009 | 2.0339484E+03 | 1.2807220E+06 |
| 2.71006 | 2.0337700E+03 | 1.2805830E+06 |
| 2.72003 | 2.0335952E+03 | 1.2804464E+06 |
| 2.73003 | 2.0334197E+03 | 1.2803093E+06 |
| 2.74018 | 2.0332272E+03 | 1.2801628E+06 |
| 2.75014 | 2.0330332E+03 | 1.2800152E+06 |
| 2.76007 | 2.0328279E+03 | 1.2798616E+06 |
| 2.77002 | 2.0326244E+03 | 1.2797091E+06 |
| 2.78002 | 2.0324222E+03 | 1.2795567E+06 |
| 2.79008 | 2.0322290E+03 | 1.2794097E+06 |
| 2.80006 | 2.0320428E+03 | 1.2792666E+06 |
| 2.81009 | 2.0318584E+03 | 1.2791244E+06 |
| 2.82006 | 2.0316917E+03 | 1.2789921E+06 |
| 2.83006 | 2.0315113E+03 | 1.2788520E+06 |
| 2.84015 | 2.0313383E+03 | 1.2787161E+06 |
| 2.85005 | 2.0311662E+03 | 1.2785814E+06 |
| 2.86003 | 2.0309809E+03 | 1.2784384E+06 |
| 2.87004 | 2.0307972E+03 | 1.2782965E+06 |
| 2.88006 | 2.0306091E+03 | 1.2781518E+06 |
| 2.89010 | 2.0304103E+03 | 1.2780018E+06 |
| 2.90019 | 2.0302106E+03 | 1.2778513E+06 |
| 2.91001 | 2.0299968E+03 | 1.2776931E+06 |
| 2.92007 | 2.0297956E+03 | 1.2775412E+06 |
| 2.93007 | 2.0295874E+03 | 1.2773863E+06 |

UFSAR Revision 30.0

| | | |
|----------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|---------------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 17.1 Table: 14.3.4-16 Page: 12 of 12</p> |
|----------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|---------------------------------------------------------------|

TABLE 14.3.4-16

DOUBLE-ENDED SPRAY LINE BREAK

MASS AND ENERGY RELEASES

(When using this table, add 15% multiplier to mass & energy results.)

| Time (sec) | Mass (lb/sec) | Energy (BTU/sec) |
|---------------|------------------|---------------------|
| 2.94014 | 2.0293708E+03 | 1.2772257E+06 |
| 2.95003 | 2.0291890E+03 | 1.2770853E+06 |
| 2.96002 | 2.0289876E+03 | 1.2769341E+06 |
| 2.97013 | 2.0287920E+03 | 1.2767858E+06 |
| 2.98010 | 2.0285960E+03 | 1.2766370E+06 |
| 2.99010 | 2.0283918E+03 | 1.2764839E+06 |
| 3.00017 | 2.0281887E+03 | 1.2763315E+06 |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revision: 17.1 Table: 14.3.4-17 Page: 1 of 2 |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------|

FAN ROOM - BACKFLOW CONTRIBUTION

| Time (sec) | Mass Flow Rate 10 ³ lb/sec | Energy Flow Rate 10 ⁶ BTU/sec |
|---------------|------------------------------------------|---------------------------------------------|
| 0 | 7.54 | 8.99 |
| .1 | 4.68 | 5.58 |
| .2 | 4.48 | 5.34 |
| .3 | 4.41 | 5.26 |
| .4 | 4.32 | 5.15 |
| .5 | 4.27 | 5.09 |
| .6 | 4.15 | 4.95 |
| .7 | 3.93 | 4.68 |
| .8 | 3.59 | 4.28 |
| .9 | 3.62 | 4.32 |
| 1.0 | 3.53 | 4.21 |
| 1.5 | 3.17 | 3.78 |
| 2.0 | 3.00 | 3.58 |
| 2.5 | 2.93 | 3.49 |
| 3.0 | 2.87 | 3.42 |
| 3.5 | 2.87 | 3.42 |
| 4.0 | 2.83 | 3.37 |
| 4.5 | 2.79 | 3.33 |
| 5.0 | 2.81 | 3.35 |
| 5.5 | 2.77 | 3.30 |
| 6.0 | 2.72 | 3.24 |
| 6.5 | 2.72 | 3.24 |
| 7.0 | 2.69 | 3.21 |
| 8.0 | 2.65 | 3.16 |
| 8.5 | 2.65 | 3.16 |
| 9.0 | 2.65 | 3.16 |
| 9.5 | 2.65 | 3.16 |
| 10.0 | 2.65 | 3.16 |

With 1.4 ft² orifice in cross-connect to steam dump header; break in longest line.

UFSAR Revision 30.0

| | | |
|---------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 17.1 Table: 14.3.4-17 Page: 2 of 2</p> |
|---------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|

FAN ROOM - FORWARD FLOW CONTRIBUTION

| Time (sec) | Mass Flow Rate 10 ³ lb/sec | Energy Flow Rate 10 ⁶ BTU/sec |
|------------|------------------------------------------|---------------------------------------------|
| 0 | 5.55 | 6.62 |
| .1 | 4.15 | 4.94 |
| .2 | 3.05 | 3.64 |
| .4 | 2.95 | 3.52 |
| .6 | 2.90 | 3.46 |
| .8 | 2.78 | 3.31 |
| 1.0 | 2.75 | 3.28 |
| 1.5 | 2.67 | 3.19 |
| 2.0 | 3.45 | 3.38 |
| 2.5 | 9.50 | 5.26 |
| 3.0 | 9.42 | 5.21 |
| 3.5 | 9.38 | 5.19 |
| 4.0 | 9.33 | 5.16 |
| 4.5 | 9.28 | 5.13 |
| 5.0 | 9.23 | 5.10 |
| 5.5 | 9.16 | 5.07 |
| 6.0 | 9.10 | 5.04 |
| 6.5 | 9.03 | 5.01 |
| 7.0 | 8.95 | 4.97 |
| 7.5 | 8.86 | 4.93 |
| 8.0 | 8.80 | 4.91 |
| 8.5 | 8.70 | 4.86 |
| 9.0 | 8.58 | 4.81 |
| 9.5 | 8.46 | 4.76 |
| 10.0 | 8.33 | 4.70 |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 17.1 Table: 14.3.4-18 Page: 1 of 2</p> |
|-----------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|

TABLE 14.3.4-18

DOUBLE-ENDED HOT LEG BREAK

MASS AND ENERGY RELEASES

| Time (sec) | Mass (lb/sec) | Energy (BTU/sec) |
|---------------|------------------|---------------------|
| 0.00000 | 0.000000+4 | 0.000000+6 |
| 0.00201 | 6.296400+4 | 3.616100+7 |
| 0.00401 | 7.377000+4 | 4.235700+7 |
| 0.00900 | 6.916800+4 | 3.973700+7 |
| 0.01200 | 7.047200+4 | 4.051200+7 |
| 0.01602 | 7.176400+4 | 4.127400+7 |
| 0.01800 | 7.220100+4 | 4.153500+7 |
| 0.02500 | 7.467100+4 | 4.308700+7 |
| 0.02600 | 9.129400+4 | 5.264000+7 |
| 0.03000 | 9.888800+4 | 5.705000+7 |
| 0.03100 | 9.359200+4 | 5.392400+7 |
| 0.03300 | 1.034800+5 | 5.976200+7 |
| 0.04100 | 9.387700+4 | 5.419200+7 |
| 0.04301 | 9.958000+4 | 5.748900+7 |
| 0.04500 | 9.310800+4 | 5.373800+7 |
| 0.04900 | 1.018200+5 | 5.884600+7 |
| 0.05300 | 9.121800+4 | 5.262800+7 |
| 0.05401 | 1.044100+5 | 6.038900+7 |
| 0.05501 | 9.202900+4 | 5.320000+7 |
| 0.05800 | 9.912800+4 | 5.729100+7 |
| 0.06000 | 9.173100+4 | 5.296500+7 |
| 0.06301 | 9.862900+4 | 5.702600+7 |
| 0.06400 | 9.010400+4 | 5.204400+7 |
| 0.06500 | 9.892900+4 | 5.723900+7 |
| 0.06701 | 9.587100+4 | 5.549400+7 |
| 0.06801 | 1.003200+5 | 5.805800+7 |

UFSAR Revision 30.0



INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT

Revision: 17.1
Table: 14.3.4-18
Page: 2 of 2

TABLE 14.3.4-18

DOUBLE-ENDED HOT LEG BREAK

MASS AND ENERGY RELEASES

| Time (sec) | Mass (lb/sec) | Energy (BTU/sec) |
|-----------------------|--------------------------|-----------------------------|
| 0.07101 | 9.013600+4 | 5.208200+7 |
| 0.07200 | 9.396300+4 | 5.452900+7 |
| 0.07501 | 8.496600+4 | 4.913900+7 |
| 0.07600 | 9.286800+4 | 5.381600+7 |
| 0.08000 | 9.345900+4 | 5.411400+7 |
| 0.08301 | 9.631400+4 | 5.578500+7 |
| 0.08900 | 9.182300+4 | 5.321800+7 |
| 0.09401 | 8.716100+4 | 5.049300+7 |
| 0.10002 | 8.686700+4 | 5.036900+7 |
| 0.10103 | 8.751800+4 | 5.074300+7 |
| 0.10702 | 8.667200+4 | 5.026600+7 |
| 0.11702 | 8.066200+4 | 4.679300+7 |
| 0.12400 | 7.836000+4 | 4.550000+7 |
| 0.13004 | 7.823800+4 | 4.547300+7 |
| 0.19005 | 6.766600+4 | 3.960300+7 |
| 0.40013 | 6.328000+4 | 3.674300+7 |
| 0.60020 | 6.005400+4 | 3.460400+7 |
| 1.00020 | 5.560800+4 | 3.192700+7 |
| 1.52020 | 5.046300+4 | 2.929200+7 |
| 2.00020 | 4.687700+4 | 2.759500+7 |
| 3.00000 | 4.687700+4 | 2.759500+7 |

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 17.1 Table: 14.3.4-19 Page: 1 of 2</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|

TABLE 14.3.4-19

SINGLE-ENDED COLD LEG BREAK

MASS AND ENERGY RELEASES

| Time (sec) | Mass (lb/sec) | Energy (BTU/sec) |
|---------------|------------------|---------------------|
| .00000 | 0.000000+4 | 0.000000+7 |
| .00200 | 2.4652E+04 | 1.2752E+07 |
| .00900 | 3.4491E+04 | 1.7946E+07 |
| .01400 | 5.0203E+04 | 2.6009E+07 |
| .02100 | 6.0914E+04 | 3.1606E+07 |
| .03203 | 7.2136E+04 | 3.7456E+07 |
| .04304 | 8.3502E+04 | 4.3434E+07 |
| .05101 | 8.5426E+04 | 4.4414E+07 |
| .06503 | 8.4836E+04 | 4.4078E+07 |
| .08305 | 8.0678E+04 | 4.1866E+07 |
| .09607 | 7.5506E+04 | 3.9152E+07 |
| .11001 | 7.4227E+04 | 3.8487E+07 |
| .13403 | 7.5861E+04 | 3.9362E+07 |
| .14601 | 7.6620E+04 | 3.9755E+07 |
| .16010 | 7.6233E+04 | 3.9551E+07 |
| .18303 | 7.5634E+04 | 3.9236E+07 |
| .19804 | 7.4886E+04 | 3.8846E+07 |
| .21101 | 7.3690E+04 | 3.8219E+07 |
| .23006 | 7.4895E+04 | 3.8860E+07 |
| .24610 | 7.5605E+04 | 3.9233E+07 |
| .25607 | 7.5224E+04 | 3.9028E+07 |
| .26309 | 7.4595E+04 | 3.8696E+07 |
| .28206 | 7.3024E+04 | 3.7873E+07 |
| .30006 | 7.3101E+04 | 3.7920E+07 |
| .31610 | 7.4255E+04 | 3.8528E+07 |
| .33509 | 7.4163E+04 | 3.8475E+07 |

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revision: 17.1 Table: 14.3.4-19 Page: 2 of 2 |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------|

TABLE 14.3.4-19

SINGLE-ENDED COLD LEG BREAK

MASS AND ENERGY RELEASES

| Time (sec) | Mass (lb/sec) | Energy (BTU/sec) |
|---------------|------------------|---------------------|
| .35108 | 7.4723E+04 | 3.8773E+07 |
| .37109 | 7.3988E+04 | 3.8382E+07 |
| .41506 | 7.5856E+04 | 3.9368E+07 |
| .44107 | 7.5568E+04 | 3.9214E+07 |
| .46702 | 7.4918E+04 | 3.8871E+07 |
| .49303 | 7.4959E+04 | 3.8896E+07 |
| .53003 | 7.4459E+04 | 3.8635E+07 |
| .64516 | 7.3810E+04 | 3.8313E+07 |
| .69503 | 7.3409E+04 | 3.8118E+07 |
| .73001 | 7.3524E+04 | 3.8194E+07 |
| .77006 | 7.3550E+04 | 3.8224E+07 |
| .83001 | 7.1814E+04 | 3.7342E+07 |
| .87509 | 7.2210E+04 | 3.7577E+07 |
| .92001 | 7.1425E+04 | 3.7191E+07 |
| .96002 | 7.1669E+04 | 3.7344E+07 |
| 1.0400 | 7.0980E+04 | 3.7031E+07 |
| 1.1701 | 7.0215E+04 | 3.6723E+07 |
| 1.3202 | 6.9872E+04 | 3.6671E+07 |
| 1.4001 | 6.9903E+04 | 3.6760E+07 |
| 1.7002 | 6.5502E+04 | 3.4750E+07 |
| 2.0000 | 6.2185E+04 | 3.3253E+07 |
| 2.5001 | 5.5091E+04 | 2.9852E+07 |
| 3.0002 | 4.8491E+04 | 2.6562E+07 |
| 5.0000 | 4.8491E+04 | 2.6562E+07 |

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 17.1 Table: 14.3.4-20 Page: 1 of 2</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|

TABLE 14.3.4-20

SINGLE-ENDED HOT LEG BREAK

MASS AND ENERGY RELEASES

| Time (sec) | Mass (lb/sec) | Energy (BTU/sec) |
|---------------|------------------|---------------------|
| .00000 | 0.000000+4 | 0.000000+7 |
| .00100 | 2.986053E+04 | 1.811825E+07 |
| .00301 | 4.343918E+04 | 2.634650E+07 |
| .00501 | 4.292521E+04 | 2.602551E+07 |
| .01001 | 4.446135E+04 | 2.695169E+07 |
| .01400 | 5.141999E+04 | 3.123442E+07 |
| .01700 | 4.673055E+04 | 2.831411E+07 |
| .02200 | 4.933676E+04 | 2.992951E+07 |
| .02700 | 6.370431E+04 | 3.867952E+07 |
| .03301 | 7.988087E+04 | 4.855038E+07 |
| .03901 | 7.280847E+04 | 4.417453E+07 |
| .05001 | 7.321976E+04 | 4.444181E+07 |
| .06002 | 6.824339E+04 | 4.137223E+07 |
| .06503 | 6.529671E+04 | 3.957400E+07 |
| .07204 | 6.781116E+04 | 4.112542E+07 |
| .08003 | 6.387430E+04 | 3.870615E+07 |
| .08701 | 6.107294E+04 | 3.699999E+07 |
| .09200 | 6.153000E+04 | 3.728505E+07 |
| .10101 | 5.928957E+04 | 3.591744E+07 |
| .11003 | 5.571592E+04 | 3.374574E+07 |
| .12001 | 5.454139E+04 | 3.303515E+07 |
| .13202 | 5.230680E+04 | 3.168585E+07 |
| .14102 | 5.268915E+04 | 3.193353E+07 |
| .14802 | 5.253517E+04 | 3.184939E+07 |
| .16105 | 5.355463E+04 | 3.248006E+07 |
| .17003 | 5.336413E+04 | 3.235884E+07 |

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 17.1 Table: 14.3.4-20 Page: 2 of 2</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|

TABLE 14.3.4-20

SINGLE-ENDED HOT LEG BREAK

MASS AND ENERGY RELEASES

| Time (sec) | Mass (lb/sec) | Energy (BTU/sec) |
|---------------|------------------|---------------------|
| .18500 | 5.353877E+04 | 3.246602E+07 |
| .20003 | 5.186517E+04 | 3.149525E+07 |
| .22500 | 4.640067E+04 | 2.829631E+07 |
| .25002 | 4.433356E+04 | 2.709931E+07 |
| .30003 | 4.316692E+04 | 2.649927E+07 |
| .32811 | 4.406912E+04 | 2.715201E+07 |
| .35016 | 4.359122E+04 | 2.691206E+07 |
| .40004 | 4.291035E+04 | 2.645033E+07 |
| .42302 | 4.323305E+04 | 2.665236E+07 |
| .45011 | 4.282392E+04 | 2.641563E+07 |
| .52004 | 4.230519E+04 | 2.601617E+07 |
| .60016 | 4.197678E+04 | 2.568951E+07 |
| .70035 | 4.194488E+04 | 2.555825E+07 |
| .80004 | 4.204749E+04 | 2.547428E+07 |
| .88531 | 4.220963E+04 | 2.546782E+07 |
| 1.00012 | 4.190713E+04 | 2.535124E+07 |
| 1.50000 | 3.994366E+04 | 2.439612E+07 |
| 2.00023 | 3.835372E+04 | 2.358048E+07 |
| 2.50028 | 3.711276E+04 | 2.282196E+07 |
| 3.00016 | 3.583929E+04 | 2.204359E+07 |
| 5.00000 | 3.583929E+04 | 2.204359E+07 |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------|----------------------------------------------------|
|  An AEP Company | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revision: 17.1 Table: 14.3.4-21 Page: 1 of 1 |
|-----------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------|----------------------------------------------------|

TABLE 14.3.4-21

STEAM GENERATOR ENCLOSURE – TMD VOLUME INPUT

| TMD Node | Volume (ft ³) |
|----------|---------------------------|
| 46 | 4106 |
| 47 | 1125 |
| 48 | 634 |
| 49 | 615 |
| 50 | 1021 |
| 51 | 1076 |
| 52 | 669 |
| 53 | 661 |
| 54 | 998 |
| 55 | 3900 |
| 56 | 1030 |
| 57 | 634 |
| 58 | 615 |
| 59 | 807 |
| 60 | 990 |
| 61 | 669 |
| 62 | 661 |
| 63 | 801 |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 17.1</p> <p>Table: 14.3.4-22</p> <p>Page: 1 of 3</p> |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------|

TABLE 14.3.4-22

PRESSURIZER ENCLOSURE MODEL – TMD VOLUME INPUT

| TMD Node | Description | Volume (ft ³) | TMD Node Unique to this Model | TMD Node Common to Loop Subcompartment Model |
|----------|------------------|---------------------------|-------------------------------|----------------------------------------------|
| 1 | Loop Compartment | 2.2415E+04 | No | Yes |
| 2 | Loop Compartment | 2.2845E+04 | No | Yes |
| 3 | Loop Compartment | 4.1329E+04 | No | Yes |
| 4 | Loop Compartment | 2.7398E+04 | No | Yes |
| 5 | Loop Compartment | 2.2839E+04 | No | Yes |
| 6 | Loop Compartment | 1.9921E+04 | No | Yes |
| 7 | Ice Condenser | 3.5230E+03 | No | Yes |
| 8 | Ice Condenser | 3.5230E+03 | No | Yes |
| 9 | Ice Condenser | 3.4090E+03 | No | Yes |
| 10 | Ice Condenser | 4.1660E+03 | No | Yes |
| 11 | Ice Condenser | 4.1660E+03 | No | Yes |
| 12 | Ice Condenser | 4.0330E+03 | No | Yes |
| 13 | Ice Condenser | 8.3300E+03 | No | Yes |
| 14 | Ice Condenser | 8.3300E+03 | No | Yes |
| 15 | Ice Condenser | 8.0590E+03 | No | Yes |
| 16 | Ice Condenser | 5.7680E+03 | No | Yes |
| 17 | Ice Condenser | 5.7680E+03 | No | Yes |
| 18 | Ice Condenser | 5.5800E+03 | No | Yes |
| 19 | Ice Condenser | 4.4850E+03 | No | Yes |
| 20 | Ice Condenser | 4.4850E+03 | No | Yes |
| 21 | Ice Condenser | 4.3400E+03 | No | Yes |
| 22 | Ice Condenser | 4.4850E+03 | No | Yes |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 17.1 Table: 14.3.4-22 Page: 2 of 3</p> |
|-----------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|

TABLE 14.3.4-22

PRESSURIZER ENCLOSURE MODEL – TMD VOLUME INPUT

| TMD Node | Description | Volume (ft ³) | TMD Node Unique to this Model | TMD Node Common to Loop Subcompartment Model |
|----------|----------------------|---------------------------|-------------------------------|----------------------------------------------|
| 23 | Ice Condenser | 4.4850E+03 | No | Yes |
| 24 | Ice Condenser | 4.3400E+03 | No | Yes |
| 25 | Upper Containment | 7.3432E+05 | No | Yes |
| 26 | Pipe Trench | 1.0435E+04 | No | Yes |
| 27 | Fan/Accumulator Room | 2.6969E+04 | No | Yes |
| 28 | Pipe Trench | 1.0435E+04 | No | Yes |
| 29 | Instrument Room | 1.7479E+04 | No | Yes |
| 30 | Pipe Trench | 1.0435E+04 | No | Yes |
| 31 | Fan/Accumulator Room | 2.6969E+04 | No | Yes |
| 32 | Pipe Trench | 1.0435E+04 | No | Yes |
| 33 | Upper Reactor Cavity | 1.8012E+04 | No | Yes |
| 34 | Ice Condenser | 5.3850E+03 | No | Yes |
| 35 | Ice Condenser | 6.3650E+03 | No | Yes |
| 36 | Ice Condenser | 1.2729E+04 | No | Yes |
| 37 | Ice Condenser | 8.8130E+03 | No | Yes |
| 38 | Ice Condenser | 6.8540E+03 | No | Yes |
| 39 | Ice Condenser | 6.8540E+03 | No | Yes |
| 40 | Ice Condenser | 2.8910E+03 | No | Yes |
| 41 | Ice Condenser | 3.4180E+03 | No | Yes |
| 42 | Ice Condenser | 6.8350E+03 | No | Yes |
| 43 | Ice Condenser | 4.7320E+03 | No | Yes |
| 44 | Ice Condenser | 3.6810E+03 | No | Yes |
| 45 | Ice Condenser | 3.6810E+03 | No | Yes |

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 17.1 Table: 14.3.4-22 Page: 3 of 3</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|

TABLE 14.3.4-22

PRESSURIZER ENCLOSURE MODEL – TMD VOLUME INPUT

| TMD Node | Description | Volume (ft ³) | TMD Node Unique to this Model | TMD Node Common to Loop Subcompartment Model |
|----------|-----------------------|---------------------------|-------------------------------|----------------------------------------------|
| 46 | Pressurizer Enclosure | 1.5517E+03 | Yes | No |
| 47 | Pressurizer Enclosure | 3.0260E+02 | Yes | No |
| 48 | Pressurizer Enclosure | 4.3106E+02 | Yes | No |
| 49 | Pressurizer Enclosure | 3.5367E+02 | Yes | No |

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------|----------------------------------------------------|
|  An AEP Company | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revision: 17.1 Table: 14.3.4-23 Page: 1 of 1 |
|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------|----------------------------------------------------|

TABLE 14.3.4-23

FAN ACCUMULATOR ROOM MODEL – TMD VOLUME INPUT

| TMD Node | Volume (ft ³) |
|----------|---------------------------|
| | |
| 27 | 3800 |
| 54 | 4000 |
| 55 | 7800 |
| 56 | 4300 |
| 57 | 4400 |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revision: 17.1 Table: 14.3.4-24 Page: 1 of 3 |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------|

TABLE 14.3.4-24

LOOP SUBCOMPARTMENT MODEL – TMD VOLUME INPUT

| TMD Node | Description | Volume (ft ³) | TMD Node Unique to this Model | TMD Node Common to Pressurizer Enclosure & Steam Generator Enclosure Models |
|----------|------------------|---------------------------|-------------------------------|-----------------------------------------------------------------------------|
| 1 | Loop Compartment | 2.2415E+04 | No | Yes |
| 2 | Loop Compartment | 2.2845E+04 | No | Yes |
| 3 | Loop Compartment | 4.1329E+04 | No | Yes |
| 4 | Loop Compartment | 2.7398E+04 | No | Yes |
| 5 | Loop Compartment | 2.2839E+04 | No | Yes |
| 6 | Loop Compartment | 1.9921E+04 | No | Yes |
| 7 | Ice Condenser | 3.5230E+03 | No | Yes |
| 8 | Ice Condenser | 3.5230E+03 | No | Yes |
| 9 | Ice Condenser | 3.4090E+03 | No | Yes |
| 10 | Ice Condenser | 4.1660E+03 | No | Yes |
| 11 | Ice Condenser | 4.1660E+03 | No | Yes |
| 12 | Ice Condenser | 4.0330E+03 | No | Yes |
| 13 | Ice Condenser | 8.3300E+03 | No | Yes |
| 14 | Ice Condenser | 8.3300E+03 | No | Yes |
| 15 | Ice Condenser | 8.0590E+03 | No | Yes |
| 16 | Ice Condenser | 5.7680E+03 | No | Yes |
| 17 | Ice Condenser | 5.7680E+03 | No | Yes |
| 18 | Ice Condenser | 5.5800E+03 | No | Yes |
| 19 | Ice Condenser | 4.4850E+03 | No | Yes |
| 20 | Ice Condenser | 4.4850E+03 | No | Yes |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 17.1</p> <p>Table: 14.3.4-24</p> <p>Page: 2 of 3</p> |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------|

TABLE 14.3.4-24

LOOP SUBCOMPARTMENT MODEL – TMD VOLUME INPUT

| TMD Node | Description | Volume (ft ³) | TMD Node Unique to this Model | TMD Node Common to Pressurizer Enclosure & Steam Generator Enclosure Models |
|----------|----------------------|---------------------------|-------------------------------|-----------------------------------------------------------------------------|
| 21 | Ice Condenser | 4.3400E+03 | No | Yes |
| 22 | Ice Condenser | 4.4850E+03 | No | Yes |
| 23 | Ice Condenser | 4.4850E+03 | No | Yes |
| 24 | Ice Condenser | 4.3400E+03 | No | Yes |
| 25 | Upper Containment | 7.3432E+05 | No | Yes |
| 26 | Pipe Trench | 1.0435E+04 | No | Yes |
| 27 | Fan/Accumulator Room | 2.6969E+04 | No | Yes |
| 28 | Pipe Trench | 1.0435E+04 | No | Yes |
| 29 | Instrument Room | 1.7479E+04 | No | Yes |
| 30 | Pipe Trench | 1.0435E+04 | No | Yes |
| 31 | Fan/Accumulator Room | 2.6969E+04 | No | Yes |
| 32 | Pipe Trench | 1.0435E+04 | No | Yes |
| 33 | Upper Reactor Cavity | 1.8012E+04 | No | Yes |
| 34 | Ice Condenser | 5.3850E+03 | No | Yes |
| 35 | Ice Condenser | 6.3650E+03 | No | Yes |
| 36 | Ice Condenser | 1.2729E+04 | No | Yes |
| 37 | Ice Condenser | 8.8130E+03 | No | Yes |
| 38 | Ice Condenser | 6.8540E+03 | No | Yes |
| 39 | Ice Condenser | 6.8540E+03 | No | Yes |
| 40 | Ice Condenser | 2.8910E+03 | No | Yes |

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revision: 17.1 Table: 14.3.4-24 Page: 3 of 3 |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------|

TABLE 14.3.4-24

LOOP SUBCOMPARTMENT MODEL – TMD VOLUME INPUT

| TMD Node | Description | Volume (ft ³) | TMD Node Unique to this Model | TMD Node Common to Pressurizer Enclosure & Steam Generator Enclosure Models |
|----------|---------------------------|---------------------------|-------------------------------|-----------------------------------------------------------------------------|
| 41 | Ice Condenser | 3.4180E+03 | No | Yes |
| 42 | Ice Condenser | 6.8350E+03 | No | Yes |
| 43 | Ice Condenser | 4.7320E+03 | No | Yes |
| 44 | Ice Condenser | 3.6810E+03 | No | Yes |
| 45 | Ice Condenser | 3.6810E+03 | No | Yes |
| 46 | Steam Generator Enclosure | 3.4040E+03 | Yes | No |
| 47 | Steam Generator Enclosure | 3.1210E+03 | Yes | No |
| 48 | Steam Generator Enclosure | 3.1210E+03 | Yes | No |
| 49 | Steam Generator Enclosure | 3.4040E+03 | Yes | No |
| 50 | Steam Generator Enclosure | 7.5010E+03 | Yes | No |
| 51 | Steam Generator Enclosure | 6.9860E+03 | Yes | No |
| 52 | Steam Generator Enclosure | 6.9860E+03 | Yes | No |
| 53 | Steam Generator Enclosure | 7.5010E+03 | Yes | No |

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 17.1 Table: 14.3.4-25 Page: 1 of 4</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|

TABLE 14.3.4-25

REACTOR CAVITY – TMD VOLUME INPUT MODEL

| TMD Node | Volume (ft ³) |
|----------|-------------------------------------------------------|
| 1 | Break Location (CPS 189) – Inspection Volume 131.4 |
| 2 | Lower Reactor Cavity – Below RPV 3724.9 |
| 3 | Reactor Vessel Annular Region 7.2 |
| 4 | Reactor Vessel Annular Region 0.6 |
| 5 | Reactor Vessel Annular Region 3.5 |
| 6 | Reactor Vessel Annular Region 4.1 |
| 7 | Reactor Vessel Annular Region 0.6 |
| 8 | Reactor Vessel Annular Region 44.8 |
| 9 | Reactor Vessel Annular Region 0.6 |
| 10 | Reactor Vessel Annular Region 3.4 |
| 11 | Reactor Vessel Annular Region 4.0 |
| 12 | Reactor Vessel Annular Region 0.5 |
| 13 | Reactor Vessel Annular Region 43.8 |
| 14 | Reactor Vessel Annular Region 0.6 |
| 15 | Reactor Vessel Annular Region 3.4 |
| 16 | Reactor Vessel Annular Region 5.6 |
| 17 | Reactor Vessel Annular Region 2.7 |
| 18 | Reactor Vessel Annular Region 43.8 |
| 19 | Reactor Vessel Annular Region 7.7 |

Unit 1

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 17.1 Table: 14.3.4-25 Page: 2 of 4</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|

TABLE 14.3.4-25

REACTOR CAVITY – TMD VOLUME INPUT MODEL

| TMD Node | Volume (ft ³) |
|----------|-----------------------------------------|
| 20 | Reactor Vessel Annular Region 11.0 |
| 21 | Reactor Vessel Annular Region 91.0 |
| 22 | Reactor Vessel Annular Region 18.9 |
| 23 | Reactor Vessel Annular Region 92.8 |
| 24 | Reactor Vessel Annular Region 19.0 |
| 25 | Reactor Vessel Annular Region 94.6 |
| 26 | Reactor Vessel Annular Region 18.9 |
| 27 | Reactor Vessel Annular Region 92.8 |
| 28 | Reactor Vessel Annular Region 18.7 |
| 29 | Reactor Vessel Annular Region 91.0 |
| 30 | Reactor Vessel Annular Region 7.9 |
| 31 | Reactor Vessel Annular Region 11.0 |
| 32 | Reactor Vessel Annular Region 92.8 |
| 33 | Reactor Vessel Annular Region 0.6 |
| 34 | Reactor Vessel Annular Region 3.5 |
| 35 | Reactor Vessel Annular Region 5.5 |
| 36 | Reactor Vessel Annular Region 2.5 |
| 37 | Reactor Vessel Annular Region 44.8 |
| 38 | Upper Reactor Cavity 15720.9 |
| 39 | Inspection Volume (CPS 188) 135.0 |

Unit 1

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 17.1 Table: 14.3.4-25 Page: 3 of 4</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|

TABLE 14.3.4-25

REACTOR CAVITY – TMD VOLUME INPUT MODEL

| TMD Node | Description | Volume (ft ³) |
|----------|------------------------------------------------|---------------------------|
| 40 | Inspection Volume (CPS 187) | 132.1 |
| 41 | Inspection Volume Port & Pipe Sleeve (CPS 186) | 217.5 |
| 42 | Inspection Volume Port & Pipe Sleeve (CPS 185) | 214.0 |
| 43 | Inspection Volume Port & Pipe Sleeve (CPS 184) | 214.0 |
| 44 | Inspection Volume (CPS 183) | 132.1 |
| 45 | Inspection Volume (CPS 182) | 133.2 |
| 46 | Broken Loop Pipe Sleeve (CPS 189) | 75.2 |
| 47 | Unbroken Loop Pipe Sleeve (CPS 188) | 26.7 |
| 48 | Unbroken Loop Pipe Sleeve (CPS 187) | 26.7 |
| 49 | Unbroken Loop Pipe Sleeve (CPS 183) | 26.7 |
| 50 | Unbroken Loop Pipe Sleeve (CPS 182) | 61.1 |
| 51 | Loop Compartment | 147644.0 |
| 52 | Loop Compartment | 147644.0 |
| 53 | Broken Loop Inspection Port (CPS 189) | 46.900 |
| 54 | Unbroken Loop Inspection Port (CPS 188) | 52.2 |
| 55 | Unbroken Loop Inspection Port (CPS 187) | 52.2 |
| 56 | Unbroken Loop Inspection Port (CPS 183) | 52.2 |

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------|
|  An AEP Company | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revision: 17.1 Table: 14.3.4-25 Page: 4 of 4 |
|------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------|

TABLE 14.3.4-25

REACTOR CAVITY – TMD VOLUME INPUT MODEL

| TMD Node | | Volume (ft ³) |
|----------|-----------------------------------------|---------------------------|
| 57 | Unbroken Loop Inspection Port (CPS 182) | 46.9 |
| 58 | Instrument Tunnel | 1825.9 |
| 59 | Upper Containment | 3934200.0 ¹ |
| 60 | Lower RX Cavity Keyway | 6547.1 |
| 61 | Reactor Vessel Annular Region | 0.5 |
| 62 | Reactor Vessel Annular Region | 0.5 |

¹ The upper compartment was modeled as an infinite sump.
Unit 1

UFSAR Revision 30.0


| | | |
|-----------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------|------------------------------------------------------------|
|  An AEP Company | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revision: 17.1 Table: 14.3.4-26 Page: 1 of 3 |
|-----------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------|------------------------------------------------------------|

TABLE 14.3.4-26

STEAM GENERATOR ENCLOSURE MODEL - TMD FLOW PATH INPUT

STEAM LINE BREAK

| Flow Path | K | f | L _I (ft) | D _H (ft) | A _T (ft ²) | L _{eq} (ft) | A _T /A |
|-----------|-------|-------|---------------------|---------------------|-----------------------------------|----------------------|-------------------|
| 46H-47 | 0.94 | 0.022 | 9.451 | 4.794 | 55.9 | 4.514 | 0.573 |
| 46R-48 | 0.673 | 0.022 | 6.590 | 3.538 | 25.4 | 1.948 | 0.290 |
| 46A-55 | 0.902 | 0.022 | 8.958 | 4.771 | 48.9 | 2.876 | 0.308 |
| 47H-51 | 0.938 | 0.022 | 9.891 | 4.297 | 50.1 | 5.102 | 0.691 |
| 47R-48 | 0.385 | 0.022 | 10.599 | 4.984 | 40.7 | 8.747 | 0.295 |
| 47A-56 | 0.765 | 0.022 | 7.776 | 4.976 | 25.5 | 3.065 | 0.352 |
| 48H-52 | 0.723 | 0.022 | 8.652 | 3.524 | 25.3 | 3.779 | 0.609 |
| 48R-49 | 0.296 | 0.022 | 13.767 | 5.057 | 41.3 | 12.841 | 0.947 |
| 48A-57 | 0.765 | 0.022 | 3.524 | 4.976 | 25.5 | 2.61 | 0.614 |
| 49H-53 | 0.757 | 0.022 | 9.229 | 3.744 | 26.712 | 4.375 | 0.662 |
| 49R-50 | 0.012 | 0.022 | 11.303 | 5.609 | 45.808 | 10.437 | 0.326 |
| 49A-46 | 0.662 | 0.022 | 7.522 | 3.967 | 28.302 | 2.93 | 0.326 |
| 50H-54 | 0.795 | 0.022 | 9.366 | 5.318 | 44.852 | 4.648 | 0.628 |
| 50R-47 | 0.677 | 0.022 | 7.590 | 5.079 | 41.48 | 5.008 | 0.295 |
| 50A-46 | 0.982 | 0.022 | 8.957 | 6.599 | 55.652 | 4.241 | 0.471 |
| 51H-2 | 1.339 | 0.022 | 8.248 | 4.107 | 46.4 | 3.522 | 0.564 |
| 51R-52 | 0.866 | 0.022 | 10.780 | 6.412 | 48.18 | 8.594 | 0.427 |

UFSAR Revision 30.0



INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT

Revision: 17.1

Table: 14.3.4-26

Page: 2 of 3

TABLE 14.3.4-26

STEAM GENERATOR ENCLOSURE MODEL - TMD FLOW PATH INPUT

STEAM LINE BREAK

| Flow Path | K | f | L _I (ft) | D _H (ft) | A _T (ft ²) | L _{eq} (ft) | A _T / A |
|-----------|-------|-------|---------------------|---------------------|-----------------------------------|----------------------|--------------------|
| 52H-2 | 0.722 | 0.022 | 10.937 | 7.201 | 49.1 | 8.128 | 0.962 |
| 52R-53 | 0.244 | 0.022 | 13.263 | 6.553 | 49.24 | 12.392 | 0.949 |
| 53H-1 | 2.100 | 0.022 | 9.453 | 6.272 | 48.212 | 7.392 | 0.963 |
| 53R-54 | 0.090 | 0.022 | 10.939 | 6.736 | 50.614 | 9.147 | 0.415 |
| 54H-1 | 0.988 | 0.022 | 6.483 | 3.730 | 39.852 | 3.164 | 0.526 |
| 54R-51 | 0.442 | 0.022 | 8.412 | 6.539 | 49.135 | 5.253 | 0.402 |
| 55H-56 | 0.703 | 0.022 | 7.977 | 3.765 | 43.90 | 2.775 | 0.470 |
| 55R-57 | 0.673 | 0.022 | 6.590 | 3.538 | 25.4 | 1.961 | 0.290 |
| 55A-58 | 0.649 | 0.022 | 7.456 | 3.91 | 27.9 | 2.863 | 0.322 |
| 56H-60 | 0.518 | 0.022 | 7.572 | 2.856 | 33.3 | 2.898 | 0.501 |
| 56R-57 | 0.373 | 0.022 | 10.568 | 4.972 | 40.6 | 8.713 | 0.291 |
| 57H-61 | 0.723 | 0.022 | 8.617 | 3.506 | 25.17 | 3.750 | 0.608 |
| 57R-58 | 0.296 | 0.022 | 13.767 | 5.057 | 41.3 | 12.841 | 0.947 |
| 58H-62 | 0.626 | 0.022 | 8.410 | 3.322 | 23.7 | 3.652 | 0.591 |
| 58R-59 | 0.015 | 0.022 | 11.778 | 5.609 | 45.644 | 10.611 | 0.429 |
| 59H-63 | 0.744 | 0.022 | 9.215 | 4.730 | 36.217 | 4.548 | 0.632 |
| 59R-56 | 0.703 | 0.022 | 7.253 | 3.88 | 31.69 | 4.938 | 0.227 |
| 59A-55 | 0.943 | 0.022 | 7.807 | 5.236 | 40.097 | 3.002 | 0.380 |

UFSAR Revision 30.0



INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT

Revision: 17.1

Table: 14.3.4-26

Page: 3 of 3

TABLE 14.3.4-26

STEAM GENERATOR ENCLOSURE MODEL - TMD FLOW PATH INPUT

STEAM LINE BREAK

| Flow Path | K | f | L _I (ft) | D _H (ft) | A _T (ft ²) | L _{eq} (ft) | A _T / A |
|-----------|-------|-------|---------------------|---------------------|-----------------------------------|----------------------|--------------------|
| 60H-2 | 1.111 | 0.022 | 7.718 | 3.567 | 40.3 | 3.304 | 0.529 |
| 60R-61 | 0.599 | 0.022 | 10.819 | 6.468 | 48.6 | 8.937 | 0.402 |
| 61H-2 | 0.857 | 0.022 | 9.837 | 6.292 | 42.9 | 6.169 | 0.839 |
| 61R-62 | 0.287 | 0.022 | 13.247 | 6.373 | 47.89 | 12.349 | 0.947 |
| 62H-3 | 2.121 | 0.022 | 9.457 | 6.245 | 48.00 | 8.091 | 1.0 |
| 62R-63 | 0.230 | 0.022 | 11.335 | 7.026 | 52.793 | 10.153 | 0.432 |
| 63H-3 | 0.820 | 0.022 | 5.494 | 2.564 | 26.517 | 2.727 | 0.412 |
| 63R-60 | 0.684 | 0.022 | 7.090 | 4.434 | 33.317 | 4.767 | 0.273 |

UFSAR Revision 30.0



INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT

Revision: 17.1
Table: 14.3.4-27
Page: 1 of 1

TABLE 14.3.4-27

STEAM GENERATOR ENCLOSURE MODEL - TMD FLOW PATH INPUT

FEEDWATER LINE BREAK

(CHANGES TO TABLE 14.3.4-26 TO CONVERT TO A FEED LINE BREAK.)

| Flow Path | K | f | L ₁ (ft) | D _H (ft) | A _T (ft ²) | L _{eq} (ft) | A _T /A |
|-----------|---|---|---------------------|---------------------|-----------------------------------|----------------------|-------------------|
| 46H-47 | | | | | | | 0.771 |
| 46R-48 | | | | | | | 0.612 |
| 47H-51 | | | | | | | 0.609 |
| 48H-52 | | | | | | | 0.496 |
| 49H-53 | | | | | | | 0.533 |
| 49A-46 | | | | | | | 0.701 |
| 50H-54 | | | | | | | 0.591 |
| 50A-46 | | | | | | | 0.780 |
| 55H-56 | | | | | | | 0.660 |
| 55R-57 | | | | | | | 0.613 |
| 55A-58 | | | | | | | 0.696 |
| 56H-60 | | | | | | | 0.437 |
| 57H-61 | | | | | | | 0.492 |
| 58H-62 | | | | | | | 0.476 |
| 59H-63 | | | | | | | 0.563 |
| 59A-55 | | | | | | | 0.700 |

UFSAR Revision 30.0



INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT

Revision: 17.1
Table: 14.3.4-28
Page: 1 of 5

TABLE 14.3.4-28

PRESSURIZER ENCLOSURE MODEL – TMD FLOW PATH INPUT

| Flow Path | K | f | L _l (ft) | D _H (ft) | A _T (ft ²) | L _{eq} (ft) | A _T /A |
|-----------|-------|--------|---------------------|---------------------|-----------------------------------|----------------------|-------------------|
| 1-2 | 0.63 | 0. | 18.6 | 1.0 | 635.0 | 0. | 0.601 |
| 1-33 | 1.5 | 0. | 4.23 | 1.0 | 11.9 | 0. | 0.016 |
| 1-27 | 2.85 | 0. | 3.6 | 1.0 | 21.4 | 0. | 0.129 |
| 2-3 | 0.72 | 0. | 25.0 | 1.0 | 600.0 | 0. | 0.601 |
| 2-27 | 2.85 | 0. | 5.5 | 1.0 | 85.3 | 0. | 0.252 |
| 3-4 | 0.28 | 0. | 33.5 | 1.0 | 570. | 0. | 0.648 |
| 3-33 | 1.5 | 0. | 4.33 | 1.0 | 32.4 | 0. | 0.021 |
| 3-27 | 2.85 | 0. | 3.6 | 1.0 | 21.3 | 0. | 0.128 |
| 4-5 | 0.56 | 0. | 19.1 | 1.0 | 600.0 | 0. | 0.601 |
| 4-33 | 1.5 | 0. | 4.42 | 1.0 | 24.5 | 0. | 0.022 |
| 4-31 | 2.85 | 0. | 3.6 | 1.0 | 21.3 | 0. | 0.128 |
| 5-6 | 0.63 | 0. | 18.6 | 1.0 | 635.0 | 0. | 0.601 |
| 5-31 | 2.85 | 0. | 5.5 | 1.0 | 85.3 | 0. | 0.129 |
| 6-1 | 1.45 | 0. | 29.2 | 1.0 | 58.5 | 0. | 0.055 |
| 6-33 | 1.5 | 0. | 4.23 | 1.0 | 11.9 | 0. | 0.014 |
| 6-31 | 2.85 | 0. | 3.6 | 1.0 | 21.4 | 0. | 0.129 |
| 7-8 | 0. | 0.0276 | 12.278 | 0.855 | 112.8 | 16.0 | 0.727 |
| 8-9 | 0. | 0.0276 | 12.278 | 0.855 | 112.8 | 16.0 | 0.727 |
| 9-34 | 0.812 | 0.0276 | 8.8558 | 0.855 | 112.8 | 8.0 | 0.727 |

UFSAR Revision 30.0



INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT

Revision: 17.1
Table: 14.3.4-28
Page: 2 of 5

TABLE 14.3.4-28

PRESSURIZER ENCLOSURE MODEL – TMD FLOW PATH INPUT

| Flow Path | K | f | L _l (ft) | D _H (ft) | A _T (ft ²) | L _{eq} (ft) | A _T /A |
|-----------|-------|--------|---------------------|---------------------|-----------------------------------|----------------------|-------------------|
| 10-11 | 0. | 0.0276 | 12.278 | 0.855 | 131.31 | 16.0 | 0.727 |
| 11-12 | 0. | 0.0276 | 12.278 | 0.855 | 131.31 | 16.0 | 0.727 |
| 12-35 | 0.812 | 0.0276 | 8.8558 | 0.855 | 131.31 | 8.0 | 0.727 |
| 13-14 | 0. | 0.0276 | 12.278 | 0.855 | 266.63 | 16.0 | 0.727 |
| 14-15 | 0. | 0.0276 | 12.278 | 0.855 | 266.63 | 16.0 | 0.727 |
| 15-36 | 0.812 | 0.0276 | 8.8558 | 0.855 | 266.63 | 8.0 | 0.727 |
| 16-17 | 0. | 0.0276 | 12.278 | 0.855 | 184.59 | 16.0 | 0.727 |
| 17-18 | 0. | 0.0276 | 12.278 | 0.855 | 184.59 | 16.0 | 0.727 |
| 18-37 | 0.812 | 0.0276 | 8.8558 | 0.855 | 184.59 | 8.0 | 0.727 |
| 19-20 | 0. | 0.0276 | 12.278 | 0.855 | 143.57 | 16.0 | 0.727 |
| 20-21 | 0. | 0.0276 | 12.278 | 0.855 | 143.57 | 16.0 | 0.727 |
| 21-38 | 0.812 | 0.0276 | 8.8558 | 0.855 | 143.57 | 8.0 | 0.727 |
| 22-23 | 0. | 0.0276 | 12.278 | 0.855 | 143.57 | 16.0 | 0.727 |
| 23-24 | 0. | 0.0276 | 12.278 | 0.855 | 143.57 | 16.0 | 0.727 |
| 24-39 | 0.812 | 0.0276 | 8.8558 | 0.855 | 143.57 | 8.0 | 0.727 |
| 25-6 | 1.45 | 0. | 6.08 | 1.0 | 2.2 | 0. | .01 |
| 26-32 | 0.99 | 0. | 64.5 | 1.0 | 17.0 | 0. | 0.85 |
| 26-28 | 0.69 | 0. | 45.8 | 1.0 | 25.0 | 0. | 0.357 |
| 27-26 | 2.85 | 0. | 8.0 | 1.0 | 55.0 | 0. | 0.417 |

UFSAR Revision 30.0



INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT

Revision: 17.1
Table: 14.3.4-28
Page: 3 of 5

TABLE 14.3.4-28

PRESSURIZER ENCLOSURE MODEL – TMD FLOW PATH INPUT

| Flow Path | K | f | L _l (ft) | D _H (ft) | A _T (ft ²) | L _{eq} (ft) | A _T /A |
|-----------|------|----|---------------------|---------------------|-----------------------------------|----------------------|-------------------|
| 27-29 | 2.85 | 0. | 2.7 | 1.0 | 2.5 | 0. | 0.008 |
| 28-3 | 2.6 | 0. | 13.2 | 1.0 | 35.7 | 0. | 0.077 |
| 28-27 | 2.85 | 0. | 8.0 | 1.0 | 43.0 | 0. | 0.254 |
| 29-28 | 2.85 | 0. | 2.0 | 1.0 | 0.25 | 0. | 0.001 |
| 29-3 | 2.85 | 0. | 3.0 | 1.0 | 0.25 | 0. | 0.002 |
| 30-28 | 0.99 | 0. | 46.6 | 1.0 | 20.0 | 0. | 1.0 |
| 30-4 | 2.6 | 0. | 13.2 | 1.0 | 35.7 | 0. | 0.106 |
| 31-30 | 2.85 | 0. | 8.0 | 1.0 | 43.0 | 0. | 0.254 |
| 31-29 | 2.85 | 0. | 2.7 | 1.0 | 2.5 | 0. | 0.007 |
| 32-30 | 0.69 | 0. | 40.0 | 1.0 | 25.0 | 0. | 0.417 |
| 32-31 | 2.85 | 0. | 8.0 | 1.0 | 55.0 | 0. | 0.331 |
| 33-2 | 1.5 | 0. | 4.69 | 1.0 | 23.8 | 0. | 0.034 |
| 33-5 | 1.5 | 0. | 4.65 | 1.0 | 23.8 | 0. | 0.034 |
| 34-25 | 1.45 | 0. | 2.8 | 1.0 | 233.8 | 0. | 0.659 |
| 35-25 | 1.43 | 0. | 2.8 | 1.0 | 267.6 | 0. | 0.65 |
| 36-25 | 1.43 | 0. | 2.8 | 1.0 | 539.5 | 0. | 0.625 |
| 37-25 | 1.41 | 0. | 3.2 | 1.0 | 376.5 | 0. | 0.636 |
| 38-25 | 1.44 | 0. | 2.8 | 1.0 | 289.4 | 0. | 0.646 |
| 39-25 | 1.43 | 0. | 2.8 | 1.0 | 296.3 | 0. | 0.646 |

UFSAR Revision 30.0



INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT

Revision: 17.1
Table: 14.3.4-28
Page: 4 of 5

TABLE 14.3.4-28

PRESSURIZER ENCLOSURE MODEL – TMD FLOW PATH INPUT

| Flow Path | K | f | L _l (ft) | D _H (ft) | A _T (ft ²) | L _{eq} (ft) | A _T /A |
|-----------|-------|---------|---------------------|---------------------|-----------------------------------|----------------------|-------------------|
| 40-1 | 0.89 | 0. | 10.36 | 1.0 | 121.9 | 1.0 | 0.225 |
| 40-7 | 0.227 | 0.01517 | 8.222 | 0.855 | 106.7 | 8.0 | 0.33 |
| 40-41 | 7.5 | 0. | 13.8 | 1.0 | 24.7 | 0. | 0.075 |
| 41-2 | 0.89 | 0. | 10.36 | 1.0 | 144.0 | 1.0 | 0.225 |
| 41-10 | 0.227 | 0.01517 | 8.222 | 0.855 | 126.1 | 8.0 | 0.33 |
| 41-42 | 12.5 | 0. | 22.4 | 1.0 | 24.7 | 0. | 0.046 |
| 42-3 | 0.89 | 0. | 10.36 | 1.0 | 288.0 | 1.0 | 0.225 |
| 42-13 | 0.227 | 0.01517 | 8.222 | 0.855 | 252.2 | 8.0 | 0.33 |
| 42-43 | 12.5 | 0. | 25.3 | 1.0 | 24.7 | 0. | 0.041 |
| 43-4 | 0.89 | 0. | 10.36 | 1.0 | 199.4 | 1.0 | 0.225 |
| 43-16 | 0.227 | 0.01517 | 8.222 | 0.855 | 174.6 | 8.0 | 0.33 |
| 43-44 | 10.0 | 0. | 18.4 | 1.0 | 24.7 | 0. | 0.056 |
| 44-5 | 0.89 | 0. | 10.36 | 1.0 | 155.1 | 1.0 | 0.225 |
| 44-19 | 0.227 | 0.01517 | 8.222 | 0.855 | 135.8 | 8.0 | 0.33 |
| 44-45 | 10.0 | 0. | 16.1 | 1.0 | 24.7 | 0. | 0.064 |
| 45-6 | 0.89 | 0. | 10.36 | 1.0 | 155.1 | 1.0 | 0.225 |
| 45-22 | 0.227 | 0.01517 | 8.222 | 0.855 | 135.87 | 8.0 | 0.33 |
| 46-47 | 1.264 | 0.025 | 15.54 | 2.50 | 17.93 | 13.86 | 0.41 |
| 46-48 | 0.856 | 0.025 | 17.86 | 5.19 | 27.24 | 15.80 | 0.65 |

UFSAR Revision 30.0



INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT

Revision: 17.1

Table: 14.3.4-28

Page: 5 of 5

TABLE 14.3.4-28

PRESSURIZER ENCLOSURE MODEL – TMD FLOW PATH INPUT

| Flow Path | K | f | L_i (ft) | D_H (ft) | A_T (ft²) | L_{eq} (ft) | A_T /A |
|------------------|----------|----------|---------------------------|---------------------------|---------------------------------------|----------------------------|-------------------------|
| 46-49 | 0.788 | 0.025 | 17.43 | 3.66 | 25.14 | 15.40 | 0.60 |
| 47-4 | 1.91 | 0.025 | 11.69 | 2.50 | 17.93 | 11.69 | 1.00 |
| 48-4 | 1.665 | 0.025 | 8.87 | 3.84 | 18.93 | 9.22 | 0.73 |
| 48-49 | 1.268 | 0.025 | 7.883 | 4.50 | 52.61 | 7.883 | 0.47 |
| 48-47 | 0.888 | 0.025 | 10.302 | 2.50 | 29.23 | 10.302 | 0.26 |
| 49-4 | 1.291 | 0.025 | 8.80 | 2.66 | 17.60 | 9.05 | 0.72 |
| 49-47 | 1.064 | 0.025 | 11.793 | 2.50 | 29.23 | 14.99 | 0.26 |

UFSAR Revision 30.0


| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 17.1 Table: 14.3.4-29 Page: 1 of 1</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|

TABLE 14.3.4-29

FAN / ACCUMULATOR ROOM MODEL – TMD FLOW PATH INPUT

| Flow Path | K | f | L _I (ft) | D _H (ft) | A _T (ft ²) | L _E (ft) | A _T / A |
|-----------|------|----|---------------------|---------------------|-----------------------------------|---------------------|--------------------|
| 27R-29 | 1.61 | 0. | 1.66 | 1.0 | 1.0 | 0. | 0.003 |
| 27H-28 | 2.17 | 0. | 0.36 | 1.0 | 13.2 | 0. | 0.094 |
| 27-3A | 2.02 | 0. | 0.085 | 1.0 | 0.68 | 0. | 0.002 |
| 54H-27 | 0.25 | 0. | 11.77 | 1.0 | 108 | 0. | 0.320 |
| 54R-28 | 1.75 | 0. | 4.22 | 1.0 | 21.2 | 0. | 0.068 |
| 54A-3 | 2.12 | 0. | 7.89 | 1.0 | 17.3 | 0. | 0.075 |
| 55H-54 | 0.21 | 0. | 15.84 | 1.0 | 170 | 0. | 0.578 |
| 55A-28 | 2.10 | 0. | 2.0 | 1.0 | 34.3 | 0. | 0.110 |
| 55R-26 | 2.09 | 0. | 29.91 | 1.0 | 34.7 | 0. | 0.111 |
| 55-2R | 1.86 | 0. | 14.07 | 1.0 | 90.9 | 0. | 0.382 |
| 55-56H | 0.21 | 0. | 16.24 | 1.0 | 170 | 0. | 0.578 |
| 56R-26 | 1.89 | 0. | 4.30 | 1.0 | 24.7 | 0. | 0.076 |
| 56A-1 | 1.72 | 0. | 5.99 | 1.0 | 14.5 | 0. | 0.060 |
| 56-57H | 0.25 | 0. | 14.26 | 1.0 | 108 | 0. | 0.635 |
| 57R-26 | 2.06 | 0. | 0.32 | 1.0 | 17.2 | 0. | 0.105 |
| 57A-1 | 2.36 | 0. | 1.27 | 1.0 | 29.6 | 0. | 0.068 |

UFSAR Revision 30.0



INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT

Revision: 17.1
Table: 14.3.4-30
Page: 1 of 6

**Table 14.3.4-30
Loop Subcompartment Model – TMD Flow Path Input**

| Flow Path | K | f | L _I (ft) | D _H (ft) | A _T (ft ²) | L _{eq} (ft) | A _T /A |
|-----------|------|----|---------------------|---------------------|-----------------------------------|----------------------|-------------------|
| 1-2 | 0.63 | 0. | 18.6 | 1.0 | 635.0 | 0. | 0.601 |
| 1-33 | 1.5 | 0. | 4.23 | 1.0 | 11.9 | 0. | 0.016 |
| 1-27 | 2.85 | 0. | 3.6 | 1.0 | 21.4 | 0. | 0.129 |
| 2-3 | 0.72 | 0. | 25.0 | 1.0 | 600.0 | 0. | 0.601 |
| 2-27 | 2.85 | 0. | 5.5 | 1.0 | 85.3 | 0. | 0.252 |
| 3-4 | 0.28 | 0. | 33.5 | 1.0 | 570. | 0. | 0.648 |
| 3-33 | 1.5 | 0. | 4.33 | 1.0 | 32.4 | 0. | 0.021 |
| 3-27 | 2.85 | 0. | 3.6 | 1.0 | 21.3 | 0. | 0.128 |
| 4-5 | 0.56 | 0. | 19.1 | 1.0 | 600.0 | 0. | 0.601 |
| 4-33 | 1.5 | 0. | 4.42 | 1.0 | 24.5 | 0. | 0.022 |
| 4-31 | 2.85 | 0. | 3.6 | 1.0 | 21.3 | 0. | 0.128 |
| 5-6 | 0.63 | 0. | 18.6 | 1.0 | 635.0 | 0. | 0.601 |
| 5-31 | 2.85 | 0. | 5.5 | 1.0 | 85.3 | 0. | 0.129 |
| 6-1 | 1.45 | 0. | 29.2 | 1.0 | 58.5 | 0. | 0.055 |
| 6-33 | 1.5 | 0. | 4.23 | 1.0 | 11.9 | 0. | 0.014 |

UFSAR Revision 30.0



INDIANA MICHIGAN POWER
D. C. COOK NUCLEAR PLANT
UPDATED FINAL SAFETY ANALYSIS REPORT

Revision: 17.1
Table: 14.3.4-30
Page: 2 of 6

Table 14.3.4-30
Loop Subcompartment Model – TMD Flow Path Input

| Flow Path | K | f | L _I (ft) | D _H (ft) | A _T (ft ²) | L _{eq} (ft) | A _T /A |
|-----------|-------|--------|---------------------|---------------------|-----------------------------------|----------------------|-------------------|
| 6-31 | 2.85 | 0. | 3.6 | 1.0 | 21.4 | 0. | 0.129 |
| 7-8 | 0. | 0.0276 | 12.278 | 0.855 | 112.8 | 16.0 | 0.727 |
| 8-9 | 0. | 0.0276 | 12.278 | 0.855 | 112.8 | 16.0 | 0.727 |
| 9-34 | 0.812 | 0.0276 | 8.8558 | 0.855 | 112.8 | 8.0 | 0.727 |
| 10-11 | 0. | 0.0276 | 12.278 | 0.855 | 131.31 | 16.0 | 0.727 |
| 11-12 | 0. | 0.0276 | 12.278 | 0.855 | 131.31 | 16.0 | 0.727 |
| 12-35 | 0.812 | 0.0276 | 8.8558 | 0.855 | 131.31 | 8.0 | 0.727 |
| 13-14 | 0. | 0.0276 | 12.278 | 0.855 | 266.63 | 16.0 | 0.727 |
| 14-15 | 0. | 0.0276 | 12.278 | 0.855 | 266.63 | 16.0 | 0.727 |
| 15-36 | 0.812 | 0.0276 | 8.8558 | 0.855 | 266.63 | 8.0 | 0.727 |
| 16-17 | 0. | 0.0276 | 12.278 | 0.855 | 184.59 | 16.0 | 0.727 |
| 17-18 | 0. | 0.0276 | 12.278 | 0.855 | 184.59 | 16.0 | 0.727 |
| 18-37 | 0.812 | 0.0276 | 8.8558 | 0.855 | 184.59 | 8.0 | 0.727 |
| 19-20 | 0. | 0.0276 | 12.278 | 0.855 | 143.57 | 16.0 | 0.727 |
| 20-21 | 0. | 0.0276 | 12.278 | 0.855 | 143.57 | 16.0 | 0.727 |

UFSAR Revision 30.0



INDIANA MICHIGAN POWER
D. C. COOK NUCLEAR PLANT
UPDATED FINAL SAFETY ANALYSIS REPORT

Revision: 17.1
Table: 14.3.4-30
Page: 3 of 6

Table 14.3.4-30
Loop Subcompartment Model – TMD Flow Path Input

| Flow Path | K | f | L _I (ft) | D _H (ft) | A _T (ft ²) | L _{eq} (ft) | A _T /A |
|-----------|-------|--------|---------------------|---------------------|-----------------------------------|----------------------|-------------------|
| 21-38 | 0.812 | 0.0276 | 8.8558 | 0.855 | 143.57 | 8.0 | 0.727 |
| 22-23 | 0. | 0.0276 | 12.278 | 0.855 | 143.57 | 16.0 | 0.727 |
| 23-24 | 0. | 0.0276 | 12.278 | 0.855 | 143.57 | 16.0 | 0.727 |
| 24-39 | 0.812 | 0.0276 | 8.8558 | 0.855 | 143.57 | 8.0 | 0.727 |
| 25-6 | 1.45 | 0. | 6.08 | 1.0 | 2.2 | 0. | .01 |
| 26-32 | 0.99 | 0. | 64.5 | 1.0 | 17.0 | 0. | 0.85 |
| 26-28 | 0.69 | 0. | 45.8 | 1.0 | 25.0 | 0. | 0.357 |
| 27-26 | 2.85 | 0. | 8.0 | 1.0 | 55.0 | 0. | 0.417 |
| 27-29 | 2.85 | 0. | 2.7 | 1.0 | 2.5 | 0. | 0.008 |
| 28-3 | 2.6 | 0. | 13.2 | 1.0 | 35.7 | 0. | 0.077 |
| 28-27 | 2.85 | 0. | 8.0 | 1.0 | 43.0 | 0. | 0.254 |
| 29-28 | 2.85 | 0. | 2.0 | 1.0 | 0.25 | 0. | 0.001 |
| 29-3 | 2.85 | 0. | 3.0 | 1.0 | 0.25 | 0. | 0.002 |
| 30-28 | 0.99 | 0. | 46.6 | 1.0 | 20.0 | 0. | 1.0 |
| 30-4 | 2.6 | 0. | 13.2 | 1.0 | 35.7 | 0. | 0.106 |

UFSAR Revision 30.0



INDIANA MICHIGAN POWER
D. C. COOK NUCLEAR PLANT
UPDATED FINAL SAFETY ANALYSIS REPORT

Revision: 17.1
Table: 14.3.4-30
Page: 4 of 6

Table 14.3.4-30
Loop Subcompartment Model – TMD Flow Path Input

| Flow Path | K | f | L _I (ft) | D _H (ft) | A _T (ft ²) | L _{eq} (ft) | A _T /A |
|-----------|-------|---------|---------------------|---------------------|-----------------------------------|----------------------|-------------------|
| 31-30 | 2.85 | 0. | 8.0 | 1.0 | 43.0 | 0. | 0.254 |
| 31-29 | 2.85 | 0. | 2.7 | 1.0 | 2.5 | 0. | 0.007 |
| 32-30 | 0.69 | 0. | 40.0 | 1.0 | 25.0 | 0. | 0.417 |
| 32-31 | 2.85 | 0. | 8.0 | 1.0 | 55.0 | 0. | 0.331 |
| 33-2 | 1.5 | 0. | 4.69 | 1.0 | 23.8 | 0. | 0.034 |
| 33-5 | 1.5 | 0. | 4.65 | 1.0 | 23.8 | 0. | 0.034 |
| 34-25 | 1.45 | 0. | 2.8 | 1.0 | 233.8 | 0. | 0.659 |
| 35-25 | 1.43 | 0. | 2.8 | 1.0 | 267.6 | 0. | 0.65 |
| 36-25 | 1.43 | 0. | 2.8 | 1.0 | 539.5 | 0. | 0.625 |
| 37-25 | 1.41 | 0. | 3.2 | 1.0 | 376.5 | 0. | 0.636 |
| 38-25 | 1.44 | 0. | 2.8 | 1.0 | 289.4 | 0. | 0.646 |
| 39-25 | 1.43 | 0. | 2.8 | 1.0 | 296.3 | 0. | 0.646 |
| 40-1 | 0.89 | 0. | 10.36 | 1.0 | 121.9 | 1.0 | 0.225 |
| 40-7 | 0.227 | 0.01517 | 8.222 | 0.855 | 106.7 | 8.0 | 0.33 |
| 40-41 | 7.5 | 0. | 13.8 | 1.0 | 24.7 | 0. | 0.075 |

UFSAR Revision 30.0



INDIANA MICHIGAN POWER
D. C. COOK NUCLEAR PLANT
UPDATED FINAL SAFETY ANALYSIS REPORT

Revision: 17.1
Table: 14.3.4-30
Page: 5 of 6

Table 14.3.4-30
Loop Subcompartment Model – TMD Flow Path Input

| Flow Path | K | f | L _I (ft) | D _H (ft) | A _T (ft ²) | L _{eq} (ft) | A _T /A |
|-----------|-------|---------|---------------------|---------------------|-----------------------------------|----------------------|-------------------|
| 41-2 | 0.89 | 0. | 10.36 | 1.0 | 144.0 | 1.0 | 0.225 |
| 41-10 | 0.227 | 0.01517 | 8.222 | 0.855 | 126.1 | 8.0 | 0.33 |
| 41-42 | 12.5 | 0. | 22.4 | 1.0 | 24.7 | 0. | 0.046 |
| 42-3 | 0.89 | 0. | 10.36 | 1.0 | 288.0 | 1.0 | 0.225 |
| 42-13 | 0.227 | 0.01517 | 8.222 | 0.855 | 252.2 | 8.0 | 0.33 |
| 42-43 | 12.5 | 0. | 25.3 | 1.0 | 24.7 | 0. | 0.041 |
| 43-4 | 0.89 | 0. | 10.36 | 1.0 | 199.4 | 1.0 | 0.225 |
| 43-16 | 0.227 | 0.01517 | 8.222 | 0.855 | 174.6 | 8.0 | 0.33 |
| 43-44 | 10.0 | 0. | 18.4 | 1.0 | 24.7 | 0. | 0.056 |
| 44-5 | 0.89 | 0. | 10.36 | 1.0 | 155.1 | 1.0 | 0.225 |
| 44-19 | 0.227 | 0.01517 | 8.222 | 0.855 | 135.8 | 8.0 | 0.33 |
| 44-45 | 10.0 | 0. | 16.1 | 1.0 | 24.7 | 0. | 0.064 |
| 45-6 | 0.89 | 0. | 10.36 | 1.0 | 155.1 | 1.0 | 0.225 |
| 45-22 | 0.227 | 0.01517 | 8.222 | 0.855 | 135.87 | 8.0 | 0.33 |
| 46-1 | 2.09 | 0. | 10.0 | 1.0 | 123.31 | 1.0 | 0.001 |

UFSAR Revision 30.0



INDIANA MICHIGAN POWER
D. C. COOK NUCLEAR PLANT
UPDATED FINAL SAFETY ANALYSIS REPORT

Revision: 17.1
Table: 14.3.4-30
Page: 6 of 6

Table 14.3.4-30
Loop Subcompartment Model – TMD Flow Path Input

| Flow Path | K | f | L _I (ft) | D _H (ft) | A _T (ft ²) | L _{eq} (ft) | A _T /A |
|-----------|-------|----|---------------------|---------------------|-----------------------------------|----------------------|-------------------|
| 46-2 | 2.21 | 0. | 11.5 | 1.0 | 104.12 | 1.0 | 0.001 |
| 47-2 | 2.21 | 0. | 11.5 | 1.0 | 104.12 | 1.0 | 0.001 |
| 47-3 | 2.09 | 0. | 10.0 | 1.0 | 123.31 | 1.0 | 0.001 |
| 48-5 | 2.21 | 0. | 11.5 | 1.0 | 104.12 | 1.0 | 0.001 |
| 48-4 | 2.09 | 0. | 10.0 | 1.0 | 123.31 | 1.0 | 0.001 |
| 49-6 | 2.09 | 0. | 10.0 | 1.0 | 123.31 | 1.0 | 0.001 |
| 49-5 | 2.21 | 0. | 11.5 | 1.0 | 104.12 | 1.0 | 0.001 |
| 50-46 | 2.93 | 0. | 17.6 | 1.0 | 121.43 | 1.0 | 0.001 |
| 50-51 | 0.874 | 0. | 8.43 | 1.0 | 44.89 | 1.0 | 0.282 |
| 51-47 | 2.93 | 0. | 17.6 | 1.0 | 121.43 | 1.0 | 0.001 |
| 52-48 | 2.93 | 0. | 17.6 | 1.0 | 121.43 | 1.0 | 0.001 |
| 53-49 | 2.93 | 0. | 17.6 | 1.0 | 121.43 | 1.0 | 0.001 |
| 53-52 | 0.874 | 0. | 8.43 | 1.0 | 44.89 | 1.0 | 0.282 |

UFSAR Revision 30.0



INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT

Revision: 22.1
Table: 14.3.4-31
Page: 1 of 6

**Table 14.3.4-31
Reactor Cavity Model – TMD Flow Path Input**

| Flow Path | K | f | L _i (ft) | D _H (ft) | A _T (ft ²) | L _{eq} (ft) | A _T / A |
|-----------|-------|-------|---------------------|---------------------|-----------------------------------|----------------------|--------------------|
| 1H-3 | 1.312 | 0.021 | 1.895 | 1.338 | 12.570 | 1.130 | 0.463 |
| 1R-53 | 0.386 | 0.021 | 2.200 | 1.420 | 9.290 | 1.290 | 0.293 |
| 1A-46 | 0.419 | 0.021 | 7.080 | 1.125 | 5.780 | 6.690 | 0.211 |
| 2H-60 | 0.230 | 0.021 | 20.202 | 13.953 | 199.980 | 17.524 | 0.645 |
| 2R-32 | 0.969 | 0.021 | 14.211 | 1.082 | 3.488 | 14.071 | 1.000 |
| 2A-8 | 0.984 | 0.021 | 12.638 | 1.082 | 1.783 | 12.567 | 1.000 |
| 3H-6 | 0.412 | 0.021 | 2.008 | 0.759 | 1.081 | 0.590 | 0.721 |
| 3R-7 | 0.287 | 0.021 | 1.752 | 0.902 | 1.357 | 1.032 | 0.522 |
| 3A-11 | 0.403 | 0.021 | 2.026 | 0.759 | 1.081 | 0.617 | 0.738 |
| 4H-9 | 0.000 | 0.021 | 3.627 | 0.459 | 0.043 | 3.627 | 1.000 |
| 4R-38 | 0.996 | 0.021 | 0.122 | 0.467 | 0.842 | 0.094 | 1.000 |
| 4A-5 | 0.363 | 0.021 | 0.431 | 0.467 | 0.842 | 0.134 | 0.349 |
| 5H-10 | 0.000 | 0.021 | 3.539 | 1.349 | 1.305 | 3.539 | 1.000 |
| 5R-34 | 0.000 | 0.021 | 3.578 | 1.349 | 1.305 | 3.578 | 1.000 |
| 5A-6 | 0.144 | 0.021 | 1.727 | 0.904 | 1.498 | 1.376 | 1.000 |
| 6H-11 | 0.000 | 0.021 | 3.285 | 0.902 | 1.016 | 3.285 | 1.000 |
| 6R-35 | 0.499 | 0.021 | 2.661 | 0.902 | 1.016 | 2.361 | 1.000 |
| 6A-61 | 0.755 | 0.021 | 1.033 | 0.805 | 0.197 | 0.088 | 1.000 |
| 7H-61 | 0.000 | 0.021 | 2.879 | 0.819 | 0.2000 | 2.879 | 1.000 |
| 7R-36 | 0.411 | 0.021 | 0.942 | 0.681 | 0.314 | 0.702 | 0.231 |
| 7A-8 | 0.788 | 0.021 | 2.915 | 0.426 | 0.200 | 1.577 | 1.000 |
| 8H-3 | 0.489 | 0.021 | 8.814 | 0.759 | 1.081 | 3.803 | 0.606 |
| 8R-13 | 0.000 | 0.021 | 3.268 | 1.079 | 13.563 | 3.268 | 1.000 |
| 8A-37 | 0.000 | 0.021 | 3.304 | 1.079 | 13.563 | 3.304 | 1.000 |
| 9H-14 | 0.000 | 0.021 | 3.587 | 0.459 | 0.043 | 3.587 | 1.000 |
| 9R-38 | 0.996 | 0.021 | 0.122 | 0.467 | 0.823 | 0.094 | 1.000 |
| 9A-10 | 0.366 | 0.021 | 0.423 | 0.467 | 0.823 | 0.132 | 0.341 |
| 10H-15 | 0.000 | 0.021 | 3.500 | 1.349 | 1.305 | 3.500 | 1.000 |

UFSAR Revision 30.0



INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT

Revision: 22.1
Table: 14.3.4-31
Page: 2 of 6

**Table 14.3.4-31
Reactor Cavity Model – TMD Flow Path Input**

| Flow Path | K | f | L _i (ft) | D _H (ft) | A _T (ft ²) | L _{eq} (ft) | A _T / A |
|-----------|-------|-------|---------------------|---------------------|-----------------------------------|----------------------|--------------------|
| 10R-11 | 0.144 | 0.021 | 1.727 | 0.904 | 1.466 | 1.376 | 1.000 |
| 11H-16 | 0.444 | 0.021 | 2.513 | 0.902 | 1.016 | 2.169 | 1.000 |
| 11R-62 | 0.789 | 0.021 | 1.056 | 0.671 | 0.164 | 0.049 | 1.000 |
| 12H-17 | 0.382 | 0.021 | 0.897 | 0.722 | 0.408 | 0.580 | 0.300 |
| 12R-3 | 0.287 | 0.021 | 1.752 | 0.902 | 1.357 | 1.032 | 0.522 |
| 12A-13 | 0.817 | 0.021 | 2.711 | 0.353 | 0.168 | 1.548 | 1.000 |
| 13H-18 | 0.000 | 0.021 | 3.232 | 1.079 | 13.563 | 3.232 | 1.000 |
| 13R-2 | 0.985 | 0.021 | 12.637 | 1.082 | 1.744 | 12.567 | 1.000 |
| 13A-3 | 0.479 | 0.021 | 8.983 | 0.759 | 1.081 | 3.984 | 0.620 |
| 14H-19 | 0.937 | 0.021 | 1.902 | 0.459 | 0.043 | 1.795 | 1.000 |
| 14R-38 | 0.996 | 0.021 | 0.122 | 0.467 | 0.823 | 0.094 | 1.000 |
| 14A-15 | 0.366 | 0.021 | 0.423 | 0.467 | 0.823 | 0.132 | 0.341 |
| 15H-19 | 0.001 | 0.021 | 5.057 | 1.349 | 1.305 | 5.150 | 1.000 |
| 15R-16 | 0.144 | 0.021 | 3.102 | 0.904 | 1.466 | 2.751 | 1.000 |
| 16H-39 | 0.971 | 0.021 | 0.506 | 1.901 | 4.232 | 0.070 | 0.320 |
| 16R-20 | 0.177 | 0.021 | 4.552 | 0.837 | 1.307 | 4.393 | 0.579 |
| 16A-17 | 0.361 | 0.021 | 3.748 | 0.647 | 0.515 | 3.648 | 0.351 |
| 17H-21 | 0.943 | 0.021 | 1.715 | 0.722 | 0.408 | 1.626 | 1.000 |
| 17R-39 | 0.698 | 0.021 | 0.591 | 2.150 | 4.943 | 0.109 | 0.785 |
| 17A-18 | 0.424 | 0.021 | 4.625 | 0.647 | 0.515 | 1.455 | 1.000 |
| 18H-21 | 0.097 | 0.021 | 4.634 | 1.079 | 13.563 | 4.530 | 0.909 |
| 18R-2 | 0.985 | 0.021 | 12.637 | 1.082 | 1.744 | 12.567 | 1.000 |
| 19H-22 | 0.262 | 0.021 | 4.919 | 1.271 | 1.348 | 4.304 | 1.000 |
| 19R-38 | 1.356 | 0.021 | 0.547 | 0.467 | 1.610 | 0.224 | 1.000 |
| 19A-20 | 0.144 | 0.021 | 3.160 | 0.904 | 2.866 | 2.775 | 1.000 |
| 20H-22 | 0.667 | 0.021 | 4.177 | 0.655 | 1.307 | 2.793 | 0.363 |
| 20R-40 | 0.934 | 0.021 | 0.557 | 1.901 | 4.232 | 0.116 | 0.166 |
| 20A-21 | 0.852 | 0.021 | 7.973 | 0.433 | 1.018 | 4.682 | 0.299 |

UFSAR Revision 30.0



INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT

Revision: 22.1
Table: 14.3.4-31
Page: 3 of 6

**Table 14.3.4-31
Reactor Cavity Model – TMD Flow Path Input**

| Flow Path | K | f | L _i (ft) | D _H (ft) | A _T (ft ²) | L _{eq} (ft) | A _T / A |
|-----------|-------|-------|---------------------|---------------------|-----------------------------------|----------------------|--------------------|
| 21H-23 | 0.067 | 0.021 | 6.285 | 1.064 | 13.971 | 6.160 | 0.936 |
| 21R-40 | 1.042 | 0.021 | 0.484 | 1.599 | 3.677 | 0.073 | 0.021 |
| 21A-2 | 0.970 | 0.021 | 14.208 | 1.082 | 3.411 | 14.071 | 1.000 |
| 22H-24 | 0.281 | 0.021 | 6.008 | 1.017 | 2.562 | 5.613 | 0.711 |
| 22R-23 | 0.879 | 0.021 | 8.429 | 0.428 | 0.992 | 5.084 | 0.284 |
| 22A-38 | 1.401 | 0.021 | 1.727 | 0.467 | 1.647 | 0.503 | 1.000 |
| 23H-25 | 0.073 | 0.021 | 6.435 | 1.045 | 13.877 | 6.314 | 0.930 |
| 23R-41 | 1.033 | 0.021 | 0.969 | 1.810 | 4.330 | 0.151 | 0.025 |
| 23A-2 | 0.969 | 0.021 | 14.211 | 1.082 | 3.488 | 14.071 | 1.000 |
| 24H-26 | 0.281 | 0.021 | 6.008 | 1.017 | 2.562 | 5.613 | 0.711 |
| 24R-38 | 1.401 | 0.021 | 1.728 | 0.467 | 1.683 | 0.503 | 1.000 |
| 24A-25 | 0.905 | 0.021 | 8.247 | 0.404 | 0.966 | 5.018 | 0.271 |
| 25H-27 | 0.073 | 0.021 | 6.435 | 1.045 | 13.877 | 6.314 | 0.930 |
| 25R-42 | 1.044 | 0.021 | 0.850 | 1.392 | 3.330 | 0.112 | 0.019 |
| 25A-2 | 0.969 | 0.021 | 14.214 | 1.082 | 3.566 | 14.071 | 1.000 |
| 26H-28 | 0.253 | 0.021 | 5.843 | 1.012 | 2.656 | 5.413 | 0.737 |
| 26R-38 | 1.401 | 0.021 | 1.727 | 0.467 | 1.647 | 0.503 | 1.000 |
| 26A-27 | 0.879 | 0.021 | 8.429 | 0.428 | 0.992 | 5.084 | 0.284 |
| 27H-29 | 0.067 | 0.021 | 6.285 | 1.064 | 13.971 | 6.160 | 0.936 |
| 27R-43 | 1.030 | 0.021 | 1.115 | 2.150 | 4.943 | 0.175 | 0.028 |
| 27A-2 | 0.969 | 0.021 | 14.211 | 1.082 | 3.488 | 14.071 | 1.000 |
| 28H-30 | 0.260 | 0.021 | 4.969 | 1.271 | 1.348 | 4.369 | 1.000 |
| 28R-38 | 1.401 | 0.021 | 1.726 | 0.467 | 1.610 | 0.503 | 1.000 |
| 28A-29 | 0.852 | 0.021 | 8.350 | 0.433 | 1.018 | 4.746 | 0.299 |
| 29H-32 | 0.067 | 0.021 | 6.421 | 1.044 | 13.971 | 6.284 | 0.936 |
| 29R-43 | 1.029 | 0.021 | 1.115 | 2.150 | 4.943 | 0.175 | 0.029 |
| 29A-2 | 0.970 | 0.021 | 14.208 | 1.082 | 3.411 | 14.071 | 1.000 |
| 30H-33 | 0.937 | 0.021 | 1.945 | 0.459 | 0.043 | 1.835 | 1.000 |

UFSAR Revision 30.0



INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT

Revision: 22.1
Table: 14.3.4-31
Page: 4 of 6

**Table 14.3.4-31
Reactor Cavity Model – TMD Flow Path Input**

| Flow Path | K | f | L _i (ft) | D _H (ft) | A _T (ft ²) | L _{eq} (ft) | A _T /A |
|-----------|-------|-------|---------------------|---------------------|-----------------------------------|----------------------|-------------------|
| 30R-38 | 1.355 | 0.021 | 0.548 | 0.467 | 1.647 | 0.224 | 1.000 |
| 30A-31 | 0.144 | 0.021 | 3.160 | 0.904 | 2.931 | 2.775 | 1.000 |
| 31H-35 | 0.214 | 0.021 | 4.778 | 0.832 | 1.213 | 4.701 | 0.538 |
| 31R-45 | 1.049 | 0.021 | 0.489 | 1.551 | 3.613 | 0.063 | 0.150 |
| 31A-28 | 0.667 | 0.021 | 4.192 | 0.655 | 1.307 | 2.805 | 0.363 |
| 32H-36 | 0.955 | 0.021 | 1.733 | 0.681 | 0.314 | 1.662 | 1.000 |
| 32R-31 | 0.879 | 0.021 | 8.070 | 0.428 | 0.992 | 5.027 | 0.284 |
| 32A-44 | 1.042 | 0.021 | 0.484 | 1.599 | 3.677 | 0.073 | 0.021 |
| 33H-4 | 0.000 | 0.021 | 3.667 | 0.459 | 0.043 | 3.667 | 1.000 |
| 33R-38 | 0.996 | 0.021 | 0.122 | 0.467 | 0.842 | 0.094 | 1.000 |
| 33A-34 | 0.363 | 0.021 | 0.431 | 0.467 | 0.842 | 0.134 | 0.349 |
| 34H-30 | 0.001 | 0.021 | 5.171 | 1.349 | 1.305 | 5.266 | 1.000 |
| 34R-35 | 0.144 | 0.021 | 3.102 | 0.904 | 1.498 | 2.751 | 1.000 |
| 35H-45 | 0.996 | 0.021 | 0.489 | 1.551 | 3.613 | 0.063 | 0.281 |
| 35R-36 | 0.373 | 0.021 | 4.946 | 0.635 | 0.483 | 4.700 | 0.322 |
| 36H-45 | 0.720 | 0.021 | 0.586 | 1.810 | 4.330 | 0.105 | 0.748 |
| 36R-37 | 0.462 | 0.021 | 4.435 | 0.635 | 0.483 | 1.495 | 1.000 |
| 37H-32 | 0.096 | 0.021 | 4.764 | 1.079 | 13.563 | 4.678 | 0.909 |
| 37R-2 | 0.984 | 0.021 | 12.638 | 1.082 | 1.783 | 12.567 | 1.000 |
| 38H-43 | 0.957 | 0.021 | 3.670 | 1.590 | 9.820 | 2.050 | 0.021 |
| 38R-42 | 0.957 | 0.021 | 3.670 | 1.590 | 9.820 | 2.050 | 0.021 |
| 38A-41 | 0.957 | 0.021 | 3.670 | 1.590 | 9.820 | 2.050 | 0.021 |
| 39H-20 | 1.033 | 0.021 | 0.506 | 1.901 | 4.232 | 0.070 | 0.166 |
| 39R-54 | 0.473 | 0.021 | 2.450 | 1.590 | 9.820 | 1.380 | 0.314 |
| 39A-21 | 1.029 | 0.021 | 0.591 | 2.150 | 4.943 | 0.109 | 0.029 |
| 40H-22 | 0.951 | 0.021 | 0.557 | 1.901 | 4.232 | 0.116 | 0.123 |
| 40R-55 | 0.473 | 0.021 | 2.450 | 1.590 | 9.820 | 1.380 | 0.314 |
| 40A-23 | 1.042 | 0.021 | 0.484 | 1.599 | 3.677 | 0.073 | 0.021 |

UFSAR Revision 30.0



INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT

Revision: 22.1
Table: 14.3.4-31
Page: 5 of 6

**Table 14.3.4-31
Reactor Cavity Model – TMD Flow Path Input**

| Flow Path | K | f | L _i (ft) | D _H (ft) | A _T (ft ²) | L _{eq} (ft) | A _T /A |
|-----------|-------|-------|---------------------|---------------------|-----------------------------------|----------------------|-------------------|
| 41H-24 | 1.071 | 0.021 | 0.856 | 1.551 | 3.613 | 0.091 | 0.093 |
| 41R-25 | 1.033 | 0.021 | 1.025 | 1.810 | 4.330 | 0.153 | 0.024 |
| 41A-22 | 1.066 | 0.021 | 0.856 | 1.551 | 3.613 | 0.091 | 0.105 |
| 42H-26 | 0.982 | 0.021 | 0.922 | 1.551 | 3.613 | 0.147 | 0.105 |
| 42R-27 | 1.044 | 0.021 | 0.850 | 1.392 | 3.330 | 0.112 | 0.019 |
| 42A-24 | 0.987 | 0.021 | 0.922 | 1.551 | 3.613 | 0.147 | 0.093 |
| 43H-28 | 1.055 | 0.021 | 0.954 | 1.901 | 4.232 | 0.114 | 0.110 |
| 43R-52 | 1.407 | 0.021 | 4.500 | 1.095 | 5.938 | 4.500 | 0.0001 |
| 43A-26 | 1.050 | 0.021 | 0.954 | 1.901 | 4.232 | 0.114 | 0.123 |
| 44H-29 | 1.042 | 0.021 | 0.484 | 1.599 | 3.677 | 0.073 | 0.021 |
| 44R-31 | 0.930 | 0.021 | 0.557 | 1.901 | 4.232 | 0.116 | 0.176 |
| 44A-28 | 0.956 | 0.021 | 0.557 | 1.901 | 4.232 | 0.116 | 0.110 |
| 45H-50 | 0.422 | 0.021 | 6.120 | 1.060 | 5.490 | 5.590 | 0.202 |
| 45R-57 | 0.394 | 0.021 | 2.200 | 1.420 | 9.290 | 1.290 | 0.293 |
| 45A-32 | 1.033 | 0.021 | 0.586 | 1.810 | 4.330 | 0.105 | 0.025 |
| 46H-51 | 0.995 | 0.021 | 6.505 | 1.125 | 5.780 | 6.505 | 1.000 |
| 47H-51 | 0.995 | 0.021 | 2.250 | 1.095 | 5.938 | 2.250 | 1.000 |
| 47R-39 | 0.412 | 0.021 | 2.280 | 1.095 | 5.940 | 2.300 | 0.228 |
| 48H-51 | 0.995 | 0.021 | 2.250 | 1.095 | 5.938 | 2.250 | 1.000 |
| 48R-40 | 0.412 | 0.021 | 2.280 | 1.095 | 5.940 | 2.300 | 0.228 |
| 49H-44 | 0.412 | 0.021 | 2.280 | 1.095 | 5.940 | 2.300 | 0.228 |
| 49R-52 | 0.995 | 0.021 | 2.250 | 1.095 | 5.938 | 2.250 | 1.000 |
| 50H-51 | 0.995 | 0.021 | 5.560 | 1.058 | 5.493 | 5.560 | 1.000 |
| 51H-38 | 1.400 | 0.021 | 4.500 | 5.011 | 80.4 | 4.500 | 0.059 |
| 51R-52 | 0.280 | 0.021 | 33.500 | 1.000 | 570.000 | 0.000 | 0.648 |
| 51A-58 | 0.854 | 0.021 | 9.183 | 9.509 | 126.000 | 7.282 | 1.000 |
| 52H-42 | 1.417 | 0.021 | 5.860 | 1.058 | 5.493 | 5.860 | 0.0001 |
| 52R-38 | 1.400 | 0.021 | 4.500 | 5.011 | 80.4 | 4.500 | 0.059 |

UFSAR Revision 30.0



INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT

Revision: 22.1
Table: 14.3.4-31
Page: 6 of 6

**Table 14.3.4-31
Reactor Cavity Model – TMD Flow Path Input**

| Flow Path | K | f | L _i (ft) | D _H (ft) | A _T (ft ²) | L _{eq} (ft) | A _T /A |
|-----------|-------|-------|---------------------|---------------------|-----------------------------------|----------------------|-------------------|
| 52A-41 | 1.417 | 0.021 | 5.860 | 1.058 | 5.493 | 5.860 | 0.0001 |
| 53H-38 | 0.958 | 0.021 | 2.236 | 2.400 | 9.710 | 2.086 | 1.000 |
| 54H-38 | 0.956 | 0.021 | 1.275 | 2.780 | 10.240 | 1.275 | 1.000 |
| 55H-38 | 0.956 | 0.021 | 1.275 | 2.780 | 10.240 | 1.275 | 1.000 |
| 56H-44 | 0.473 | 0.021 | 2.450 | 1.590 | 9.820 | 1.380 | 0.314 |
| 56R-38 | 0.956 | 0.021 | 1.275 | 2.780 | 10.240 | 1.275 | 1.000 |
| 57H-38 | 0.958 | 0.021 | 2.240 | 2.400 | 9.710 | 2.086 | 1.000 |
| 58H-60 | 0.374 | 0.021 | 9.918 | 9.509 | 126.000 | 7.675 | 0.321 |
| 59H-52 | 2.819 | 0.000 | 50.625 | 1.000 | 465.65 | 50.625 | 0.001 |
| 59R-51 | 2.819 | 0.000 | 50.625 | 1.000 | 465.65 | 50.625 | 0.001 |
| 60H-0 | 0.000 | 0.000 | 0.000 | 1.000 | 1.000 | 0.000 | 0.000 |
| 60R-0 | 0.000 | 0.000 | 0.000 | 1.000 | 1.000 | 0.000 | 0.000 |
| 60A-0 | 0.000 | 0.000 | 0.000 | 1.000 | 1.000 | 0.000 | 0.000 |
| 61H-3 | 0.307 | 0.021 | 1.623 | 0.902 | 1.240 | 0.903 | 0.478 |
| 61R-35 | 0.474 | 0.021 | 1.434 | 0.832 | 1.213 | 1.137 | 1.000 |
| 62H-3 | 0.307 | 0.021 | 1.623 | 0.902 | 1.240 | 0.903 | 0.478 |
| 62R-12 | 0.000 | 0.021 | 2.879 | 0.685 | 0.168 | 2.879 | 1.000 |
| 62A-16 | 0.438 | 0.021 | 1.329 | 0.902 | 1.240 | 1.056 | 1.000 |

UFSAR Revision 30.0

| | | |
|----------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 17.1 Table: 14.3.4-32 Page: 1 of 1</p> |
|----------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|

Compartment Volume and Area¹

| Compartment | Free Volume (ft ³) | Vent Area (ft ²) |
|----------------------|-----------------------------------|---------------------------------|
| Upper Reactor Cavity | 15,720 | 165 |
| Lower Reactor Cavity | 14,769 | 172 |
| Steam Generator | | |
| Enclosure A | 10,905 | 412 |
| Enclosure B | 10,107 | 330 |
| Pressurizer | 2,,639 | 54 |
| Fan Accumulator Room | 26,969 | 299 |

¹ The volumes listed are those that were utilized for the respective subcompartment analysis.

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 19.3</p> <p>Table: 14.3.4-33</p> <p>Page: 1 of 1</p> |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------|

PEAK DIFFERENTIAL PRESSURE (PSI)

STEAM LINE BREAK AT OUTLET NOZZLE (BOUNDING)¹

| | | | | | | Limiting Containment Conditions |
|-------------------------------------------|-----------------|-----|---|-------|-----|-----------------------------------------------------|
| Across Structures: | DP55-25=42.7691 | PSI | @ | 1.210 | SEC | T _{High} /P _{Low} |
| | DP56-25=31.1990 | PSI | @ | 1.297 | SEC | T _{High} /P _{Low} |
| | DP57-25=31.1953 | PSI | @ | 1.296 | SEC | T _{High} /P _{Low} |
| | DP58-25=31.5021 | PSI | @ | 1.291 | SEC | T _{High} /P _{Low} |
| | DP59-25=31.5003 | PSI | @ | 1.292 | SEC | T _{High} /P _{Low} |
| | DP60-25=19.3257 | PSI | @ | 1.344 | SEC | T _{High} /P _{Low} |
| | DP61-25=19.1868 | PSI | @ | 1.346 | SEC | T _{High} /P _{Low} |
| | DP62-25=19.1902 | PSI | @ | 1.342 | SEC | T _{High} /P _{Low} |
| | DP63-25=19.3621 | PSI | @ | 1.340 | SEC | T _{High} /P _{Low} |
| | DP55-46=25.7593 | PSI | @ | .017 | SEC | T _{Low} /P _{Low} |
| | DP56-47=13.7783 | PSI | @ | .022 | SEC | T _{Low} /P _{Low} |
| | DP57-48=12.1139 | PSI | @ | .034 | SEC | T _{Low} /P _{Low} |
| | DP60-51=11.0594 | PSI | @ | .038 | SEC | T _{Low} /P _{Low} |
| | DP61-52=10.0894 | PSI | @ | .041 | SEC | T _{Low} /P _{Low} |
| Across Steam Generator Vessel: | DP56-58=-2.8489 | PSI | @ | .024 | SEC | T _{Low} /P _{Low} |
| | DP57-59=-3.9901 | PSI | @ | .023 | SEC | T _{Low} /P _{Low} Node 46 Break |
| | DP60-62=2.6747 | PSI | @ | .041 | SEC | T _{Low} /P _{Low} |
| | DP61-63=-1.9412 | PSI | @ | .030 | SEC | T _{Low} /P _{Low} Node 46 Break |

¹ All breaks are in Node 55 unless otherwise noted.

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 17.1</p> <p>Table: 14.3.4-34</p> <p>Page: 1 of 1</p> |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------|

PEAK DIFFERENTIAL PRESSURE (PSI)
FEEDWATER LINE BREAK AT SIDE
(BOUNDING)¹

| | | | | | | Limiting Containment Conditions |
|--------------------------------|------------------|-----|---|------|-----|-------------------------------------------------------------------------|
| Across Structures: | DP55-25=5.3159 | PSI | @ | .220 | SEC | T _{Low} /P _{Low} /ICE _{Low} |
| | DP56-25=5.3788 | PSI | @ | .217 | SEC | T _{Low} /P _{Low} /ICE _{Low} |
| | DP57-25=5.3801 | PSI | @ | .219 | SEC | T _{Low} /P _{Low} /ICE _{Low} |
| | DP58-25=5.8566 | PSI | @ | .222 | SEC | T _{Low} /P _{Low} /ICE _{Low} |
| | DP59-25=6.0058 | PSI | @ | .161 | SEC | T _{Low} /P _{Low} /ICE _{High} |
| | DP60-25=5.6043 | PSI | @ | .214 | SEC | T _{Low} /P _{Low} /ICE _{Low} |
| | DP61-25=5.5785 | PSI | @ | .212 | SEC | T _{Low} /P _{Low} /ICE _{Low} |
| | DP62-25=6.8782 | PSI | @ | .022 | SEC | T _{Low} /P _{Low} /ICE _{High} |
| | DP63-25=16.2857 | PSI | @ | .012 | SEC | T _{Low} /P _{Low} /ICE _{High} |
| | DP55-46=3.2606 | PSI | @ | .045 | SEC | T _{Low} /P _{Low} /ICE _{High} |
| | DP56-47=3.3787 | PSI | @ | .030 | SEC | T _{Low} /P _{Low} /ICE _{Low} Node 54 Break |
| | DP57-48=2.9672 | PSI | @ | .039 | SEC | T _{Low} /P _{Low} /ICE _{High} |
| | DP60-51=5.2378 | PSI | @ | .021 | SEC | T _{Low} /P _{Low} /ICE _{Low} Node 54 Break |
| | DP61-52=5.0053 | PSI | @ | .027 | SEC | T _{Low} /P _{Low} /ICE _{High} |
| Across Steam Generator Vessel: | DP56-58=-1.4657 | PSI | @ | .023 | SEC | T _{High} /P _{Low} /ICE _{High} |
| | DP57-59=-3.9920 | PSI | @ | .015 | SEC | T _{Low} /P _{Low} /ICE _{High} |
| | DP60-62=-2.2928 | PSI | @ | .027 | SEC | T _{Low} /P _{Low} /ICE _{High} |
| | DP61-63=-15.5871 | PSI | @ | .011 | SEC | T _{Low} /P _{Low} /ICE _{High} |

¹ All breaks are in Node 63 unless otherwise noted.

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------|------------------------------------------------------------|
|  An AEP Company | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revision: 17.1 Table: 14.3.4-35 Page: 1 of 1 |
|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------|------------------------------------------------------------|

ICE CONDENSER AZIMUTHAL DIFFERENTIAL PRESSURE DISTRIBUTION

| TMD BREAK LOCATION ELEMENTS | | | | | | |
|-----------------------------|------------------|------------------|------------------|-------------------|-------------------|-------------------|
| | 1 | 2 | 3 | 4 | 5 | 6 |
| Ice Condenser | Bays 1 thru 2.75 | Bays 2.75 thru 6 | Bays 7 thru 12.5 | Bays 12.5 thru 17 | Bays 18 thru 20.5 | Bays 20.5 thru 24 |
| <u>Elements</u> | 9 | 12 | 15 | 18 | 21 | 24 |
| Pressure | 7.4 psid | 6.1 psid | 5.5 psid | 5.5 psid | 6.1 psid | 7.4 psid |
| <u>Elements</u> | 8 | 11 | 14 | 17 | 20 | 23 |
| Pressure | 9.2 psid | 7.6 psid | 6.8 psid | 6.8 psid | 7.5 psid | 9.2 psid |
| <u>Elements</u> | 7 | 10 | 13 | 16 | 19 | 22 |
| Pressure | 11.8 psid | 9.8 psid | 8.7 psid | 8.7 psid | 9.7 psid | 11.8 psid |
| <u>Elements</u> | 40 | 41 | 42 | 43 | 44 | 45 |
| Pressure | 14.8 psid | 12.6 psid | 11.2 psid | 11.2 psid | 12.4 psid | 14.5 psid |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------|
|  <p style="font-size: small; margin-top: 5px;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 17.1</p> <p>Table: 14.3.4-36</p> <p>Page: 1 of 2</p> |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------|

SENSITIVITY STUDIES FOR COOK NUCLEAR PLANT

| Parameter | Change Made From Base Value | Change In Operating Deck Dp | Change In Peak Pressure Against The Shell |
|----------------------------------------|-----------------------------|-----------------------------|-------------------------------------------|
| Blowdown | +10% | +11% | +12% |
| Blowdown | -10% | -10% | -12% |
| Blowdown | -20% | -20% | -23% |
| Blowdown | -50% | -50% | -53% |
| Break Compartment Inertial Length | +10% | +4% | +1% |
| Break Compartment Inertial Length | -10% | -4% | -1% |
| Break Compartment Volume | +10% | -2% | -1% |
| Break Compartment Volume | -10% | +2% | +1% |
| Break Compartment Vent Areas | +10% | -6% | -5% |
| Break Compartment Vent Areas | -10% | +8% | +5% |
| Door Port Failure in Break Compartment | one door port fails to open | +1% | -1% |
| Ice Mass | +10% | 0 | 0 |
| Ice Mass | -10% | 0 | 0 |
| Door Inertia | +10% | +1% | 0 |
| Door Inertia | -10% | -1% | 0 |
| All Inertial Lengths | +10% | +5% | +4% |
| All Inertial Lengths | -10% | -5% | -3% |
| Ice Bed Loss Coefficients | +10% | 0 | 0 |
| Ice Bed Loss Coefficients | -10% | 0 | 0 |
| Entrainment Level | 0% Ent | -27% | -11% |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------|
|  <p style="font-size: small; margin-top: 5px;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revision: 17.1 Table: 14.3.4-36 Page: 2 of 2 |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------|

SENSITIVITY STUDIES FOR COOK NUCLEAR PLANT

| Parameter | Change Made From Base Value | Change In Operating Deck Dp | Change In Peak Pressure Against The Shell |
|-------------------------------------|----------------------------------------|-----------------------------|-------------------------------------------|
| Entrainment Level | 30% Ent. | -19% | -15% |
| Entrainment Level | 50% Ent. | -13% | -12% |
| Entrainment Level | 75% Ent. | -6% | -6% |
| Lower Compartment Loss Coefficients | +10% | 0 | 0 |
| Lower Compartment Loss Coefficients | -10% | 0 | 0 |
| Cross Flow in Lower Plenum | Low estimate of resistance | 0 | -7% |
| Cross Flow in Lower Plenum | High estimate of resistance | 0 | -3% |
| Ice Condenser Flow Area | +10% | 0 | -3% |
| Ice Condenser Flow Area | -10% | 0 | +4% |
| Ice Condenser | +20% | 0 | -6% |
| Ice Condenser Flow Area | -50% | 0 | +8% |
| Initial Pressure in Containment | +0.3 psi | +2% | +2% |
| Initial Pressure in Containment | -0.3 psi | -2% | -2% |
| Reactor Coolant Break Enthalpy | -13.0% | +6% | +3% |
| Compressibility Factor | Addition of the compressibility factor | +4% | 0 |

All values shown are to the nearest percent.

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------|------------------------------------------------------------|
|  An AEP Company | INDIANA AND MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revision: 17.1 Table: 14.3.4-37 Page: 1 of 1 |
|------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------|------------------------------------------------------------|

1973 WALTZ MILL PRELIMINARY TEST CONDITIONS

| | | | Nominal Conditions | |
|---------------------------------|-------------------------------------------|--------------------------------------------------------------|----------------------------------|--------------------------------------|
| Test Series | G_{test}/G_{plant} | (Total Energy/Ice Wt.) test/ (Total Energy/Ice Wt.) plant | Subcooling In Piping | Varied in Test Setup |
| Blowdown rate Series | 37% 75% 100% 150% 10% 1.5% | 100% | 40°F | Variable Orifice Sizes |
| Blowdown Energy Series | 75% 100% 100% | 150% 150% 200% | ~40°F | Variable Boiler Water levels |
| Blowdown Transient Shape Series | 75% 75% 100% 100% | 100% | ~10°F ~25°F ~10°F ~25°F | Variable Conditions In Subcooled Leg |

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 17.1 Table: 14.3.4-38 Page: 1 of 1</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|

PEAK PRESSURES / DIFFERENTIALS

| | DEHL Break In Element #6 | DECL Break In Element #6 |
|----------------------------------------------------------------------------------|-------------------------------------|-------------------------------------|
| Pressure In Element #6 (Psig) | 14.8 / 14.4 | 13.4 / 13.0 |
| Peak Pressure In Ice Condenser Compartments (Psig) | 10.6 / 10.6 | 9.8 / 9.9 |
| Peak Differential Pressure Across Operating Deck or Lower Crane Wall (Psi) | 14.5 / 14.1 | 12.3 / 11.7 |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------|
|  <p style="font-size: small; margin-top: 5px;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 17.1</p> <p>Table: 14.3.4-39</p> <p>Page: 1 of 1</p> |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------|

EFFECTS OF VARYING POLYTROPIC EXPONENT

| | Base Case | 5% Decrease | 10% Decrease | 20% Decrease |
|----------------------------------------------------------------------------|-----------|-------------|--------------|--------------|
| Pressure In Element #6 (Psig) | 14.8 | 14.8 | 14.8 | 14.9 |
| Peak Pressure In Ice Condenser Compartment (Psig) | 10.6 | 10.6 | 10.6 | 10.6 |
| Peak Differential Pressure Across Operating Deck or Lower Crane Wall (Psi) | 14.5 | 14.5 | 14.5 | 14.6 |
| | | | | |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 17.1</p> <p>Table: 14.3.4-40</p> <p>Page: 1 of 3</p> |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------|

CALCULATED MAXIMUM PEAK PRESSURES COMPARED WITH DESIGN PRESSURE

(HISTORICAL INFORMATION)

| Type of Break | Location ¹ | Peak Pressure | | Peak Differential Pressure ² | | Design |
|---------------|-----------------------|---------------|-------------------|-----------------------------------------|-------------------|--------|
| | | Augmented | Unaugmented | Augmented | Unaugmented | |
| DECL | Element 1 | 13.7 | 14.1 | 10.8 | 12.7 | 16.6 |
| DECL | Element 2 | 10.8 | 12.2 ³ | 8.6 ³ | 10.5 ³ | 12.0 |
| DECL | Element 3 | 9.8 | 11.2 ³ | 7.5 ³ | 9.4 ³ | 12.0 |
| DECL | Element 4 | 9.7 | 11.1 ³ | 7.6 ³ | 9.5 ³ | 12.0 |
| DECL | Element 5 | 10.5 | 11.9 ³ | 8.6 ³ | 10.5 ³ | 12.0 |
| DECL | Element 6 | 11.6 | 13.0 ³ | 10.4 ³ | 12.3 ³ | 16.6 |
| DEHL | Element 1 | 13.3 | 13.7 ³ | 13.0 ³ | 13.5 ³ | 16.6 |
| DEHL | Element 2 | 10.6 | 11.0 ³ | 10.3 ³ | 10.8 ³ | 12.0 |
| DEHL | Element 3 | 8.9 | 9.3 ³ | 8.3 ³ | 8.8 ³ | 12.0 |
| DEHL | Element 4 | 9.0 | 9.4 ³ | 8.0 ³ | 8.5 ³ | 12.0 |
| DEHL | Element 5 | 10.5 | 10.9 ³ | 10.2 ³ | 10.7 ³ | 12.0 |
| DEHL | Element 6 | 13.6 | 14.0 | 13.2 | 13.7 | 16.6 |
| DECL | Element 40 | 9.8 | 10.6 | 9.8 | 10.6 | 12.0 |
| DECL | Element 41 | 8.7 | 9.5 ³ | 8.7 | 9.5 | 12.0 |
| DECL | Element 42 | 7.8 | 8.6 ³ | 7.8 | 8.6 | 12.0 |
| DECL | Element 43 | 7.8 | 8.6 ³ | 7.8 | 8.6 | 12.0 |
| DECL | Element 44 | 8.5 | 9.3 ³ | 8.5 | 9.3 | 12.0 |

¹ Element 1-6 are break locations

² For Elements 1 through 6 the peak differential pressure is across the operating deck or the lower crane wall. For Elements 7 through 24 the peak differential pressure is across the upper crane wall. For Elements 40 through 45 the peak differential pressure is across the containment shell.

³ The unaugmented peak pressure and peak differential pressure other than Elements 1/40 (DECL) and 6/45 (DEHL) are conservatively estimated by taking the ΔP (unaug-aug) and adding it to the augmented pressure. Elements 2 through 6 and 41 through 45 for DECL and 1 through 5 and 40 through 44 for DEHL reflect this change. In Elements 7 through 24 the ΔP (unaug-aug) for peak pressure was used to estimate the unaugmented peak differential pressure.

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 17.1</p> <p>Table: 14.3.4-40</p> <p>Page: 2 of 3</p> |
|-----------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------|

CALCULATED MAXIMUM PEAK PRESSURES COMPARED WITH DESIGN PRESSURE

(HISTORICAL INFORMATION)

| Type of Break | Location ¹ | Peak Pressure | | Peak Differential Pressure ² | | Design |
|---------------|-----------------------|---------------|-------------------|-----------------------------------------|------------------|--------|
| | | Augmented | Unaugmented | Augmented | Unaugmented | |
| DECL | Element 45 | 9.5 | 10.3 ³ | 9.5 | 10.3 | 12.0 |
| DEHL | Element 40 | 10.7 | 10.8 ³ | 10.7 | 10.8 | 12.0 |
| DEHL | Element 41 | 8.3 | 8.4 ³ | 8.3 | 8.4 | 12.0 |
| DEHL | Element 42 | 7.0 | 8.1 ³ | 7.0 | 8.1 | 12.0 |
| DEHL | Element 43 | 7.1 | 7.2 ³ | 7.1 | 7.2 | 12.0 |
| DEHL | Element 44 | 8.4 | 8.5 ³ | 8.4 | 8.5 | 12.0 |
| DEHL | Element 45 | 10.7 | 10.8 | 10.7 | 10.8 | 12.0 |
| DECL | Elements 7-8-9 | 6.1 | 6.1 | 6.6 ³ | 6.6 ³ | 12.0 |
| DECL | Elements 10-11-12 | 5.9 | 6.1 | 5.9 | 6.1 ³ | 12.0 |
| DECL | Elements 13-14-15 | 5.6 | 6.0 | 5.2 | 5.6 ³ | 12.0 |
| DECL | Elements 16-17-18 | 6.0 | 6.2 | 5.4 | 5.6 ³ | 12.0 |
| DECL | Elements 19-20-21 | 6.7 | 6.7 | 6.0 | 6.0 ³ | 12.0 |
| DECL | Elements 22-23-24 | 6.0 | 6.1 | 6.6 | 6.7 ³ | 12.0 |
| DEHL | Elements 7-8-9 | 7.1 | 7.2 | 7.8 | 7.9 ³ | 12.0 |
| DEHL | Elements 10-11-12 | 7.6 | 7.6 | 6.8 | 6.8 ³ | 12.0 |
| DEHL | Elements 13-14-15 | 6.4 | 6.8 | 6.0 | 6.4 ³ | 12.0 |
| DEHL | Elements 16-17-18 | 6.0 | 6.5 | 6.1 | 6.6 ³ | 12.0 |
| DEHL | 19-20-21 | 6.8 | 6.8 | 6.9 | 6.9 ³ | 12.0 |
| DEHL | 22-23-24 | 7.1 | 7.5 | 7.6 | 8.0 ³ | 12.0 |
| STEAMLINE | S.G. Doghouse | 20.8 | 20.8 | 20.5 | 20.5 | 26.4 |
| STEAMLINE | Fan Room | 13.9 | 13.9 | 13.9 | 13.9 | 16.0 |

UFSAR Revision 30.0


| | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------|
|  <p style="font-size: small; margin-top: 5px;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 17.1</p> <p>Table: 14.3.4-40</p> <p>Page: 3 of 3</p> |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------|

CALCULATED MAXIMUM PEAK PRESSURES COMPARED WITH DESIGN PRESSURE

(HISTORICAL INFORMATION)

| Type of Break | Location ¹ | Peak Pressure | | Peak Differential Pressure ² | | Design |
|---------------|------------------------|---------------|-------------|-----------------------------------------|-------------|--------|
| | | Augmented | Unaugmented | Augmented | Unaugmented | |
| SECL | Lower Rx Cavity | 12.2 | 13.8 | 11.4 | 12.3 | 15.0 |
| SECL | Upper Rx Cavity | 40.4 | 47.0 | 36.9 | 44.1 | 48.0 |
| 6" Spray Line | Pressurizer Enclosure | 14.0 | 17.8 | 13.1 | 16.4 | 80.0 |
| LOCA | Reactor Vessel Annulus | 63.0 | 95.0 | 63.0 | 95.0 | 1000.0 |
| LOCA | Reactor Pipe Annulus | 419.0 | 735.0 | 419.0 | 735.0 | 2000.0 |
| | | | | | | |
| | | | | | | |


UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|--------------------------------------------------|
|  An AEP Company | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revised: 27.0 Table:14.3.4-41 Page: 1 of 2 |
|-----------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|--------------------------------------------------|

DECL Minimum Safeguards Blowdown Mass & Energy

| Time (sec) | Break Path 1 | | Break Path 2 | |
|------------|--------------|---------------|--------------|---------------|
| | Flow (lbm/s) | Energy (BTUs) | Flow (lbm/s) | Energy (BTUs) |
| 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 1.00 | 69541.05 | 38072128.38 | 25274.17 | 13708526.28 |
| 2.00 | 59082.07 | 32734686.00 | 23523.83 | 13033059.18 |
| 3.00 | 43630.13 | 24731959.23 | 18283.46 | 10507768.61 |
| 4.00 | 35614.74 | 20458788.80 | 13731.27 | 7728808.39 |
| 5.00 | 31074.76 | 18041086.00 | 10691.77 | 6319115.92 |
| 6.00 | 28747.32 | 16793275.59 | 9608.03 | 5772305.39 |
| 7.00 | 25328.05 | 15318005.81 | 9202.82 | 5537586.42 |
| 8.00 | 20584.46 | 13406087.99 | 8493.19 | 5173844.80 |
| 9.00 | 16598.22 | 11561693.69 | 7677.87 | 4727423.32 |
| 10.00 | 13878.16 | 10235512.37 | 6945.21 | 4311501.04 |
| 11.00 | 11775.93 | 9157678.86 | 6207.16 | 3877731.54 |
| 12.00 | 10082.38 | 8255713.00 | 5513.96 | 3444372.92 |
| 13.00 | 8964.29 | 7114235.22 | 4885.53 | 3000354.64 |
| 14.00 | 9167.35 | 5969225.12 | 4181.30 | 2473806.33 |
| 15.00 | 8638.11 | 4897363.27 | 3479.19 | 1902292.53 |
| 16.00 | 8235.41 | 4000941.83 | 2913.84 | 1407060.24 |
| 17.00 | 7980.17 | 3354039.35 | 1663.75 | 592718.07 |
| 18.00 | 7652.02 | 2907301.23 | 1429.69 | 235952.37 |
| 19.00 | 7517.17 | 2517308.71 | 1548.75 | 222953.41 |
| 20.00 | 6899.28 | 2061869.74 | 1646.23 | 213900.65 |


UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revised: 27.0 Table:14.3.4-41 Page: 2 of 2</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|

DECL Minimum Safeguards Blowdown Mass & Energy

| Time (sec) | Break Path 1 | | Break Path 2 | |
|------------|--------------|---------------|--------------|---------------|
| | Flow (lbm/s) | Energy (BTUs) | Flow (lbm/s) | Energy (BTUs) |
| 21.00 | 5911.31 | 1611796.68 | 1712.29 | 210866.49 |
| 22.00 | 6186.76 | 1456722.22 | 1769.97 | 223369.02 |
| 23.00 | 4915.57 | 1100883.69 | 1838.57 | 232658.29 |
| 24.00 | 2928.20 | 661283.58 | 1850.57 | 242488.78 |
| 25.00 | 1237.20 | 265272.72 | 1854.23 | 238119.92 |
| 26.00 | 259.50 | 60950.94 | 1712.71 | 190109.81 |
| 27.00 | 259.50 | 60950.94 | 1622.04 | 160051.49 |
| 28.00 | 259.50 | 60950.94 | 1625.74 | 156190.40 |
| 29.00 | 259.50 | 60950.94 | 1496.97 | 140730.10 |
| 30.00 | 259.50 | 60950.94 | 1324.40 | 121410.32 |
| 31.00 | 259.50 | 60950.94 | 1936.18 | 175388.25 |
| 32.00 | 259.50 | 60950.94 | 1717.65 | 168218.37 |


UFSAR Revision 30.0

| | | |
|----------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------|
|  <p style="font-size: small; margin-top: 5px;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revised: 27.0 Table:14.3.4-42 Page: 1 of 14 |
|----------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------|

DECL Minimum Safeguards Post-Blowdown Mass & Energy

| Time (sec) | Break Path 1 | | Break Path 2 | |
|---------------|-----------------|------------------|-----------------|------------------|
| | Flow (lbm/s) | Energy (BTUs) | Flow (lbm/s) | Energy (BTUs) |
| 32.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 32.01 | 259.50 | 60950.94 | 1529.62 | 150693.05 |
| 32.99 | 259.50 | 60950.94 | 1529.62 | 150693.05 |
| 33.00 | 0.68 | 740.84 | 1686.47 | 184224.75 |
| 33.99 | 0.68 | 740.84 | 1686.47 | 184224.75 |
| 34.00 | 2041.99 | 484024.18 | 681.70 | 218031.44 |
| 53.99 | 2041.99 | 484024.18 | 681.70 | 218031.44 |
| 54.00 | 936.12 | 348048.67 | 228.87 | 126717.15 |
| 73.99 | 936.12 | 348048.67 | 228.87 | 126717.15 |
| 74.00 | 133.31 | 92740.89 | 169.55 | 60335.44 |
| 93.99 | 133.31 | 92740.89 | 169.55 | 60335.44 |
| 94.00 | 200.22 | 113509.29 | 185.90 | 63125.74 |
| 113.99 | 200.22 | 113509.29 | 185.90 | 63125.74 |
| 114.00 | 434.69 | 160224.09 | 193.90 | 69155.68 |
| 133.99 | 434.69 | 160224.09 | 193.90 | 69155.68 |
| 134.00 | 496.52 | 171162.54 | 194.18 | 69259.58 |
| 153.99 | 496.52 | 171162.54 | 194.18 | 69259.58 |
| 154.00 | 484.42 | 164758.35 | 188.51 | 66676.60 |
| 173.99 | 484.42 | 164758.35 | 188.51 | 66676.60 |
| 174.00 | 341.36 | 126112.47 | 187.84 | 60369.74 |
| 193.99 | 341.36 | 126112.47 | 187.84 | 60369.74 |


UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------|
|  <p style="font-size: small; margin-top: 5px;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revised: 27.0 Table:14.3.4-42 Page: 2 of 14</p> |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------|

DECL Minimum Safeguards Post-Blowdown Mass & Energy

| Time (sec) | Break Path 1 | | Break Path 2 | |
|---------------|-----------------|------------------|-----------------|------------------|
| | Flow (lbm/s) | Energy (BTUs) | Flow (lbm/s) | Energy (BTUs) |
| 194.00 | 296.67 | 111859.40 | 186.23 | 58202.67 |
| 213.99 | 296.67 | 111859.40 | 186.23 | 58202.67 |
| 214.00 | 235.07 | 98279.71 | 185.46 | 57878.89 |
| 233.99 | 235.07 | 98279.71 | 185.46 | 57878.89 |
| 234.00 | 200.80 | 93212.45 | 188.90 | 59963.60 |
| 253.99 | 200.80 | 93212.45 | 188.90 | 59963.60 |
| 254.00 | 258.35 | 117147.14 | 193.93 | 66361.33 |
| 273.99 | 258.35 | 117147.14 | 193.93 | 66361.33 |
| 274.00 | 476.25 | 165200.81 | 196.59 | 69750.08 |
| 323.99 | 476.25 | 165200.81 | 196.59 | 69750.08 |
| 324.00 | 244.12 | 108658.64 | 191.40 | 63004.55 |
| 373.99 | 244.12 | 108658.64 | 191.40 | 63004.55 |
| 374.00 | 370.40 | 147334.73 | 199.45 | 72649.77 |
| 423.99 | 370.40 | 147334.73 | 199.45 | 72649.77 |
| 424.00 | 386.48 | 145510.06 | 197.08 | 69708.86 |
| 473.99 | 386.48 | 145510.06 | 197.08 | 69708.86 |
| 474.00 | 285.56 | 124470.10 | 196.96 | 69050.41 |
| 523.99 | 285.56 | 124470.10 | 196.96 | 69050.41 |
| 524.00 | 453.97 | 168390.65 | 204.79 | 78240.10 |
| 573.99 | 453.97 | 168390.65 | 204.79 | 78240.10 |
| 574.00 | 386.29 | 153608.64 | 203.96 | 76553.49 |


UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------|
|  <p style="font-size: small; margin: 0;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revised: 27.0 Table:14.3.4-42 Page: 3 of 14</p> |
|-----------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------|

DECL Minimum Safeguards Post-Blowdown Mass & Energy

| Time (sec) | Break Path 1 | | Break Path 2 | |
|---------------|-----------------|------------------|-----------------|------------------|
| | Flow (lbm/s) | Energy (BTUs) | Flow (lbm/s) | Energy (BTUs) |
| 623.99 | 386.29 | 153608.64 | 203.96 | 76553.49 |
| 624.00 | 307.52 | 134565.16 | 200.92 | 73474.29 |
| 673.99 | 307.52 | 134565.16 | 200.92 | 73474.29 |
| 674.00 | 434.25 | 166350.42 | 208.41 | 80283.50 |
| 723.99 | 434.25 | 166350.42 | 208.41 | 80283.50 |
| 724.00 | 362.19 | 146367.64 | 204.02 | 75664.94 |
| 773.99 | 362.19 | 146367.64 | 204.02 | 75664.94 |
| 774.00 | 368.61 | 148685.27 | 207.10 | 77957.47 |
| 823.99 | 368.61 | 148685.27 | 207.10 | 77957.47 |
| 824.00 | 400.04 | 157351.26 | 209.89 | 80226.97 |
| 873.99 | 400.04 | 157351.26 | 209.89 | 80226.97 |
| 874.00 | 377.42 | 153664.13 | 213.41 | 82911.40 |
| 923.99 | 377.42 | 153664.13 | 213.41 | 82911.40 |
| 924.00 | 374.39 | 153418.33 | 218.44 | 86902.02 |
| 973.99 | 374.39 | 153418.33 | 218.44 | 86902.02 |
| 974.00 | 316.18 | 137637.64 | 214.00 | 82247.70 |
| 1023.99 | 316.18 | 137637.64 | 214.00 | 82247.70 |
| 1024.00 | 395.90 | 159231.26 | 232.11 | 96590.55 |
| 1073.99 | 395.90 | 159231.26 | 232.11 | 96590.55 |
| 1074.00 | 379.84 | 158622.36 | 226.96 | 93127.19 |
| 1123.99 | 379.84 | 158622.36 | 226.96 | 93127.19 |


UFSAR Revision 30.0

| | | |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|
|  <small>An AEP Company</small> | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revised: 27.0 Table: 14.3.4-42 Page: 4 of 14 |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|

DECL Minimum Safeguards Post-Blowdown Mass & Energy

| Time (sec) | Break Path 1 | | Break Path 2 | |
|---------------|-----------------|------------------|-----------------|------------------|
| | Flow (lbm/s) | Energy (BTUs) | Flow (lbm/s) | Energy (BTUs) |
| 1124.00 | 312.18 | 141775.18 | 229.84 | 93794.70 |
| 1173.99 | 312.18 | 141775.18 | 229.84 | 93794.70 |
| 1174.00 | 377.80 | 163888.46 | 239.14 | 101396.33 |
| 1223.99 | 377.80 | 163888.46 | 239.14 | 101396.33 |
| 1224.00 | 318.81 | 151447.59 | 249.13 | 106422.61 |
| 1273.99 | 318.81 | 151447.59 | 249.13 | 106422.61 |
| 1274.00 | 392.11 | 171402.74 | 252.48 | 110393.74 |
| 1323.99 | 392.11 | 171402.74 | 252.48 | 110393.74 |
| 1324.00 | 304.71 | 143861.52 | 245.81 | 104280.95 |
| 1373.99 | 304.71 | 143861.52 | 245.81 | 104280.95 |
| 1374.00 | 373.43 | 170512.87 | 259.92 | 113873.85 |
| 1423.99 | 373.43 | 170512.87 | 259.92 | 113873.85 |
| 1424.00 | 291.54 | 148783.97 | 266.66 | 113413.92 |
| 1473.99 | 291.54 | 148783.97 | 266.66 | 113413.92 |
| 1474.00 | 271.78 | 142834.55 | 301.32 | 125478.43 |
| 1523.99 | 271.78 | 142834.55 | 301.32 | 125478.43 |
| 1524.00 | 229.24 | 131923.31 | 367.69 | 135927.28 |
| 1573.99 | 229.24 | 131923.31 | 367.69 | 135927.28 |
| 1574.00 | 158.10 | 109482.96 | 381.65 | 129932.15 |
| 1623.99 | 158.10 | 109482.96 | 381.65 | 129932.15 |
| 1624.00 | 116.25 | 84640.51 | 439.41 | 135415.35 |


UFSAR Revision 30.0

| | | |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|
|  <small>An AEP Company</small> | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revised: 27.0 Table: 14.3.4-42 Page: 5 of 14 |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|

DECL Minimum Safeguards Post-Blowdown Mass & Energy

| Time (sec) | Break Path 1 | | Break Path 2 | |
|---------------|-----------------|------------------|-----------------|------------------|
| | Flow (lbm/s) | Energy (BTUs) | Flow (lbm/s) | Energy (BTUs) |
| 1673.99 | 116.25 | 84640.51 | 439.41 | 135415.35 |
| 1674.00 | 115.37 | 87695.35 | 463.55 | 137231.27 |
| 1723.99 | 115.37 | 87695.35 | 463.55 | 137231.27 |
| 1724.00 | 133.08 | 105191.32 | 342.94 | 122912.64 |
| 1773.99 | 133.08 | 105191.32 | 342.94 | 122912.64 |
| 1774.00 | 77.41 | 76446.17 | 174.88 | 84851.57 |
| 1823.99 | 77.41 | 76446.17 | 174.88 | 84851.57 |
| 1824.00 | 69.01 | 69732.06 | 108.91 | 64882.52 |
| 1873.99 | 69.01 | 69732.06 | 108.91 | 64882.52 |
| 1874.00 | 62.52 | 63595.65 | 101.04 | 59912.47 |
| 1923.99 | 62.52 | 63595.65 | 101.04 | 59912.47 |
| 1924.00 | 52.86 | 52618.60 | 150.11 | 62536.38 |
| 2123.99 | 52.86 | 52618.60 | 150.11 | 62536.38 |
| 2124.00 | 47.47 | 44916.11 | 353.27 | 109647.01 |
| 2323.99 | 47.47 | 44916.11 | 353.27 | 109647.01 |
| 2324.00 | 26.36 | 26516.93 | 396.35 | 119506.62 |
| 2523.99 | 26.36 | 26516.93 | 396.35 | 119506.62 |
| 2524.00 | 4.33 | 4793.89 | 397.58 | 120954.33 |
| 2723.99 | 4.33 | 4793.89 | 397.58 | 120954.33 |
| 2724.00 | 0.38 | 419.09 | 398.10 | 115923.21 |
| 2923.99 | 0.38 | 419.09 | 398.10 | 115923.21 |


UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------|
|  <p style="font-size: small; margin-top: 5px;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revised: 27.0 Table:14.3.4-42 Page: 6 of 14 |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------|

DECL Minimum Safeguards Post-Blowdown Mass & Energy

| Time (sec) | Break Path 1 | | Break Path 2 | |
|---------------|-----------------|------------------|-----------------|------------------|
| | Flow (lbm/s) | Energy (BTUs) | Flow (lbm/s) | Energy (BTUs) |
| 2924.00 | 7.64 | 3014.99 | 395.39 | 110002.00 |
| 3123.99 | 7.64 | 3014.99 | 395.39 | 110002.00 |
| 3124.00 | 119.76 | 30193.40 | 391.10 | 102294.41 |
| 3323.99 | 119.76 | 30193.40 | 391.10 | 102294.41 |
| 3324.00 | 3.48 | 2944.70 | 386.15 | 105742.93 |
| 3523.99 | 3.48 | 2944.70 | 386.15 | 105742.93 |
| 3524.00 | 38.19 | 9859.87 | 391.32 | 102943.28 |
| 3723.99 | 38.19 | 9859.87 | 391.32 | 102943.28 |
| 3724.00 | 130.64 | 25508.17 | 369.45 | 92730.58 |
| 3923.99 | 130.64 | 25508.17 | 369.45 | 92730.58 |
| 3924.00 | 30.33 | 6084.03 | 367.85 | 92571.63 |
| 4123.99 | 30.33 | 6084.03 | 367.85 | 92571.63 |
| 4124.00 | 5.48 | 1045.09 | 335.02 | 96823.53 |
| 4323.99 | 5.48 | 1045.09 | 335.02 | 96823.53 |
| 4324.00 | 0.05 | 57.80 | 141.02 | 65695.50 |
| 4523.99 | 0.05 | 57.80 | 141.02 | 65695.50 |
| 4524.00 | 0.00 | 4.51 | 118.72 | 61254.09 |
| 4723.99 | 0.00 | 4.51 | 118.72 | 61254.09 |
| 4724.00 | 0.03 | 33.96 | 116.23 | 59526.42 |
| 4923.99 | 0.03 | 33.96 | 116.23 | 59526.42 |
| 4924.00 | 0.02 | 25.81 | 128.46 | 61201.15 |


UFSAR Revision 30.0

| | | |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|---------------------------------------------------|
|  <small>An AEP Company</small> | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revised: 27.0 Table:14.3.4-42 Page: 7 of 14 |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|---------------------------------------------------|

DECL Minimum Safeguards Post-Blowdown Mass & Energy

| Time (sec) | Break Path 1 | | Break Path 2 | |
|---------------|-----------------|------------------|-----------------|------------------|
| | Flow (lbm/s) | Energy (BTUs) | Flow (lbm/s) | Energy (BTUs) |
| 5123.99 | 0.02 | 25.81 | 128.46 | 61201.15 |
| 5124.00 | 0.03 | 36.50 | 131.84 | 61294.88 |
| 5323.99 | 0.03 | 36.50 | 131.84 | 61294.88 |
| 5324.00 | 0.02 | 17.94 | 126.24 | 59042.74 |
| 5523.99 | 0.02 | 17.94 | 126.24 | 59042.74 |
| 5524.00 | 0.04 | 41.56 | 129.55 | 58830.68 |
| 5723.99 | 0.04 | 41.56 | 129.55 | 58830.68 |
| 5724.00 | 0.03 | 31.33 | 134.85 | 59411.87 |
| 5923.99 | 0.03 | 31.33 | 134.85 | 59411.87 |
| 5924.00 | 0.03 | 29.55 | 131.44 | 58352.90 |
| 6123.99 | 0.03 | 29.55 | 131.44 | 58352.90 |
| 6124.00 | 0.02 | 17.62 | 128.74 | 57416.45 |
| 6323.99 | 0.02 | 17.62 | 128.74 | 57416.45 |
| 6324.00 | 0.05 | 51.96 | 125.70 | 55976.66 |
| 6523.99 | 0.05 | 51.96 | 125.70 | 55976.66 |
| 6524.00 | 0.03 | 31.58 | 133.51 | 57429.33 |
| 6723.99 | 0.03 | 31.58 | 133.51 | 57429.33 |
| 6724.00 | 0.03 | 35.97 | 149.80 | 60217.58 |
| 6923.99 | 0.03 | 35.97 | 149.80 | 60217.58 |
| 6924.00 | 0.08 | 80.78 | 135.08 | 56705.62 |
| 7123.99 | 0.08 | 80.78 | 135.08 | 56705.62 |


UFSAR Revision 30.0

| | | |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|---------------------------------------------------|
|  <small>An AEP Company</small> | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revised: 27.0 Table:14.3.4-42 Page: 8 of 14 |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|---------------------------------------------------|

DECL Minimum Safeguards Post-Blowdown Mass & Energy

| Time (sec) | Break Path 1 | | Break Path 2 | |
|---------------|-----------------|------------------|-----------------|------------------|
| | Flow (lbm/s) | Energy (BTUs) | Flow (lbm/s) | Energy (BTUs) |
| 7124.00 | 0.09 | 91.71 | 155.80 | 60313.85 |
| 7323.99 | 0.09 | 91.71 | 155.80 | 60313.85 |
| 7324.00 | 0.13 | 138.16 | 141.47 | 56394.37 |
| 7523.99 | 0.13 | 138.16 | 141.47 | 56394.37 |
| 7524.00 | 0.12 | 131.00 | 138.72 | 55837.43 |
| 7723.99 | 0.12 | 131.00 | 138.72 | 55837.43 |
| 7724.00 | 0.10 | 105.77 | 129.96 | 53973.77 |
| 7923.99 | 0.10 | 105.77 | 129.96 | 53973.77 |
| 7924.00 | 0.10 | 112.89 | 129.87 | 53807.18 |
| 8123.99 | 0.10 | 112.89 | 129.87 | 53807.18 |
| 8124.00 | 0.08 | 90.35 | 127.90 | 53613.33 |
| 8323.99 | 0.08 | 90.35 | 127.90 | 53613.33 |
| 8324.00 | 0.08 | 87.92 | 127.23 | 52915.15 |
| 8523.99 | 0.08 | 87.92 | 127.23 | 52915.15 |
| 8524.00 | 0.07 | 80.67 | 133.71 | 53881.36 |
| 8723.99 | 0.07 | 80.67 | 133.71 | 53881.36 |
| 8724.00 | 0.10 | 108.62 | 128.32 | 52436.24 |
| 8923.99 | 0.10 | 108.62 | 128.32 | 52436.24 |
| 8924.00 | 0.07 | 74.12 | 128.65 | 51886.80 |
| 9123.99 | 0.07 | 74.12 | 128.65 | 51886.80 |
| 9124.00 | 0.07 | 72.73 | 126.79 | 50967.27 |


UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------|
|  <p style="font-size: small; margin-top: 5px;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revised: 27.0 Table:14.3.4-42 Page: 9 of 14</p> |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------|

DECL Minimum Safeguards Post-Blowdown Mass & Energy

| Time (sec) | Break Path 1 | | Break Path 2 | |
|---------------|-----------------|------------------|-----------------|------------------|
| | Flow (lbm/s) | Energy (BTUs) | Flow (lbm/s) | Energy (BTUs) |
| 9323.99 | 0.07 | 72.73 | 126.79 | 50967.27 |
| 9324.00 | 0.07 | 80.57 | 131.32 | 52068.57 |
| 9523.99 | 0.07 | 80.57 | 131.32 | 52068.57 |
| 9524.00 | 0.04 | 41.48 | 130.54 | 51729.07 |
| 9723.99 | 0.04 | 41.48 | 130.54 | 51729.07 |
| 9724.00 | 0.04 | 46.40 | 130.89 | 51085.18 |
| 9923.99 | 0.04 | 46.40 | 130.89 | 51085.18 |
| 9924.00 | 0.05 | 58.80 | 128.33 | 50241.49 |
| 10123.99 | 0.05 | 58.80 | 128.33 | 50241.49 |
| 10124.00 | 0.06 | 61.68 | 125.64 | 49433.24 |
| 10323.99 | 0.06 | 61.68 | 125.64 | 49433.24 |
| 10324.00 | 0.08 | 81.57 | 128.99 | 49735.65 |
| 10523.99 | 0.08 | 81.57 | 128.99 | 49735.65 |
| 10524.00 | 0.06 | 61.92 | 123.27 | 49377.78 |
| 10723.99 | 0.06 | 61.92 | 123.27 | 49377.78 |
| 10724.00 | 0.03 | 38.01 | 126.86 | 50355.47 |
| 10923.99 | 0.03 | 38.01 | 126.86 | 50355.47 |
| 10924.00 | 0.01 | 11.49 | 137.91 | 51858.61 |
| 11123.99 | 0.01 | 11.49 | 137.91 | 51858.61 |
| 11124.00 | 0.01 | 8.70 | 134.26 | 51017.92 |
| 11323.99 | 0.01 | 8.70 | 134.26 | 51017.92 |


UFSAR Revision 30.0

| | | |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|
|  <small>An AEP Company</small> | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revised: 27.0 Table:14.3.4-42 Page: 10 of 14 |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|

DECL Minimum Safeguards Post-Blowdown Mass & Energy

| Time (sec) | Break Path 1 | | Break Path 2 | |
|---------------|-----------------|------------------|-----------------|------------------|
| | Flow (lbm/s) | Energy (BTUs) | Flow (lbm/s) | Energy (BTUs) |
| 11324.00 | 0.00 | 1.44 | 129.31 | 49922.57 |
| 11523.99 | 0.00 | 1.44 | 129.31 | 49922.57 |
| 11524.00 | 0.02 | 16.85 | 132.54 | 50146.44 |
| 11723.99 | 0.02 | 16.85 | 132.54 | 50146.44 |
| 11724.00 | 0.02 | 18.24 | 128.57 | 49163.67 |
| 11923.99 | 0.02 | 18.24 | 128.57 | 49163.67 |
| 11924.00 | 0.00 | 4.62 | 130.65 | 49597.79 |
| 12123.99 | 0.00 | 4.62 | 130.65 | 49597.79 |
| 12124.00 | 0.03 | 28.53 | 129.02 | 48868.44 |
| 12323.99 | 0.03 | 28.53 | 129.02 | 48868.44 |
| 12324.00 | 0.02 | 19.81 | 130.04 | 48901.11 |
| 12523.99 | 0.02 | 19.81 | 130.04 | 48901.11 |
| 12524.00 | 0.01 | 12.25 | 134.80 | 49660.73 |
| 12723.99 | 0.01 | 12.25 | 134.80 | 49660.73 |
| 12724.00 | 0.01 | 7.23 | 127.80 | 48290.41 |
| 12923.99 | 0.01 | 7.23 | 127.80 | 48290.41 |
| 12924.00 | 0.01 | 10.91 | 125.73 | 47420.18 |
| 13123.99 | 0.01 | 10.91 | 125.73 | 47420.18 |
| 13124.00 | 0.04 | 46.45 | 128.02 | 47720.36 |
| 13323.99 | 0.04 | 46.45 | 128.02 | 47720.36 |
| 13324.00 | 0.02 | 16.88 | 132.33 | 48157.60 |


UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|
|  An AEP Company | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revised: 27.0 Table:14.3.4-42 Page: 11 of 14 |
|-----------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|

DECL Minimum Safeguards Post-Blowdown Mass & Energy

| Time (sec) | Break Path 1 | | Break Path 2 | |
|---------------|-----------------|------------------|-----------------|------------------|
| | Flow (lbm/s) | Energy (BTUs) | Flow (lbm/s) | Energy (BTUs) |
| 13523.99 | 0.02 | 16.88 | 132.33 | 48157.60 |
| 13524.00 | 0.01 | 13.41 | 127.37 | 47643.24 |
| 13723.99 | 0.01 | 13.41 | 127.37 | 47643.24 |
| 13724.00 | 0.00 | 5.24 | 130.37 | 47699.14 |
| 13923.99 | 0.00 | 5.24 | 130.37 | 47699.14 |
| 13924.00 | 0.02 | 16.45 | 134.24 | 48251.35 |
| 14123.99 | 0.02 | 16.45 | 134.24 | 48251.35 |
| 14124.00 | 0.02 | 21.22 | 129.17 | 46980.21 |
| 14323.99 | 0.02 | 21.22 | 129.17 | 46980.21 |
| 14324.00 | 0.01 | 11.57 | 133.56 | 47728.45 |
| 14523.99 | 0.01 | 11.57 | 133.56 | 47728.45 |
| 14524.00 | 0.01 | 6.58 | 133.44 | 47914.23 |
| 14723.99 | 0.01 | 6.58 | 133.44 | 47914.23 |
| 14724.00 | 0.01 | 8.04 | 127.32 | 46612.04 |
| 14923.99 | 0.01 | 8.04 | 127.32 | 46612.04 |
| 14924.00 | 0.03 | 34.06 | 125.18 | 46638.62 |
| 15123.99 | 0.03 | 34.06 | 125.18 | 46638.62 |
| 15124.00 | 0.03 | 37.42 | 131.51 | 47737.44 |
| 15323.99 | 0.03 | 37.42 | 131.51 | 47737.44 |
| 15324.00 | 0.06 | 59.86 | 125.41 | 45532.79 |
| 15523.99 | 0.06 | 59.86 | 125.41 | 45532.79 |


UFSAR Revision 30.0

| | | |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|
|  <small>An AEP Company</small> | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revised: 27.0 Table:14.3.4-42 Page: 12 of 14 |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|

DECL Minimum Safeguards Post-Blowdown Mass & Energy

| Time (sec) | Break Path 1 | | Break Path 2 | |
|---------------|-----------------|------------------|-----------------|------------------|
| | Flow (lbm/s) | Energy (BTUs) | Flow (lbm/s) | Energy (BTUs) |
| 15524.00 | 0.04 | 45.91 | 135.23 | 48010.88 |
| 15723.99 | 0.04 | 45.91 | 135.23 | 48010.88 |
| 15724.00 | 0.00 | 3.96 | 123.62 | 46113.24 |
| 15923.99 | 0.00 | 3.96 | 123.62 | 46113.24 |
| 15924.00 | 0.02 | 16.75 | 128.65 | 47155.70 |
| 16123.99 | 0.02 | 16.75 | 128.65 | 47155.70 |
| 16124.00 | 0.01 | 6.96 | 119.16 | 44750.70 |
| 16323.99 | 0.01 | 6.96 | 119.16 | 44750.70 |
| 16324.00 | 0.03 | 33.10 | 123.17 | 45506.51 |
| 16523.99 | 0.03 | 33.10 | 123.17 | 45506.51 |
| 16524.00 | 0.04 | 39.51 | 124.63 | 45408.22 |
| 16723.99 | 0.04 | 39.51 | 124.63 | 45408.22 |
| 16724.00 | 0.03 | 36.72 | 123.75 | 45355.16 |
| 16923.99 | 0.03 | 36.72 | 123.75 | 45355.16 |
| 16924.00 | 0.06 | 64.79 | 122.55 | 44988.95 |
| 17123.99 | 0.06 | 64.79 | 122.55 | 44988.95 |
| 17124.00 | 0.20 | 215.56 | 121.50 | 44510.42 |
| 17323.99 | 0.20 | 215.56 | 121.50 | 44510.42 |
| 17324.00 | 0.17 | 181.30 | 122.31 | 44511.93 |
| 17523.99 | 0.17 | 181.30 | 122.31 | 44511.93 |
| 17524.00 | 0.03 | 36.66 | 124.99 | 44587.89 |


UFSAR Revision 30.0

| | | |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|
|  <small>An AEP Company</small> | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revised: 27.0 Table:14.3.4-42 Page: 13 of 14 |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|

DECL Minimum Safeguards Post-Blowdown Mass & Energy

| Time (sec) | Break Path 1 | | Break Path 2 | |
|---------------|-----------------|------------------|-----------------|------------------|
| | Flow (lbm/s) | Energy (BTUs) | Flow (lbm/s) | Energy (BTUs) |
| 17723.99 | 0.03 | 36.66 | 124.99 | 44587.89 |
| 17724.00 | 0.06 | 60.54 | 133.59 | 45884.13 |
| 17923.99 | 0.06 | 60.54 | 133.59 | 45884.13 |
| 17924.00 | 0.06 | 61.86 | 126.30 | 44629.85 |
| 18123.99 | 0.06 | 61.86 | 126.30 | 44629.85 |
| 18124.00 | 0.07 | 74.52 | 130.94 | 45415.03 |
| 18323.99 | 0.07 | 74.52 | 130.94 | 45415.03 |
| 18324.00 | 0.04 | 44.35 | 130.07 | 44954.87 |
| 18523.99 | 0.04 | 44.35 | 130.07 | 44954.87 |
| 18524.00 | 0.04 | 47.62 | 128.95 | 44951.28 |
| 18723.99 | 0.04 | 47.62 | 128.95 | 44951.28 |
| 18724.00 | 0.04 | 41.48 | 129.30 | 44821.25 |
| 18923.99 | 0.04 | 41.48 | 129.30 | 44821.25 |
| 18924.00 | 0.05 | 52.31 | 128.49 | 44598.03 |
| 19123.99 | 0.05 | 52.31 | 128.49 | 44598.03 |
| 19124.00 | 0.03 | 33.80 | 130.54 | 44857.31 |
| 19323.99 | 0.03 | 33.80 | 130.54 | 44857.31 |
| 19324.00 | 0.03 | 37.93 | 127.77 | 44246.79 |
| 19523.99 | 0.03 | 37.93 | 127.77 | 44246.79 |
| 19524.00 | 0.05 | 50.35 | 127.73 | 43920.88 |
| 19723.99 | 0.05 | 50.35 | 127.73 | 43920.88 |


UFSAR Revision 30.0

| | | |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|
|  <small>An AEP Company</small> | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revised: 27.0 Table:14.3.4-42 Page: 14 of 14 |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|----------------------------------------------------|

DECL Minimum Safeguards Post-Blowdown Mass & Energy

| Time (sec) | Break Path 1 | | Break Path 2 | |
|---------------|-----------------|------------------|-----------------|------------------|
| | Flow (lbm/s) | Energy (BTUs) | Flow (lbm/s) | Energy (BTUs) |
| 19724.00 | 0.03 | 31.33 | 130.55 | 44661.27 |
| 19924.00 | 0.03 | 31.33 | 130.55 | 44661.27 |
| 19924.1 | 0.06 | 11.81 | 130.84 | 44121.56 |
| 40000.0 | 88.46 | 16065.35 | 42.44 | 23087.88 |
| 60000.0 | 103.48 | 16013.02 | 27.42 | 20560.47 |
| 78272.0 | 108.62 | 14140.93 | 22.28 | 20897.30 |
| 78272.1 | 110.03 | 14323.78 | 20.87 | 19579.55 |
| 80000.0 | 110.34 | 14108.51 | 20.56 | 19650.11 |
| 89179.0 | 111.59 | 12891.10 | 19.31 | 20285.50 |
| 89179.1 | 111.94 | 12931.90 | 18.96 | 19914.41 |
| 100000.0 | 113.05 | 11415.34 | 17.85 | 20745.13 |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|
|  <p style="font-size: small; margin: 0;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revised: 27.0 Table:14.3.4-47 Page: 1 of 1 |
|-----------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|


Parameters Used in Steamline Break Mass / Energy Releases for Unit 1

| Parameter ¹ | Parameter Value |
|----------------------------------------------------|-----------------|
| NSSS Power, MWt | 3,327 |
| Core Power, MWt | 3,304 |
| RCS Flowrate (total), gpm (Thermal Design Flow) | 354,000 |
| Pressurizer Pressure psia | 2,250 |
| Pressurizer Water Volume, % span | 56.06 |
| RCS Vessel Average Temperature, °F | 575.4 |
| Steam Generator ² | |
| Steam Temperature, °F | 527.9 |
| Steam Pressure, psia | 870 |
| Feedwater Temperature, °F | 437.4 |
| Water Level, % narrow-range span | 43.8 |
| Zero-Load Temperature, °F | 547 |

¹ Nominal parameters are listed in this table.

² Steam generator performance data used in the analysis is conservatively high for steam temperature and pressure.


UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|
|  <p style="font-size: small; margin-top: 5px;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER</p> <p>D. C. COOK NUCLEAR PLANT</p> <p>UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revised: 28.0 Table: 14.3.5-1 Page: 1 of 5 |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|

Parameters Used for the Radiological Consequence Analysis of a Loss of Coolant Accident

| Parameter | Value |
|--------------------------------------------|-------------------------------------|
| Core Power Level | 3480 MWt |
| Containment Purge Release | |
| Containment Volume | 1,066,352 ft ³ (minimum) |
| Iodine Chemical Form | |
| Elemental | 4.85% |
| Organic | 0.15% |
| Particulate | 95% |
| Containment Purge Flow Rate | 36,300 cfm |
| Containment Purge Isolation time | 15 seconds |
| Containment Purge Filtration | 0% |
| Removal by Wall Deposition | None |
| Removal by Sprays | None |
| Release Location | |
| Offsite | Unit 1 Vent |
| Onsite | Unit 2 Vent |
| Containment Leakage Release | |
| Containment Compartment Volumes(max) | |
| Upper Containment (Sprayed) | 621,968 ft ³ |
| Lower Containment (Sprayed) | 103,770 ft ³ |
| Fan Rooms (Sprayed) | 48,913 ft ³ |
| Upper Containment (Unsprayed) | 122,600 ft ³ |
| Ice Condenser (Unsprayed) | 105,577 ft ³ |
| Lower Containment (Unsprayed) | 66,188 ft ³ |
| Dead-End (Unsprayed) | 18,663 ft ³ |
| Containment Ventilation Flow Rates | |
| Fan Rooms to Lower Containment (Unsprayed) | 14,580.5 cfm |
| Fan Rooms to Lower Containment (Sprayed) | 22,859.5 cfm |


UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|
|  <p style="font-size: small; margin: 0;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revised: 28.0 Table: 14.3.5-1 Page: 2 of 5 |
|-----------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|

Parameters Used for the Radiological Consequence Analysis of a Loss of Coolant Accident

| Parameter | Value |
|------------------------------------------------|-----------------------------------------|
| Lower Containment (Unsprayed) to Dead-End | 90 cfm |
| Dead-End to Fan Rooms | 90 cfm |
| Lower Containment (Unsprayed) to Fan Rooms | 1,350 cfm |
| Lower Containment (Unsprayed) to Ice Condenser | 13,140.5 cfm |
| Lower Containment (Sprayed) to Ice Condenser | 22,859.5 cfm |
| Ice Condenser to Upper Containment (Sprayed) | 30,072.3 cfm |
| Ice Condenser to Upper Containment (Unsprayed) | 5,927.7 cfm |
| Upper Containment (Sprayed) to Fan Rooms | 30,072.3 cfm |
| Upper Containment (Unsprayed) to Fan Rooms | 5,927.7 cfm |
| Lower Containment – Sprayed to/from Unsprayed | 2,206.3 cfm (spray induced circulation) |
| Upper Containment – Sprayed to/from Unsprayed | 4,086.7 cfm (spray induced circulation) |
| Containment Spray Start Time | 300 seconds |
| Time that Containment Spray is Secured | 24 hours |
| Containment Spray Flow Rate | |
| Upper Containment | 1,466 gpm |
| Lower Containment | 660 gpm |
| Fan Rooms | 201 gpm |
| Elemental Iodine Removal Coefficients | |
| Upper Containment | 20 hr ⁻¹ |
| Lower Containment | 20 hr ⁻¹ |
| Fan Rooms | 20 hr ⁻¹ |
| Time that Total Elemental DF Reaches 200 | 2 hours |
| Aerosol Spray Removal Coefficient | |
| Upper Containment | 5.06 hr ⁻¹ |
| Lower Containment | 6.65 hr ⁻¹ |
| Fan Rooms | 3.03 hr ⁻¹ |
| Time that Total Aerosol DF Reaches 50 | 2.32 hours |


UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revised: 28.0 Table: 14.3.5-1 Page: 3 of 5 |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|

Parameters Used for the Radiological Consequence Analysis of a Loss of Coolant Accident

| Parameter | Value |
|------------------------------------------------------|----------------------------|
| Natural Deposition | |
| Elemental Iodine | None |
| Organic Iodine | None |
| Particulates | 0.1 hr ⁻¹ |
| Containment Leakage Rate | |
| 0-24 hours | 0.18 %/day |
| 24 hours-30 days | 0.09 |
| Containment Leakage Filtration | 0% |
| Iodine Chemical Form | |
| Elemental | 4.85% |
| Organic | 0.15% |
| Particulate | 95% |
| Iodine/Particulate Removal by Containment Sprays | None |
| Release Location | |
| Offsite | Unit 1 Containment Surface |
| Onsite | Unit 2 Containment Surface |
| ESF Leakage Release to the Auxiliary Building | |
| Containment Sump Volume | 50,955 ft ³ |
| ECCS Recirculation Start Time | 1,388.4 seconds |
| Effective ESF Leakage Flow Rate | 0.2 gpm |
| ESF Leakage Flashing Fraction | 10% |
| Auxiliary Building Ventilation Filtration | 0% |
| Iodine Chemical Form | |
| Elemental | 97% |
| Organic | 3% |
| Particulate | 0% |


UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|
|  <p style="font-size: small; margin: 0;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revised: 28.0 Table: 14.3.5-1 Page: 4 of 5 |
|-----------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|

Parameters Used for the Radiological Consequence Analysis of a Loss of Coolant Accident

| Parameter | Value |
|------------------------------------------------|-----------------------------|
| Release Location | |
| Offsite | Unit 1 Vent |
| Onsite | Unit 2 Vent |
| ESF Leakage Release to the RWST | |
| Containment Sump Volume | 50,955 ft ³ |
| ECCS Recirculation Start Time | 1,388.4 seconds |
| Effective ESF Leakage Flow Rate | 1.0 gpm |
| Total Iodine Mass Released into the Sump | 12,035.5 grams |
| Sump pH | 7.0 |
| Initial RWST pH | 4.479 |
| Initial RWST Liquid Volume | 53,637.5 gallons |
| Elemental Iodine Release Fraction | 0.0-0.1914 |
| Organic Iodine Release Fraction | 0.0015 |
| RWST Liquid/Vapor Iodine Partition Coefficient | |
| Elemental | 31.92 - 45.41 |
| Organic | 1.0 |
| Release Location | |
| Offsite | Unit 1 RWST |
| Onsite | Unit 2 RWST |
| Offsite Breathing Rates | |
| 0-8 hours | 3.5E-04 m ³ /sec |
| 8-24 hours | 1.8E-04 m ³ /sec |
| 24-720 hours | 2.3E-04 m ³ /sec |
| Control Room Parameters | |
| Volume | 50,616 ft ³ |
| Normal Ventilation Makeup Flow Rate | 880 cfm |
| Emergency Ventilation Makeup Flow Rate | 880 cfm |

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revised: 28.0 Table: 14.3.5-1 Page: 5 of 5</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|

Parameters Used for the Radiological Consequence Analysis of a Loss of Coolant Accident

| Parameter | Value |
|------------------------------------------------------|-------------------------------|
| Emergency Ventilation Recirculation Flow Rate | 4,520 cfm |
| Emergency Ventilation Filter Efficiency ¹ | |
| Elemental Iodine | 94.05% |
| Organic Iodine | 94.05% |
| Particulates | 98.01% |
| Delay to Switch to Emergency Mode | 70 minutes (Safety Injection) |
| Unfiltered Inleakage | 40 cfm |
| Occupancy Factors | |
| 0-24 hours | 1.0 |
| 24-96 hours | 0.6 |
| 96-720 hours | 0.4 |
| Breathing Rate | 3.5E-04 m ³ /sec |

¹ Includes 1% filter bypass leakage

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|------------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 16.4 Table: 14.3.9-1 Page: 1 of 1</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|------------------------------------------------------------|

D.C. COOK MAAP 14-NODE CONTAINMENT NODALIZATION

| Node | Region |
|------|------------------------------------------|
| 1 | Cavity |
| 2 | Lower Compartment |
| 3 | Pipe Annulus Region |
| 4 | Ice Condenser |
| 5 | Ice Condenser Upper Plenum |
| 6 | Cylindrical Section of Upper Compartment |
| 7 | Lower Dome of Upper Compartment |
| 8 | Upper Dome of Upper Compartment |
| 9 | Pressurizer Enclosure |
| 10 | Steam Generator 1/4 Enclosure |
| 11 | Steam Generator 2/3 Enclosure |
| 12 | East Fan Room |
| 13 | West Fan Room |
| 14 | Instrument Room |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 16.4 Table: 14.3.9-2 Page: 1 of 3</p> |
|-----------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|------------------------------------------------------------|

D.C. COOK MAAP 14-NODE CONTAINMENT MODEL FLOW JUNCTIONS

| Junction | Type | Description |
|----------|-------------------|----------------------------------------------------------------------|
| 1 | AO ¹ | Cavity 6 Lower Compartment (Bypass Tunnel) |
| 2 | AO | Cavity 6 Lower Compartment (Annular Gap) |
| 3 | AO | Lower Compartment 6 Upper Cylindrical Sec. (Refueling Cavity Drains) |
| 4 | UD ² | Lower Compartment 6 Ice Condenser (Door Model) |
| 5 | AO | Lower Compartment 6 Pipe Annulus (over Weir Wall) |
| 6 | UD | Ice Condenser 6 Ice Upper Plenum |
| 7 | AO | Lower Compartment 6 Upper Cylindrical Section (Bypass) |
| 8 | Fan | Upper Cylindrical Section 6 West Fan Room (Cont. Air Recirc.) |
| 9 | OOAO ³ | Ice Upper Plenum 6 Upper Compartment Lower Dome |
| 10 | AO | Normal Cont. Leakage (Pipe Annuls 6 Env.) |
| 11 | OOAO | Cont. Failure (Pipe Annulus 6 Env.) |
| 12 | AO | Lower Compartment 6 PZR Enclosure |
| 13 | AO | Lower Compartment 6 SG 1/4 Enclosure |
| 14 | AO | Upper Compartment Lower Dome 6 Upper Dome |
| 15 | AO | Upper Cylinder Section 6 Upper Compartment Lower Dome |
| 16 | Fan | PZR Enclosure 6 East Fan Room (H ₂ Skimmer) |

¹ AO Always Open - means junction is always open and flow may occur in either direction as well as counter-current natural circulation flow when applicable.

² UD Uni-Directional - means that the junction performs like a check valve and only permits flow in one direction, as well as counter-current flow if the junction is open due to uni-directional flow.

³ OOA Once Opened Always Open - means that once a sufficient pressure differential is developed to open the junction, it remains open thereafter regardless of the pressure differential.

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|------------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 16.4</p> <p>Table: 14.3.9-2</p> <p>Page: 2 of 3</p> |
|-----------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|------------------------------------------------------------------|

D.C. COOK MAAP 14-NODE CONTAINMENT MODEL FLOW JUNCTIONS

| Junction | Type | Description |
|----------|------|------------------------------------------------------------------|
| 17 | Fan | SG 1&4 Enclosure 6 East Fan Room (H ₂ Skimmer) |
| 18 | Fan | Upper Dome 6 East Fan Room (H ₂ Skimmer) |
| 19 | UD | Ice Condenser 6 Lower Compartment (Flappers) |
| 20 | AO | Ice Condenser 6 Lower Compartment. (Drain Line) |
| 21 | AO | Lower Compartment 6 SG 2/3 Enclosure |
| 22 | Fan | SG 2/3 Enclosure 6 East Fan Room (H ₂ Skimmer) |
| 23 | Fan | Instrument Room 6 East Fan Room (H ₂ Skimmer) |
| 24 | Fan | West Fan Room 6 East Fan Room (H ₂ Skimmer) |
| 25 | Fan | Upper Cylinder Section 6 East Fan Room (Containment Air Recirc.) |
| 26 | Fan | PZR 6 West Fan Room (H ₂ Skimmer) |
| 27 | Fan | SG 1/4 Enclosure 6 West Fan Room (H ₂ Skimmer) |
| 28 | Fan | SG 2/3 Enclosure 6 West Fan Room (H ₂ Skimmer) |
| 29 | Fan | Instrument Room 6 West Fan Room (H ₂ Skimmer) |
| 30 | Fan | Upper Dome 6 West Fan Room (H ₂ Skimmer) |
| 31 | Fan | East Fan Room 6 West Fan Room (H ₂ Skimmer) |
| 32 | AO | East Fan Room 6 Pipe Annulus (Floor Holes) |
| 33 | AO | West Fan Room 6 Pipe Annulus (Floor Holes) |
| 34 | AO | Instrument Room 6 Pipe Annulus (Floor Holes) |
| 35 | AO | East Fan Room 6 Lower Compartment (Fan Windows) |
| 36 | AO | West Fan Room 6 Lower Compartment (Fan Windows) |
| 37 | AO | East Fan Room 6 Instrument Room (Wall Openings) |
| 38 | AO | West Fan Room 6 Instrument Room (Wall Openings) |
| 39 | AO | Instrument Room 6 Lower Compartment |
| 40 | AO | Ice Upper Plenum 6 Upper Cylindrical Section (Bypass Area) |
| 41 | AO | Ice Condenser 6 Ice Upper Plenum (Bypass Area) |

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|------------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 16.4 Table: 14.3.9-2 Page: 3 of 3</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|------------------------------------------------------------|

D.C. COOK MAAP 14-NODE CONTAINMENT MODEL FLOW JUNCTIONS

| Junction | Type | Description |
|----------|------|-------------------------------------------------------|
| 42 | AO | Lower Compartment 6 Pipe Annulus (Holes in Weir Wall) |
| 43 | AO | Lower Compartment 6 Rx Cavity (NIS Holes) |
| 44 | AO | Lower Compartment 6 Rx Cavity (NIS Holes) |

UFSAR Revision 30.0




INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT

Revision: 22
Table: 14.3.9-3
Page: 1 of 1

BOUNDING INSULATION QUANTITIES BY POTENTIAL BREAK LOCATION

| | Transco RMI, ft ² | DP RMI, ft ² | Cal-Sil, ft ³ | Fiberglass, ft ³ | Marinite, ft ³ | Min-K, ft ³ |
|--------------------------------------------------------|---------------------------------|----------------------------|-----------------------------|--------------------------------|------------------------------|---------------------------|
| Lower Containment – Inside Crane Wall – Loop 1 | -- | 39,530 | 348 | -- | 2.09 | -- |
| Lower Containment – Inside Crane Wall – Loop 2 | -- | 42,542 | 326 | -- | 0.61 | 0.18 |
| Lower Containment – Inside Crane Wall – Loop 3 | -- | 43,828 | 352 | -- | 7.05 | 0.08 |
| Lower Containment – Inside Crane Wall – Loop 4 | -- | 39,443 | 401 | -- | 2.56 | -- |
| Lower Containment – Inside Crane Wall – PZR Vault area | -- | 19,942 | 121 | -- | -- | -- |
| Reactor Cavity | 19,802 | -- | -- | 5 | -- | -- |
| Total | 19,802 | 185,285 | 1,548 | 5 | 12.31 | 0.26 |


UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------|---------------------------------------------------------|
|  An AEP Company | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revision: 22 Table: 14.3.9-4 Page: 1 of 1 |
|------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------|---------------------------------------------------------|

DEGB COATINGS DEBRIS GENERATED WITHIN ZOI

| Coating Type | Area, ft ² | Thickness, mils | Volume, ft ³ | Density, lbs/ft ³ | Weight, lbs |
|---------------------------------------------------|-----------------------|-----------------|-------------------------|------------------------------|--------------|
| Qualified Coatings – Concrete Surfaces (ZOI – 5D) | 894 | 12 | 0.894 | 111.6 | 99.8 |
| Qualified Coatings – Steel Surfaces (ZOI – 5D) | 1,007 | 12 | 1.007 | 111.6 | 112.7 |
| Total Qualified (ZOI – 5D) | 1,901 | - | 1.90 | - | 212.5 |
| Unqualified Alkyd Coatings (ZOI – 10D) | 57.7 | 4 | 0.019 | 98 | 1.9 |
| Unqualified Epoxy Coatings (ZOI – 10D) | 112.0 | 4 | 0.037 | 94 | 3.5 |
| Total Unqualified (ZOI – 10D) | 169.7 | - | 0.056 | - | 5.4 |


UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------|-------------------------------------------------|
|  An AEP Company | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revision: 22 Table: 14.3.9-5 Page: 1 of 1 |
|-----------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------|-------------------------------------------------|

DGBS COATINGS DEBRIS GENERATED WITHIN ZOI

| Coating Type | Area, ft ² | Thickness, mils | Volume, ft ³ | Density, lbs/ft ³ | Weight, lbs |
|---------------------------------------------------|-----------------------|-----------------|-------------------------|------------------------------|-------------|
| Qualified Coatings – Concrete Surfaces (ZOI – 5D) | 0 | 12 | 0.0 | 111.6 | 0.0 |
| Qualified Coatings – Steel Surfaces (ZOI – 5D) | 20 | 12 | 0.02 | 111.6 | 2.2 |
| Total Qualified (ZOI – 5D) | 20 | - | 0.02 | - | 2.2 |
| Unqualified Alkyd Coatings (ZOI – 10D) | 16.9 | 4 | 0.006 | 98 | 0.6 |
| Unqualified Epoxy Coatings (ZOI – 10D) | 56.0 | 4 | 0.019 | 94 | 1.8 |
| Total Unqualified (ZOI – 10D) | 72.9 | - | 0.025 | - | 2.4 |


UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------|---------------------------------------------------------|
|  An AEP Company | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revision: 22 Table: 14.3.9-6 Page: 1 of 1 |
|-----------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------|---------------------------------------------------------|

UNQUALIFIED COATINGS DEBRIS GENERATED OUTSIDE ZOI

| Coating Type | Area, ft ² | Thickness, mils | Volume, ft ³ | Density, lbs/ft ³ | Weight, lbs |
|--------------------------------------------------------------------------|--------------------------|--------------------|----------------------------|---------------------------------|----------------|
| Unqualified OEM Alkyd Handwheels and Limitorque Coatings outside 10D ZOI | 1,429.5 | 4 | 0.48 | 98 | 47.0 |
| Remaining Unqualified OEM Alkyd Coatings outside 10D ZOI | 841.7 | 4 | 0.28 | 98 | 27.4 |
| Remaining Unqualified OEM Epoxy Coatings outside 10D ZOI | 538.0 | 4 | 0.18 | 94 | 16.9 |
| Unqualified non-OEM Alkyd Coatings outside 10D ZOI | 105.8 | 4 | 0.035 | 98 | 3.4 |
| Unqualified non-OEM Epoxy Coatings outside 10D ZOI | 991.2 | 4 | 0.33 | 94 | 31.0 |
| Cold Galvanizing Compound | 9,324.98 | 4 | 3.11 | 250 | 777.5 |
| Total Unqualified | 13,231.18 | - | 4.415 | - | 903.2 |

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------|----------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 22 Table: 14.3.9-7 Page: 1 of 1</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------|----------------------------------------------------------|

LATENT DEBRIS LOCATION UNIT 1 AND UNIT 2 BOUNDING VALUES

| Debris Type | Upper Containment | Loop Compartment | Pipe Annulus | Ice Condenser | Total |
|----------------------------------------------------------------------------|-------------------|------------------|--------------|---------------|---------------|
| Latent Fiber, lbs | 5.4 | 15.6 | 8.4 | 0.6 | 30 |
| Latent Dirt/Dust, lbs | 30.6 | 88.4 | 47.6 | 3.4 | 170 |
| Electromark Labels - break in Loop 1 or Loop 4, ft ² | -- | 21.8 | 30.48 | -- | 52.28 |
| Electromark Labels - break in Loop 2 or Loop 3, ft ² | -- | 20.14 | 30.48 | -- | 50.62 |
| Unqualified Labels, ft ² | 8.77 | 13.62 | 3.55 | -- | 25.94 |
| Flexible Conduit PVC Jacketing, ft ² | -- | 1.57 | -- | -- | 1.57 |
| Fire Barrier Tape, ft ² | -- | 708.83 | -- | -- | 708.83 |
| Ice Storage Bag Fibers, ft ² | -- | -- | -- | 5.0 | 5.0 |
| Ice Storage Bag Liner Shards, ft ² | -- | -- | -- | 0.87 | 0.87 |
| Pieces of Rubber from platform where ice bags were opened, ft ² | -- | -- | -- | 0.22 | 0.22 |

UFSAR Revision 30.0

| | | |
|----------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|----------------------------------------------------------------|
|  <p style="font-size: small; margin-top: 5px;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 22</p> <p>Table: 14.3.9-8</p> <p>Page: 1 of 1</p> |
|----------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|----------------------------------------------------------------|

CONTAINMENT MATERIALS

| Submerged Aluminum Metal (Below El. 614 ft) | Mass, lb | Area, ft ² |
|-------------------------------------------------------------------------|---------------|-----------------------|
| Electrical Equipment (Limit Switches) | 1.5 | 0.44 |
| Fans and Motors | 2.31 | 3.67 |
| Radiation Detectors | 0.72 | 0.36 |
| Miscellaneous Components | 17.72 | 6.46 |
| NSSS Components (NRI-32,-36,-41A thru -44B) – Located in Reactor Cavity | 244.00 | 83.00 |
| TOTAL – Including Components in Reactor Cavity | 266.25 | 93.93 |
| TOTAL – Excluding NSSS Components in Reactor Cavity | 22.25 | 10.93 |

| Non-submerged Aluminum Metal (Above El. 614 ft) | Mass, lb | Area, ft ² |
|-------------------------------------------------|-----------------|-----------------------|
| Electrical Equipment | 0.80 | 0.81 |
| Radiation Detectors | 0.03 | 0.06 |
| Valve Components | 8.00 | 2.47 |
| Crane Components | 1.05 | 0.72 |
| Miscellaneous Components | 22.97 | 9.33 |
| NSSS Components (RCP Cooling Coils) | 1,152.00 | 8,000.00 |
| TOTAL | 1,184.85 | 8,013.39 |

| Uncoated Concrete (Exposed Concrete) | Area, ft ² |
|--------------------------------------|-----------------------|
| Submerged (Below El. 614 ft) | 6,412.78 |
| Non-submerged (Above El. 614 ft) | 1,077.10 |

| Zinc Coated Steel (Below El. 614 ft) | Area, ft ² |
|-------------------------------------------|-----------------------|
| Galvanized Steel (Below El. 614 ft) | 70,831.64 |
| Cold Zinc Coated Steel (Below El. 614 ft) | 330.98 |
| Total submerged zinc coated steel | 71,162.62 |

| Zinc Coated Steel (Above 614 ft) | Area, ft ² |
|----------------------------------------------|-----------------------|
| Galvanized Steel (Above El. 614 ft) | 495,734.96 |
| Cold Zinc Coated Steel (Above El. 614 ft) | 8994.00 |
| Total non-submerged zinc coated steel | 504,728.96 |

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|----------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 22 Table: 14.3.9-9 Page: 1 of 1</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|----------------------------------------------------------|

MAXIMUM ECCS/CTS FLOW RATES

| ECCS/CTS Phase | Maximum ECCS/CTS Flow |
|---------------------------------|-----------------------|
| Injection Phase - RWST Drawdown | 15,500 gpm |
| Recirculation Phase | 14,400 gpm |

UFSAR Revision 30.0



INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT

Revision: 22
Table: 14.3.9-10
Page: 1 of 2

LOOP 4 RCS CROSSOVER LEG BREAK (DEGB) DEBRIS LOADS AT THE MAIN STRAINER AND REMOTE STRAINER

| Debris Type | Debris Load at Main Strainer at End of Pool Fill Phase | Overall Debris Load at Main Strainer | Overall Debris Load at Remote Strainer |
|---------------------------------------------------|-----------------------------------------------------------|-----------------------------------------|-------------------------------------------|
| RMI Small Pieces, ft ² | 5267.52 | 7608.64 | 0 |
| RMI Large Pieces, ft ² | 975.5 | 1560.8 | 0 |
| Cal-Sil Fines, lbs | 89.568 | 123.156 | 133.904 |
| Erosion of Cal-Sil Small Pieces to fines, lbs | 0 | 23.2 | 18.56 |
| Cal-Sil Small Pieces, lbs | 11.6 | 23.2 | 0 |
| Marinite I fines, lbs | 0.0448 | 0.0616 | 0.0728 |
| Erosion of Marinite I Small Pieces to fines, lbs | 0 | 0.005 | 0.004 |
| Marinite I Small Pieces, lbs | 0.0025 | 0.005 | 0 |
| Erosion of Marinite I Large Pieces to fines, lbs | 0 | 0.0322 | 0.0138 |
| Marinite I Large Pieces, lbs | 0.0092 | 0.0161 | 0 |
| Marinite 36 fines, lbs | 0.3456 | 0.4752 | 0.5616 |
| Erosion of Marinite 36 Small Pieces to fines, lbs | 0 | 0.036 | 0.0288 |
| Marinite 36 Small Pieces, lbs | 0.018 | 0.036 | 0 |
| Erosion of Marinite 36 Large Pieces to fines, lbs | 0 | 0.3024 | 0.1296 |
| Marinite 36 Large Pieces, lbs | 0.0864 | 0.1512 | 0 |
| Min-K, lbs | 0.512 | 0.704 | 0.832 |
| Epoxy Paint (inside ZOI), lbs | 69.12 | 95.04 | 112.32 |
| Alkyd Paint (inside ZOI), lbs | 0.608 | 0.836 | 0.988 |
| Unqualified OEM Epoxy (outside ZOI), lbs | 0 | 6.76 | 12.168 |

UFSAR Revision 30.0



INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT

Revision: 22
Table: 14.3.9-10
Page: 2 of 2

LOOP 4 RCS CROSSOVER LEG BREAK (DEGB) DEBRIS LOADS AT THE MAIN STRAINER AND REMOTE STRAINER

| Debris Type | Debris Load at Main Strainer at End of Pool Fill Phase | Overall Debris Load at Main Strainer | Overall Debris Load at Remote Strainer |
|--------------------------------------------------|-----------------------------------------------------------|-----------------------------------------|-------------------------------------------|
| Unqualified OEM Alkyd (outside ZOI), lbs | 0 | 10.416 | 66.96 |
| Unqualified Non-OEM Epoxy (outside ZOI), lbs | 0 | 16.12 | 0 |
| Unqualified Non-OEM Alkyd (outside ZOI), lbs | 0 | 1.972 | 2.006 |
| Unqualified Cold Galvanizing Compound, lbs | 0 | 723.075 | 272.125 |
| Dirt/Dust, lbs | 40.8 | 88.4 | 95.2 |
| Latent Fiber, ft ³ | 3.00 | 6.5 | 7 |
| Fire Proof Tape Fines, ft ² | 8.032 | 11.044 | 13.052 |
| Fire Proof Tape Small Pieces, ft ² | 1.296 | 1.872 | 0 |
| Fire Proof Tape Large Pieces, ft ² | 4.869 | 7.033 | 0 |
| Ice Storage Bag Fibers, ft ³ | 0.0117 | 0.01638 | 0.01092 |
| Ice Storage Bag Liner Shards, ft ³ | 0.000099 | 0.0001386 | 0.0000924 |
| Pieces of Work Platform Rubber, ft ³ | 0.0009 | 0.00126 | 0.00084 |
| Electromark Label (inside ZOI), ft ² | 0.063 | 0.091 | 0.329 |
| Electromark Label (outside ZOI), ft ² | 0 | 1.188 | 27.324 |
| Unqualified Labels – Paper, ft ² | 0 | 0.2408 | 0.112 |
| Unqualified Labels – Other, ft ² | 0 | 22.0676 | 10.264 |
| Flex Conduit PVC Jacketing, ft ² | 0 | 1.57 | 0.471 |

UFSAR Revision 30.0




INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT

Revision: 22
Table: 14.3.9-11
Page: 1 of 2

LOOP 4 ALTERNATE RCS LOOP PIPING BREAK (DGBS) DEBRIS LOADS AT THE MAIN STRAINER AND REMOTE STRAINER

| Debris Type | Debris Load at Main Strainer at End of Pool Fill Phase | Overall Debris Load at Main Strainer | Overall Debris Load at Remote Strainer |
|---------------------------------------------------|-----------------------------------------------------------|-----------------------------------------|-------------------------------------------|
| RMI Small Pieces, ft ² | 2791.89 | 4032.73 | 0 |
| RMI Large Pieces, ft ² | 517.05 | 827.28 | 0 |
| Cal-Sil Fines, lbs | 23.2 | 31.9 | 34.684 |
| Erosion of Cal-Sil Small Pieces to fines, lbs | 0 | 4.64 | 3.712 |
| Cal-Sil Small Pieces, lbs | 2.32 | 4.64 | 0 |
| Marinite I fines, lbs | 0 | 0 | 0 |
| Erosion of Marinite I Small Pieces to fines, lbs | 0 | 0 | 0 |
| Marinite I Small Pieces, lbs | 0 | 0 | 0 |
| Erosion of Marinite I Large Pieces to fines, lbs | 0 | 0 | 0 |
| Marinite I Large Pieces, lbs | 0 | 0 | 0 |
| Marinite 36 fines, lbs | 0.2528 | 0.3476 | 0.4108 |
| Erosion of Marinite 36 Small Pieces to fines, lbs | 0 | 0.03 | 0.024 |
| Marinite 36 Small Pieces, lbs | 0.015 | 0.03 | 0 |
| Erosion of Marinite 36 Large Pieces to fines, lbs | 0 | 0.2268 | 0.0972 |
| Marinite 36 Large Pieces, lbs | 0.0648 | 0.1134 | 0 |
| Min-K, lbs | 0 | 0 | 0 |
| Epoxy Paint (inside ZOI), lbs | 1.824 | 2.508 | 2.964 |
| Alkyd Paint (inside ZOI), lbs | 0.608 | 0.836 | 0.988 |

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------|-----------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 22 Table: 14.3.9-11 Page: 2 of 2</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------|-----------------------------------------------------------|

LOOP 4 ALTERNATE RCS LOOP PIPING BREAK (DGBS) DEBRIS LOADS AT THE MAIN STRAINER AND REMOTE STRAINER

| Debris Type | Debris Load at Main Strainer at End of Pool Fill Phase | Overall Debris Load at Main Strainer | Overall Debris Load at Remote Strainer |
|--------------------------------------------------|-----------------------------------------------------------|-----------------------------------------|-------------------------------------------|
| Unqualified OEM Epoxy (outside ZOI), lbs | 0 | 6.76 | 12.168 |
| Unqualified OEM Alkyd (outside ZOI), lbs | 0 | 10.416 | 66.96 |
| Unqualified Non-OEM Epoxy (outside ZOI), lbs | 0 | 16.12 | 0 |
| Unqualified Non-OEM Alkyd (outside ZOI), lbs | 0 | 1.972 | 2.006 |
| Unqualified Cold Galvanizing Compound, lbs | 0 | 723.075 | 272.125 |
| Dirt/Dust, lbs | 40.8 | 88.4 | 95.2 |
| Latent Fiber, ft ³ | 3 | 6.5 | 7 |
| Fire Proof Tape Fines, ft ² | 8.032 | 11.044 | 13.052 |
| Fire Proof Tape Small Pieces, ft ² | 1.296 | 1.872 | 0 |
| Fire Proof Tape Large Pieces, ft ² | 4.869 | 7.033 | 0 |
| Ice Storage Bag Fibers, ft ³ | 0.0117 | 0.01638 | 0.01092 |
| Ice Storage Bag Liner Shards, ft ³ | 0.000099 | 0.0001386 | 0.0000924 |
| Pieces of Work Platform Rubber, ft ³ | 0.0009 | 0.00126 | 0.00084 |
| Electromark Label (inside ZOI), ft ² | 0.063 | 0.091 | 0.329 |
| Electromark Label (outside ZOI), ft ² | 0 | 1.188 | 27.324 |
| Unqualified Labels – Paper, ft ² | 0 | 0.2408 | 0.112 |
| Unqualified Labels – Other, ft ² | 0 | 22.0676 | 10.264 |
| Flex Conduit PVC Jacketing, ft ² | 0 | 1.57 | 0.471 |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 22</p> <p>Table: 14.3.9-12</p> <p>Page: 1 of 1</p> |
|-----------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------|

QUANTITY OF DEBRIS AT MAIN STRAINER FOR LARGE SCALE TESTING FOR DEGB AND DGBS

| Debris Type | Units | DEGB Test Quantity | DGBS Test Quantity |
|------------------------------------------------|-----------------|--------------------|--------------------|
| RMI | ft ² | 221.09 | 118.98 |
| Cal-Sil Fines | lbs | 3.50 | 0.87 |
| Marinite I Fines | lbs | 0.002 | 0 |
| Marinite 36 Fines | lbs | 0.02 | 0.01 |
| Min-K | lbs | 0.02 | 0 |
| Epoxy Paint (inside ZOI) | lbs | 2.25 | 0.04 |
| Alkyd Paint (inside ZOI) | lbs | 0.01 | 0.00 |
| Unqualified OEM Epoxy (outside ZOI) | lbs | 0.17 | 0.17 |
| Unqualified OEM Alkyd (outside ZOI) | lbs | 0.26 | 0.26 |
| Unqualified Non-OEM Epoxy (outside ZOI) | lbs | 0.20 | 0.20 |
| Unqualified Non-OEM Alkyd (outside ZOI) | lbs | 0.05 | 0.05 |
| Unqualified Cold Galvanizing Compound | lbs | 17.64 | 18 |
| Dirt/Dust | lbs | 2.57 | 2.57 |
| Latent Fiber | ft ³ | 0.19 | 0.19 |
| Fire Proof Tape Fines | ft ³ | 0.001 | 0.001 |
| Ice Storage Bag Fibers | ft ³ | 0.0004 | 0.0004 |
| Ice Storage Bag Liner Shards | ft ³ | 0.0000 | 0.0000 |
| Pieces of Work Platform Rubber | ft ³ | 0.0000 | 0.0000 |
| Fire Proof Tape Pieces ¹ | ft ³ | 0.002 | 0.002 |
| Electromark Label (inside ZOI) ⁽¹⁾ | ft ² | 0.003 | 0.003 |
| Electromark Label (outside ZOI) ⁽¹⁾ | ft ² | 0.07 | 0.07 |
| Unqualified Labels ⁽¹⁾ | ft ² | 0.61 | 0.61 |
| Flex Conduit PVC Jacketing ⁽¹⁾ | ft ² | 0.04 | 0.04 |

¹ These debris materials were included in the sacrificial strainer area.

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 22</p> <p>Table: 14.3.9-13</p> <p>Page: 1 of 1</p> |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------|

QUANTITY OF DEBRIS AT REMOTE STRAINER FOR LARGE SCALE TESTING FOR DEGB AND DGBS

| Debris Type | Units | DEGB Test Quantity | DGBS Test Quantity |
|------------------------------------------------|-----------------|--------------------|--------------------|
| RMI | ft ² | 0 | 0 |
| Cal-Sil Fines | lbs | 4.003 | 1.010 |
| Marinite I Fines | lbs | 0.002 | 0 |
| Marinite 36 Fines | lbs | 0.018 | 0.013 |
| Min-K | lbs | 0.020 | 0 |
| Epoxy Paint (inside ZOI) | lbs | 2.718 | 0.051 |
| Alkyd Paint (inside ZOI) | lbs | 0.008 | 0.008 |
| Unqualified OEM Epoxy (outside ZOI) | lbs | 0.309 | 0.309 |
| Unqualified OEM Alkyd (outside ZOI) | lbs | 1.655 | 1.655 |
| Unqualified Non-OEM Epoxy (outside ZOI) | lbs | 0 | 0 |
| Unqualified Non-OEM Alkyd (outside ZOI) | lbs | 0.052 | 0.052 |
| Unqualified Cold Galvanizing Compound | lbs | 6.637 | 6.637 |
| Dirt/Dust | lbs | 1.783 | 1.783 |
| Latent Fiber | ft ³ | 0.131 | 0.131 |
| Fire Proof Tape Fines | ft ³ | 0.001 | 0.001 |
| Ice Storage Bag Fibers | ft ³ | 0.0003 | 0.0003 |
| Ice Storage Bag Liner Shards | ft ³ | 0.0000 | 0.0000 |
| Pieces of Work Platform Rubber | ft ³ | 0.0000 | 0.0000 |
| Fire Proof Tape Pieces ¹ | ft ³ | 0.010 | 0.010 |
| Electromark Label (inside ZOI) ⁽¹⁾ | ft ² | 0.010 | 0.010 |
| Electromark Label (outside ZOI) ⁽¹⁾ | ft ² | 0.453 | 0.453 |
| Unqualified Labels ⁽¹⁾ | ft ² | 0.209 | 0.209 |
| Flex Conduit PVC Jacketing ⁽¹⁾ | ft ² | 0.011 | 0.011 |

¹ These debris materials were included in the sacrificial strainer area.

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revision: 22 Table: 14.3.9-14 Page: 1 of 1 |
|------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------|

DEBRIS QUANTITIES FOR MFTL HEAD LOSS TESTS

| Debris Type | Units | Mass Test 1 (DEGB) | Mass Test 2 (DGBS) |
|---------------------------|-------|-----------------------|-----------------------|
| Fibrous Debris | | | |
| Nukon | kg | 0.447 | 0.447 |
| Particulate Debris | | | |
| RMI | kg | 17.590 | 9.466 |
| Cal-Sil | kg | 3.402 | 0.855 |
| Marinite I | kg | 0.002 | 0.000 |
| Wollastonite | kg | 0.006 | 0.004 |
| Min-K | kg | 0.016 | 0.000 |
| Unqualified Non-OEM Epoxy | kg | 0.196 | 0.083 |
| Unqualified Non-OEM Alkyd | kg | 0.049 | 0.249 |
| Stone Flour | kg | 17.766 | 14.564 |

UFSAR Revision 30.0

| | | |
|----------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 22 Table: 14.3.9-15 Page: 1 of 1</p> |
|----------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|

CHEMICAL QUANTITIES FOR DEGB CHEMICAL EFFECTS TESTING

| Chemical | Units | Mass DEGB Test |
|-------------------------------|--------------|---------------------------|
| Boric Acid | kg | 25.311 |
| Sodium Tetraborate (Borax) | kg | 12.753 |
| Sodium Aluminate Solution 36% | kg | 35.666 |
| Calcium Chloride Solution 34% | kg | 39.550 |
| Sodium Silicate Solution 38% | kg | 26.926 |

UFSAR Revision 30.0

| | | |
|----------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 22 Table: 14.3.9-16 Page: 1 of 1</p> |
|----------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|

CHEMICAL QUANTITIES FOR DGBS CHEMICAL EFFECTS TESTING

| Chemical | Units | Mass DGBS Test |
|-------------------------------|-------|-------------------|
| Boric Acid | kg | 25.311 |
| Sodium Tetraborate (Borax) | kg | 12.753 |
| Sodium Aluminate Solution 36% | kg | 35.666 |
| Calcium Chloride Solution 34% | kg | 39.550 |
| Sodium Silicate Solution 38% | kg | 26.926 |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 22</p> <p>Table: 14.3.9-17</p> <p>Page: 1 of 1</p> |
|-----------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------|

VUEZ CHEMICAL EFFECTS TESTING DEBRIS QUANTITIES

| Debris Source | Plant | Units | Test | Units | Test | Units (SI) |
|------------------------------|--------|-----------------|----------|-------|-------|------------|
| Latent Fiber ¹ | 6.5 | ft ³ | 0.096 | lbs | 43.5 | g |
| Epoxy (inside ZOI, 10 mil) | 95.04 | lbs | 0.5873 | lbs | 266.4 | g |
| Epoxy (OEM, outside ZOI) | 6.76 | lbs | 0.0418 | lbs | 18.96 | g |
| Epoxy (non-OEM, outside ZOI) | 16.12 | lbs | 0.0996 | lbs | 45.2 | g |
| Alkyd (inside ZOI, 10 mil) | 0.836 | lbs | 0.0052 | lbs | 2.359 | g |
| Alkyd (OEM, outside ZOI) | 10.416 | lbs | 0.0644 | lbs | 29.2 | g |
| Alkyd (non-OEM, outside ZOI) | 1.972 | lbs | 0.0122 | lbs | 5.53 | g |
| Marinite I | 0.1199 | lbs | 0.000741 | lbs | 0.336 | g |
| Marinite 36 | 1.00 | lbs | 0.006185 | lbs | 2.805 | g |
| Min-K | 0.704 | lbs | 0.00435 | lbs | 1.973 | g |
| Cal-Sil | 169.56 | lbs | 1.048 | lbs | 475.4 | g |
| Dirt/Dust | 88.4 | lbs | 0.546 | lbs | 247.7 | g |

¹ (Plant fiber volume) x (2.4 lb/ft³) x (strainer scaling factor) = test fiber mass

UFSAR Revision 30.0

| | | |
|----------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 22 Table: 14.3.9-18 Page: 1 of 1</p> |
|----------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|

VUEZ CHEMICAL EFFECTS TESTING MATERIAL QUANTITIES SUBMERGED IN CONTAINMENT SUMP

| Material | Source | Quantity |
|------------------------------------------|--------------------------------|--------------------------|
| Metallic Aluminum | Miscellaneous Components | 10.9 ft ² |
| Galvanized Steel, Cold Zinc Coated Steel | Structural Material | 71,162.6 ft ² |
| Copper | Wires, tubing | 1,021.6 ft ² |
| Concrete | Containment Building Structure | 6,412.8 ft ² |
| Glycol (undiluted) | Cooling System | 93.58 ft ³ |
| Oil | Lubricant | 32.76 ft ³ |

UFSAR Revision 30.0

| | | |
|----------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 22 Table: 14.3.9-19 Page: 1 of 1</p> |
|----------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|

VUEZ CHEMICAL EFFECTS TESTING NON-SUBMERGED MATERIAL QUANTITIES

| Material | Source | Quantity |
|---------------------------------------------|-------------------------------|---------------------------|
| Metallic Aluminum | HVAC Equipment | 8,013.4 ft ² |
| Galvanized Steel, Cold Zinc Coated Steel | Structural Material | 504,729 ft ² |
| Carbon Steel | Structural Material | 32,666.2 ft ² |
| Copper | Wires, Tubing, HVAC Equipment | 39,735.24 ft ² |
| Concrete | Containment Structure | 1,077.1 ft ² |
| Grease ¹ | Lubricant | 420.9 ft ² |

¹ 0.175 ft³ spread over the 420 ft² area.

UFSAR Revision 30.0



INDIANA MICHIGAN POWER
D. C. COOK NUCLEAR PLANT
UPDATED FINAL SAFETY ANALYSIS REPORT

Revision: 22
Table: 14.3.9-20
Page: 1 of 1

STRAINER MINIMUM SUBMERGENCE DETERMINATION

| Break Size | Containment Water Level at Initiation of Recirculation, ft | Minimum Water Level During Recirculation, ft | Time from Event Initiation until Minimum Water Level, ~ hours | Minimum Submergence Main Strainer, ft | Minimum Submergence Remote Strainer, ft |
|-------------------|------------------------------------------------------------|----------------------------------------------|---------------------------------------------------------------|---------------------------------------|-----------------------------------------|
| DEGB | 7.7 | 5.9 | 9.1 | 0.9 | 1.3 |
| DGBS ¹ | 6.9 | 5.6 | 2.5 | 0.6 | 1.0 |
| SBLOCA (2 in) | 6.8 | 5.1 | 9.5 | 0.1 | 0.5 |

¹ This break was analyzed as occurring in the reactor cavity at the reactor vessel nozzle, resulting in 30% of the break flow going to the reactor cavity and 70% going to the loop compartment.

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 22 Table: 14.3.9-21 Page: 1 of 1</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|

IN-VESSEL FUEL ROD DEBRIS DEPOSITION

| Case | Scale Thickness (μm) | Total Deposition Thickness (μm) | Total Deposition Thickness (mils) | Max Clad Temperature ($^{\circ}\text{F}$) |
|-----------------------------|--------------------------------------|----------------------------------------------------|-----------------------------------------|---------------------------------------------------|
| Unit 1 (min sump volume) | 151 | 443 | 17 | 365.71 |
| Unit 1 (max sump volume) | 61 | 353 | 14 | 365.71 |
| Unit 2 (min sump volume) | 122 | 414 | 16 | 358.10 |
| Unit 2 (max sump volume) | 54 | 346 | 14 | 358.09 |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 22</p> <p>Table: 14.3.9-22</p> <p>Page: 1 of 1</p> |
|-----------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------|

BOUNDING DEBRIS AT MAIN STRAINER FOR SACRIFICIAL STRAINER AREA CONSIDERATION FOR DEGB AND DGBS

| Debris Type | Debris Generated | Transport Fraction | Debris at Strainer |
|----------------------------------------------------------|------------------|--------------------|--------------------|
| Electromark Labels (inside ZOI), ft ² | 0.7 | 0.13 | 0.091 |
| Electromark Labels (outside ZOI), ft ² | 39.6 | 0.03 | 1.188 |
| Unqualified Labels (all of containment), ft ² | 25.94 | 0.86 | 22.308 |
| Fire Barrier Tape Small Pieces (< 4 in), ft ² | 14.4 | 0.13 | 1.872 |
| Fire Barrier Tape Large Pieces (≥ 4 in), ft ² | 54.1 | 0.13 | 7.033 |
| Flexible Conduit PVC Jacketing, ft ² | 1.57 | 1 | 1.57 |
| Ice Storage Bag Liner Shards, ft ² | 0.87 | 0.63 | 0.548 |
| Pieces of Work Platform Rubber, ft ² | 0.22 | 0.63 | 0.139 |
| Total, ft² | 137.4 | - | 34.75 |


UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 22</p> <p>Table: 14.3.9-23</p> <p>Page: 1 of 1</p> |
|------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------|

BOUNDING DEBRIS AT REMOTE STRAINER FOR SACRIFICIAL STRAINER AREA CONSIDERATION FOR DEGB AND DGBS

| Debris Type | Debris Generated | Transport Fraction | Debris at Strainer |
|----------------------------------------------------------|------------------|--------------------|--------------------|
| Electromark Labels (inside ZOI), ft ² | 0.7 | 0.47 | 0.329 |
| Electromark Labels (outside ZOI), ft ² | 39.6 | 0.69 | 27.324 |
| Unqualified Labels (all of containment), ft ² | 25.94 | 0.4 | 10.38 |
| Fire Barrier Tape Small Pieces (< 4 in), ft ² | 14.4 | 0 | 0 |
| Fire Barrier Tape Large Pieces (≥ 4 in), ft ² | 54.1 | 0 | 0 |
| Flexible Conduit PVC Jacketing, ft ² | 1.57 | 0.3 | 0.471 |
| Ice Storage Bag Liner Shards, ft ² | 0.87 | 0.42 | 0.365 |
| Pieces of Work Platform Rubber, ft ² | 0.22 | 0.42 | 0.092 |
| Total, ft² | 137.4 | - | 38.96 |

UFSAR Revision 30.0

| | | |
|----------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------|
|  <p style="font-size: small; margin-top: 5px;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER</p> <p>D. C. COOK NUCLEAR PLANT</p> <p>UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revised: 28.0</p> <p>Table: 14.A.1-1</p> <p>Page: 1 of 2</p> |
|----------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------|

Core Activities for Radiological Consequence Analysis

| Nuclide | Activity (Curies) | Nuclide | Activities (Curies) |
|---------|-------------------|---------|---------------------|
| Co-58 | 8.884E+05 | Pr-143 | 1.398E+08 |
| Co-60 | 6.796E+05 | Nd-147 | 6.178E+07 |
| Kr-85 | 1.280E+06 | Np-239 | 2.609E+09 |
| Kr-85m | 2.364E+07 | Pu-238 | 4.130E+05 |
| Kr-87 | 4.661E+07 | Pu-239 | 3.727E+04 |
| Kr-88 | 6.222E+07 | Pu-240 | 6.637E+04 |
| Rb-86 | 2.272E+05 | Pu-241 | 1.603E+07 |
| Sr-89 | 8.677E+07 | Am-241 | 1.707E+04 |
| Sr-90 | 1.002E+07 | Cm-242 | 7.417E+06 |
| Sr-91 | 1.100E+08 | Cm-244 | 1.838E+06 |
| Sr-92 | 1.184E+08 | Kr-83m | 1.119E+07 |
| Y-90 | 1.038E+07 | Br-82 | 3.972E+05 |
| Y-91 | 1.142E+08 | Br-83 | 1.106E+07 |
| Y-92 | 1.197E+08 | Br-84 | 2.009E+07 |
| Y-93 | 1.358E+08 | Rb-89 | 8.303E+07 |
| Zr-95 | 1.566E+08 | Y-91m | 6.384E+07 |
| Zr-97 | 1.586E+08 | Y-95 | 1.496E+08 |
| Nb-95 | 1.578E+08 | Nb-95m | 1.795E+06 |
| Mo-99 | 1.742E+08 | Nb-97 | 1.596E+08 |
| Tc-99m | 1.546E+08 | Rh-103m | 1.849E+08 |
| Ru-103 | 1.850E+08 | Pd-109 | 5.749E+07 |
| Ru-105 | 1.491E+08 | Sb-124 | 1.434E+05 |
| Ru-106 | 9.480E+07 | Sb-125 | 1.231E+06 |
| Rh-105 | 1.309E+08 | Sb-126 | 5.873E+04 |
| Sb-127 | 1.067E+07 | Te-125m | 2.725E+05 |
| Sb-129 | 3.215E+07 | Te-131 | 8.174E+07 |
| Te-127 | 1.054E+07 | Te-133 | 1.024E+08 |
| Te-127m | 1.841E+06 | Te-133m | 8.990E+07 |
| Te-129 | 3.017E+07 | Te-134 | 1.700E+08 |
| Te-129m | 5.821E+06 | I-130 | 3.945E+06 |
| Te-131m | 2.119E+07 | Xe-131m | 1.385E+06 |
| Te-132 | 1.374E+08 | Xe-133m | 6.099E+06 |
| I-131 | 9.814E+07 | Xe-135m | 4.335E+07 |
| I-132 | 1.420E+08 | Xe-138 | 1.627E+08 |
| I-133 | 1.916E+08 | Cs-134m | 5.865E+06 |

UFSAR Revision 30.0




INDIANA MICHIGAN POWER
D. C. COOK NUCLEAR PLANT
UPDATED FINAL SAFETY ANALYSIS REPORT

Revised: 28.0
Table: 14.A.1-1
Page: 2 of 2

Core Activities for Radiological Consequence Analysis

| Nuclide | Activity (Curies) | Nuclide | Activities (Curies) |
|---------|-------------------|---------|---------------------|
| I-134 | 2.148E+08 | Cs-138 | 1.776E+08 |
| I-135 | 1.832E+08 | Ba-141 | 1.522E+08 |
| Xe-133 | 1.919E+08 | La-143 | 1.419E+08 |
| Xe-135 | 5.900E+07 | Pm-147 | 1.944E+07 |
| Cs-134 | 2.523E+07 | Pm-148 | 1.841E+07 |
| Cs-136 | 6.388E+06 | Pm-148m | 4.711E+06 |
| Cs-137 | 1.325E+07 | Pm-149 | 6.245E+07 |
| Ba-139 | 1.693E+08 | Pm-151 | 2.177E+07 |
| Ba-140 | 1.639E+08 | Sm-153 | 6.797E+07 |
| La-140 | 1.700E+08 | Eu-154 | 9.557E+05 |
| La-141 | 1.533E+08 | Eu-155 | 4.427E+05 |
| La-142 | 1.475E+08 | Eu-156 | 4.798E+07 |
| Ce-141 | 1.548E+08 | Np-238 | 5.165E+07 |
| Ce-143 | 1.430E+08 | Pu-243 | 1.153E+08 |
| Ce-144 | 1.296E+08 | Am-242 | 1.148E+07 |


UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|--------------------------------------------------|
|  An AEP Company | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revised: 28.0 Table: 14.A.2-1 Page: 1 of 2 |
|-----------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|--------------------------------------------------|

Core Activities in the Highest Discharge Assembly for Radiological Consequence Analysis

| Nuclide | Activity (Ci) | Nuclide | Activities (Ci) |
|---------|---------------|---------|-----------------|
| Co-58 | 7.595E+03 | Pr-143 | 1.195E+06 |
| Co-60 | 5.810E+03 | Nd-147 | 5.282E+05 |
| Kr-85 | 2.189E+04 | Np-239 | 2.230E+07 |
| Kr-85m | 2.021E+05 | Pu-238 | 3.531E+03 |
| Kr-87 | 3.985E+05 | Pu-239 | 3.186E+02 |
| Kr-88 | 5.319E+05 | Pu-240 | 5.674E+02 |
| Rb-86 | 1.942E+03 | Pu-241 | 1.370E+05 |
| Sr-89 | 7.418E+05 | Am-241 | 1.459E+02 |
| Sr-90 | 8.566E+04 | Cm-242 | 6.341E+04 |
| Sr-91 | 9.404E+05 | Cm-244 | 1.571E+04 |
| Sr-92 | 1.012E+06 | Kr-83m | 9.567E+04 |
| Y-90 | 8.874E+04 | Br-82 | 3.396E+03 |
| Y-91 | 9.763E+05 | Br-83 | 9.455E+04 |
| Y-92 | 1.023E+06 | Br-84 | 1.718E+05 |
| Y-93 | 1.161E+06 | Rb-89 | 7.098E+05 |
| Zr-95 | 1.339E+06 | Y-91m | 5.458E+05 |
| Zr-97 | 1.356E+06 | Y-95 | 1.279E+06 |
| Nb-95 | 1.349E+06 | Nb-95m | 1.535E+04 |
| Mo-99 | 1.489E+06 | Nb-97 | 1.364E+06 |
| Tc-99m | 1.322E+06 | Rh-103m | 1.581E+06 |
| Ru-103 | 1.582E+06 | Pd-109 | 4.915E+05 |
| Ru-105 | 1.275E+06 | Sb-124 | 1.226E+03 |
| Ru-106 | 8.105E+05 | Sb-125 | 1.052E+04 |
| Rh-105 | 1.119E+06 | Sb-126 | 5.021E+02 |
| Sb-127 | 9.122E+04 | Te-125m | 2.330E+03 |
| Sb-129 | 2.749E+05 | Te-131 | 6.988E+05 |
| Te-127 | 9.011E+04 | Te-133 | 8.754E+05 |
| Te-127m | 1.574E+04 | Te-133m | 7.686E+05 |
| Te-129 | 2.574E+05 | Te-134 | 1.453E+06 |
| Te-129m | 4.977E+04 | I-130 | 3.373E+04 |
| Te-131m | 1.812E+05 | Xe-131m | 1.184E+04 |
| Te-132 | 1.175E+06 | Xe-133m | 5.214E+04 |
| I-131 | 1.342E+06 | Xe-135m | 3.706E+05 |
| I-132 | 1.214E+06 | Xe-138 | 1.391E+06 |
| I-133 | 1.638E+06 | Cs-134m | 5.014E+04 |


UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|--------------------------------------------------|
|  An AEP Company | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revised: 28.0 Table: 14.A.2-1 Page: 2 of 2 |
|-----------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|--------------------------------------------------|

Core Activities in the Highest Discharge Assembly for Radiological Consequence Analysis

| Nuclide | Activity (Ci) | Nuclide | Activities (Ci) |
|---------|---------------|---------|-----------------|
| I-134 | 1.836E+06 | Cs-138 | 1.518E+06 |
| I-135 | 1.566E+06 | Ba-141 | 1.301E+06 |
| Xe-133 | 1.641E+06 | La-143 | 1.213E+06 |
| Xe-135 | 5.044E+05 | Pm-147 | 1.662E+05 |
| Cs-134 | 2.157E+05 | Pm-148 | 1.574E+05 |
| Cs-136 | 5.461E+04 | Pm-148m | 4.028E+04 |
| Cs-137 | 1.133E+05 | Pm-149 | 5.339E+05 |
| Ba-139 | 1.447E+06 | Pm-151 | 1.861E+05 |
| Ba-140 | 1.401E+06 | Sm-153 | 5.811E+05 |
| La-140 | 1.453E+06 | Eu-154 | 8.170E+03 |
| La-141 | 1.311E+06 | Eu-155 | 3.785E+03 |
| La-142 | 1.261E+06 | Eu-156 | 4.102E+05 |
| Ce-141 | 1.323E+06 | Np-238 | 4.416E+05 |
| Ce-143 | 1.223E+06 | Pu-243 | 9.857E+05 |
| Ce-144 | 1.108E+06 | Am-242 | 9.815E+04 |


UFSAR Revision 30.0

| | | |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|--------------------------------------------------|
|  <small>An AEP Company</small> | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revised: 28.0 Table: 14.A.3-1 Page: 1 of 2 |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|--------------------------------------------------|

Parameters Used in the Calculation of Reactor Coolant Fission Product Concentrations

| Parameter | Value |
|---------------------------------------------------|--------------------------|
| Core Thermal Power | 3480 MWt |
| Fraction of Fuel Rods Containing Cladding Defects | 0.01 |
| Reactor Coolant Liquid Volume | 10,309.9 ft ³ |
| Reactor Coolant Average Temperature | 574°F |
| Purification Flow Rate | 75 gpm |
| Cation Bed Flow Rate | 800 gpd |
| Boron Dilution/Makeup Flow Rate | 400 gpd |
| Fission Product Escape Rate Coefficients: | |
| Kr, Xe | 6.5E-08 |
| I, Br, Rb, Cs | 1.3E-08 |
| Mo, Tc | 2.0E-09 |
| Te Isotopes | 1.0E-09 |
| Sr, Ba Isotopes | 1.0E-11 |
| Y, Zr, Nb, Ru, Rh, La, Ce, Pr | 1.6E-12 |
| Mixed Bed Demineralizer Decontamination Factors: | |
| Noble Gases | 1 |
| I, Br Isotopes | 10 |
| Sr, Ba Isotopes | 10 |
| All Other Isotopes | 1 |
| Cation Bed Demineralizer Decontamination Factors: | |
| Kr, Xe | 1 |
| Sr, Ba Isotopes | 1 |
| Rb-86, Cs-134, Cs-137 | 10 |
| Rb-88, Rb-89, Cs-136, Cs-138 | 1 |
| All Other Isotopes | 1 |
| Volume Control Tank Noble Gas Stripping Fractions | |
| Kr-83m | 0.78 |
| Kr-85m | 0.61 |
| Kr-85 | 7.3E-05 |
| Kr-87 | 0.84 |


UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|
|  An AEP Company | <p style="text-align: center;">INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revised: 28.0 Table: 14.A.3-1 Page: 2 of 2 |
|-----------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|

Parameters Used in the Calculation of Reactor Coolant Fission Product Concentrations

| Parameter | Value |
|-------------------------------------|-------|
| Kr-88 | 0.71 |
| Xe-131m | 0.017 |
| Xe-133m | 0.085 |
| Xe-133 | 0.037 |
| Xe-135m | 0.95 |
| Xe-135 | 0.35 |
| Xe-138 | 0.95 |
| Volume Control Tank Purge Flow Rate | 0 cfm |


UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|--------------------------------------------------|
|  An AEP Company | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revised: 28.0 Table: 14.A.3-3 Page: 1 of 1 |
|-----------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|--------------------------------------------------|

Reactor Coolant Equilibrium Fission Product Concentrations

| Nuclide | Activity ($\mu\text{Ci/g}$) | Nuclide | Activities ($\mu\text{Ci/g}$) |
|---------|----------------------------------|---------|------------------------------------|
| Kr-85 | 2.385E+01 | Xe-135 | 3.361E+00 |
| Kr-85m | 5.204E-01 | Cs-134 | 3.327E+01 |
| Kr-87 | 3.299E-01 | Cs-136 | 2.188E+00 |
| Kr-88 | 9.148E-01 | Cs-137 | 1.852E+01 |
| Rb-86 | 8.797E-02 | Ba-139 | 1.975E-04 |
| Sr-89 | 1.335E-03 | Ba-140 | 1.940E-03 |
| Sr-90 | 1.237E-04 | La-140 | 2.878E-03 |
| Sr-91 | 5.681E-04 | La-141 | 1.301E-04 |
| Sr-92 | 2.488E-04 | La-142 | 3.346E-05 |
| Y-90 | 2.152E-04 | Ce-141 | 1.445E-02 |
| Y-91 | 1.692E-02 | Ce-143 | 6.911E-04 |
| Y-92 | 3.067E-04 | Ce-144 | 4.229E-02 |
| Y-93 | 2.010E-04 | Pr-143 | 6.713E-03 |
| Zr-95 | 2.409E-02 | Kr-83m | 1.350E-01 |
| Zr-97 | 3.920E-04 | Br-82 | 4.641E-03 |
| Nb-95 | 3.478E-02 | Br-83 | 2.720E-02 |
| Mo-99 | 2.070E+00 | Br-84 | 1.244E-02 |
| Tc-99m | 1.980E+00 | Rb-89 | 2.530E-02 |
| Ru-103 | 1.991E-02 | Y-91m | 3.314E-04 |
| Ru-105 | 9.723E-05 | Nb-95m | 1.867E-04 |
| Ru-106 | 3.340E-02 | Nb-97 | 4.900E-05 |
| Rh-105 | 7.689E-04 | Rh-103m | 1.988E-02 |
| Te-127 | 2.489E-01 | Kr-83m | 1.350E-01 |
| Te-127m | 2.465E-01 | Te-125m | 2.449E-02 |
| Te-129 | 2.281E-01 | Te-131 | 1.599E-02 |
| Te-129m | 3.463E-01 | Te-133m | 7.643E-03 |
| Te-131m | 5.787E-02 | Te-134 | 1.092E-02 |
| Te-132 | 9.639E-01 | Xe-131m | 1.600E+00 |
| I-131 | 8.087E-01 | Xe-133m | 1.423E+00 |
| I-132 | 6.411E-01 | Xe-135m | 2.138E-01 |
| I-133 | 1.0304E+00 | Xe-138 | 2.292E-01 |
| I-134 | 1.231E-01 | Cs-134m | 2.031E-02 |
| I-135 | 5.365E-01 | Cs-138 | 3.420E-01 |
| Xe-133 | 1.037E+02 | Ba-141 | 4.233E-05 |

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|
|  An AEP Company | <p style="text-align: center;">INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revised: 28.0 Table: 14.A.3-5 Page: 1 of 1 |
|------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|

Reactor Coolant Iodine Appearance Rates (Ci/min)

| Isotope | Appearance Rate (Ci/min) |
|---------|-----------------------------|
| I-131 | 0.4469 |
| I-132 | 1.2307 |
| I-133 | 0.7099 |
| I-134 | 0.5128 |
| I-135 | 0.5459 |

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|----------------------------------------------------------|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 23 Table: 14.A.4-1 Page: 1 of 1</p> |
|------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|----------------------------------------------------------|

TRITIUM PRODUCTION IN THE REACTOR COOLANT (ci/yr) ¹

| RELEASED TO THE COOLANT | | | |
|----------------------------------------------------------------|-----------------------|---------------------|-----------------------|
| Tritium Source | Total Produced | Design Value | Expected Value |
| Ternary Fissions | 10,420 | 3126 | 104 |
| Burnable Poison Rods (Initial Cycle) | 922 | 277 | 9 |
| Soluble Poison Boron (Initial Cycle) (Equilibrium Cycle) | 378 525 | 378 525 | 378 525 |
| Li-7 Reaction | 11 | 11 | 11 |
| Li-6 Reaction | 6 | 6 | 6 |
| Deuterium Reaction | 1 | 1 | 1 |
| Totals Initial Cycle | 11,738 | 3799 | 509 |
| Totals Equilibrium | 10,963 | 3669 | 647 |

¹ This table was applicable at the time Unit 1 was licensed.

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|----------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 23 Table: 14.A.4-2 Page: 1 of 1</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|----------------------------------------------------------|

REVISED TRITIUM PRODUCTION IN THE REACTOR COOLANT ¹


| Tritium Source | Total Produced (curies/yr) | Expected Release to Reactor Coolant (curies/yr) |
|-----------------------------------------|-------------------------------|-------------------------------------------------------|
| Ternary Fission | 10,000 | 1000 |
| Burnable Poison Rods (Initial Cycle) | 1420 | 142 |
| Soluble Boron (Initial Cycle) | 206 | 206 |
| (Equilibrium Cycle) | 294 | 294 |
| Lithium and Deuterium Reactions | 105 | 105 |
| Total Initial Cycle | 11,730 | 1453 |
| Total Equilibrium Cycle | 10,400 | 1400 |

Basis:

| | |
|--------------------------------------------|----------|
| Release Fraction from Fuel | 10% |
| Release Fraction from Burnable Poison Rods | 10% |
| Burnable Poison Rod B-10 Mass | 6160 gpm |

¹ This table was included in the Original FSAR in May, 1976.


UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|--------------------------------------------------|
|  An AEP Company | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revised: 28.0 Table:14.A.5-1a Page: 1 of 1 |
|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|--------------------------------------------------|

Volume Control Tank Activities for Offsite Dose Consequence Analysis

| Nuclide | VCT Gas Phase Activity (Ci) | VCT Liquid Phase Activity (Ci) | Letdown Activity (Ci) | Total Activity (Ci) |
|---------|-----------------------------|--------------------------------|-----------------------|---------------------|
| Kr-85 | 2.793E+03 | 1.780E+02 | 2.231E+02 | 3.194E+03 |
| Kr-85m | 3.923E+01 | 4.484E+00 | 5.619E+00 | 4.933E+01 |
| Kr-87 | 1.359E+01 | 2.462E+00 | 3.085E+00 | 1.913E+01 |
| Kr-88 | 6.477E+01 | 7.334E+00 | 9.191E+00 | 8.129E+01 |
| Xe-133 | 1.668E+04 | 1.146E+03 | 1.436E+03 | 1.926E+04 |
| Xe-133m | 2.176E+02 | 1.547E+01 | 1.939E+01 | 2.524E+02 |
| Xe-135 | 2.779E+02 | 2.335E+01 | 2.927E+01 | 3.305E+02 |
| Xe-135m | 2.705E+00 | 1.835E+00 | 2.299E+00 | 6.837E+00 |


UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|--------------------------------------------------|
|  An AEP Company | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revised: 28.0 Table:14.A.5-1b Page: 1 of 1 |
|------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|--------------------------------------------------|

Volume Control Tank Activities for Control Room Dose Consequence Analysis

| Nuclide | VCT Gas Phase Activity (Ci) | VCT Liquid Phase Activity (Ci) | Letdown Flow Activity (Ci) | Total Activity (Ci) |
|---------|-----------------------------|--------------------------------|----------------------------|---------------------|
| Kr-85m | 1.596E+02 | 1.021E+01 | 1.012E+01 | 1.799E+02 |
| Kr-85 | 1.835E+04 | 4.679E+02 | 4.639E+02 | 1.929E+04 |
| Kr-87 | 3.955E+01 | 6.472E+00 | 6.416E+00 | 5.244E+01 |
| Kr-88 | 2.070E+02 | 1.794E+01 | 1.779E+01 | 2.427E+02 |
| Xe-131m | 8.716E+02 | 3.138E+01 | 3.111E+01 | 9.341E+02 |
| Xe-133m | 7.125E+02 | 2.791E+01 | 2.766E+01 | 7.681E+02 |
| Xe-133 | 5.421E+04 | 2.035E+03 | 2.017E+03 | 5.826E+04 |
| Xe-135m | 5.806E+00 | 4.194E+00 | 4.158E+00 | 1.4160E+01 |
| Xe-135 | 1.200E+03 | 6.593E+01 | 6.535E+01 | 1.331E+03 |
| Xe-138 | 5.770E+00 | 4.497E+00 | 4.458E+00 | 1.473E+01 |

UFSAR Revision 30.0

| | | |
|-----------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|
|  An AEP Company | <p style="text-align: center;">INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revised: 28.0 Table: 14.A.5-2 Page: 1 of 1 |
|-----------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|

Waste Gas Decay Tank Activity

| Nuclide | Total Activity (Ci) |
|----------------|----------------------------|
| Kr-85m | 1.433E+02 |
| Kr-85 | 6.570E+03 |
| Kr-87 | 9.087E+01 |
| Kr-88 | 2.520E+02 |
| Xe-131m | 4.407E+02 |
| Xe-133m | 3.920E+02 |
| Xe-133 | 2.857E+04 |
| Xe-135m | 5.889E+01 |
| Xe-135 | 9.258E+02 |
| Xe-138 | 6.314E+01 |


UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|----------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 16.1 Table: 14.G-1 Page: 1 of 1</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|----------------------------------------------------------|

COMPONENTS NOMENCLATURE

| COMPONENT | ELEMENT |
|------------------------------------|-------------------------|
| Vessel Supports | Number 1 and 49 |
| Barrel Flange and Hold-Down Spring | Numbers 2 thru 6 |
| Barrel | Numbers 7 thru 10 |
| Lower Core Supports | Numbers 11 thru 15 |
| Major Fuel Assemblies | Even Numbers 16 thru 38 |
| Minor Fuel Assemblies | Odd Numbers 17 thru 39 |
| Upper Internals | Numbers 40 thru 48 |

UFSAR Revision 30.0


| | | |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|---------------------------------------------------------|
|  <small>An AEP Company</small> | INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT | Revision: 16.1 Table: 14.G-2 Page: 1 of 1 |
|--------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|---------------------------------------------------------|

HISTORICAL
MAXIMUM DEFLECTIONS UNDER BLOWDOWN (INCHES)
 (1-MILLISECOND DOUBLE-ENDED BREAK)

| Component | Hot Leg | Cold Leg | Seismic Horizontal | Maximum Total | Allowable | No Loss Of Function |
|------------------------------------------------------|----------------|----------|--------------------|---------------|--------------------|---------------------|
| Upper Barrel | | | | | | |
| Radial inward | 0.057 | 0.0 | 0.002 | 0.059 | 5 | 10 |
| Radial outward | 0.029 | 0.431 | 0.002 | 0.460 | 4.125 | 8.25 |
| Upper core plant | 0.015 | 0.016 | 0 | 0.016 | 0.100 ¹ | 0.150 |
| RCC Guide Tubes (deflection as a beam) | (54)<Allowable | | 0.010 | <Allowable | 1.0 | 1.60 to 1.75 |
| | (2)<N.L.F. | | 0.010 | <N.L.F. | 1.0 | 1.60 to 1.75 |
| | >Allowable | | | >Allowable | | 1.60 to 1.75 |
| | (5)>N.L.F | | 0.010 | >N.L.F. | 1.0 | |
| Fuel Assembly Thimbles (cross-section distortion) | 0 | 0 | 0 | 0 | 0.036 | 0.072 |

¹ Only to assure that the plate will not touch a guide tube.

UFSAR Revision 30.0

| | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------|----------------------------------------------------------|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 16.1 Table: 14.G-3 Page: 1 of 1</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------|----------------------------------------------------------|

HISTORICAL
SUMMARY OF MAXIMUM STRESS INTENSITIES (PSI)
(1-MILLISECOND PIPE BREAK AND SEISMICS)

| Component | Hot Leg Break | | Cold Leg Break | | Maximum Total Seismic | | Maximum Total Blowdown Plus Seismic |
|-----------------------------------|---------------------|------------------|---------------------|------------------|-----------------------|------------|-------------------------------------------|
| | Maximum Membrane | Maximum Total | Maximum Membrane | Maximum Total | Vertical | Horizontal | |
| Barrel (Girth weld) | 21,440 | 31,340 | 38,900 | 46,200 | 133 | 533 | 46,733 |
| Barrel-Flange (weld) | 19,820 | 29,720 | 18,430 | 47,700 | 545 | 800 | 49,045 |
| Fuel Assembly Top Nozzle Plate | | 28,700 | 0 | 8,000 | 0 | 0 | 28,700 |
| Fuel Assembly Bottom Nozzle Plate | | 38,700 | | 40,800 | 533 | | 41,333 |
| Fuel Assembly Thimbles | 6,600 | 6,600 | 2,300 | 2,300 | | | 6,600 |
| | | | | | | | |

Allowable Stress, S_m :

S_m at 588°F = 16,600 psi ¹

Maximum Membrane Stress = $P_m = 2.4 S_m = 39,800$ psi

Maximum Total Stress = $P_m + P_b = 49,800$ psi

¹ Per Winter 1969 Addenda ASME Section III Code