

UFSAR Revision 30.0

| | | |
|--|--|--|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 29</p> <p>Table: 14.2.5-1</p> <p>Page: 1 of 1</p> |
|--|--|--|

LIMITING STEAMLINE BREAK STATEPOINT DOUBLE ENDED RUPTURE INSIDE CONTAINMENT WITH OFFSITE POWER AVAILABLE

| Time (sec) | Pressure Psia | HeatFlux Fraction | Inlet Temp | | Flow Frac | Boron PPM | Reactivity Percent | Density GM/CC |
|---------------|------------------|----------------------|------------|--------|--------------|--------------|-----------------------|------------------|
| | | | Cold °F | Hot °F | | | | |
| 118.4 | 600.77 | 0.173 | 334.1 | 448.9 | 1.0 | 1.19 | 0.030 | 0.856 |


UFSAR Revision 30.0

| | | |
|---|--|--|
|  <p style="font-size: small; margin-top: 5px;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 29</p> <p>Table: 14.2.5-2</p> <p>Page: 1 of 1</p> |
|---|--|--|

TIME SEQUENCE OF EVENTS

| Accident | Event | Time (sec) |
|---|---|------------|
| Rupture of a Steamline | | |
| 1. Inside Containment With Offsite Power available | Steam line ruptures | 0.0 |
| | Low steamline pressure setpoint reached | 0.26 |
| | Feedwater Isolation (All loops) | 8.26 |
| | Steamline Isolation (Loops 2, 3 and 4) | 11.26 |
| | Pressurizer empties | 13.8 |
| | SI flow starts | 27.26 |
| | Criticality attained | 22.6 |
| | Boron from SI reaches core | 38.4 |
| | Peak heat flux attained | 118.4 |
| | Core becomes subcritical | 121.0 |
| 2. Inside Containment Without Offsite Power available | Steam line ruptures | 0.0 |
| | Low steamline pressure setpoint reached | 0.26 |
| | Feedwater Isolation (All loops) | 8.26 |
| | Steam Isolation | 11.26 |
| | Pressurizer empties | 15.4 |
| | Criticality attained | 27.4 |
| | SI flow starts | 37.26 |
| | Boron from SI reaches core | 52.0 |
| | Peak heat flux attained | 299.7 |
| | Core becomes subcritical | ~ 309 |

UFSAR Revision 30.0

| | | |
|--|--|--|
|  <p>INDIANA MICHIGAN POWER <small>An AEP Company</small></p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 27.0 Table: 14.2.6-1 Page: 1 of 1</p> |
|--|--|--|

Parameters Used in the Analysis of the Rod Cluster Control Assembly Ejection Accident

| Accident Parameters | Time in Cycle | | | |
|--|------------------|------------------|------------|------------|
| | HZP Beginning | HFP Beginning | HZP End | HFP End |
| Power Level (%) | 0 | 102 | 0 | 102 |
| Ejected Rod Worth (% Δk) | 0.75 | 0.15 | 0.89 | 0.19 |
| Delayed Neutron Fraction (%) | 0.50 | 0.50 | 0.40 | 0.40 |
| Feedback Reactivity Weighting | 2.071 | 1.30 | 3.621 | 1.30 |
| Trip Reactivity (% Δk) | 2. | 4. | 2. | 4. |
| F _Q before Rod Ejection | 2.50 | 2.50 | 2.36 | 2.50 |
| F _Q after Rod Ejection | 12. | 7.0 | 25.0 | 7.3 |
| Number of Operational Pumps | 2. | 4. | 2. | 4. |
| Results | | | | |
| Maximum Fuel Pellet Average Temperature (°F) | 3439 | 4268 | 3630 | 4159 |
| Maximum Fuel Center Temperature (°F) | 3922 | 4983 | 4009 | 4910 |
| Maximum Fuel Stored Enthalpy (cal/gm) | 145.6 | 188.6 | 155.3 | 182.8 |
| Fuel Melt in Hot Pellet, % | 0 | <10 | 0 | <10 |

UFSAR Revision 30.0

| | | |
|---|--|---|
|  <p style="font-size: small;">An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | Revision: 16.1 Table: 14.2.8-1 Page: 1 of 2 |
|---|--|---|

TIME SEQUENCE OF EVENTS

| Accident | Event | Time (sec) |
|---|--|---------------|
| Main Feedwater Line Rupture (With Power) | | |
| | Main feedwater line rupture occurs | 10.0 |
| | Low-low steam generator water level trip signal initiated | 16.0 |
| | Rods begin to fall into core | 18.0 |
| | SIS low pressurizer pressure setpoint reached | 78.0 |
| | Feedwater isolation (Loops 2, 3, 4) | 86.0 |
| | SIS flow starts | 106.0 |
| | SIS low steamline pressure setpoint reached in two loops | 239.8 |
| | Steamline isolation (All loops) | 250.8 |
| | Auxiliary feedwater starts to deliver to intact steam generators | 610.0 |
| | Steam generator safety valve setpoint reached in intact steam generators | 910.0 |
| | Core decay heat plus RCP heat decreases to auxiliary feedwater heat removal capacity | ~1500.0 |
| | Pressurizer safety valve setpoint reached | Never reached |
| Main Feedwater Line Rupture (Without Power) | | |
| | Main feedwater line rupture occurs | 10.0 |
| | Low-low steam generator water level trip signal initiated | 16.0 |
| | Rods begin to fall into core | 18.0 |
| | RCS pumps begin to coastdown | 20.0 |
| | SIS low steamline pressure setpoint reached in two loops | 150.6 |
| | Feedwater isolation (Loops 2,3,4) | 158.6 |
| | Steamline isolation (All loops) | 161.6 |
| SIS flow starts | 189.0 | |

UFSAR Revision 30.0

| | | |
|--|---|--|
|  <p>INDIANA MICHIGAN POWER An AEP Company</p> | <p>INDIANA MICHIGAN POWER D. C. COOK NUCLEAR PLANT UPDATED FINAL SAFETY ANALYSIS REPORT</p> | <p>Revision: 16.1 Table: 14.2.8-1 Page: 2 of 2</p> |
|--|---|--|

TIME SEQUENCE OF EVENTS

| Accident | Event | Time (sec) |
|----------|--|---------------|
| | Auxiliary feedwater started to deliver to intact steam generators | 610.0 |
| | Steam generator safety valve setpoint reached in intact steam generators | 668.0 |
| | Core decay heat decreases to auxiliary feedwater heat removal capacity | ~1200.0 |
| | Pressurizer safety valve setpoint reached | Never reached |