

Acceleration Spectra for REACTOR ENCL.

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)


Node: 154 Direction: VERTICAL Elev: 177'-0

Damping: 0.005,0.01,0.02,0.03,0.05

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
REACTOR ENCLOSURE GLOBAL  
RESPONSE SPECTRA, VERTICAL,  
CO - ADS AXISYMMETRIC**

**FIGURE 3A-320**



Acceleration Spectra for REACTOR ENCL.

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)


Node: 128 Direction: VERTICAL Elev: 201'-0

Damping: 0.005,0.01,0.02,0.03,0.05

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
REACTOR ENCLOSURE GLOBAL  
RESPONSE SPECTRA, VERTICAL,  
CO - ADS AXISYMMETRIC**

**FIGURE 3A-321**



Acceleration Spectra for REACTOR ENCL.

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)


Node: 130 Direction: VERTICAL Elev: 201'-0

Damping: 0.005, 0.01, 0.02, 0.03, 0.05

LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
REACTOR ENCLOSURE GLOBAL  
RESPONSE SPECTRA, VERTICAL,  
CO - ADS AXISYMMETRIC

FIGURE 3A-322



Acceleration Spectra for REACTOR ENCL.

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)


Node: 106 Direction: VERTICAL Elev: 217'-0

Damping: 0.005,0.01,0.02,0.03,0.05

LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
REACTOR ENCLOSURE GLOBAL  
RESPONSE SPECTRA, VERTICAL,  
CO - ADS AXISYMMETRIC

FIGURE 3A-323



Acceleration Spectra for REACTOR ENCL.

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)


Node: 108 Direction: VERTICAL Elev: 217'-0

Damping: 0.005,0.01,0.02,0.03,0.05

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
REACTOR ENCLOSURE GLOBAL  
RESPONSE SPECTRA, VERTICAL,  
CO - ADS AXISYMMETRIC**

**FIGURE 3A-324**



Acceleration Spectra for REACTOR ENCL.

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)


Node: 104 Direction: VERTICAL Elev: 239'-0

Damping: 0.005,0.01,0.02,0.03,0.05

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
REACTOR ENCLOSURE GLOBAL  
RESPONSE SPECTRA, VERTICAL,  
CO - ADS AXISYMMETRIC**

**FIGURE 3A-325**



Acceleration Spectra for REACTOR ENCL.

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)


Node: 81 Direction: VERTICAL Elev: 253'-0

Damping: 0.005,0.01,0.02,0.03,0.05

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
REACTOR ENCLOSURE GLOBAL  
RESPONSE SPECTRA, VERTICAL,  
CO - ADS AXISYMMETRIC**

**FIGURE 3A-326**



Acceleration Spectra for REACTOR ENCL.

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)

Node: 19 Direction: VERTICAL Elev: 253'-0


Damping: 0.005,0.01,0.02,0.03,0.05

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
REACTOR ENCLOSURE GLOBAL  
RESPONSE SPECTRA, VERTICAL,  
CO - ADS AXISYMMETRIC**

**FIGURE 3A-327**





Acceleration Spectra for REACTOR ENCL.

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)


Node: 77 Direction: VERTICAL Elev: 269'-0

Damping: 0.005,0.01,0.02,0.03,0.05

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
REACTOR ENCLOSURE GLOBAL  
RESPONSE SPECTRA, VERTICAL,  
CO - ADS AXISYMMETRIC**

**FIGURE 3A-328**



Acceleration Spectra for REACTOR ENCL.

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)


Node: 58 Direction: VERTICAL Elev: 283'-0

Damping: 0.005, 0.01, 0.02, 0.03, 0.05

LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
REACTOR ENCLOSURE GLOBAL  
RESPONSE SPECTRA, VERTICAL,  
CO - ADS AXISYMMETRIC

FIGURE 3A-329



Acceleration Spectra for REACTOR ENCL.

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)


Node: 60 Direction: VERTICAL Elev: 283'-0

Damping: 0.005,0.01,0.02,0.03,0.05

LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
REACTOR ENCLOSURE GLOBAL  
RESPONSE SPECTRA, VERTICAL,  
CO - ADS AXISYMMETRIC

FIGURE 3A-330



**Acceleration Spectra for REACTOR ENCL.**

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)

Node: 56 Direction: VERTICAL Elev: 304'-0


Damping: 0.005, 0.01, 0.02, 0.03, 0.05

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

---

**DESIGN ASSESSMENT REPORT  
REACTOR ENCLOSURE GLOBAL  
RESPONSE SPECTRA, VERTICAL,  
CO - ADS AXISYMMETRIC**

**FIGURE 3A-331**



Acceleration Spectra for REACTOR ENCL.

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)


Node: 35 Direction: VERTICAL Elev: 313'-0

Damping: 0.005,0.01,0.02,0.03,0.05

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
REACTOR ENCLOSURE GLOBAL  
RESPONSE SPECTRA, VERTICAL,  
CO - ADS AXISYMMETRIC**

**FIGURE 3A-332**



Acceleration Spectra for REACTOR ENCL.

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)


Node: 43 Direction: VERTICAL Elev: 313'-0

Damping: 0.005,0.01,0.02,0.03,0.05

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
REACTOR ENCLOSURE GLOBAL  
RESPONSE SPECTRA, VERTICAL,  
CO - ADS AXISYMMETRIC**

**FIGURE 3A-333**



Acceleration Spectra for REACTOR ENCL.

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)


Node: 21 Direction: VERTICAL Elev: 333'-0

Damping: 0.005,0.01,0.02,0.03,0.05

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
REACTOR ENCLOSURE GLOBAL  
RESPONSE SPECTRA, VERTICAL,  
CO - ADS AXISYMMETRIC**

**FIGURE 3A-334**



Acceleration Spectra for REACTOR ENCL.

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)

Node: 33 Direction: VERTICAL Elev: 333'-0


Damping: 0.005,0.01,0.02,0.03,0.05

LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
 REACTOR ENCLOSURE GLOBAL  
 RESPONSE SPECTRA, VERTICAL,  
 CO - ADS AXISYMMETRIC

FIGURE 3A-335





Acceleration Spectra for REACTOR ENCL.

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)


Node: 9 Direction: VERTICAL Elev: 352'-0

Damping: 0.005,0.01,0.02,0.03,0.05

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
REACTOR ENCLOSURE GLOBAL  
RESPONSE SPECTRA, VERTICAL,  
CO - ADS AXISYMMETRIC**

**FIGURE 3A-336**



Acceleration Spectra for REACTOR ENCL.

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)


Node: 13 Direction: VERTICAL Elev: 352'-0

Damping: 0.005,0.01,0.02,0.03,0.05

LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
REACTOR ENCLOSURE GLOBAL  
RESPONSE SPECTRA, VERTICAL,  
CO - ADS AXISYMMETRIC

FIGURE 3A-337



Acceleration Spectra for REACTOR ENCL.

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)


Node: 129 Direction: VERTICAL Elev: 201'-0

Damping: 0.005,0.01,0.02,0.03,0.05

LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
REACTOR ENCLOSURE GLOBAL  
RESPONSE SPECTRA, VERTICAL,  
CO - ADS AXISYMMETRIC

FIGURE 3A-338



Acceleration Spectra for REACTOR ENCL.

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)


Node: 107 Direction: VERTICAL Elev: 217'-0

Damping: 0.005,0.01,0.02,0.03,0.05

LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
 REACTOR ENCLOSURE GLOBAL  
 RESPONSE SPECTRA, VERTICAL,  
 CO - ADS AXISYMMETRIC

FIGURE 3A-339



Acceleration Spectra for REACTOR ENCL.

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)


Node: 80 Direction: VERTICAL Elev: 253'-0

Damping: 0.005,0.01,0.02,0.03,0.05

LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
REACTOR ENCLOSURE GLOBAL  
RESPONSE SPECTRA, VERTICAL,  
CO - ADS AXISYMMETRIC

FIGURE 3A-340



Acceleration Spectra for REACTOR ENCL.

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)


Node: 59 Direction: VERTICAL Elev: 283'-0

Damping: 0.005,0.01,0.02,0.03,0.05

LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
REACTOR ENCLOSURE GLOBAL  
RESPONSE SPECTRA, VERTICAL,  
CO - ADS AXISYMMETRIC

FIGURE 3A-341



Acceleration Spectra for REACTOR ENCL.

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)


Node: 54 Direction: VERTICAL Elev: 313'-0

Damping: 0.005,0.01,0.02,0.03,0.05

LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
REACTOR ENCLOSURE GLOBAL  
RESPONSE SPECTRA, VERTICAL,  
CO - ADS AXISYMMETRIC

FIGURE 3A-342



Acceleration Spectra for REACTOR ENCL.

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)

Node: 32 Direction: VERTICAL Elev: 333'-0


Damping: 0.005,0.01,0.02,0.03,0.05

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
REACTOR ENCLOSURE GLOBAL  
RESPONSE SPECTRA, VERTICAL,  
CO - ADS AXISYMMETRIC**

**FIGURE 3A-343**





Acceleration Spectra for REACTOR ENCL.

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)


Node: 12 Direction: VERTICAL Elev: 352'-0

Damping: 0.005,0.01,0.02,0.03,0.05

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
REACTOR ENCLOSURE GLOBAL  
RESPONSE SPECTRA, VERTICAL,  
CO - ADS AXISYMMETRIC**

**FIGURE 3A-344**



Acceleration Spectra for REACTOR ENCL.

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)


Node: 6 Direction: VERTICAL Elev: 410'-0

Damping: 0.005,0.01,0.02,0.03,0.05

LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
REACTOR ENCLOSURE GLOBAL  
RESPONSE SPECTRA, VERTICAL,  
CO-ADS AXISYMMETRIC

FIGURE 3A-345



Acceleration Spectra for CONTROL STRUCTURE


Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)

Node: 7 Direction: VERTICAL Elev: 217'

Damping: 0.005,0.01,0.02,0.03,0.05

LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT  
 DESIGN ASSESSMENT REPORT  
 CONTROL STRUCTURE  
 LOCAL RESPONSE SPECTRA, VERTICAL,  
 CO - ADS AXISYMMETRIC

FIGURE 3A-346



Acceleration Spectra for CONTROL STRUCTURE

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)


Node: 7 Direction: VERTICAL Elev: 239'

Damping: 0.005,0.01,0.02,0.03,0.05

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
CONTROL STRUCTURE  
LOCAL RESPONSE SPECTRA, VERTICAL,  
CO - ADS AXISYMMETRIC**

**FIGURE 3A-347**



Acceleration Spectra for CONTROL STRUCTURE

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)


Node: 7 Direction: VERTICAL Elev: 254'

Damping: 0.005,0.01,0.02,0.03,0.05

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
CONTROL STRUCTURE  
LOCAL RESPONSE SPECTRA, VERTICAL,  
CO - ADS AXISYMMETRIC**

**FIGURE 3A-348**



Acceleration Spectra for CONTROL STRUCTURE

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)


Node: 7 Direction: VERTICAL Elev: 269'-0

Damping: 0.005,0.01,0.02,0.03,0.05

LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
CONTROL STRUCTURE  
LOCAL RESPONSE SPECTRA, VERTICAL,  
CO - ADS AXISYMMETRIC

FIGURE 3A-349



Acceleration Spectra for CONTROL STRUCTURE

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)


Node: 7 Direction: VERTICAL Elev: 289'

Damping: 0.005,0.01,0.02,0.03,0.05

LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
CONTROL STRUCTURE  
LOCAL RESPONSE SPECTRA, VERTICAL,  
CO - ADS AXISYMMETRIC

FIGURE 3A-350



Acceleration Spectra for CONTROL STRUCTURE

Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)

Node: 7 Direction: VERTICAL Elev: 304'-0


Damping: 0.005,0.01,0.02,0.03,0.05

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
CONTROL STRUCTURE  
LOCAL RESPONSE SPECTRA, VERTICAL,  
CO - ADS AXISYMMETRIC**

**FIGURE 3A-351**







Acceleration Spectra for CONTROL STRUCTURE  
 Load Case: AXISYMMETRIC GE CO-ADS ENVELOPE (WIDENED - 15%)  
 Node: 7 Direction: VERTICAL Elev: 332'  
 Damping: 0.005,0.01,0.02,0.03,0.05

LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
 CONTROL STRUCTURE  
 LOCAL RESPONSE SPECTRA, VERTICAL,  
 CO - ADS AXISYMMETRIC

FIGURE 3A-352




LOAD POINT NO. 1

LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
 LOCA AIR CLEARING VELOCITY  
 (SHEET 1 OF 4)

FIGURE 3A-353





LOAD POINT NO. 1	LOAD POINT NO. 2	LOAD POINT NO. 3	LOAD POINT NO. 4
.	.	.	.

LOAD POINT NO. 2

LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
 LOCA AIR CLEARING VELOCITY  
 (SHEET 2 OF 4)

FIGURE 3A-353




LOAD POINT NO. 3

LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
 LOCA AIR CLEARING VELOCITY  
 (SHEET 3 OF 4)

FIGURE 3A-353



LOAD POINT NO. 4


**LIMERICK GENERATING STATION**  
**UNITS 1 AND 2**  
**UPDATED FINAL SAFETY ANALYSIS REPORT**

---

**DESIGN ASSESSMENT REPORT**  
**LOCA AIR CLEARING VELOCITY**  
**(SHEET 4 OF 4)**

---

**FIGURE 3A-353**




LOAD POINT NO. 1	LOAD POINT NO. 2	LOAD POINT NO. 3	LOAD POINT NO. 4
.	.	.	.

LOAD POINT NO. 1

LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
 LOCA AIR CLEARING  
 ACCELERATION  
 (SHEET 1 OF 4)



FIGURE 3A-354



LOAD POINT NO. 1	LOAD POINT NO. 2	LOAD POINT NO. 3	LOAD POINT NO. 4
.	.	.	.

LOAD POINT NO. 2

<b>LIMERICK GENERATING STATION          UNITS 1 AND 2          UPDATED FINAL SAFETY ANALYSIS REPORT</b>
<b>DESIGN ASSESSMENT REPORT          LOCA AIR CLEARING          ACCELERATION          (SHEET 2 OF 4)</b>
<b>FIGURE 3A-354</b>




LOAD POINT NO. 3

LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
 LOCA AIR CLEARING  
 ACCELERATION  
 (SHEET 3 OF 4)

FIGURE 3A-354





LOAD POINT NO. 1	LOAD POINT NO. 2	LOAD POINT NO. 3	LOAD POINT NO. 4
.	.	.	.


LOAD POINT NO. 4

**LIMERICK GENERATING STATION**  
**UNITS 1 AND 2**  
**UPDATED FINAL SAFETY ANALYSIS REPORT**

---

**DESIGN ASSESSMENT REPORT**  
**LOCA AIR CLEARING**  
**ACCELERATION**  
**(SHEET 4 OF 4)**


**FIGURE 3A-354**



LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
 TOP VIEW OF 36° SECTOR OF  
 A TYPICAL MARK II  
 SUPPRESSION POOL


FIGURE 3A-355



LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT


DESIGN ASSESSMENT REPORT  
SCHEMATIC VIEW OF  
SECTION A-A OF TYPICAL  
MARK II SUPPRESSION POOL

FIGURE 3A-356



$$F = \rho \pi a^2 (1 + C_M) U + \rho a C_L U^2$$

— REFERENCE 3A-41  
 ○ MODEL



LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT




DESIGN ASSESSMENT REPORT  
 MODEL/DATA COMPARISONS  
 (SHEET 1 OF 4)

FIGURE 3A-357

$$F = (1 + C_M) \rho \pi a^2 U + \rho a C_L U U$$

where  $a = D/2$


○●--- REFERENCE 3A-42  
○ MODEL




LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
MODEL/DATA COMPARISONS  
(SHEET 2 OF 4)

FIGURE 3A-357




$$F = C_M \rho \pi a^2 \dot{U} + C_L \rho a U^2$$



LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT


DESIGN ASSESSMENT REPORT  
 MODEL/DATA COMPARISONS  
 (SHEET 3 OF 4)

FIGURE 3A-357



$$F = \rho \pi a^2 \dot{U} + C_M \rho \pi a^2 \dot{U} + \rho a C_L |U| |U|$$

LIFT AND ACCELERATION COEFFICIENTS




- $C_L$  References 3A-43 and 3A-45 (Oregon State University Data 1975)
- $C_M$  References 3A-43 and 3A-45 (Oregon State University Data 1975)
- ..... References 3A-43 and 3A-45
- Model

LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT

---

DESIGN ASSESSMENT REPORT  
 MODEL/DATA COMPARISONS  
 (SHEET 4 OF 4)

FIGURE 3A-357




LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
 CYLINDER LOCATIONS

FIGURE 3A-358






LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
INTERFERENCE ON STANDARD DRAG:  
THREE CYLINDER ARRANGEMENT


FIGURE 3A-359



LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
INTERFERENCE ON STANDARD DRAG:  
THREE CYLINDER SIDE-BY-SIDE  
ARRANGEMENT

FIGURE 3A-360



LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
 FLOW AROUND UNEQUAL  
 CYLINDERS


FIGURE 3A-361

**SECTIONS**

- 1-5
- 6-11
- 12-13
- 14-20
- 21-25
- 26-30

**LOCATIONS**

- DRYWELL WALL
- WETWELL WALL
- SHIELD WALL
- PEDESTAL
- DIAPHRAGM SLAB
- BASE SLAB



○ SECTION WHERE STRESSES ARE ASSESSED

LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
 CONTAINMENT ASSESSMENT  
 SECTION LOCATION

FIGURE 3A-362

DRYWELL WALL  
SECTIONS: 1, 2

Load Combination Equation (4)	MAXIMUM REBAR STRESSES, KSI (1) (3)						Max. Concrete Stress, KSI (2) (3)
	INNER		OUTER			Transverse Ties	
	Vert	Hoop	Vert	Hoop	Diag.		
1	-	-	-	-	-	-	-
3, 6	-	-	-	-	-	-	-
4, 4a	18.57	31.36	5.82	13.90	11.17	6.50	-0.233
4T, 4aT	7.14	6.83	13.4	19.75	16.83	10.99	-0.967
5, 5a, 7, 7a	25.66	30.66	9.95	13.45	20.82	4.60	-0.257
5T, 5aT, 7T, 7aT	11.36	-4.66	16.34	24.41	32.46	11.67	-1.542

- NOTES:
- (1) Allowable Reinforcing Steel Stress = 54 KSI
  - (2) Allowable Concrete Compressive Stress = 3.4 KSI
  - (3) "+" for Tensile Stress; "-" for Compressive Stress
  - (4) Load Combination Equations are taken from Table 3A-14, 4T, 4aT, 5T, 5aT, 7T, 7aT include thermal components.
  - (5) Values reflect analysis with an initial Drywell air temperature of 135°F. Increasing this temperature to 150°F does not adversely impact the results of this Design Assessment Report.

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
CONTAINMENT STRESSES  
DRYWELL WALL**

FIGURE 3A-363

Rev. 12 9/04

DRYWELL WALL  
SECTIONS: 3

Load Combination Equation (4)	MAXIMUM REBAR STRESSES, KSI (1) (3)						Max. Concrete Stress, KSI (2) (3)
	INNER		OUTER			Transverse Ties	
	Vert	Hoop	Vert	Hoop	Diag.		
1	-0.46	-0.07	-0.55	-0.04	-0.28	0.12	-0.432
3, 6	11.4	6.26	11.3	4.2	15.7	15.1	-0.200
4, 4a	9.97	43.0	14.8	19.5	17.4	11.4	-0.218
4T, 4aT	3.45	18.7	23.8	28.0	24.5	12.2	-0.926
5, 5a, 7, 7a	21.1	40.2	21.3	17.4	36.9	20.1	-0.460
5T, 5aT, 7T, 7aT	14.9	15.9	34.5	27.4	52.0	17.6	-1.38

- NOTES:
- (1) Allowable Reinforcing Steel Stress = 54 KSI
  - (2) Allowable Concrete Compressive Stress = 3.4 KSI
  - (3) "+" for Tensile Stress; "-" for Compressive Stress
  - (4) Load Combination Equations are taken from Table 3A-14, 4T, 4aT, 5T, 5aT, 7T, 7aT include thermal components.
  - (5) Values reflect analysis with an initial Drywell air temperature of 135°F. Increasing this temperature to 150°F does not adversely impact the results of this Design Assessment Report.

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
CONTAINMENT STRESSES  
DRYWELL WALL**

FIGURE 3A-364

Rev. 12 9/04

DRYWELL WALL  
SECTIONS: 4

Load Combination Equation (4)	MAXIMUM REBAR STRESSES, KSI (1) (3)						Max. Concrete Stress, KSI (2) (3)
	INNER		OUTER			Transverse Ties	
	Vert	Hoop	Vert	Hoop	Diag.		
1	-0.55	-0.02	-0.69	0.06	-0.35	0.15	-0.097
3, 6	13.0	6.44	13.0	4.2	17.1	20.31	-0.230
4, 4a	8.49	41.7	21.8	20.9	23.2	10.8	-0.202
4T, 4aT	4.43	20.3	29.2	30.2	32.4	11.4	-0.822
5, 5a, 7, 7a	26.3	39.3	28.7	17.5	39.7	24.9	-0.522
5T, 5aT, 7T, 7aT	16.8	16.3	40.6	28.6	48.0	21.8	-1.431

- NOTES:
- (1) Allowable Reinforcing Steel Stress = 54 KSI
  - (2) Allowable Concrete Compressive Stress = 3.4 KSI
  - (3) "+" for Tensile Stress; "-" for Compressive Stress
  - (4) Load Combination Equations are taken from Table 3A-14, 4T, 4aT, 5T, 5aT, 7T, 7aT include thermal components.
  - (5) Values reflect analysis with an initial Drywell air temperature of 135°F. Increasing this temperature to 150°F does not adversely impact the results of this Design Assessment Report.

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
CONTAINMENT STRESSES  
DRYWELL WALL**

FIGURE 3A-365

Rev. 12 9/04

DRYWELL WALL  
SECTIONS: 5

Load Combination Equation (4)	MAXIMUM REBAR STRESSES, KSI (1) (3)						Max. Concrete Stress, KSI (2) (3)
	INNER		OUTER			Transverse Ties	
	Vert	Hoop	Vert	Hoop	Diag.		
1	-0.73	1.04	-0.80	1.0	-0.35	0.16	-0.106
3, 6	15.5	10.3	14.6	5.5	20.0	18.6	-0.294
4, 4a	31.2	33.7	21.6	6.9	14.6	39.8	-0.671
4T, 4aT	22.6	13.2	24.1	24.4	22.7	36.5	-0.671
5, 5a, 7, 7a	43.6	33.2	32.8	9.5	37.6	54.0	-0.931
5T, 5aT, 7T, 7aT	30.4	9.9	45.5	22.1	47.7	46.2	-1.71

- NOTES:
- (1) Allowable Reinforcing Steel Stress = 54 KSI
  - (2) Allowable Concrete Compressive Stress = 3.4 KSI
  - (3) "+" for Tensile Stress; "-" for Compressive Stress
  - (4) Load Combination Equations are taken from Table 3A-14, 4T, 4aT, 5T, 5aT, 7T, 7aT include thermal components.
  - (5) Values reflect analysis with an initial Drywell air temperature of 135°F. Increasing this temperature to 150°F does not adversely impact the results of this Design Assessment Report.

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
CONTAINMENT STRESSES  
DRYWELL WALL**

FIGURE 3A-366

Rev. 12 9/04



DRYWELL WALL  
SECTIONS: 6

Load Combination Equation (4)	MAXIMUM REBAR STRESSES, KSI (1) (3)						Max. Concrete Stress, KSI (2) (3)
	INNER		OUTER			Transverse Ties	
	Vert	Hoop	Vert	Hoop	Diag.		
1	-1.2	1.08	-0.76	1.7	0.63	0.161	-0.99
3, 6	16.9	17.7	16.5	4.8	20.6	0.52	-0.361
4, 4a	31.1	39.6	26.8	9.2	18.6	43.7	-0.582
4T, 4aT	26.0	48.7	26.7	8.1	28.2	35.0	-0.718
5, 5a, 7, 7a	50.1	43.1	36.0	12.9	45.7	44.8	-1.009
5T, 5aT, 7T, 7aT	24.9	48.8	53.9	26.7	47.6	27.5	-1.592

- NOTES:
- (1) Allowable Reinforcing Steel Stress = 54 KSI
  - (2) Allowable Concrete Compressive Stress = 3.4 KSI
  - (3) "+" for Tensile Stress; "-" for Compressive Stress
  - (4) Load Combination Equations are taken from Table 3A-14, 4T, 4aT, 5T, 5aT, 7T, 7aT include thermal components.
  - (5) Values reflect analysis with an initial Drywell air temperature of 135°F. Increasing this temperature to 150°F does not adversely impact the results of this Design Assessment Report.

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
CONTAINMENT STRESSES  
WETWELL WALL**

FIGURE 3A-367

Rev. 12 9/04

DRYWELL WALL  
SECTIONS: 7, 8, 9

Load Combination Equation (4)	MAXIMUM REBAR STRESSES, KSI (1) (3)						Max. Concrete Stress, KSI (2) (3)
	INNER		OUTER			Transverse Ties	
	Vert	Hoop	Vert	Hoop	Diag.		
1	-1.36	9.7	-1.4	4.8	2.09	0.89	-0.210
3, 6	25.5	20.3	23.3	6.8	28.4	5.3	-0.427
4, 4a	14.8	38.4	26.8	25.5	26.2	13.6	-0.616
4T, 4aT	12.8	46.2	34.6	33.0	33.8	14.0	-1.31
5, 5a, 7, 7a	37.7	37.0	47.9	21.8	48.6	15.2	-0.819
5T, 5aT, 7T, 7aT	33.2	41.0	50.0	46.3	53.9	17.3	-2.12

- NOTES:
- (1) Allowable Reinforcing Steel Stress = 54 KSI
  - (2) Allowable Concrete Compressive Stress = 3.4 KSI
  - (3) "+" for Tensile Stress; "-" for Compressive Stress
  - (4) Load Combination Equations are taken from Table 3A-14, 4T, 4aT, 5T, 5aT, 7T, 7aT include thermal components.
  - (5) Values reflect analysis with an initial Drywell air temperature of 135°F. Increasing this temperature to 150°F does not adversely impact the results of this Design Assessment Report.

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
CONTAINMENT STRESSES  
WETWELL WALL**

FIGURE 3A-368

Rev. 12 9/04

DRYWELL WALL  
SECTIONS: 10

Load Combination Equation (4)	MAXIMUM REBAR STRESSES, KSI (1) (3)						Max. Concrete Stress, KSI (2) (3)
	INNER		OUTER			Transverse Ties	
	Vert	Hoop	Vert	Hoop	Diag.		
1	-1.68	15.8	-1.5	7.4	3.35	1.1	-0.254
3, 6	27.5	30.7	25.5	7.58	31.1	0.70	-0.503
4, 4a	16.6	42.4	29.1	35.3	31.4	5.3	-0.744
4T, 4aT	12.2	35.6	38.0	39.7	37.9	8.13	-1.50
5, 5a, 7, 7a	37.5	40.1	43.6	27.5	50.1	6.7	-1.13
5T, 5aT, 7T, 7aT	29.4	46.7	53.8	35.6	52.4	7.4	-2.25

- NOTES:
- (1) Allowable Reinforcing Steel Stress = 54 KSI
  - (2) Allowable Concrete Compressive Stress = 3.4 KSI
  - (3) "+" for Tensile Stress; "-" for Compressive Stress
  - (4) Load Combination Equations are taken from Table 3A-14, 4T, 4aT, 5T, 5aT, 7T, 7aT include thermal components.
  - (5) Values reflect analysis with an initial Drywell air temperature of 135°F. Increasing this temperature to 150°F does not adversely impact the results of this Design Assessment Report.

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
CONTAINMENT STRESSES  
WETWELL WALL**

FIGURE 3A-369

Rev. 12 9/04

DRYWELL WALL  
SECTIONS: 11

Load Combination Equation (4)	MAXIMUM REBAR STRESSES, KSI (1) (3)						Max. Concrete Stress, KSI (2) (3)
	INNER		OUTER			Transverse Ties	
	Vert	Hoop	Vert	Hoop	Diag.		
1	-1.57	4.95	-1.5	2.96	1.16	2.81	-0.233
3, 6	29.8	21.2	27.1	8.48	34.3	15.3	-0.527
4, 4a	38.1	35.5	33.2	6.48	20.3	42.9	-0.703
4T, 4aT	36.1	18.5	38.2	11.2	25.1	44.5	-0.990
5, 5a, 7, 7a	53.9	32.9	46.0	9.0	45.0	45.0	-1.04
5T, 5aT, 7T, 7aT	47.2	40.6	51.2	17.0	47.4	45.4	-1.69

- NOTES:
- (1) Allowable Reinforcing Steel Stress = 54 KSI
  - (2) Allowable Concrete Compressive Stress = 3.4 KSI
  - (3) "+" for Tensile Stress; "-" for Compressive Stress
  - (4) Load Combination Equations are taken from Table 3A-14, 4T, 4aT, 5T, 5aT, 7T, 7aT include thermal components.
  - (5) Values reflect analysis with an initial Drywell air temperature of 135°F. Increasing this temperature to 150°F does not adversely impact the results of this Design Assessment Report.

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
CONTAINMENT STRESSES  
WETWELL WALL**

FIGURE 3A-370

Rev. 12 9/04

DRYWELL WALL  
SECTIONS: 12

Load Combination Equation (4)	MAXIMUM REBAR STRESSES, KSI (1) (3)					Max. Concrete Stress, KSI (2) (3)
	INNER PLATE		OUTER PLATE		Transverse Ties	
	Vert	Hoop	Vert	Hoop		
1	0.39	3.6	-0.11	1.2	1.0	-0.071
3, 6	7.1	8.7	2.1	2.9	1.4	-0.293
4, 4a	2.2	9.2	-0.64	3.7	7.5	-0.265
4T, 4aT	2.0	8.8	0.81	3.3	7.5	-0.265
5, 5a, 7, 7a	8.5	12.8	2.7	5.1	9.5	-0.407
5T, 5aT, 7T, 7aT	8.3	12.4	2.5	4.7	9.5	-0.407

- NOTES:
- (1) Allowable Reinforcing Steel Stress = 54 KSI
  - (2) Allowable Concrete Compressive Stress = 3.4 KSI
  - (3) "+" for Tensile Stress; "-" for Compressive Stress
  - (4) Load Combination Equations are taken from Table 3A-14, 4T, 4aT, 5T, 5aT, 7T, 7aT include thermal components.
  - (5) Values reflect analysis with an initial Drywell air temperature of 135°F. Increasing this temperature to 150°F does not adversely impact the results of this Design Assessment Report.

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
CONTAINMENT STRESSES  
SHIELD WALL**

FIGURE 3A-371

Rev. 12 9/04

DRYWELL WALL  
SECTIONS: 13

Load Combination Equation (4)	MAXIMUM REBAR STRESSES, KSI (1) (3)					Max. Concrete Stress, KSI (2) (3)
	INNER PLATE		OUTER PLATE		Transverse Ties	
	Vert	Hoop	Vert	Hoop		
1	-0.28	0.08	-0.57	-0.10	0.128	-0.077
3, 6	9.7	3.5	2.9	1.1	0.63	-0.404
4, 4a	-0.65	0.29	-0.94	-0.15	0.26	-0.128
4T, 4aT	-1.45	-1.73	-0.53	1.03	0.26	-0.128
5, 5a, 7, 7a	10.7	3.6	2.9	1.1	2.4	-0.444
5T, 5aT, 7T, 7aT	9.9	1.9	3.3	2.1	2.4	-0.444

- NOTES:
- (1) Allowable Reinforcing Steel Stress = 54 KSI
  - (2) Allowable Concrete Compressive Stress = 3.4 KSI
  - (3) "+" for Tensile Stress; "-" for Compressive Stress
  - (4) Load Combination Equations are taken from Table 3A-14, 4T, 4aT, 5T, 5aT, 7T, 7aT include thermal components.
  - (5) Values reflect analysis with an initial Drywell air temperature of 135°F. Increasing this temperature to 150°F does not adversely impact the results of this Design Assessment Report.

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
CONTAINMENT STRESSES  
SHIELD WALL**

FIGURE 3A-372

Rev. 12 9/04

DRYWELL WALL  
SECTIONS: 14

Load Combination Equation (4)	MAXIMUM REBAR STRESSES, KSI (1) (3)					Max. Concrete Stress, KSI (2) (3)
	INNER		OUTER		Transverse Ties	
	Radial	Hoop	Radial	Hoop		
1	-1.0	1.0	-1.2	1.2	0.34	-0.157
3, 6	17.2	13.4	29.2	17.4	3.9	-0.352
4, 4a	-1.3	2.4	-1.7	2.0	0.31	-0.230
4T, 4aT	7.98	7.0	-2.31	4.97	0.31	-0.230
5, 5a, 7, 7a	17.2	14.7	25.6	17.2	3.3	-0.432
5T, 5aT, 7T, 7aT	25.7	19.3	25.0	20.2	3.3	-0.432

- NOTES:
- (1) Allowable Reinforcing Steel Stress = 54 KSI
  - (2) Allowable Concrete Compressive Stress = 3.4 KSI
  - (3) "+" for Tensile Stress; "-" for Compressive Stress
  - (4) Load Combination Equations are taken from Table 3A-14, 4T, 4aT, 5T, 5aT, 7T, 7aT include thermal components.
  - (5) Values reflect analysis with an initial Drywell air temperature of 135°F. Increasing this temperature to 150°F does not adversely impact the results of this Design Assessment Report.

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
CONTAINMENT STRESSES  
RPV PEDESTAL**

FIGURE 3A-373

Rev. 12 9/04

DRYWELL WALL  
SECTIONS: 15

Load Combination Equation (4)	MAXIMUM REBAR STRESSES, KSI (1) (3)					Max. Concrete Stress, KSI (2) (3)
	INNER		OUTER		Transverse Ties	
	Radial	Hoop	Radial	Hoop		
1	-1.5	0.94	-2.2	0.32	0.35	-0.290
3, 6	43.9	27.2	52.5	33.6	4.7	-0.649
4, 4a	4.5	32.2	6.1	47.0	21.1	-0.474
4T, 4aT	14.5	-4.8	4.9	-5.9	48.3	-0.910
5, 5a, 7, 7a	52.9	50.1	52.9	51.8	39.4	-0.856
5T, 5aT, 7T, 7aT	49.9	8.2	51.9	-4.0	27.4	-1.017

- NOTES:
- (1) Allowable Reinforcing Steel Stress = 54 KSI
  - (2) Allowable Concrete Compressive Stress = 3.4 KSI
  - (3) "+" for Tensile Stress; "-" for Compressive Stress
  - (4) Load Combination Equations are taken from Table 3A-14, 4T, 4aT, 5T, 5aT, 7T, 7aT include thermal components.
  - (5) Values reflect analysis with an initial Drywell air temperature of 135°F. Increasing this temperature to 150°F does not adversely impact the results of this Design Assessment Report.

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
CONTAINMENT STRESSES  
RPV PEDESTAL**

FIGURE 3A-374

Rev. 12 9/04



DRYWELL WALL  
SECTIONS: 16

Load Combination Equation (4)	MAXIMUM REBAR STRESSES, KSI (1) (3)					Max. Concrete Stress, KSI (2) (3)
	INNER		OUTER		Transverse Ties	
	Radial	Hoop	Radial	Hoop		
1	-1.5	1.1	-2.0	3.1	0.34	-0.266
3, 6	30.3	13.02	39.4	29.1	0.86	-0.526
4, 4a	6.9	12.6	4.8	30.4	7.9	-0.678
4T, 4aT	13.3	13.3	5.7	28.0	15.0	-1.051
5, 5a, 7, 7a	45.0	26.1	42.7	36.8	19.6	-0.931
5T, 5aT, 7T, 7aT	37.3	16.0	22.7	15.5	27.9	-1.249

- NOTES:
- (1) Allowable Reinforcing Steel Stress = 54 KSI
  - (2) Allowable Concrete Compressive Stress = 3.4 KSI
  - (3) "+" for Tensile Stress; "-" for Compressive Stress
  - (4) Load Combination Equations are taken from Table 3A-14, 4T, 4aT, 5T, 5aT, 7T, 7aT include thermal components.
  - (5) Values reflect analysis with an initial Drywell air temperature of 135°F. Increasing this temperature to 150°F does not adversely impact the results of this Design Assessment Report.

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
CONTAINMENT STRESSES  
RPV PEDESTAL**

FIGURE 3A-375

Rev. 12 9/04

DRYWELL WALL  
SECTIONS: 17, 18

Load Combination Equation (4)	MAXIMUM REBAR STRESSES, KSI (1) (3)				Transverse Ties	Max. Concrete Stress, KSI (2) (3)
	INNER		OUTER			
	Radial	Hoop	Radial	Hoop		
1	-2.1	5.0	-2.7	12.9	9.0	-0.382
3, 6	9.9	8.5	10.5	17.0	12.9	-0.690
4, 4a	-4.1	11.9	-4.8	28.3	17.0	-0.681
4T, 4aT	4.13	13.8	-4.3	28.9	26.8	-0.635
5, 5a, 7, 7a	18.6	15.7	20.5	29.8	22.5	-1.017
5T, 5aT, 7T, 7aT	23.0	22.1	22.0	32.6	38.9	-0.968

- NOTES:
- (1) Allowable Reinforcing Steel Stress = 54 KSI
  - (2) Allowable Concrete Compressive Stress = 3.4 KSI
  - (3) "+" for Tensile Stress; "-" for Compressive Stress
  - (4) Load Combination Equations are taken from Table 3A-14, 4T, 4aT, 5T, 5aT, 7T, 7aT include thermal components.
  - (5) Values reflect analysis with an initial Drywell air temperature of 135°F. Increasing this temperature to 150°F does not adversely impact the results of this Design Assessment Report.

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
CONTAINMENT STRESSES  
RPV PEDESTAL**

FIGURE 3A-376

Rev. 12 9/04

DRYWELL WALL  
SECTIONS: 19, 20

Load Combination Equation (4)	MAXIMUM REBAR STRESSES, KSI (1)(3)					Max. Concrete Stress, KSI (2)(3)
	INNER		OUTER		Transverse Ties	
	Radial	Hoop	Radial	Hoop		
1	-2.01	-0.176	-2.95	0.27	0.59	-0.424
3, 6	17.9	5.26	11.8	5.4	4.7	-0.483
4, 4a	4.86	3.69	-5.2	7.1	5.68	-0.744
4T, 4aT	5.2	-6.1	-5.39	-4.8	5.68	-0.744
5, 5a, 7, 7a	25.9	7.2	32.5	12.8	15.9	-0.851
5T, 5aT, 7T, 7aT	26.2	-5.8	32.3	8.2	15.9	-0.851

- NOTES:
- (1) Allowable Reinforcing Steel Stress = 54 KSI
  - (2) Allowable Concrete Compressive Stress = 3.4 KSI
  - (3) "+" for Tensile Stress; "-" for Compressive Stress
  - (4) Load Combination Equations are taken from Table 3A-14, 4T, 4aT, 5T, 5aT, 7T, 7aT include thermal components.
  - (5) Values reflect analysis with an initial Drywell air temperature of 135°F. Increasing this temperature to 150°F does not adversely impact the results of this Design Assessment Report.

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
CONTAINMENT STRESSES  
RPV PEDESTAL**

FIGURE 3A-377

Rev. 12 9/04

DRYWELL WALL  
SECTIONS: 21

Load Combination Equation (4)	MAXIMUM REBAR STRESSES, KSI (1) (3)					Max. Concrete Stress, KSI (2) (3)
	INNER		OUTER		Transverse Ties	
	Radial	Hoop	Radial	Hoop		
1	-	-	-	-	-	-
3, 6	8.5	8.6	6.9	7.7	1.01	-0.073
4, 4a	38.8	30.2	28.9	22.7	8.8	-0.374
4T, 4aT	32.8	21.6	35.9	27.6	9.5	-1.82
5, 5a, 7, 7a	35.6	30.1	29.3	23.3	8.8	-0.365
5T, 5aT, 7T, 7aT	31.7	21.5	34.6	28.0	8.9	-1.83

- NOTES:
- (1) Allowable Reinforcing Steel Stress = 54 KSI
  - (2) Allowable Concrete Compressive Stress = 3.4 KSI
  - (3) "+" for Tensile Stress; "-" for Compressive Stress
  - (4) Load Combination Equations are taken from Table 3A-14, 4T, 4aT, 5T, 5aT, 7T, 7aT include thermal components.
  - (5) Values reflect analysis with an initial Drywell air temperature of 135°F. Increasing this temperature to 150°F does not adversely impact the results of this Design Assessment Report.

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
CONTAINMENT STRESSES  
DIAPHRAGM SLAB**

FIGURE 3A-378

Rev. 12 9/04

DRYWELL WALL  
SECTIONS: 22, 23

Load Combination Equation (4)	MAXIMUM REBAR STRESSES, KSI (1) (3)					Max. Concrete Stress, KSI (2) (3)
	INNER		OUTER		Transverse Ties	
	Radial	Hoop	Radial	Hoop		
1	-	-	-	-	-	-
3, 6	7.9	9.5	10.2	13.0	4.46	-0.370
4, 4a	14.1	21.5	18.4	24.2	16.1	-0.383
4T, 4aT	-11.1	12.3	26.2	29.8	7.0	-1.367
5, 5a, 7, 7a	16.4	23.1	23.7	27.9	18.0	-0.623
5T, 5aT, 7T, 7aT	-13.1	16.0	25.5	35.9	7.2	-1.727

- NOTES:
- (1) Allowable Reinforcing Steel Stress = 54 KSI
  - (2) Allowable Concrete Compressive Stress = 3.4 KSI
  - (3) "+" for Tensile Stress; "-" for Compressive Stress
  - (4) Load Combination Equations are taken from Table 3A-14, 4T, 4aT, 5T, 5aT, 7T, 7aT include thermal components.
  - (5) Values reflect analysis with an initial Drywell air temperature of 135°F. Increasing this temperature to 150°F does not adversely impact the results of this Design Assessment Report.

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
CONTAINMENT STRESSES  
DIAPHRAGM SLAB**

FIGURE 3A-379

Rev. 12 9/04

DRYWELL WALL  
SECTIONS: 24

Load Combination Equation (4)	MAXIMUM REBAR STRESSES, KSI (1) (3)					Max. Concrete Stress, KSI (2) (3)
	INNER		OUTER		Transverse Ties	
	Radial	Hoop	Radial	Hoop		
1	-	-	-	-	-	-
3, 6	10.2	9.6	9.1	8.0	3.0	-0.272
4, 4a	22.8	22.6	30.5	21.1	5.9	-0.842
4T, 4aT	-8.61	-8.29	33.2	29.4	4.2	-1.59
5, 5a, 7, 7a	27.9	25.4	33.4	24.4	6.2	-0.931
5T, 5aT, 7T, 7aT	-10.3	12.3	35.5	30.8	4.9	-1.738

- NOTES:
- (1) Allowable Reinforcing Steel Stress = 54 KSI
  - (2) Allowable Concrete Compressive Stress = 3.4 KSI
  - (3) "+" for Tensile Stress; "-" for Compressive Stress
  - (4) Load Combination Equations are taken from Table 3A-14, 4T, 4aT, 5T, 5aT, 7T, 7aT include thermal components.
  - (5) Values reflect analysis with an initial Drywell air temperature of 135°F. Increasing this temperature to 150°F does not adversely impact the results of this Design Assessment Report.

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
CONTAINMENT STRESSES  
DIAPHRAGM SLAB**

FIGURE 3A-380

Rev. 12 9/04

DIAPHRAGM SLAB  
SECTION: 25

Load Combination Equations (4)	MAXIMUM REBAR STRESSES, KSI (1)(3)					Max. Concrete Stress, KSI (2)(3)
	INNER		OUTER		Transverse Ties	
	Radial	Hoop	Radial	Hoop		
1	-	-	-	-	-	-
3, 6	13.0	15.5	12.1	14.5	0.66	-.157
4, 4a	26.7	28.0	23.5	30.6	9.9	-.336
4T, 4aT	12.9	24.0	26.1	35.4	6.5	-2.04
5, 5a, 7, 7a	33.6	38.5	28.6	35.9	10.4	-.423
5T, 5aT, 7T, 7aT	19.3	31.8	41.1	42.4	9.5	-2.40

- NOTES: (1) Allowable Reinforcing Steel Stress = 54 KSI  
(2) Allowable Concrete Compressive Stress = 3.4 KSI  
(3) "+" for Tensile Stress; "-" for Compressive Stress  
(4) Load Combination Equations are taken from Table 3A-14, 4T, 4aT, 5T, 5aT, 7T, 7aT include thermal components.

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
CONTAINMENT STRESSES  
DIAPHRAGM SLAB**

**FIGURE 3A-381**

BASE SLAB  
SECTION: 26

Load Combination Equations (4)	MAXIMUM REBAR STRESSES, KSI (1)(3)					Max. Concrete Stabs, KSI (2)(3)
	INNER		OUTER		Transverse Ties	
	Radial	Hoop	Radial	Hoop		
1	-	-	-	-	-	-
3, 6	1.7	16.6	5.93	6.22	5.29	-0.318
4, 4a	2.72	1.61	7.10	3.29	0.43	-0.213
4T, 4aT	-5.21	-5.63	15.2	14.9	3.4	-1.21
5, 5a, 7, 7a	10.9	20.7	10.4	9.51	4.03	-0.443
5T, 5aT, 7T, 7aT	-6.36	-4.95	18.4	17.3	3.12	-1.34

- NOTES: (1) Allowable Reinforcing Steel Stress = 54 KSI  
(2) Allowable Concrete Compressive Stress = 3.4 KSI  
(3) "+" for Tensile Stress; "-" for Compressive Stress  
(4) Load Combination Equations are taken from Table 3A-14 ,  
4T, 4aT, 5T, 5aT, 7T, 7aT include thermal components.

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
CONTAINMENT STRESSES  
BASE SLAB**

**FIGURE 3A-382**



BASE SLAB  
SECTION: 27

Load Combination Equations (4)	MAXIMUM REBAR STRESSES, KSI (1)(3)					Max. Concrete Stress, KSI (2)(3)
	INNER		OUTER		Transverse Ties	
	Radial	Hoop	Radial	Hoop		
1	-	-	-	-	-	-
3, 6	25.4	26.8	15.5	6.43	24.7	-0.479
4, 4a	10.3	-0.43	11.1	0.65	23.9	-0.309
4T, 4aT	22.4	-7.3	29.8	13.3	33.1	-1.70
5, 5a, 7, 7a	39.8	34.4	29.3	13.9	41.0	-0.540
5T, 5aT, 7T, 7aT	30.0	20.2	29.0	17.1	39.8	-1.79

- NOTES: (1) Allowable Reinforcing Steel Stress = 54 KSI
- (2) Allowable Concrete Compressive Stress = 3.4 KSI
- (3) "+" for Tensile Stress; "-" for Compressive Stress
- (4) Load Combination Equations are taken from Table 3A-14, 4T, 4aT, 5T, 5aT, 7T, 7aT include thermal components.

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
CONTAINMENT STRESSES  
BASE SLAB**

**FIGURE 3A-383**

BASE SLAB  
SECTION: 28

Load Combination Equations (4)	MAXIMUM REBAR STRESSES, KSI (1)(3)					Max. Concrete Stress, KSI (2)(3)
	INNER		OUTER		Transverse Ties	
	Radial	Hoop	Radial	Hoop		
1	-	-	-	-	-	-
3, 6	34.0	17.8	11.1	10.6	17.5	-0.910
4, 4a	21.7	9.15	16.9	8.7	12.5	-0.304
4T, 4aT	-8.25	-8.07	17.7	13.4	6.7	-1.59
5, 5a, 7, 7a	42.1	21.2	18.2	16.1	25.2	-0.985
5T, 5aT, 7T, 7aT	25.4	-8.4	23.7	19.8	18.7	-1.72

- NOTES: (1) Allowable Reinforcing Steel Stress = 54 KSI  
(2) Allowable Concrete Compressive Stress = 3.4 KSI  
(3) "+" for Tensile Stress; "-" for Compressive Stress  
(4) Load Combination Equations are taken from Table 3A-14 , 4T, 4aT, 5T, 5aT, 7T, 7aT include thermal components.

LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
CONTAINMENT STRESSES  
BASE SLAB

FIGURE 3A-384

BASE SLAB  
SECTION: 29

Load Combination Equations (4)	MAXIMUM REBAR STRESSES, KSI (1)(3)					Max. Concrete Stress, KSI (2)(3)
	INNER		OUTER		Transverse Ties	
	Radial	Hoop	Radial	Hoop		
1	-	-	-	-	-	-
3, 6	12.7	15.6	9.01	8.52	11.1	-0.524
4, 4a	11.8	9.51	17.3	7.95	11.0	-0.243
4T, 4aT	9.32	-6.40	20.6	12.6	12.0	-1.23
5, 5a, 7, 7a	17.7	18.9	19.0	13.3	18.5	-0.508
5T, 5aT, 7T, 7aT	14.4	-6.22	21.5	16.1	18.9	-1.18

- NOTES: (1) Allowable Reinforcing Steel Stress = 54 KSI  
(2) Allowable Concrete Compressive Stress = 3.4 KSI  
(3) "+" for Tensile Stress; "-" for Compressive Stress  
(4) Load Combination Equations are taken from Table 3A-14, 4T, 4aT, 5T, 5aT, 7T, 7aT include thermal components.

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
CONTAINMENT STRESSES  
BASE SLAB**

**FIGURE 3A-385**

BASE SLAB  
SECTION: 30

Load Combination Equations (4)	MAXIMUM REBAR STRESSES, KSI (1)(3)					Max. Concrete Stress, KSI (2)(3)
	INNER		OUTER		Transverse Ties	
	Radial	Hoop	Radial	Hoop		
1	-	-	-	-	-	-
3, 6	9.32	16.9	9.14	8.54	7.0	-0.414
4, 4a	29.9	33.5	34.1	10.2	25.6	-0.430
4T, 4aT	29.2	5.5	38.5	12.9	27.4	-0.902
5, 5a, 7, 7a	23.9	36.5	32.9	16.6	28.4	-0.688
5T, 5aT, 7T, 7aT	22.5	-6.36	36.5	19.6	28.9	-0.915

- NOTES: (1) Allowable Reinforcing Steel Stress = 54 KSI
- (2) Allowable Concrete Compressive Stress = 3.4 KSI
- (3) "+" for Tensile Stress; "-" for Compressive Stress
- (4) Load Combination Equations are taken from Table 3A-14 ,  
4T, 4aT, 5T, 5aT, 7T, 7aT include Thermal Components.


**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
CONTAINMENT STRESSES  
BASE SLAB**


**FIGURE 3A-386**



MODE 1  
f=20 HZ



MODE 2  
f=53 HZ



MODE 3  
f=93 HZ

(WITH WATER MASS)

LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
SUPPRESSION CHAMBER  
COLUMNS MODE SHAPES

FIGURE 3A-387


SUPPRESSION CHAMBER COLUMNS

COLUMN	MAXIMUM AXIAL STRESS (KSI)	ALLOWABLE AXIAL STRESS (KSI)	MAXIMUM FLEXURAL STRESS (KSI)	ALLOWABLE FLEXURAL STRESS (KSI)	COMBINED STRESS RATIO	STRESS MARGIN %
42" dia pipe (shell element)	11.7	27.3	8.7	28.0	0.74	26
Top Anchorage	22.6	29.9	-	-	0.76	24
Bottom Anchorage	-	-	-	-	-	10

NOTE: These stress margins are based on load combination 7 of Table 3A-15 which is the critical load combination.

**LIMERICK GENERATING STATION**  
**UNITS 1 AND 2**  
**UPDATED FINAL SAFETY ANALYSIS REPORT**  
**DESIGN ASSESSMENT REPORT**  
**SUPPRESSION CHAMBER**  
**COLUMNS DESIGN MARGIN**


**FIGURE 3A-388**



LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
 DOWNCOMER MODE SHAPES,  
 $K = 50 \text{ k/in}$

FIGURE 3A-389




**LIMERICK GENERATING STATION**  
**UNITS 1 AND 2**  
**UPDATED FINAL SAFETY ANALYSIS REPORT**

---

**DESIGN ASSESSMENT REPORT**  
**DOWNCOMER MODE SHAPES,**  
 **$K = 350k/in$**

**FIGURE 3A-390**





LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
 DOWNCOMER MODE SHAPES,  
 $K = 15000 \text{ k/in}$

FIGURE 3A-391

DOWNCOMER - STRESS SUMMARY AND DESIGN MARGINS

LOAD COMBINATION	CONDITION	ALLOWABLE STRESS (KSI)	STRESS (KSI)	DESIGN MARGIN (%)
Equation 1	Upset	28.4	17.5	38.4
Equation 2	Emergency	42.5	19.9	53.2
Equation 3	Emergency	42.5	37.4	12.0
Equation 4	Faulted	56.7	20.0	64.7
Equation 5	Faulted	56.7	37.4	34.0
Equation 6	Faulted	56.7	37.5	33.9
Equation 7	Faulted	56.7	24.5	56.8

NOTE: Equation numbers are based on Table 3A-17.

LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
DOWNCOMER DESIGN MARGIN

FIGURE 3A-392

**USAGE FACTOR SUMMARY OF DOWNCOMERS**

LOADS	NORMAL/UPSET CONDITION				EMERGENCY/FAULTED CONDITIONS			CUMULATIVE USAGE
	± OBE ± SRV <sub>1</sub> ± SRV <sub>2</sub>	± SRV <sub>1</sub> ± SRV <sub>2</sub> ± CHUG	± SRV <sub>1</sub> ± SRV <sub>2</sub>	± SRV <sub>1</sub>	SBA o PRESSURE o THERMAL TRANSIENT o STEAM FLOW ± CHUG ± SRV <sub>1</sub> ± SRV <sub>2</sub>	IBA OR SBA o PRESSURE o THERMAL TRANSIENT o STEAM FLOW ± CHUG ± SRV <sub>1</sub> ± SRV <sub>2</sub> ± SSE	DBA o PRESSURE o THERMAL TRANSIENT o STEAM FLOW ± CHUG ± SSE	
AT PLATFORM RING	0.001	0.600	0.116	0.080	0.003			0.80
AT 24" x 24" VACUUM BREAKER TEE	0.002	0.194	0.160	0.151	0.001			0.51
AT PIPE ATTACHMENT <sup>(1)</sup> ELEV. 221'-0"	0.001	0.545	0.078	0.071	0.003			0.70

<sup>(1)</sup> ORIGINAL LOCATION OF VACUUM BREAKER (ABANDONED)

**LIMERICK GENERATING STATION**  
**UNITS 1 AND 2**  
**UPDATED FINAL SAFETY ANALYSIS REPORT**  
**DESIGN ASSESSMENT REPORT**  
**DOWNCOMER FATIGUE**  
**USAGE FACTOR**

**FIGURE 3A-393**

STRESS CYCLES FOR FATIGUE EVALUATION OF DOWNCOMERS

LOAD TYPE	No. OF CYCLES
NSRV1	14100
NSRV2	7700
NOBE	50
NCHUG	3000
NSSE	10








NOBE = Cycles associated with OBE  
NSRV1 = Cycles associated with SRV<sub>1</sub> (Submerged Structure Load)  
NSRV2 = Cycles associated with SRV<sub>2</sub> (Inertia)  
NCHUG = Cycles associated with Chugging  
NSSE = Cycles associated with SSE

LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
DOWNCOMER FATIGUE CYCLES

FIGURE 3A-394

FATIGUE LOAD HISTOGRAM FOR DOWNCOMERS

NORMAL/UPSET CONDITION				EMERGENCY	FAULTED	
				SBA	IBA or SBA	DBA
+ OBE	+ SRV <sub>1</sub>	+ SRV <sub>1</sub>	+ SRV <sub>1</sub>	° Pressure	° Pressure	° Pressure
+ SRV <sub>1</sub>	+ SRV <sub>2</sub>	+ SRV <sub>2</sub>		° Thermal	° Thermal	° Thermal
+ SRV <sub>2</sub>	+ CHUG			° Transient	° Transient	° Transient
				° Steam Flow	° Steam Flow	° Steam Flow
				+ CHUG	+ CHUG	+ CHUG
				+ SRV <sub>1</sub>	+ SRV <sub>1</sub>	+ SSE
				+ SRV <sub>2</sub>	+ SRV <sub>2</sub>	
					+ SSE	
						
50 cycles	3000 cycles	4650 cycles	6400 cycles	Load set pair 9-10 is for one of the three above events which produce the largest combined stress.		
				The cycles associated with oscillatory loads combined with SSE are assumed conservatively to be 10.		

LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT  
 DESIGN ASSESSMENT REPORT  
 DOWNCOMER FATIGUE  
 HISTOGRAM


FIGURE 3A-395

○ Downcomer

● SRV Line

— 10"  $\phi$  pipe or equiv.

— 12"  $\phi$  pipe or equiv.



LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
DOWNCOMER BRACING  
MATHEMATICAL MODEL

FIGURE 3A-396

DOWNCOMER BRACING SYSTEM - STRESS SUMMARY

BRACING MEMBER DESIGN MARGINS FOR CRITICAL  
MEMBERS AND GOVERNING LOAD COMBINATION


<u>QUADRANT (2)</u>	<u>MEMBER (2)</u>	<u>EQUATION (1)</u>	<u>MARGIN - %</u>
1	58	7	5%
2	75	7	6%
3	126	7	5%
4	217	7	4%
Link between Quadrants	221	7	3%

- NOTES: (1) Equation number is based on Table 3A-15  
(2) Figure 3A-396 gives location reference

LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
DOWNCOMER BRACING SYSTEM  
DESIGN MARGIN

FIGURE 3A-397




**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
REACTOR ENCLOSURE & CONTROL  
STRUCTURE FLOOR PLAN AT  
ELEVATION 177 FT.**

**FIGURE 3A-398**






**LIMERICK GENERATING STATION**  
**UNITS 1 AND 2**  
**UPDATED FINAL SAFETY ANALYSIS REPORT**

---

**DESIGN ASSESSMENT REPORT**  
**REACTOR ENCLOSURE**  
**STEEL FRAMING PLAN**  
**EL. 201'**


**FIGURE 3A-399**



LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
 REACTOR ENCLOSURE  
 STEEL FRAMING PLAN  
 EL. 217'


FIGURE 3A-400



LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT


DESIGN ASSESSMENT REPORT  
 REACTOR ENCLOSURE  
 STEEL FRAMING PLAN  
 EL. 253'

FIGURE 3A-401



**LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT**  
  
**DESIGN ASSESSMENT REPORT  
 REACTOR ENCLOSURE  
 STEEL FRAMING PLAN  
 EL. 283'**


FIGURE 3A-402




LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
 REACTOR ENCLOSURE  
 STEEL FRAMING PLAN  
 EL. 313'


FIGURE 3A-403



**LIMERICK GENERATING STATION**  
**UNITS 1 AND 2**  
**UPDATED FINAL SAFETY ANALYSIS REPORT**  
  
**DESIGN ASSESSMENT REPORT**  
**REACTOR ENCLOSURE**  
**STEEL FRAMING PLAN**  
**EL. 331'**  
  
**FIGURE 3A-404**



**LIMERICK GENERATING STATION**  
**UNITS 1 AND 2**  
**UPDATED FINAL SAFETY ANALYSIS REPORT**  
  
**DESIGN ASSESSMENT REPORT**  
**REACTOR ENCLOSURE**  
**STEEL FRAMING PLAN**  
**EL. 352'**  
  
**FIGURE 3A-405**




LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT


DESIGN ASSESSMENT REPORT  
 CONTROL STRUCTURE  
 STEEL FRAMING PLAN  
 EL. 200'

FIGURE 3A-406






**LIMERICK GENERATING STATION**  
**UNITS 1 AND 2**  
**UPDATED FINAL SAFETY ANALYSIS REPORT**  
  
**DESIGN ASSESSMENT REPORT**  
**CONTROL STRUCTURE**  
**STEEL FRAMING PLAN**  
**EL. 217'**  
  
**FIGURE 3A-407**



LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT


DESIGN ASSESSMENT REPORT  
 CONTROL STRUCTURE  
 STEEL FRAMING PLAN  
 EL. 239'

FIGURE 3A-408



**LIMERICK GENERATING STATION**  
**UNITS 1 AND 2**  
**UPDATED FINAL SAFETY ANALYSIS REPORT**  
**DESIGN ASSESSMENT REPORT**  
**CONTROL STRUCTURE**  
**STEEL FRAMING PLAN**  
**EL. 254'**

FIGURE 3A-409




**LIMERICK GENERATING STATION**  
**UNITS 1 AND 2**  
**UPDATED FINAL SAFETY ANALYSIS REPORT**

---

**DESIGN ASSESSMENT REPORT**  
**CONTROL STRUCTURE**  
**STEEL FRAMING PLAN**  
**EL. 269'**

**FIGURE 3A-410**




**LIMERICK GENERATING STATION**  
**UNITS 1 AND 2**  
**UPDATED FINAL SAFETY ANALYSIS REPORT**

---


**DESIGN ASSESSMENT REPORT**  
**CONTROL STRUCTURE**  
**STEEL FRAMING PLAN**  
**EL. 289'**

---

**FIGURE 3A-411**



**LIMERICK GENERATING STATION**  
**UNITS 1 AND 2**  
**UPDATED FINAL SAFETY ANALYSIS REPORT**  
**DESIGN ASSESSMENT REPORT**  
**CONTROL STRUCTURE**  
**STEEL FRAMING PLAN**  
**EL. 304'**  
**FIGURE 3A-412**




**LIMERICK GENERATING STATION**  
**UNITS 1 AND 2**  
**UPDATED FINAL SAFETY ANALYSIS REPORT**

---

**DESIGN ASSESSMENT REPORT**  
**CONTROL STRUCTURE**  
**STEEL FRAMING PLAN**  
**EL. 332'**

**FIGURE 3A-413**




LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
 CONTROL STRUCTURE  
 STEEL FRAMING PLAN  
 EL. 350'

FIGURE 3A-414






LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT

---

DESIGN ASSESSMENT REPORT  
 CONTROL STRUCTURE  
 PLATFORMS  
 EL. 313'


---

FIGURE 3A-415




LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT  
 DESIGN ASSESSMENT REPORT  
 CONTROL STRUCTURE  
 PLATFORMS  
 EL. 322'

FIGURE 3A-416



LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT  
 DESIGN ASSESSMENT REPORT  
 CONTROL STRUCTURE  
 PLATFORMS  
 EL. 340'  
 FIGURE 3A-417




LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT


---

DESIGN ASSESSMENT REPORT  
 CONTROL STRUCTURE  
 PLATFORMS  
 EL. 350'

FIGURE 3A-418




**LIMERICK GENERATING STATION**  
**UNITS 1 AND 2**  
**UPDATED FINAL SAFETY ANALYSIS REPORT**  
**DESIGN ASSESSMENT REPORT**  
**REACTOR ENCLOSURE & CONTROL**  
**STRUCTURE VERTICAL AXIAL FORCES**  
**(X10<sup>3</sup> KIPS)**  
**OBE+SRV (2% DAMPING)**  
**FIGURE 3A-419**



**LIMERICK GENERATING STATION**  
**UNITS 1 AND 2**  
**UPDATED FINAL SAFETY ANALYSIS REPORT**


---

**DESIGN ASSESSMENT REPORT**  
**REACTOR ENCLOSURE & CONTROL**  
**STRUCTURE VERTICAL AXIAL FORCES**  
**( $\times 10^3$  KIPS)**  
**DBE+SRV+LOCA (5% DAMPING)**  
**FIGURE 3A-420**




**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
REACTOR ENCLOSURE & CONTROL  
STRUCTURE N-S SHEAR FORCES  
( $\times 10^3$  KIPS)  
OBE+SRV (2% DAMPING)  
FIGURE 3A-421**




**LIMERICK GENERATING STATION**  
**UNITS 1 AND 2**  
**UPDATED FINAL SAFETY ANALYSIS REPORT**  
 DESIGN ASSESSMENT REPORT  
**REACTOR ENCLOSURE & CONTROL**  
**STRUCTURE N-S SHEAR FORCES**  
**(X10<sup>3</sup> KIPS)**  
**DBE+LOCA+SRV (5% DAMPING)**  
**FIGURE 3A-422**






LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
 REACTOR ENCLOSURE & CONTROL  
 STRUCTURE N-S OVERTURNING  
 MOMENTS ( $\times 10^6$  K-FT)  
 OBE+SRV (2% DAMPING)  
 FIGURE 3A-423



LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT


DESIGN ASSESSMENT REPORT  
 REACTOR ENCLOSURE & CONTROL  
 STRUCTURE N-S OVERTURNING  
 MOMENTS (X10<sup>6</sup> K-FT)  
 DBE+LOCA+SRV (5% DAMPING)  
 FIGURE 3A-424



LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT


DESIGN ASSESSMENT REPORT  
 REACTOR ENCLOSURE & CONTROL  
 STRUCTURE E-W SHEAR FORCES  
 (X10<sup>3</sup> KIPS)  
 OBE+SRV (2% DAMPING)

FIGURE 3A-425



LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT


DESIGN ASSESSMENT REPORT  
 REACTOR ENCLOSURE & CONTROL  
 STRUCTURE E-W SHEAR FORCES  
 (X10<sup>3</sup> KIPS)  
 DBE+LOCA+SRV (5% DAMPING)  
 FIGURE 3A-426



LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
 REACTOR ENCLOSURE & CONTROL  
 STRUCTURE E-W OVERTURNING  
 MOMENTS (X10<sup>6</sup> K-FT)  
 OBE+SRV (2% DAMPING)

FIGURE 3A-427



**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
REACTOR ENCLOSURE & CONTROL  
STRUCTURE E-W OVERTURNING  
MOMENTS (X10<sup>6</sup> K-FT)  
DBE+LOCA+SRV (5% DAMPING)  
FIGURE 3A-428**

REACTOR ENCLOSURE FLOOR SLABS

ELEMENT NUMBER	ELEVATION (FT)	SLAB THICKNESS (FT)	GOVERNING EQUATION <sup>(1)</sup>	REBAR <sup>(2)</sup> STRESS (KSI)	STRESS MARGIN (%)
1	201	1.5	1	13.13	75.7
2	201	2.5	1	30.55	43.4
3	217	1.5	7a	30.90	42.8
4	217	2.0	7a	27.70	48.7
5	253	1.25	7a	51.26	5.1
6	253	2.0	1	20.40	62.2
7	283	1.25	7a	42.74	20.9
8	283	2.75	1	28.13	47.9
9	313	1.75	1	30.52	43.5
10	313	2.0	7a	23.83	55.9
11	313	3.0	7a	28.16	47.9
12	333	1.25	1	21.22	60.7
13	333	1.67	1	15.47	71.4
14	352	2.0	7a	36.35	32.7
15	352	3.25	7a	11.18	79.3

NOTES: (1) Taken from Table 3A-14 as follows:

Load Combination EQN 1 = 1.4D + 1.7L + 1.5 SRV  
 Load Combination EQN 7a = 1.0D + 1.0L + 1.0 ESS  
 + 1.0 SRV + 1.0 LOCA

(2) Allowable Reinforcing Steel Stress = 54 KSI

**LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
 REACTOR ENCLOSURE MARGINS  
 FLOOR SLABS**

**FIGURE 3A-429**

REACTOR ENCLOSURE FLOOR STEEL BEAM(1)

ELEMENT NUMBER	ELEVATION (FT)	STEEL SIZE	GOVERNING EQUATION <sup>(2)</sup>	BENDING STRESS (KSI)	STRESS MARGIN <sup>(3)</sup> %
16	201	W27 x 145	1	23.00	4.2
17	201	W24 x 68	1	20.00	16.7
18	217	W33 x 141	1	21.90	8.6
19	217	W33 x 130	7	27.40	15.5
20	253	W24 x 76	1	22.66	5.6
21	253	W27 x 84	1	20.92	12.8
22	283	72" Girder	1	24.00	0.
23	283	W33 x 152	1	19.27	19.7
24	313	56" Girder	7	30.28	6.5
25	313	W36 x 300	7	29.44	9.1
26	331	W36 x 182	7	23.58	27.2
27	331	W21 x 73	7	20.31	37.3
28	352	W36 x 300	7	18.54	42.7
29	352	W24 x 68	7	16.94	47.7

NOTES: (1) All beams are A-36 steel.

(2) Taken from Table 3A-15 as follows:

Load Combination EQN 1 = D + L + SRV

Load Combination EQN 7 = D + L + E<sup>1</sup> + SRV + LOCA

(3) Allowable Bending Stresses for Governing Equations 1 and 7 are 24.0 KSI and 32.4 KSI, respectively.

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
REACTOR ENCLOSURE MARGINS  
FLOOR STEEL BEAM**

**FIGURE 3A-430**



REACTOR ENCLOSURE SUPPORTING COLUMNS

ELEVATION RANGE	LOCATION(1)	MATERIALS(2)	INTERACTION EQUATION	STRESS MARGIN%
177'-201'	29 & E	Steel	0.77	23
177'-201'	30.5 & E	Reinforced Concrete	-	8
201'-217'	29 & E	Steel	0.78	22
201'-217'	30.5 & E	Reinforced Concrete	-	1
217'-253'	30.5 & E	Steel	1.02	0
253'-283'	30.5 & F	Steel	0.88	12
283'-313'	30.5 & E	Steel	0.78	22
313'-333'	27.5 & E	Steel	0.97	3
313'-333'	30.5 & E	Steel	0.91	9
333'-352'	29 & E	Steel	0.65	35

NOTES: (1) Figure **3A-398** gives location reference

(2) For Steel Supports, Load Combination EQN (7) of Table 5.3-1 is used:  $D + L + E + LOCA + SRV + P$ .

For Reinforced Concrete Supports, Load Combination EQN (7) of Table **3A-14** is used:  
 $D + L + E_O + LOCA + SRV + P_B$

**LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
 REACTOR ENCLOSURE MARGINS  
 SUPPORTING COLUMNS**

**FIGURE 3A-431**

REACTOR ENCLOSURE SHEAR WALLS

WALL ELEVATION (FT)	WALL MARK(1)	GOVERNING EQUATION(2)	COMBINED AXIAL & BENDING STRESS MARGIN (%) (3)	SHEAR STRESS MARGIN (%) (4)
177	Line 14.1	7a	67	1
177	Line 31.9	7a	67	1
177	D	7a	48	12
177	Line 23	7a	24	8
177	Line 21.5	7a	29	9

NOTES: (1) Figure 3A-398 gives location reference

(2) Taken from Table 3A-14 as follows:

Load Combination EQN 7a = D + L + Ess + SRV + LOCA

(3) Allowable Reinforcing Steel Stress = 54 KSI

(4) Allowable Reinforcing Steel Stress = 51 KSI

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
REACTOR ENCLOSURE MARGINS  
SHEAR WALLS**

**FIGURE 3A-432**

CONTROL STRUCTURE FLOOR SLABS

ELEMENT NUMBER	ELEVATION (FT)	SLAB THICKNESS (FT)	GOVERNING EQUATION(1)	REBAR STRESS(2) KSI	STRESS MARGIN (%)
30	200	1.5	1	14.47	73.2
31	200	6.0	1	37.64	30.3
32	217	1.25	1	14.15	73.8
33	237	1.0	1	31.10	42.4
34	237	1.0	1	30.89	42.8
35	254	1.0	1	27.86	48.4
36	269	1.5	1	12.15	77.5
37	289	1.5	1	10.26	81.0
38	304	1.0	1	22.95	57.5
39	332	1.5	1	16.92	68.7
40	332	2.0	1	41.4	23.3
41	350	1.5	1	16.65	69.2

NOTES: (1) Taken from Table 3A-14 as follows:

Load Combination EQN 1 = 1.4D + 1.7L + 1.5 SRV

(2) Allowable Reinforcing Steel Stress = 54 KSI

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
CONTROL STRUCTURE MARGINS  
FLOOR SLABS**

**FIGURE 3A-433**

CONTROL STRUCTURE FLOOR STEEL BEAM<sup>(1)</sup>

ELEMENT NUMBER	ELEVATION (FT)	STEEL SIZE	GOVERNING EQUATION(2)	BENDING STRESS (KSI)	STRESS MARGIN <sup>(3)</sup> %
42	200	W24 x 130	1	23.78	0.9
43	217	W30 x 210	7	29.90	7.7
44	237	W36 x 300	7	27.60	14.8
45	254	W36 x 245	7	28.80	11.1
46	269	42" Girder	7	25.53	21.2
47	289	W36 x 160	7	27.90	13.9
48	304	W36 x 194	7	30.00	7.4
49	332	38" Girder	7	24.80	23.5
50	350	W18 x 105	7	10.30	68.2

NOTES: (1) All beams are A-36 steel.

(2) Taken from Table 3A-15 as follows:

Load Combination EQN 1 = D + L + SRV

Load Combination EQN 7 = D + L + E' + SRV + LOCA

(3) Allowable bending stresses for governing equations 1 and 7 are 24.0 KSI and 32.4 KSI, respectively.

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
CONTROL STRUCTURE MARGINS  
FLOOR STEEL BEAM**

**FIGURE 3A-434**

CONTROL STRUCTURE SHEAR WALLS

WALL ELEVATION (FT)	WALL MARK	GOVERNING EQUATION(2)	COMBINED AXIAL & BENDING STRESS MARGIN (%) (3)	SHEAR STRESS MARGIN (%) (4)
177	Mh	7a	2	12
200	Mh	7a	39	2
269	J	1	44	24
239	J	1	48	19
177	Line 19.4	7a	23	0
239	Line 19.4	1	3.4	24
177	Line 26.6	7a	28	0

NOTES: (1) Figure 3A-398 gives location reference.

(2) Taken from Table 3A-14 as follows:

Load Combination EQN 1 = 1.4D + 1.7L + 1.5 SRV  
 Load Combination EQN 7a = 1.0D + 1.0L + 1.0 E<sub>SS</sub>  
 + 1.0 SRV + 1.0 LOCA

(3) Allowable Reinforcing Steel Stress = 54 KSI  
 Allowable Concrete Compressive Stress = 2.8 KSI

(4) Allowable Reinforcing Steel Stress = 51 KSI

**LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
 CONTROL STRUCTURE MARGINS  
 SHEAR WALLS**

FIGURE 3A-435

CONTROL STRUCTURE STEEL PLATFORM (1)

ELEMENT NUMBER	ELEVATION (FT)	STEEL GRADE	GOVERNING EQUATION(2)	BENDING STRESS (KSI)	STRESS MARGIN <sup>(3)</sup> (%)
51	313	W10x21	2	14.7	38.8
52	313	W12x27	2	18.9	21.3
53	322	W12x27	2	10.7	55.4
54	340	W8x24	2	10.0	58.3
55	350	W8x24	2	17.6	26.7
56	350	W10x54	2	10.6	55.8



- NOTES: (1) All beams are A-36 steel.  
 (2) Allowable bending stress = 24 KSI  
 (3) Taken from Table 3A-15 as follows:

Load Combination EQN 2 = D + L + To + SRV

**LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
 CONTROL STRUCTURE MARGINS  
 STEEL PLATFORM**

**FIGURE 3A-436**




NOTES:  
 1. FOR LEGEND AND GENERAL NOTES SEE DWG M-705  
 2. DISTANCE BETWEEN TWO REDUNDANT SENSORS (E.G. TE-101A & TE-101B) SHOULD BE AT LEAST 12" OR MORE.  
 3. APPROX. ELEV. OF SUPPRESSION POOL T.S. CONN. CENTER LINE IS 218'-5". FOR EXACT ELEV. SEE INSTALLATION DETAIL 80214-830-1079.

PLATFORM AT EL. 217'-0 1/2"  
 T.O.S. E. = 218'-10 1/2"  
 W. 1/2" x 3/8" GRATING

PLATFORM AT EL. 223'-4" U.N.O.  
 T.O.S. E. = 223'-2 1/2" U.N.O.  
 W. 1/2" x 3/8" GRATING TYP.

LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
 SUPPRESSION POOL  
 TEMPERATURE MONITORING  
 SYSTEM SENSOR LOCATIONS  
 FIGURE 3A-437




**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
PLAN VIEW OF MESH SYSTEM MODELING OF  
SUPPRESSION POOL FOR SRV-H HIGH AND  
LOW REACTOR PRESSURE BLOWDOWN  
(WITH SPTMS SENSOR LOCATIONS)**

**FIGURE 3A-438**



VIEW A-A OF FIGURE 3A-438




LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT


DESIGN ASSESSMENT REPORT  
 SECTION VIEW OF MESH SYSTEM MODELING OF  
 SUPPRESSION POOL FOR SRV-H HIGH  
 REACTOR PRESSURE BLOWDOWN  
 (WITH SPTMS SENSOR LOCATIONS)

FIGURE 3A-439

VIEW A-A OF FIGURE 3A-438



**LIMERICK GENERATING STATION**  
**UNITS 1 AND 2**  
**UPDATED FINAL SAFETY ANALYSIS REPORT**  
**DESIGN ASSESSMENT REPORT**  
**SECTION VIEW OF MESH SYSTEM MODELING OF**  
**SUPPRESSION POOL FOR SRV-H**  
**LOW REACTOR PRESSURE BLOWDOWN**  
**(WITH SPTMS SENSOR LOCATIONS)**  
**FIGURE 3A-440**




**LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT**

DESIGN ASSESSMENT REPORT


**PLAN VIEW OF MESH SYSTEM MODELING OF  
 SUPPRESSION POOL FOR SRV-L  
 HIGH REACTOR PRESSURE BLOWDOWN  
 (WITH SPTMS SENSOR LOCATIONS)**

FIGURE 3A-441

VIEW A-A OF FIGURE 3A-441




**LIMERICK GENERATING STATION**  
**UNITS 1 AND 2**  
**UPDATED FINAL SAFETY ANALYSIS REPORT**  
**DESIGN ASSESSMENT REPORT**  
**SECTION VIEW OF MESH**  
**SYSTEM MODELING OF SUPPRESSION**  
**POOL FOR SRV-L HIGH REACTOR BLOWDOWN**  
**(WITH SPTMS SENSOR LOCATIONS)**  
**FIGURE 3A-442**



**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**


**DESIGN ASSESSMENT REPORT  
TEMPERATURE TIME HISTORIES OF  
COLUMN MOUNTED SPTMS SENSORS  
(TE-101 B, D, F & H) FOR SRV-H  
HIGH REACTOR PRESSURE BLOWDOWN  
FIGURE 3A-443**




**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
TEMPERATURE TIME HISTORIES OF  
CONTAINMENT WALL MOUNTED SPTMS  
SENSORS (TE-101 A, C, E & G) FOR SRV-H  
HIGH REACTOR PRESSURE BLOWDOWN**

**FIGURE 3A-444**



**LIMERICK GENERATING STATION**  
**UNITS 1 AND 2**  
**UPDATED FINAL SAFETY ANALYSIS REPORT**  
 DESIGN ASSESSMENT REPORT  
**TEMPERATURE TIME HISTORIES OF**  
**COLUMN MOUNTED SPTMS SENSORS**  
**(TE-101 B, D, F & H) FOR SRV-L**  
**HIGH REACTOR PRESSURE BLOWDOWN**  
**FIGURE 3A-445**




**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

DESIGN ASSESSMENT REPORT

**TEMPERATURE TIME HISTORIES OF  
CONTAINMENT WALL MOUNTED SPTMS  
SENSORS (TE-101 A, C, E & G) FOR SRV-L  
HIGH REACTOR PRESSURE BLOWDOWN**

FIGURE 3A-446






**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

---

**DESIGN ASSESSMENT REPORT  
TEMPERATURE TIME HISTORIES OF  
COLUMN MOUNTED SPTMS SENSORS  
(TE-101 B, D, F & H) FOR SRV-H  
LOW REACTOR PRESSURE BLOWDOWN  
FIGURE 3A-447**




**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

DESIGN ASSESSMENT REPORT


**TEMPERATURE TIME HISTORIES OF  
CONTAINMENT WALL MOUNTED SPTMS  
SENSORS (TE-101 A, C, E & G) FOR SRV-H  
LOW REACTOR PRESSURE BLOWDOWN**

FIGURE 3A-448




**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
BULK TEMPERATURE VERSUS AVERAGE  
TEMPERATURE FROM SPTMS DIVISION 1  
(TE 101A...TE-101H) FOR SRV-H  
HIGH REACTOR PRESSURE BLOWDOWN  
FIGURE 3A-449**




**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
BULK TEMPERATURE VERSUS AVERAGE  
TEMPERATURE FROM SPTMS DIVISION 1  
(TE 101A...TE-101H) FOR SRV-L  
HIGH REACTOR PRESSURE BLOWDOWN  
FIGURE 3A-450**



**LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
 BULK TEMPERATURE VERSUS AVERAGE  
 TEMPERATURE FROM SPTMS DIVISION 1  
 (TE 101A...TE-101H) FOR SRV-H  
 LOW REACTOR PRESSURE BLOWDOWN  
 FIGURE 3A-451**




**NOTE:** The information presented in this figure is based on the original design basis conditions. The current suppression pool temperature response results are discussed in Section 3A.15.2. The results reasonably represent the general characteristics of the suppression pool temperature response.

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
SUPPRESSION POOL  
TEMPERATURE TRANSIENT  
CASE 1.a**

FIGURE 3A-452

Rev. 5, 4/96




**NOTE:** The information presented in this figure is based on the original design basis conditions. The current suppression pool temperature response results are discussed in Section 3A.15.2. The results reasonably represent the general characteristics of the suppression pool temperature response.

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
SUPPRESSION POOL  
TEMPERATURE TRANSIENT  
CASE 1.b**

FIGURE 3A-453

Rev. 5, 4/96



**NOTE:** The information presented in this figure is based on the original design basis conditions. The current suppression pool temperature response results are discussed in Section 3A.15.2. The results reasonably represent the general characteristics of the suppression pool temperature response.


**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
SUPPRESSION POOL  
TEMPERATURE TRANSIENT  
CASE 2.a**

FIGURE 3A-454

Rev. 5, 4/96






**NOTE:** The information presented in this figure is based on the original design basis conditions. The current suppression pool temperature response results are discussed in Section 3A.15.2. The results reasonably represent the general characteristics of the suppression pool temperature response.

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

---

**DESIGN ASSESSMENT REPORT  
SUPPRESSION POOL  
TEMPERATURE TRANSIENT  
CASE 2.b**

FIGURE 3A-455 Rev. 5, 4/96




**NOTE:** The information presented in this figure is based on the original design basis conditions. The current suppression pool temperature response results are discussed in Section 3A.15.2 and Table 3A-30. The results reasonably represent the general characteristics of the suppression pool temperature response.

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

DESIGN ASSESSMENT REPORT  
**SUPPRESSION POOL  
TEMPERATURE TRANSIENT  
CASE 3.a**

FIGURE 3A-456

Rev. 5, 4/96




**NOTE:** The information presented in this figure is based on the original design basis conditions. The current suppression pool temperature response results are discussed in Section 3A.15.2. The results reasonably represent the general characteristics of the suppression pool temperature response.

**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

**DESIGN ASSESSMENT REPORT  
SUPPRESSION POOL  
TEMPERATURE TRANSIENT  
CASE 3.b**

FIGURE 3A-457


Rev. 5, 4/96



**LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT**

DESIGN ASSESSMENT REPORT

**LOCAL-TO-BULK  
TEMPERATURE DIFFERENCE ( $\Delta T$ )  
TRACE FOR SRV-H BLOWDOWN  
UNDER HIGH REACTOR PRESSURE  
FIGURE 3A-458**




**LIMERICK GENERATING STATION**  
**UNITS 1 AND 2**  
**UPDATED FINAL SAFETY ANALYSIS REPORT**

---

**DESIGN ASSESSMENT REPORT**  
**LOCAL-TO-BULK**  
**TEMPERATURE DIFFERENCE ( $\Delta T$ )**  
**TRACE FOR SRV-L BLOWDOWN UNDER**  
**HIGH REACTOR PRESSURE**  
**FIGURE 3A-459**

TIME HISTORY PLOT OF LOCAL TEMPERATURE




NOTES

1. ENLARGED SCALE
2. ELEVATED POOL TEMPERATURE REFLECTS RHR SYSTEM INOPERATION

LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
 LOCAL-TO-BULK  
 TEMPERATURE DIFFERENCE ( $\Delta T$ )  
 TRACE FOR SRV-H BLOWDOWN  
 UNDER LOW REACTOR PRESSURE  
 FIGURE 3A-460




NOTE:  
 VACUUM BREAKERS ARE INSTALLED  
 ON DOWNCOMERS 10, 31, 50 AND 77  
 WHICH ARE CAPPED (E.G., [Symbol])

LIMERICK GENERATING STATION  
 UNITS 1 AND 2  
 UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
 LOCATION OF CAPPED  
 DOWNCOMERS WITH  
 VACUUM BREAKERS

FIGURE 3A-461



LIMERICK GENERATING STATION  
UNITS 1 AND 2  
UPDATED FINAL SAFETY ANALYSIS REPORT

DESIGN ASSESSMENT REPORT  
DETAILS OF  
CAPPED DOWNCOMER

FIGURE 3A-462