



PG&E Letter DCL-21-043

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Docket No. 50-275, OL-DPR-80
Docket No. 50-323, OL-DPR-82
Diablo Canyon Units 1 and 2
Report of Completion of Implementation of Risk-Informed Evaluation Methodology to
Address Open Phase Condition

References:

1. PG&E Letter DCL-20-108, "Use of Risk-Informed Evaluation Methodology to Address Open Phase Condition," dated December 29, 2020 (ML20364A208)
2. Nuclear Energy Institute Open Phase Condition Initiative, Revision 3, dated June 2019 (transmitted to NRC under NEI letter dated June 6, 2019, Douglas E. True to Ho Nieh, Jr., re: "Industry Initiative on Open Phase Condition, Revision 3") (ML19163A176)

Dear Commissioners and Staff:

Reference 1 informed the NRC that Pacific Gas and Electric Company (PG&E) would implement the risk-informed evaluation methodology in Reference 2 to address potential open phase conditions at Diablo Canyon Power Plant (DCPP). Implementation was completed on March 11, 2021, for DCPP Unit 1 and on April 5, 2021, for DCPP Unit 2.

Note that the Unit 2 implementation was delayed past the Reference 1 commitment date of March 31, 2021. This constitutes a change to the commitment; however, the delay was warranted to allow certain relay setpoint changes to be made safely during the spring refueling outage for that unit.

PG&E makes no new or other revisions to regulatory commitments (as defined by NEI 99-04) in this letter.

If you have any questions or require additional information, please contact Mr. Jim Morris, Regulatory Services Manager, at 805-545-4609.

Sincerely,



Paula Gerfen
Site Vice President

May 20, 2021

Date

jmsp/50601137-12

cc: Donald R. Krause, NRC Senior Resident Inspector
Samson S. Lee, NRC Project Manager
Scott A. Morris, NRC Region IV Administrator
Diablo Canyon Distribution