

PUBLIC SUBMISSION

SUNI Review Complete
Template=ADM-013
E-RIDS=ADM-03

ADD: Jim Steckel, Mary
Neely
Comment (1)
Publication Date: 5/7/2021
Citation: 86 FR 24672

As of: 5/21/21 10:52 AM Received: May 19, 2021 Status: Pending_Post Tracking No. kov-rneo-f21x Comments Due: July 06, 2021 Submission Type: Web
--

Docket: NRC-2020-0252

Quality Group Classifications and Standards for Water-, Steam-, and Radioactive-Waste-Containing Components of Nuclear Power Plants

Comment On: NRC-2020-0252-0001

Quality Group Classifications and Standards for Water-, Steam-, and Radioactive-Waste-Containing Components of Nuclear Power Plants

Document: NRC-2020-0252-DRAFT-0003

Comment on FR Doc # 2021-09728

Submitter Information

Email: Norbert.Carte@nrc.gov

Government Agency Type: Federal

Government Agency: NRC

General Comment

There were two regulatory requirements not lists in the DG. Please add the following two regulatory requirements or explain why they are not applicable.

10 CFR 50.54 Conditions of licenses. “(jj) Structures, systems, and components subject to the codes and standards in 10 CFR 50.55a must be designed, fabricated, erected, constructed, tested, and inspected to quality standards commensurate with the importance of the safety function to be performed.”

10 CFR 50.55 Conditions of construction permits, early site permits, combined licenses, and manufacturing licenses. “(i) Structures, systems, and components subject to the codes and standards in 10 CFR 50.55a must be designed, fabricated, erected, constructed, tested, and inspected to quality standards commensurate with the importance of the safety function to be performed.”