

PSEG Nuclear LLC
P.O. Box 236, Hancocks Bridge, New Jersey 08038-0236



LR-N21-0042

TS 6.9.1.9

May 24, 2021

United States Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Hope Creek Generating Station
Renewed Facility Operating License No. NPF-57
NRC Docket No. 50-354

Subject: Core Operating Limits Report, Reload 23, Cycle 24, Revision 21

PSEG Nuclear LLC submits the Core Operating Limits Report (COLR) for Hope Creek Generating Station (HCGS) Reload 23, Cycle 24, Revision 21 as required by Hope Creek Technical Specification 6.9.1.9.

Attachment 1 is marked proprietary in its entirety because it contains information proprietary to Global Nuclear Fuel - Americas, LLC (GNF-A). GNF-A requests that Attachment 1 be withheld from public disclosure per 10 CFR 2.390(a)(4) and 10 CFR 9.17(a)(4). Attachment 2 is a non-proprietary version of the COLR. Attachment 3 is the GNF-A affidavit requesting withholding of proprietary information from public disclosure.

There are no commitments contained in this letter.

Should you have any questions, please contact Mr. Thomas Cachaza at (856) 339-5038.

Sincerely,

A handwritten signature in cursive script that reads "Jean Fleming".

Jean Fleming
Director – Site Regulatory Affairs

Attachment 1 - Core Operating Limits Report, Reload 23, Cycle 24, Revision 21 – Proprietary
Attachment 2 - Core Operating Limits Report, Reload 23, Cycle 24, Revision 21 – Non-Proprietary
Attachment 3 - Affidavit for Core Operating Limits Report for Hope Creek Generating Station Unit 1

Attachment 1 transmitted herewith contains Proprietary Information.
When separated from Attachment 1, this transmittal document is decontrolled.

Document Control Desk
LR-N21-0042
Page 2

cc: Administrator- Region I- USNRC
Project Manager - USNRC
Mr. Jigar Patel, USNRC Senior Resident Inspector - Hope Creek
Chief- NJ Bureau of Nuclear Engineering (NJBNE)
Mr. Lee Marabella, Corporate Commitment Tracking Coordinator
Mr. Thomas Cachaza, Site Commitment Tracking Coordinator

Document Control Desk
LR-N21-0042

Attachment 2

Core Operating Limits Report, Reload 23, Cycle 24, Revision 21
(Non-Proprietary Version)

COLR HOPE CREEK 1 Rev 21 (Cycle 24)

CORE OPERATING LIMITS REPORT

FOR

Hope Creek Generating Station Unit 1

RELOAD 23, CYCLE 24

Prepared By: (SAP#80126636/1630) Date: 05/09/2021
Benjamin A. Troxell

Reviewed By: (SAP#80126636/1640) Date: 05/09/2021
Eric S. Scott

Approved By: (SAP#80126636/1660) Date: 05/09/2021
Francis J. Safin

COLR HOPE CREEK 1 Rev 21 (Cycle 24)

Table of Contents

1.0	Terms and Definitions	4
2.0	References	5
3.0	General Information	6
4.0	Precautions and Limitations	7
5.0	Technical Specifications that Reference the COLR	8
5.1	Average Planar Linear Heat Generation Rate	9
5.2	Minimum Critical Power Ratio	10
5.3	Linear Heat Generation Rate	13
5.4	OPRM Setpoints	15
5.5	Rod Block Monitor	15
Appendix A	Method of Core Average Scram Speed Calculation	16
Appendix B	Exposure-Dependent Linear Heat Generation Rate Limits	18
Appendix C	Backup Stability Protection	23
Appendix D	MCPR _{99.9%} Value	26

COLR HOPE CREEK 1 Rev 21 (Cycle 24)

List of Tables

TABLE 5.1-1	APLHGR Data for GNF2	9
TABLE 5.2-1	MCPR Operating Limits Cycle Exposure $\leq 7,998$ MWd/MTU ($\leq 7,256$ MWd/STU)	11
TABLE 5.2-2	MCPR Operating Limits Cycle Exposure $> 7,998$ MWd/MTU ($> 7,256$ MWd/STU)	11
TABLE 5.2-3	Power Dependent MCPR Multiplier (K_p) Data	12
TABLE 5.2-4	Flow Dependent MCPR Limit ($MCPR_f$)	12
TABLE 5.3-1	Power Dependent Linear Heat Generation Rate Multiplier ($LHGRFAC_p$)	14
TABLE 5.3-2	Flow Dependent Linear Heat Generation Rate Multiplier ($LHGRFAC_f$)	14
TABLE 5.5.2-1	Control Rod Block Instrumentation Setpoints, Trip Function 1, Rod Block Monitor	15
TABLE B-1	GNF2 LHGR Limits – UO ₂ Fuel Rods	20
TABLE B-2	GNF2 LHGR Limits – Gadolinia Bearing Rods	20
TABLE B-3	GNF2 LHGR Limits – UO ₂ Fuel Rods	21
TABLE B-4	GNF2 LHGR Limits – Gadolinia Bearing Rods	22
TABLE C-1	BSP Region Intercepts (Operation Prior to FFWTR)	24
TABLE C-2	BSP Region Intercepts (Required for FFWTR)	24
TABLE C-3	ABSP Region Setpoints	25
TABLE D-1	MCPR _{99.9%} Value	27

COLR HOPE CREEK 1 Rev 21 (Cycle 24)

1.0 Terms and Definitions

ABSP	Automated Backup Stability Protection
APLHGR	Average Planar Linear Heat Generation Rate
ARTS	APRM and RBM Technical Specification Analysis
BSP	Backup Stability Protection
COLR	Core Operating Limits Report
DSS-CD	Detect and Suppress Solution – Confirmation Density
ECCS	Emergency Core Cooling Systems
EOC	End-of-Cycle
EOC-RPT	End-of-Cycle Recirculation Pump Trip
FFWTR	Final Feedwater Temperature Reduction
FWHOOS	Feedwater Heaters Out of Service
GNF	Global Nuclear Fuel
LCO	Limiting Condition for Operation
LHGR	Linear Heat Generation Rate
LHGRFAC _f	ARTS LHGR thermal limit flow dependent adjustments and multipliers
LHGRFAC _p	ARTS LHGR thermal limit power dependent adjustments and multipliers
MCPR	Minimum Critical Power Ratio
MCPR _{99.9%}	Cycle-specific MCPR that ensures at least 99.9% of fuel rods are not susceptible to boiling transition
MCPR _f	ARTS MCPR flow dependent thermal limit
MCPR _p	ARTS MCPR power dependent thermal limit which is the product of the rated thermal power MCPR limit and a power dependent multiplier, K _p
OPRM	Oscillation Power Range Monitor
RBM	Rod Block Monitor
RDF	Recirculation Drive Flow
RTP	Rated Thermal Power
S _{AD}	Amplitude Discriminator Setpoint
SLO	Single Recirculation Loop Operation
TLO	Two Recirculation Loop Operation

COLR HOPE CREEK 1 Rev 21 (Cycle 24)

2.0 References

Methodology References

1. "General Electric Standard Application for Reactor Fuel," NEDE-24011-P-A-30, and the U.S. Supplement NEDE-24011-P-A-30-US, April 2020.

User References

2. "GE Hitachi Boiling Water Reactor Detect and Suppress Solution – Confirmation Density," NEDC-33075P-A, Revision 8, November 2013.
3. Renewed Facility Operating License No. NPF-57, PSEG Nuclear LLC, Hope Creek Generating Station, Docket No. 50-354.
4. "Applicability of GE Methods to Expanded Operating Domains," NEDC-33173P-A, Revision 5, August 2019.
5. "Supplemental Reload Licensing Report for Hope Creek Reload 23 Cycle 24," Global Nuclear Fuel Document No. 005N5052, Revision 0, March 2021.
6. "Fuel Bundle Information Report for Hope Creek Reload 23 Cycle 24," Global Nuclear Fuel Document No. 005N5053, Revision 0, March 2021.
7. "Option B Licensing Basis & Cycle-Independent Transient Evaluation for Implementation of the Technical Specification Improvement Program (TSIP) Scram Speed," Global Nuclear Fuel Document No. 0000-0119-7785-R0, Revision 0, October 2010.
8. "SRLR Bases Confirmation with Control Rods Inserted at End of Cycle for Hope Creek (KT1)," Global Nuclear Fuel Document No. 002N4856, Revision 0, February 18, 2015.
9. "GNF2 Advantage Generic Compliance with NEDE-24011-P-A (GESTAR II)," NEDC-33270P, Revision 11, August 2020.
10. "Hope Creek SRLR Bases Confirmation for Control Rods Inserted at the End of Cycle," Global Nuclear Fuel Letter 005N3138, Revision 0, May 31, 2019.
11. "GESTAR II Section 3.4 Compliance Assessment for Hope Creek Cycle 24," Global Nuclear Fuel Document No. 006N5145, Revision 1, April 2021.

COLR HOPE CREEK 1 Rev 21 (Cycle 24)

3.0 General Information

This revision of the Core Operating Limits Report provides the core operating limits for Hope Creek Generating Station Unit 1 Cycle 24 operation. This report provides information relative to OPRM setpoints, backup stability protection regions, RBM setpoints, single recirculation loop operation, and core average scram speed. The power distribution limits presented here correspond to the core thermal limits for Average Planar Linear Heat Generation Rate (APLHGR), Minimum Critical Power Ratio (MCPR), and Linear Heat Generation Rate (LHGR). The MCPR_{99.9%} values determined for the generation of the MCPR power distribution limits are provided in Appendix D. Finally, this report provides references to the most recent revision of the implemented approved methodology.

These operating limit values have been determined using NRC approved methods contained in GESTAR-II (Reference 1).

These operating limit values also include limitations where required by the NRC Safety Evaluation Report for Hope Creek License Amendment Number 174, Extended Power Uprate (Reference 3) for the use of GE Licensing Topical Report NEDC-33173P, Applicability of GE Methods to Expanded Operating Domains (Reference 4).

The following sections contain operating limit values applicable for the GNF2 fuel design in use for Cycle 24.

The method of calculating core average scram speed, τ , is provided in Option B Licensing Basis & Cycle-Independent Transient Evaluation for Implementation of the Technical Specification Improvement Program (TSIP) Scram Speed (Reference 7).

These operating limits are established such that all applicable fuel thermal-mechanical, core thermal-hydraulic, ECCS, and nuclear limits such as shutdown margin, and transient and accident analysis limits are met.

Various sections of the Hope Creek Technical Specifications reference this COLR. Those sections are listed in Section 5 of this document. Hope Creek Technical Specification 6.9.1.9 also requires that this report, including any mid-cycle revisions, shall be provided upon issuance to the NRC.

COLR HOPE CREEK 1 Rev 21 (Cycle 24)

4.0 Precautions and Limitations

This document is specific to Hope Creek Generating Station Unit 1 Cycle 24 and shall not be applicable to any other core or cycle design. Revision 21 of the COLR is applicable for Cycle 24 operating from the date of issuance through the end of cycle including consideration of reduced feedwater temperatures for FWHOOS or FFWTR, and a power coastdown to a core thermal power that shall not go below 40% rated core thermal power. End of full power capability is reached when 100% rated power can no longer be maintained by increasing core flow (up to 105% of rated core flow), at allowable feedwater temperatures, in the all-rods-out configuration. The term "all-rods-out" excludes control rods that have been inserted to suppress fuel leakers, address cell friction performance, or other circumstances that would require control rod insertion such as, but not limited to, meeting Technical Specification Operability requirements. Inserted rods may be removed at any point of the cycle, including after the end of full power capability (References 8 and 10). Operation beyond the end of full power capability is defined as power coastdown operation which includes an operating assumption that vessel dome pressure will decrease during the power coastdown period as steam flow decreases (maintaining constant vessel dome pressure during the power coastdown period was not generically considered by GESTAR-II for determining the operating limit LCO values described above).

FWHOOS was evaluated for a final feedwater temperature reduction of up to 60°F from the design rated thermal power final feedwater temperature of 433.5°F (433.5°F - 60°F = 373.5°F). Therefore, Cycle 24 FWHOOS operation is limited to feedwater system configurations that result in a final feedwater temperature greater than or equal to 373.5°F at rated thermal power. FWHOOS operation and the associated limitations may be implemented any time during the operating cycle prior to cycle extension utilizing FFWTR.

FFWTR was evaluated for a final feedwater temperature reduction of up to 102°F from the design rated thermal power final feedwater temperature of 433.5°F (433.5°F - 102°F = 331.5°F). Therefore, Cycle 24 FFWTR operation is limited to feedwater system configurations that result in a final feedwater temperature greater than or equal to 331.5°F at rated thermal power which is compliant with Renewed Facility Operating License No. NPF-57 License Condition 2.C.(11): The facility shall not be operated with a rated thermal power feedwater temperature less than 331.5°F for the purpose of extending the normal fuel cycle. FFWTR operation and the associated limitations shall only be implemented for the purposes of cycle extension after rated thermal power cannot be maintained at 100% rated total core flow in the all-rods-out configuration.

COLR HOPE CREEK 1 Rev 21 (Cycle 24)

5.0 Technical Specifications that Reference the COLR

The following Hope Creek Technical Specifications reference this COLR:

<u>Technical Specification</u>	<u>Title</u>
2.1	Safety Limits
2.2	Reactor Protection System Instrumentation Setpoints
3/4.1.4.3	Rod Block Monitor
3/4.2.1	Average Planar Linear Heat Generation Rate
3/4.2.3	Minimum Critical Power Ratio
3/4.2.4	Linear Heat Generation Rate
3/4.3.1	Reactor Protection System Instrumentation
3/4.3.6	Control Rod Block Instrumentation
3/4.4.1	Recirculation System Recirculation Loops
6.9.1.9	Administrative Controls, Core Operating Limits Report

COLR HOPE CREEK 1 Rev 21 (Cycle 24)

5.1 Average Planar Linear Heat Generation Rate

LIMITING CONDITION FOR OPERATION

All AVERAGE PLANAR LINEAR HEAT GENERATION RATES (APLHGRs) shall be less than or equal to the limits specified in Table 5.1-1 for two recirculation loop operation (TLO).

When the Technical Specification 3.4.1.1 Action Statement a.1.d is entered from that section's Limiting Condition for Operation, reduce the APLHGR limits to the values specified in Table 5.1-1 for single recirculation loop operation (SLO).

Linear interpolation shall be used to determine APLHGR limits as a function of exposure for intermediate values in Table 5.1-1.

TABLE 5.1-1 APLHGR Data for GNF2

Average Planar Exposure		APLHGR Limit (kW/ft)	
MWd/MTU	MWd/STU	TLO	SLO
0.00	0.00	13.78	11.02
18910	17150	13.78	11.02
67000	60780	6.87	5.50
70000	63500	5.50	4.40

COLR HOPE CREEK 1 Rev 21 (Cycle 24)

5.2 Minimum Critical Power Ratio

LIMITING CONDITION FOR OPERATION

The MINIMUM CRITICAL POWER RATIO (MCPR) shall be equal to or greater than the MCPR limit computed from the following steps:

1. Determine τ as defined in Appendix A.

NOTE

The SLO operating condition MCPR values in Tables 5.2-1, 5.2-2, and 5.2-4 implement the increase in the MCPR_{99.9%} Limit to meet the requirements of Technical Specification 3.4.1.1 Action Statement a.1.c.

2. Linearly interpolate a rated MCPR limit as a function of τ from the MCPR value at $\tau=0$ and MCPR value at $\tau=1$ as specified in Table 5.2-1 and Table 5.2-2 for the appropriate condition.
3. When thermal power is $\geq 24\%$ rated core thermal power, determine a power dependent MCPR adjustment (K_p) value by linearly interpolating a K_p value as a function of core rated thermal power from Table 5.2-3. Multiply the rated MCPR value obtained from Step 2 by the K_p value to determine the power dependent MCPR limit (MCPR_p).

When core thermal power is $< 24\%$ rated thermal power, no thermal limits are required.

4. For the flow dependent MCPR adjustment, determine the appropriate flow dependent MCPR limit (MCPR_f) by linearly interpolating between the MCPR_f values as a function of rated core flow using the information in Table 5.2-4.
5. Choose the most limiting (highest value) of the power and flow dependent MCPR limits determined in Steps 3 and 4 as the value for the MCPR limit for the Limiting Condition for Operation.

Note that the MCPR limit is a function of core average scram speed (τ), cycle exposure, core thermal power, total core flow, EOC-RPT operability, the number of reactor coolant recirculation loops in operation, and main turbine bypass operability.

EOC-RPT system operability is defined by Hope Creek Technical Specification 3.3.4.2.

Reactor coolant recirculation loop operation is defined by Hope Creek Technical Specification 3.4.1.1.

Main Turbine Bypass operability is defined by Hope Creek Technical Specification 3.7.7.

COLR HOPE CREEK 1 Rev 21 (Cycle 24)

TABLE 5.2-1 MCPR Operating Limits Cycle Exposure \leq 7,998 MWd/MTU (\leq 7,256 MWd/STU)

Main Turbine Bypass Operable		
Operating Condition	Scram Speed Option	GNF2
TLO-EOC-RPT Operable	A	1.49
	B	1.39
TLO-EOC-RPT Inoperable	A	1.51
	B	1.41
SLO-EOC-RPT Operable	A	1.51
	B	1.41
SLO-EOC-RPT Inoperable	A	1.53
	B	1.43

Scram Speed Option A $\tau=1$, Scram Speed Option B $\tau=0$

TLO = Two Recirculation Loop Operation

SLO = Single Recirculation Loop Operation

TABLE 5.2-2 MCPR Operating Limits Cycle Exposure $>$ 7,998 MWd/MTU ($>$ 7,256 MWd/STU)

Main Turbine Bypass Operable		
Operating Condition	Scram Speed Option	GNF2
TLO-EOC-RPT Operable	A	1.55
	B	1.45
TLO-EOC-RPT Inoperable	A	1.57
	B	1.47
SLO-EOC-RPT Operable	A	1.57
	B	1.47
SLO-EOC-RPT Inoperable	A	1.59
	B	1.49

Scram Speed Option A $\tau=1$, Scram Speed Option B $\tau=0$

TLO = Two Recirculation Loop Operation

SLO = Single Recirculation Loop Operation

COLR HOPE CREEK 1 Rev 21 (Cycle 24)

TABLE 5.2-3 Power Dependent MCPR Multiplier (K_p) Data

Operating Condition	Core Thermal Power (% of Rated)			
	24	45	60	≥100
	MCPR Multiplier K_p			
TLO	1.561	1.280	1.150	1.000
SLO	1.561	1.280	1.150	1.000

K_p is linearly interpolated between core thermal power entries.

TLO = Two Recirculation Loop Operation

SLO = Single Recirculation Loop Operation

TABLE 5.2-4 Flow Dependent MCPR Limit ($MCPR_f$)

Operating Condition	Core Flow (% of Rated)			
	30	60	91.1	105
	MCPR Limit			
TLO	1.56		1.20	1.20
SLO	1.58	1.40		

$MCPR_f$ is linearly interpolated between core flow entries.

TLO = Two Recirculation Loop Operation

SLO = Single Recirculation Loop Operation

COLR HOPE CREEK 1 Rev 21 (Cycle 24)

5.3 Linear Heat Generation Rate

LIMITING CONDITION FOR OPERATION

The LINEAR HEAT GENERATION RATE (LHGR) shall not exceed the limit computed from the following steps:

NOTE

The steps performed in 1 through 6 below should be repeated for both UO₂ and gadolinia bearing fuel rods in each bundle type.

1. Determine the exposure dependent LHGR limit using linear interpolation between the table values in Appendix B.

NOTE

For two recirculation loop operation (TLO) utilize steps 1, 2, 3, and 6 to determine the LCO LHGR limits.

When the Technical Specification 3.4.1.1 ACTION statement a.1.e is entered from that section's Limiting Condition for Operation (LCO), utilize steps 1, 4, 5, and 6 to determine the LCO LHGR limits for single recirculation loop operation (SLO).

2. For the power dependent LHGR adjustment for TLO, determine a LHGRFAC_p value by linearly interpolating a LHGRFAC_p value as a function of rated core thermal power from the TLO entries in Table 5.3-1. Multiply the LHGR values obtained from Step 1 by the LHGRFAC_p value to determine the power dependent LHGR limit.
3. For the flow dependent LHGR adjustment for TLO, determine a LHGRFAC_f value by linearly interpolating a LHGRFAC_f value as a function of rated core flow from the TLO entries in Table 5.3-2. Multiply the LHGR values obtained from Step 1 by the LHGRFAC_f value to determine the flow dependent LHGR limit.
4. For the power dependent LHGR adjustment for SLO, determine a LHGRFAC_p value by linearly interpolating a LHGRFAC_p value as a function of rated core thermal power from the SLO entries in Table 5.3-1. Multiply the LHGR values obtained from Step 1 by the LHGRFAC_p value to determine the power dependent LHGR limit.
5. For the flow dependent LHGR adjustment for SLO, determine a LHGRFAC_f value by linearly interpolating a LHGRFAC_f value as a function of rated core flow from

COLR HOPE CREEK 1 Rev 21 (Cycle 24)

the SLO entries in Table 5.3-2. Multiply the LHGR values obtained from Step 1 by the LHGRFAC_f value to determine the flow dependent LHGR limit.

6. Choose the most limiting (lowest value) of the power and flow dependent LHGR limits determined in Steps 2 and 3 (TLO) or 4 and 5 (SLO) as the value for the LHGR limit for the Limiting Condition for Operation.

TABLE 5.3-1 Power Dependent Linear Heat Generation Rate Multiplier (LHGRFAC_p)

Operating Condition	Core Thermal Power (% of Rated)		
	24	59.89	≥ 100
	LHGRFAC _p Multiplier		
TLO	0.603		1.000
SLO	0.603	0.790	

LHGRFAC_p is linearly interpolated between core thermal power entries.

TLO = Two Recirculation Loop Operation

SLO = Single Recirculation Loop Operation

TABLE 5.3-2 Flow Dependent Linear Heat Generation Rate Multiplier (LHGRFAC_f)

Operating Condition	Core Flow (% of Rated)					
	30	50	52.7	60	82.2	105
	LHGRFAC _f Multiplier					
TLO	0.500	0.782			1.000	1.000
SLO	0.500	0.782	0.800	0.800		

LHGRFAC_f is linearly interpolated between core flow entries.

TLO = Two Recirculation Loop Operation

SLO = Single Recirculation Loop Operation

COLR HOPE CREEK 1 Rev 21 (Cycle 24)

5.4 OPRM Setpoints

5.4.1 Technical Specifications Table 2.2.1-1, Function 2.f, OPRM Upscale

A DSS-CD evaluation was completed for Hope Creek Cycle 24 in accordance with the licensing methodology described in Reference 2. The DSS-CD evaluation confirms that the DSS-CD solution is applicable to Hope Creek Cycle 24 and confirms $S_{AD} = 1.10$ for Hope Creek Cycle 24 operation.

The $S_{AD} = 1.10$ is applicable under all operating conditions within the OPRM Armed Region.

5.5 Rod Block Monitor

5.5.1 Reactivity Control Systems, Rod Block Monitor

Limiting Condition For Operation

Technical Specifications 3.1.4.3 Both rod block monitor (RBM) channels shall be OPERABLE.

APPLICABILITY: OPERATIONAL CONDITION 1, when THERMAL POWER is greater than or equal to 30% of RATED THERMAL POWER and less than 90% of RATED THERMAL POWER with MCPR less than 1.73, or THERMAL POWER greater than or equal to 90% of RATED THERMAL POWER with MCPR less than 1.43.

5.5.2 Technical Specifications Table 3.3.6-2, Control Rod Block Instrumentation Setpoints, Trip Function 1, Rod Block Monitor

TABLE 5.5.2-1 Control Rod Block Instrumentation Setpoints, Trip Function 1, Rod Block Monitor

Trip Function	Trip Setpoint*	Allowable Value*
a.i) Low Trip Setpoint (LTSP)	123.0	123.4
a.ii) Intermediate Trip Setpoint (ITSP)	118.2	118.6
a.iii) High Trip Setpoint (HTSP)	113.2	113.6
c. Downscale	5	N/A

* % RBM Reference Level

Appendix A: Method of Core Average Scram Speed Calculation

COLR HOPE CREEK 1 Rev 21 (Cycle 24)
Method of Core Average Scram Speed, τ , Calculation

τ is defined as
$$\tau = \frac{(\tau_{ave} - \tau_B)}{\tau_A - \tau_B}$$

where:
$$\tau_B = 0.672 + 1.65 \left[\frac{N_1}{\sum_{i=1}^n N_i} \right]^{1/2} \quad (0.016)$$

$$\tau_{ave} = \frac{\sum_{i=1}^n N_i \tau_i}{\sum_{i=1}^n N_i}$$

τ_A = 0.86 seconds, control rod scram insertion time limit to notch 39 per Specification 3.1.3.3,

n = number of surveillance tests performed to date in cycle,

N_i = number of active control rods measured in the i th surveillance test,

τ_i = average scram time to notch 39 of all rods measured in the i th surveillance test, and

N_1 = total number of active rods measured in Specification 4.1.3.3.a or 4.1.3.3.d.

If $\tau_{ave} \leq \tau_B$, set $\tau = 0$ to apply Option B OLMCPR.

τ shall be 1.0 ($\tau = 1.0$) prior to performance of the initial scram time measurements for the cycle in accordance with Specification 4.1.3.3.

Appendix B: Exposure-Dependent Linear Heat Generation Rate Limits

COLR HOPE CREEK 1 Rev 21 (Cycle 24)

Exposure-Dependent Linear Heat Generation Rate Limits

The LHGR limits for all fuel and rod types are considered proprietary information of the vendor. Tables B-1 through B-4 contain exposure-dependent LHGR limits. The tables are presented in pairs since the LHGR limits are presented at separate peak pellet exposures for UO₂ and gadolinia bearing fuel rods. Several of the bundle types have the same exposure-dependent LHGR limits, and the applicable bundle types are noted before each set of tables. The gadolinia fuel rod limits provided for each bundle type reflect the bounding gadolinia LHGR limit for all gadolinium concentrations occurring in that bundle type.

COLR HOPE CREEK 1 Rev 21 (Cycle 24)

Tables B-1 and B-2 contain limits applicable to the GNF2 bundle types that follow.

- GNF2-P10CG2B392-13G4.0-100T2-150-T6-4533
- GNF2-P10CG2B392-14G4.0-100T2-150-T6-4534
- GNF2-P10CG2B370-12GZ-100T2-150-T6-4651
- GNF2-P10CG2B385-14GZ-100T2-150-T6-4653
- GNF2-P10CG2B373-13G4.0-100T2-150-T6-4875

TABLE B-1: GNF2 LHGR Limits – UO₂ Fuel Rods

Peak Pellet Exposure		UO ₂ LHGR Limit
MWd/MTU	MWd/STU	kW/ft
[[
]]

TABLE B-2: GNF2 LHGR Limits – Gadolinia Bearing Rods

Peak Pellet Exposure		Most Limiting Gadolinia LHGR Limit
MWd/MTU	MWd/STU	kW/ft
[[
]]

COLR HOPE CREEK 1 Rev 21 (Cycle 24)

Tables B-3 and B-4 contain limits applicable to the GNF2 bundle types that follow.

- GNF2-P10CG2B382-15GZ-100T2-150-T6-4438
- GNF2-P10CG2B382-6G5.0/7G4.0-100T2-150-T6-4439
- GNF2-P10CG2B377-15GZ-100T2-150-T6-4440
- GNF2-P10CG2B375-6G5.0/7G4.0-100T2-150-T6-4441
- GNF2-P10CG2B392-10G5.0/5G4.0-100T2-150-T6-4442
- GNF2-P10CG2B372-12GZ-100T2-150-T6-4531
- GNF2-P10CG2B383-14GZ-100T2-150-T6-4532
- GNF2-P10CG2B368-14GZ-100T2-150-T6-4650
- GNF2-P10CG2B373-2G5.0/12G4.0-100T2-150-T6-4652
- GNF2-P10CG2B399-15GZ-100T2-150-T6-4654
- GNF2-P10CG2B408-2G5.0/10G4.0-100T2-150-T6-4655
- GNF2-P10CG2B369-6G5.0/8G4.0-100T2-150-T6-4876
- GNF2-P10CG2B399-12GZ0-100T2-150-T6-4877
- GNF2-P10CG2B399-13GZ-100T2-150-T6-4878
- GNF2-P10CG2B398-12GZ-100T2-150-T6-4879

TABLE B-3: GNF2 LHGR Limits – UO₂ Fuel Rods

Peak Pellet Exposure		UO ₂ LHGR Limit
MWd/MTU	MWd/STU	kW/ft
[[
]]

COLR HOPE CREEK 1 Rev 21 (Cycle 24)

TABLE B-4: GNF2 LHGR Limits – Gadolinia Bearing Rods

Peak Pellet Exposure		Most Limiting Gadolinia LHGR Limit
MWd/MTU	MWd/STU	kW/ft
[[
]]

Appendix C: Backup Stability Protection

COLR HOPE CREEK 1 Rev 21 (Cycle 24)
Backup Stability Protection Region Intercepts

Table C-1 values reflect the cycle-specific BSP region intercepts determined for Cycle 24 considering nominal feedwater temperature operation and FWHOOS (Reference 5).

Table C-2 provides BSP region intercepts for Cycle 24 for the implementation of FFWTR operation (Reference 5).

TABLE C-1: BSP Region Intercepts (Operation Prior to FFWTR)

Region Boundary Intercept	% Power	% Flow
Region 1 High Flow Control Line	60.4	43.8
Region 1 Natural Circulation Line	43.8	35.1
Region 2 High Flow Control Line	67.0	52.1
Region 2 Natural Circulation Line	31.7	36.3

TABLE C-2: BSP Region Intercepts (Required for FFWTR)

Region Boundary Intercept	% Power	% Flow
Region 1 High Flow Control Line	67.8	53.1
Region 1 Natural Circulation Line	41.1	35.5
Region 2 High Flow Control Line	73.4	60.3
Region 2 Natural Circulation Line	31.7	36.3

Region 1 = BSP Scram Region
Region 2 = BSP Controlled Entry Region

COLR HOPE CREEK 1 Rev 21 (Cycle 24)

Automated Backup Stability Protection (ABSP) Region Setpoints

Table C-3 values reflect the cycle-specific modified Simulated Thermal Power – Upscale scram setpoints for implementation of the ABSP region (Reference 5).

The ABSP region is conservatively constructed to encompass BSP Region 1 and generates an immediate automatic reactor scram upon entry. The ABSP region provided is applicable for Nominal, FWHOOS, and FFWTR conditions.

TABLE C-3: ABSP Region Setpoints

Parameter	Setpoint
Slope for Trip (m_{TRIP})	0.79 (% RTP / % RDF)
Constant Power Line for Trip ($P_{BSP-TRIP}$)	43.5 (% RTP)
Constant Flow Line for Trip ($W_{BSP-TRIP}$)	37.8 (% RDF)
Flow Breakpoint ($W_{BSP-BREAK}$)	16.0 (% RDF)

COLR HOPE CREEK 1 Rev 21 (Cycle 24)

Appendix D: $MCPR_{99.9\%}$ Value

COLR HOPE CREEK 1 Rev 21 (Cycle 24)

M CPR_{99.9%} Value

Table D-1 contains the M CPR_{99.9%} values developed for the determination of the Hope Creek Cycle 24 LCO 3.2.3 M CPR Operating Limits (Reference 5), generated in accordance with Section 5.2. The M CPR_{99.9%} value is dependent on the number of reactor coolant recirculation loops in operation.

TABLE D-1: M CPR_{99.9%} Value

Operating Condition	M CPR_{99.9%} Value
TLO	1.09
SLO	1.11

TLO = Two Recirculation Loop Operation
SLO = Single Recirculation Loop Operation

Document Control Desk
LR-N21-0042

Attachment 3

Affidavit for Core Operating Limits Report for Hope Creek Generating Station Unit 1

Global Nuclear Fuel – Americas

AFFIDAVIT

I, **Lukas Trosman**, state as follows:

- (1) I am Engineering Manager, Reactor Physics Technology, Global Nuclear Fuel - Americas, LLC (“GNF-A”), and have been delegated the function of reviewing the information described in paragraph (2) which is sought to be withheld, and have been authorized to apply for its withholding.
- (2) The information sought to be withheld is contained in Appendix B of the Core Operating Limits Report for Hope Creek Generating Station Unit 1, titled “Exposure-Dependent Linear Heat Generation Rate Limits.” GNF-A proprietary information in Appendix B of the Core Operating Limits Report for Hope Creek Generating Station Unit 1 is identified by a dotted underline inside double square brackets. [[This sentence is an example.^{3}]] In all cases, the superscript notation ^{3} refers to Paragraph (3) of this affidavit, which provides the basis for the proprietary determination.
- (3) In making this application for withholding of proprietary information of which it is the owner or licensee, GNF-A relies upon the exemption from disclosure set forth in the Freedom of Information Act (“FOIA”), 5 USC Sec. 552(b)(4), and the Trade Secrets Act, 18 USC Sec. 1905, and NRC regulations 10 CFR 9.17(a)(4), and 2.390(a)(4) for “trade secrets” (Exemption 4). The material for which exemption from disclosure is here sought also qualify under the narrower definition of “trade secret”, within the meanings assigned to those terms for purposes of FOIA Exemption 4 in, respectively, Critical Mass Energy Project v. Nuclear Regulatory Commission, 975F2d871 (DC Cir. 1992), and Public Citizen Health Research Group v. FDA, 704F2d1280 (DC Cir. 1983).
- (4) Some examples of categories of information which fit into the definition of proprietary information are:
 - a. Information that discloses a process, method, or apparatus, including supporting data and analyses, where prevention of its use by GNF-A's competitors without license from GNF-A constitutes a competitive economic advantage over other companies;
 - b. Information which, if used by a competitor, would reduce his expenditure of resources or improve his competitive position in the design, manufacture, shipment, installation, assurance of quality, or licensing of a similar product;
 - c. Information which reveals aspects of past, present, or future GNF-A customer-funded development plans and programs, resulting in potential products to GNF-A;
 - d. Information which discloses patentable subject matter for which it may be desirable to obtain patent protection.

The information sought to be withheld is considered to be proprietary for the reasons set forth in paragraphs (4)a. and (4)b. above.

- (5) To address 10 CFR 2.390 (b) (4), the information sought to be withheld is being submitted to NRC in confidence. The information is of a sort customarily held in confidence by GNF-A, and is in fact so held. The information sought to be withheld has, to the best of my knowledge and belief, consistently been held in confidence by GNF-A, no public disclosure has been made, and it is not available in public sources. All disclosures to third parties including any required transmittals to NRC, have been made, or must be made, pursuant to regulatory provisions or proprietary agreements which provide for maintenance of the information in confidence. Its initial designation as proprietary information, and the subsequent steps taken to prevent its unauthorized disclosure, are as set forth in paragraphs (6) and (7) following.
- (6) Initial approval of proprietary treatment of a document is made by the manager of the originating component, the person most likely to be acquainted with the value and sensitivity of the information in relation to industry knowledge, or subject to the terms under which it was licensed to GNF-A.
- (7) The procedure for approval of external release of such a document typically requires review by the staff manager, project manager, principal scientist or other equivalent authority, by the manager of the cognizant marketing function (or his delegate), and by the Legal Operation, for technical content, competitive effect, and determination of the accuracy of the proprietary designation. Disclosures outside GNF-A are limited to regulatory bodies, customers, and potential customers, and their agents, suppliers, and licensees, and others with a legitimate need for the information, and then only in accordance with appropriate regulatory provisions or proprietary agreements.
- (8) The information identified in paragraph (2) is classified as proprietary because it contains details of GNF-A's fuel design and licensing methodology.

The development of the methods used in these analyses, along with the testing, development and approval of the supporting methodology was achieved at a significant cost to GNF-A or its licensor.

- (9) Public disclosure of the information sought to be withheld is likely to cause substantial harm to GNF-A's competitive position and foreclose or reduce the availability of profit-making opportunities. The information is part of GNF-A's comprehensive BWR safety and technology base, and its commercial value extends beyond the original development cost. The value of the technology base goes beyond the extensive physical database and analytical methodology and includes development of the expertise to determine and apply the appropriate evaluation process. In addition, the technology base includes the value derived from providing analyses done with NRC-approved methods.

The research, development, engineering, analytical, and NRC review costs comprise a substantial investment of time and money by GNF-A.

The precise value of the expertise to devise an evaluation process and apply the correct analytical methodology is difficult to quantify, but it clearly is substantial.

GNF-A's competitive advantage will be lost if its competitors are able to use the results of the GNF-A experience to normalize or verify their own process or if they are able to claim an equivalent understanding by demonstrating that they can arrive at the same or similar conclusions.

The value of this information to GNF-A would be lost if the information were disclosed to the public. Making such information available to competitors without their having been required to undertake a similar expenditure of resources would unfairly provide competitors with a windfall, and deprive GNF-A of the opportunity to exercise its competitive advantage to seek an adequate return on its large investment in developing and obtaining these very valuable analytical tools.

I declare under penalty of perjury that the foregoing is true and correct.

Executed on this 28th day of October 2016.



Lukas Trosman

Engineering Manager, Reactor Physics Technology
Global Nuclear Fuel - Americas, LLC
3901 Castle Hayne Road
Wilmington, NC 28401
Lukas.Trosman@ge.com