

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards

Docket Number: (n/a)

Location: teleconference

Date: Wednesday, May 5, 2021

Work Order No.: NRC-1500

Pages 1-149

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

685TH MEETING

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

WEDNESDAY

MAY 5, 2021

+ + + + +

The Advisory Committee met via
Videoconference, at 2:00 p.m. EDT, Matthew W. Sunseri,
Chairman, presiding.

COMMITTEE MEMBERS:

MATTHEW W. SUNSERI, Chairman

VICKI BIER, Member

DENNIS BLEY, Member

CHARLES H. BROWN, JR. Member

VESNA B. DIMITRIJEVIC, Member

GREG HALNON, Member

WALTER L. KIRCHNER, Member

JOSE MARCH-LEUBA, Member

DAVID A. PETTI, Member

JOY L. REMPE, Vice Chairman

PETER RICCARDELLA, Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

ACRS CONSULTANT:

MICHAEL CORRADINI

DESIGNATED FEDERAL OFFICIAL:

DEREK WIDMAYER

ALSO PRESENT:

CYRIL DRAFFIN, USNIC

SCOTT MOORE, Executive Director, ACRS

QUYNH NGUYEN, ACRS

WILLIAM RECKLEY, NRR

JOHN SEGALA, NRR

MARTIN STUTZKE, NRR

NANETTE VALLIERE, NRR

P R O C E E D I N G S

2:00 P.M.

CHAIR SUNSERI: It is 2:00 p.m. Eastern Time. The meeting will now come to order. This is the first day of the 685th meeting of the Advisory Committee on Reactor Safeguards. I'm Matthew Sunseri, chair of the ACRS.

I will now call the roll and confirm a quorum and that clear communications exist. Normally, we would start with Ron Ballinger, but he's not available to attend this week and he has an excused absence, so I'll go to Vicki Bier. And I know that Vicki had contacted me and thought her availability might be a little uncertain this afternoon, so sounds like she's not available either. And that is an excused absence also.

Dennis Bley.

MEMBER BLEY: I'm here.

CHAIR SUNSERI: Charles Brown. Charles Brown. Vesna Dimitrijevic.

MEMBER DIMITRIJEVIC: Here.

CHAIR SUNSERI: Greg Halnon.

MEMBER HALNON: I'm here.

CHAIR SUNSERI: Walt Kirchner. Walt Kirchner. Jose March-Leuba. Jose? Dave Petti.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER PETTI: Here.

2 CHAIR SUNSERI: Joy Rempe.

3 MEMBER REMPE: Here.

4 CHAIR SUNSERI: Pete Riccardella.

5 MEMBER RICCARDELLA: Here.

6 CHAIR SUNSERI: And myself. So let me
7 check here. One, two, three, four, five, six, seven.
8 We barely have a quorum.

9 Walt, are you on yet?

10 MR. CORRADINI: I thought Walt said he was
11 coming on at 3 p.m.

12 CHAIR SUNSERI: Oh, that's right. Yes, he
13 did talk to me about that. That's another excused
14 absence. So how about Jose? Jose?

15 MR. NGUYEN: I just let him in, so I think
16 he's here.

17 CHAIR SUNSERI: Jose, are you talking
18 about Jose?

19 MR. NGUYEN: Correct. Charlie is also
20 showing up.

21 MEMBER BROWN: I have got to leave my desk
22 here for a minute. I am here.

23 CHAIR SUNSERI: Okay, you're there.

24 MEMBER BROWN: I've got to take care of
25 myself. I'll be back in about three minutes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER RICCARDELLA: Walt shows as being
2 here, too.

3 MEMBER BROWN: I just logged in just now.

4 CHAIR SUNSERI: All right. Well, we have
5 a starter quorum now. We'll go ahead and get started.
6 Maybe by the time we get through with the
7 introductions everybody will be present.

8 MEMBER BROWN: Okay, I'll answer present
9 when you call me out.

10 CHAIR SUNSERI: That's fine. All right,
11 so let me just divert a little bit here before I
12 continue. I want to take a moment and recognize the
13 fact that former Commissioner Lyons passed away last
14 week and you've likely seen reports on the multitude
15 of technical accomplishments he made. I unfortunately
16 never had the privilege to work with him during his
17 times as a Commissioner and made several drop-ins and
18 visits with him and I found him to be a very brilliant
19 technically, and of very sound character.

20 And I know there's other members on the
21 committee that knew him much better than me and I'll
22 just pause at this moment to see if anyone wants to
23 say anything.

24 MEMBER REMPE: Sure, Matt. This is Joy.
25 And yes, I was fortunate enough to work with Pete when

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 he was at DOE. Again, there are many kind and
2 wonderful things one can say about Pete, but what
3 always amazes me was his low-key manner and civility
4 and had a very kind of way interacting with people
5 which I greatly appreciated.

6 CHAIR SUNSERI: Yes, I totally agree. He
7 was a special person. He's going to be missed by our
8 industry.

9 I think Walt had a close relationship with
10 him as well and wish he was here to say something, but
11 anyway. All right, anybody else? Thank you for that.

12 The ACRS was established by the Atomic
13 Energy Act as governed by the Federal Advisory
14 Committee Act. The ACRS section of the U.S. NRC
15 public website provides information about the history
16 of the ACRS and provides documents such as our charter
17 bylaws, Federal Register notices for meetings, letter
18 reports, and transcripts of all full and subcommittee
19 meetings including all slides presented at the
20 meeting.

21 The committee provides its advice on
22 safety matters to the Commission through its publicly
23 available letter report. The Federal Register notice
24 announcing this meeting was published on April 7th,
25 2021, and provided an agenda and instructions for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 interested parties to provide written documents or
2 request opportunities to address the committee. The
3 Designated Federal Officer for this meeting is Mr.
4 Derek Widmayer.

5 During this week, the committee will focus
6 on the following for the remainder of most of the day
7 or the remainder of the day, we're going to take up an
8 interim letter report on 10 CFR Part 53, rulemaking
9 for licensing of advanced reactors. There will be
10 some staff presentations and then we will get into
11 report preparation following that.

12 Tomorrow morning, we will begin with a
13 White Paper on Fusion which is an informational
14 briefing.

15 Regarding Agenda Item 5 for tomorrow,
16 updated NuScale standard design approval application
17 update, NuScale has requested that this item be
18 removed from the agenda. NuScale plans to provide an
19 update at a date closer to when the standard design
20 approval would be submitted. The purpose of the
21 meeting was to discuss NuScale's 250 megawatt thermal
22 standard design approval regulatory engagement plan
23 and which proposed four phase review process.

24 Interested members of the public may
25 access the regulatory engagement plan in ADAMS and I'm

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 going to give a number here so I'll pause just a
2 second so that you can ready yourself to copy. The
3 ADAMS number is M as in Mike, L as in Lima, 21047 A as
4 in Alpha, 475. That's the engagement plan and the
5 four phase review process proposal is M as in Mike, L
6 as in Lima, 21112 A as in Alpha 183.

7 I apologize for any inconveniences this
8 may have caused by changing this agenda this way.

9 The other topics that we will take up in
10 under the general topic of report preparation and
11 other committee business and that is the NuScale
12 control room staffing plan. This is a letter report
13 that carried over from the last committee meeting.
14 And this will be our number one priority to get this
15 letter report out this meeting. And we also are
16 updating our bylaws as an action item from our
17 retreat. We will work this item in as time permits.

18 As far as the interim letter on Part 53,
19 there's a lot of work that still needs to go into this
20 letter and I talked to Dennis. My goal will be to
21 have a read in of the draft letter today and then try
22 to get agreement on recommendations and conclusions by
23 the end of the week. If we can complete the letter by
24 the end of the week, that would be the stretch goal,
25 but right now I don't know if that's going to be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 achievable or not, but we can get at least through the
2 read through and the agreement on the draft
3 recommendations and conclusions that would be a good
4 position to be in.

5 A phone line, a phone bridge line has been
6 opened to all members of the public to listen in on
7 the presentation and committee discussions. We have
8 received no comments and only one request to make oral
9 statements from a member of public regarding today's
10 session. And this is a request from USNIC and that
11 will come during the comment period following the Part
12 53 presentation.

13 There is also an opportunity for public
14 comment and we have set aside time in the agenda for
15 comments of members of the public attending this
16 meeting. Written comments may be forwarded to Mr.
17 Derek Widmayer, the Designated Federal Officer. A
18 transcript of the open portion of the meeting is being
19 kept and it is requested that speakers identify
20 themselves and speak with sufficient clarity and
21 volume so that they may be readily heard.
22 Additionally, participants should mute themselves when
23 not speaking.

24 Now one small change you noticed during
25 the roll call is we have two new members that have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 been appointed to ACRS since our last full committee
2 meeting. And I want to welcome Vicki Bier and Greg
3 Halnon to the committee here. I'm going to do a
4 little bit of introductions here. I'll put my camera
5 on for this. Vicki is not here, so I'll save this for
6 tomorrow.

7 But Greg Halnon is an independent nuclear
8 industry consultant who has more than 40 years of
9 experience in the nuclear industry. Mr. Halnon has
10 expertise in all aspects of nuclear plant operations,
11 as well as quality standards, security maintenance,
12 and engineering processes. He currently holds a
13 professional engineering license in two states and has
14 held two senior reactor operator licenses during his
15 career.

16 Mr. Halnon earned a Bachelor of Science
17 degree in engineering from the University of Central
18 Florida with emphasis on mechanical and thermal
19 hydraulics. And it is also worthy to note that Greg
20 is a life member of the American Nuclear Society.

21 So Greg, welcome to the committee. If you
22 have anything you want to say before we get started?

23 MEMBER HALNON: Thank you, Matt. Real
24 briefly. I just appreciate everybody's welcoming and
25 it didn't take me long to very much appreciate the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 quality of people, both on the staff and ACRS. And I
2 really look forward to interacting through this
3 appointment. So I appreciate the time.

4 CHAIR SUNSERI: And I'm not doing
5 something right here with my attendee list, but I see
6 somebody has their hand up and I don't know who that
7 is, so whoever has their hand up, you have the floor.

8 MEMBER MARCH-LEUBA: It might be me,
9 sorry. This is Jose. I'm back. I've been taking
10 every single thing so yes, I am back.

11 CHAIR SUNSERI: Could you hear us when we
12 were doing the roll call?

13 MEMBER MARCH-LEUBA: No, I couldn't. It
14 was a long story, but I'm back.

15 CHAIR SUNSERI: Okay, all right. No
16 problem. All right, all right, well, that's good. We
17 have a strong quorum now.

18 All right, so that is all for the
19 introductions and opening remarks. I'll open the
20 floor to the committee. Any member have anything you
21 want to say before we get into the agenda?

22 All right, well, then at this point I will
23 turn the floor over to Dennis Bley for the interim
24 letter report on 10 CFR 53.

25 MEMBER BLEY: Thank you, Mr. Chairman.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 This is not dealing directly to the letter; the staff
2 at the back to give us a presentation. I have asked
3 them to do another overview especially on Subparts B
4 and C for members who were not able to listen in all
5 of our subcommittee meetings.

6 I've asked the staff to do this as quickly
7 as reasonable to do that review. There were also some
8 areas that came up at our April 22nd meeting where
9 some additional staff's expertise would have been in
10 response to questions from the committee and I've
11 asked them to go back over some of those issues so
12 that they're planning to do that.

13 After we get through the staff
14 presentation, you may know that USNIC has asked for a
15 chance to speak and Mr. Cyril Draffin will then
16 provide comments to us on their behalf. And then
17 we'll do a read through of the letter that's been put
18 together to support this thing and we'll try to make
19 sure we get through all of that before the end of the
20 day.

21 So at this time, I'm going to turn it over
22 to staff.

23 John Segala, did you want to begin or
24 somebody else?

25 MR. SEGALA: Yes, thank you. Yes, this is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 John Segala, Chief of the Advanced Reactor Policy
2 Branch in the Office of Nuclear Reactor Regulation.
3 And consistent with the Nuclear Energy Innovation and
4 Modernization Act, or NEMA, we are committed to
5 developing a technology inclusive, risk informed, and
6 performance based regulatory framework for a wide
7 range of advanced reactor designs and publishing the
8 final Part 53 rule by October of 2024 in accordance
9 with the Commission's directed schedule.

10 We are committed to a regulatory framework
11 for advanced reactors that achieves the goals of the
12 Commission's advanced reactor policy statement and the
13 NRC's principles of good regulation. We are having
14 extensive stakeholder engagement where we release
15 preliminary rule language to solicit feedback to
16 better inform the staff's proposals and to ensure a
17 shared understanding of what will be included in the
18 final rule.

19 As we are considering changes to the
20 previously released preliminary rule language, we want
21 to ensure that we have appropriately considered the
22 feedback we have received from all stakeholders
23 including the public, industry, standards development
24 organizations, trade groups, non-governmental
25 organizations, and the Advisory Committee on Reactor

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Safeguards.

2 Since we are at the early stages of the
3 rulemaking process, the draft preliminary rule
4 language will remain open for discussion as the staff
5 works towards providing the Commission a proposed
6 rule. We are here today in the fifth of many ACRS
7 meetings we will be having this year to seek ACRS
8 feedback on the NRC's development of Part 53
9 preliminary proposed rule language for advanced
10 reactors.

11 We previously briefed the ACRS
12 Subcommittee in January on the first set of
13 preliminary rule language in Subparts B and F, in
14 February on Subparts C and D in March, where
15 stakeholders shared their insights and we discussed
16 the structure and logic of Part 53, key guidance
17 needed for Part 53 and Subpart E on construction and
18 manufacturing.

19 In April, our last meeting where we
20 discussed the second iteration of the preliminary rule
21 language in Subparts B and C and the key elements of
22 the Part 53 framework in order to set the stage for
23 the ACRS full committee meeting today.

24 Today, we plan to provide the full
25 committee an overview of the Part 53 structure and the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 preliminary rule language for Subpart B and C. We
2 also plan to provide additional information to help
3 answer questions brought up during the April
4 subcommittee meeting. We understand that ACRS plans
5 to develop an interim letter report following this
6 full committee meeting and we are looking forward to
7 hearing any insights and feedback from the full
8 committee today, as well as the conclusions and
9 recommendations in the ACRS interim letter.

10 This completes my opening remarks. And I
11 can turn it over to Bill Reckley or Bob Beall.

12 MR. RECKLEY: Yes, this is Bill Reckley.
13 Did you have something, Dennis?

14 MEMBER BLEY: No, I'm conferring, but I
15 would like to hear from you though.

16 MR. RECKLEY: All right. We can go to the
17 next slide.

18 So on Slide 2, as John mentioned, we're
19 going to go over the overall structure. We're not
20 going to spend too much time on that. There seem to
21 be an general understanding and at least for now a
22 general support of the overall structure. Then we're
23 going to look at Subpart B on the safety requirements
24 and Subpart C design and analysis.

25 As Dennis mentioned, there's a fair amount

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of material to try to go through in a couple of hours.
2 So we're going to go relatively quickly. If there's
3 a need to stop and pause and go over some things, that
4 would be understandable. But some of it also, some of
5 the specific topics like the probabilistic risk
6 assessment, some elaboration on our plans to use PRA
7 within Part 53, we have added a few slides and Marty
8 Stutzke will be doing that presentation when we get
9 into Subpart C on design and analysis.

10 But for now, if we go to slide -- the next
11 slide. John mentioned this in the background already.
12 We had, as part of overall plans for advanced
13 reactors, considered a rulemaking even back in 2016,
14 as we were laying out our strategies. We were -- then
15 events kind of overtook us with the passage of NEMA
16 and signing that into law in 2019 and that law
17 specifically told us to develop a framework through
18 rulemaking to address advanced reactors and so that
19 changed our schedule a bit and is largely the reason
20 we're here today.

21 If we go to Slide 4 --

22 MEMBER REMPE: Bill?

23 MR. RECKLEY: Yes.

24 MEMBER REMPE: This is Joy. I thought of
25 something when we last met that Dennis and I discussed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 later. And I think Dennis said he didn't hear what I
2 heard and I'm not, maybe I got confused. But I asked
3 you a couple of questions last meeting about mostly
4 gatekeeper, you were trying to do with Part 53 giving
5 folks a little more flexibility because they are an
6 advanced reactor with increased reliance on passive
7 and inherent safety features.

8 So what if someone comes with something
9 that's a Superphenix, you know, Clinch River thing
10 that doesn't have any passive, well, not many, passive
11 or inherent safety features. What's the gatekeeper --
12 because I thought you'd said well, if we see something
13 like that and it's not meeting the requirements, we're
14 going to impose some additional requirements on them.
15 It sounds kind of fuzzy to me.

16 When do you decide it's got sufficiently
17 increased reliance on passive and inherent features?
18 That sounds a little fuzzy.

19 MR. RECKLEY: And to be clear, NEMA gave
20 a number of criteria and some of it was related to
21 passive or inherent safety features. Other of the
22 criteria within NEMA had to do with cost of
23 electricity, fuel utilization, or waste yields,
24 reliability, proliferation, increased thermal
25 efficiency which most or at least many of the non-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 lights would engender, or the ability to use for non-
2 electric applications like hydrogen production. So
3 within the NRC's advanced reactor policy statement,
4 the focus was, as you mentioned, passive inherent
5 safety benefits.

6 Within NEMA, there's a number of
7 considerations that could qualify one to be quote an
8 advanced reactor. So we had in our rulemaking plan
9 acknowledged that light water at a minimum, light
10 water SMR, Small Modular Reactors, and any non-light
11 water reactors, so a generation for technology be it
12 a Superphenix or a medium size fast reactor like PRISM
13 or some of the micro reactor designs being considered
14 now. Any of those would have been falling into that
15 category most likely.

16 The question had become what about large
17 light water reactors, the Generation III+ kind of
18 technologies. Our original thinking was they may or
19 may not come into play. So at this point, you know,
20 there will be many more that would go through the gate
21 than would be stopped by the gate. Maybe I can just
22 put it that way, if that answers the question?

23 MEMBER REMPE: What's the gate? I recall
24 a long time ago that the Commission said well, the
25 current fleet is safe enough and advanced reactors

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 don't have to be safer because the current fleet is
2 safe enough. And we didn't give them increased
3 flexibility, so it would sound to me is what you're
4 saying is everything gets in or is there some place
5 where if they meet the safety criteria everybody is
6 in, right?

7 MR. RECKLEY: Yes, pretty much. The only
8 question that really NEMA raised when you look at
9 those criterias and this is just from my point of
10 view, the only question raised is it said advanced
11 reactors other than those under construction at the
12 time of the act. And the only construction under way
13 at the time of the act was AP1000.

14 So that's why we were questioning whether
15 Gen III+ might be included, but all of this will be
16 kind of brought out as we finish out this rulemaking
17 and agree on the scope. But there won't be very many
18 technologies excluded in my mind based on the criteria
19 that Congress included which went well beyond passive
20 or inherent safety features and included things like
21 fuel utilization, non-electric uses and so forth.

22 MEMBER REMPE: Then I guess my next
23 question is why do you keep saying these things are
24 going to be safer because you just had told me
25 everybody is in?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. RECKLEY: In the advanced reactor
2 policy statement, first of all, I hope we don't
3 overuse that they are safer, as you mentioned, and as
4 we'll get into as we go through Subparts B and C. The
5 way I like to put it is they provide their safety
6 through different mechanisms and light water reactors
7 include a certain amount of reliance, for example, on
8 mitigation, including emergency planning, siting
9 restrictions, and so forth.

10 One of the goals of Generation IV reactors
11 and we've heard from stakeholders that this remains
12 true is to lessen the reliance on things like siting
13 and emergency planning as a safety measure and as it
14 was discussed in the advanced reactor policy
15 statement, to ensure safety more through the design of
16 the facility and the use as you've mentioned a couple
17 of times, the use of passive and inherent safety
18 features.

19 So when you look at it as an integrated
20 assessment of the safety of any particular plant down
21 the road, the overall safety in terms of protecting
22 public health and safety will be at least as good as
23 what we have now for the light water reactors, but
24 more importantly how you get that safety might be
25 different.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER REMPE: It might be different, but
2 it doesn't have to be different.

3 MR. RECKLEY: It doesn't have to be
4 different.

5 MEMBER REMPE: Yes. I think we need to
6 keep this in mind because making a lot of assumptions
7 about oh, they're going to do more things with passive
8 and inherent, but unless there's a gate to keep that
9 and what is more reliance, there isn't any.

10 MR. RECKLEY: Right.

11 MEMBER REMPE: So that's like of a fiction
12 here, it's all everybody's dream, but anybody can get
13 through the gate is I guess what I'm learning a little
14 more explicitly.

15 MR. RECKLEY: And another way to put that
16 is, for example, we're allowing, we're trying the way
17 we're writing the rule, to allow for the use of less
18 reliance on emergency planning if it can be justified.
19 But we're not requiring that there be no reliance on
20 emergency planning, right?

21 So going to exactly what you said, they
22 could achieve safety through some of the same
23 measures, siting restrictions, and emergency planning,
24 and so forth as the current fleet. And we're trying
25 not to preclude it, but we're also saying if in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 design process you can justify that you don't need to
2 rely on those measures, then we're trying to build in
3 the flexibility to say that you've proved your point
4 through the design process and you don't need those
5 additional measures that were imposed for light water
6 reactors.

7 MEMBER REMPE: Thank you. I appreciate
8 this long discussion on this, but I think it's good to
9 lay it out on the table.

10 MR. RECKLEY: And it's actually, thank
11 you, because it's kind of important as we go to the
12 next -- we can go to the next slide on Slide 4.

13 MEMBER BROWN: Bill, Bill?

14 MR. RECKLEY: Yes.

15 MEMBER BROWN: I just want to echo Joy --
16 go backwards again.

17 MR. RECKLEY: Okay.

18 MEMBER BROWN: You make the comment, this
19 is what bothered me the whole time on these advanced
20 reactors, they're safer, they're passive. We've heard
21 that continually and they're uranium. It's got to be
22 fissioned in order to produce power. And you won't
23 produce power for large populations, a lot of power in
24 many cases, most cases. So you've got all the same --
25 the same pot is cooking, it's just being handled

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 differently.

2 How in the world can you ever get away
3 from emergency planning zones and site boundaries and
4 all that other kind of stuff and/or dosage
5 requirements? I don't see how you could ever -- it's
6 all the same stuff. All we're doing is adding more
7 toxic means in most circumstances, lead bismuth,
8 sodium. I'd love to have one of those plants go melt
9 down somewhere.

10 So the idea that they're passive and that
11 makes them safer just means it's less complex to be --
12 to make sure the plant shuts down. So I hate the
13 advertising of we're going to get rid of emergency
14 planning zones and everything else. It's just an
15 observation. I had to see it used. So I just needed
16 to say my piece as well.

17 I'm not criticizing you, Bill.

18 MR. RECKLEY: No, that's fine. And again,
19 we're just trying, and we'll get into this a little
20 later in the discussion, trying to take this
21 integrated look and say when would you rely on certain
22 provisions and when might you justify that you don't
23 need to rely on those provisions. We'll get into that
24 a little later as we go along.

25 MEMBER PETTI: Just for the record, your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 discussion of how safety is achieved is exactly what
2 the Gen IV International Forum and the experts
3 internationally thought about as they rolled out the
4 leading Gen IV concepts. So I see a lot of
5 consistency with that, thank you. Thanks.

6 MR. RECKLEY: Okay, thanks, Dave. Okay,
7 so if we can go to Slide 4. This is our overall
8 structure for Part 53 and how we arranged it into a
9 number of subparts.

10 And most of the discussion with the
11 subcommittee thus far has been on Subparts B and C.
12 But the general arrangement is that Subpart B was
13 intended to layout the safety goals, the safety
14 objectives, the criteria that would be used and the
15 need to identify safety functions.

16 And then the other subparts were basically
17 organized along the lines of a project lifecycle and
18 were intended to, for example, under design and
19 analysis, Subpart C say, what is the contribution that
20 design and analysis provides to make sure that any
21 particular plant, any particular design meets the
22 safety objectives and meets the safety criteria.

23 And then likewise, what's the role of
24 citing, construction, operations and how would that be
25 carried into retirement. So that was the nature of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the main technical subparts, B through G.

2 Then in addition, there were subparts
3 related to licensing that we're currently developing.
4 Those are Subparts H and I. And then administrative
5 reporting, other general provisions, that would be in
6 Subparts A and J.

7 But again, most of the focus with the
8 Subcommittee, and with external stakeholders, has been
9 on Subparts B and C, up to this point.

10 So, if we got to Slide 5, another way to
11 lay this out for the Subcommittee. We had gone
12 through the individual chapters. For the sake of time
13 I didn't do that today, but this just lays out the
14 same thing from the graphic in kind of more of a chart
15 or a table of contents with the Subparts A through J.

16 Subparts B and C are highlighted because
17 we want to spend more time talking about those today.
18 In red is just some of the, some notes on particular
19 subparts.

20 And in particular, on Subpart B, under
21 safety criteria, some of the discussion topics as
22 included. Our organization of the requirements into
23 the first and second tiers, or categories, of safety
24 objectives.

25 The use of as low as reasonably achievable

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 within the criteria related to normal operations. And
2 how you achieve defense-in-depth.

3 And then under the design and analysis,
4 some discussion on how we propose to have the design
5 criteria addressed and the role of probabilistic risk
6 assessments that we'll get into in a few minutes.

7 So, I had not planned on spending much
8 more time. If we can just go back to Slide 4 for a
9 second.

10 I hadn't planned to spend much more time
11 on the overall structure or organization of Part 53,
12 unless there are specific questions.

13 MEMBER BLEY: Yes. This is Dennis, Bill.
14 Charlie brought up a point and argued it, and it's
15 similar to, Charlie, it's similar to what you wrote
16 down for, and delivered it in the last meeting last
17 week.

18 And essentially it boils down to, you
19 cannot assume that new reactors coming in will be
20 safer. And the objective to that assumption.

21 And it seems to me, although some of the
22 hype makes that assumption the approaching you're
23 taking doesn't allow for it. You can't assume it, you
24 have to show that you meet the level of safety. You
25 can comment on that or not?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. RECKLEY: Well, I think as we're
2 trying to, as we get into Subpart B, on the criteria,
3 the other thing that we will emphasize is that based
4 on past Commission decisions, the highest level
5 criteria remain the same. We haven't proposed, for
6 example, and we'll get into the discussion on the
7 health objectives, but we haven't proposed to use
8 different health objectives, we're using the same ones
9 from the advance reactor policy statement.

10 Again, how you achieve those objectives
11 might differ from design to design. In terms of the
12 plant design, there is going to be reliance on
13 different barriers and technologies based on the type
14 of reactor.

15 And again, we're laying out the
16 possibility that if any designer or licensee wanted to
17 use mitigation measures, the comparable up to what
18 light water reactors do, then we're not precluding
19 that. So, I'm not sure I addressed your question, but
20 --

21 MEMBER BLEY: That's fine, Bill.

22 MR. RECKLEY: Okay. All right, so if
23 there is no other discussion of the overall structure,
24 we can get into Subpart B. Yes, thank you.

25 And then just go onto Slide 7. One point

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that I'm not sure we emphasized in the Subcommittee
2 meeting that I did want to just revisit and emphasize
3 by having a slide is that we have said in various
4 papers, including the rulemaking plan sent up to the
5 Commission, SECY-32, that we were planning to build
6 Part 53 based on the activities that were ongoing at
7 that time or that we had completed shortly before
8 then. Such as Secy-19-0117. Which I won't read that
9 long title, but the shorthand of that is licensing
10 modernization project.

11 And NEI 18-04, the ACRS looked at that
12 paper and at the associated reg guide, Reg Guide
13 1.233. But I just wanted to reiterate that our plan
14 was to take such a risk-informed approach. And that's
15 what was communicated to the Commission in those
16 papers and what was accepted within the SRM for both
17 the rulemaking plan and SECY-19-0117.

18 So, if we go to Slide 8. This goes
19 largely to both Charlie and Joy were mentioning. The
20 nature of a reactor is that it's making fission
21 process. It's how it makes its energy, and as a side
22 product it's making fission products. And that's the
23 hazard.

24 And this graph basically shows that as the
25 black inventory shape. And the nature of reactor

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 safety is basically to provide barriers to the
2 dispersion of those radionuclides to the environment.

3 And in some cases, as we talked about a
4 couple of times, if you cannot preclude the dispersion
5 then you might have mitigation measures on the
6 outside. Such as restricting where you can cite them
7 and/or providing protective actions, such as the
8 sheltering or evacuation in nearby populations. And
9 so, all of those things considered are what determines
10 the risk to public health and safety.

11 We first used this graphic, or a graphic
12 that was similar to it, in SECY-19-0117 to try to
13 describe how within the risk-informed approach we were
14 reflecting in that paper, considers things like
15 mechanistic source term and a more integrated
16 approach.

17 And so, you will see the other paper cited
18 there is the functional containment paper, SECY-18-
19 096. Where if, to simplify a little bit, for light
20 water reactors the general approach has been generally
21 to pick bounding, challenging kind of events for each
22 barrier.

23 And so there would be challenges to the
24 cladding and then there would be challenges to the
25 reactor coolant system and challenges to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 containment. They may be different events. And the
2 most challenging event basically establishes the
3 design requirements on each barrier.

4 Under this you're still looking, you
5 largely are going to have the same or types of
6 barriers, but you're taking a more, you're looking at
7 more event scenarios and taking an integrated approach
8 to looking at each scenario. And that is reflected,
9 again, the functional containment paper, in the
10 licensing modernization paper, as another way to
11 basically look at ensuring that appropriate barriers
12 are in place to the release of radionuclides.

13 And we'll get into this as we go into the
14 discussion a little more on licensing bases events and
15 Marty's discussion on the use of the probabilistic
16 risk assessments.

17 But the, so, let's go on to Slide 9. This
18 is a slide we used during the Subcommittee meeting.

19 And we look at Part 53 in our construct,
20 and that overall structure, one of the things to keep
21 in mind, just to keep the terminology straight as we
22 go through Subparts B and C, is this --

23 THE OPERATOR: If you're on the bridge
24 line please mute your phone. Please mute your phone.

25 MR. RECKLEY: Okay, thank you. The kind

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of hierarchy is shown in the chevrons that we start in
2 Subpart B laying out the safety criteria, then we
3 require safety functions as a means to satisfy those
4 criteria.

5 And then when we get into Subpart C we'll
6 talk about design features. Which is the hardware,
7 the structure systems and components needed to carry
8 out the safety function. And then functional design
9 criteria, which are the more specific things
10 associated with the design feature to make sure that
11 it will support meeting the safety functions and the
12 safety criteria.

13 So over in the white boxes, the functions
14 are things like what barrier is needed, what cooling
15 might be needed to maintain a barrier.

16 The design feature would be specific
17 structures and systems and components, pumps, heat
18 exchangers, control rods, whatever the function and
19 then whatever the design feature you're using.

20 And then the design criteria would be
21 things like leak rate, reactivity insertion rates,
22 cooling capacities, more specific engineering
23 parameters associated with components. Like pumps and
24 heat exchangers and so forth.

25 So this is the layout of Subpart B, with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the first, or major focus being the safety criteria
2 and the safety functions. And then in addition we
3 have specific requirements on assessing the unplanned
4 or licensing basis events, ensuring defense-in-depth
5 and the protection of workers.

6 So, another way to characterize Subpart B
7 is these are the, Subpart B is the what. What are we
8 trying to accomplish. And that's, again, meeting the
9 safety criteria, supplying the safety functions.

10 Subpart C, and all the other subparts, get
11 into the how. What are the design features. In the
12 parentheses we start to address things that we will
13 put in requirements in operations related to human
14 actions. What are the role of personnel and so forth.
15 So, the other subparts talk about the how.

16 So, if we go down one more. I repeated
17 this graphic, again, in Slide 10, and enhanced it just
18 a little bit to bring in an example of how, in the
19 past, we've used such an exercise of going from
20 functions to features to functional design criteria in
21 a specific reactor type. And this is the MHTGR.
22 Modular high temperature gas reactor.

23 As we'll talk about in a minute, this
24 exercise was also gone through in order to arrive at
25 the general design criteria or the advance reactor

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 design criteria that are included in either Appendix
2 A to Part 50 or in Reg Guide 1.232.

3 But you can see that the safety function,
4 as we've currently defined it in Subpart B, and we'll
5 get to the language in a minute, starts off with the
6 ultimate goal of limiting the release or
7 radionuclides. And then identifies what other
8 functions are needed to carry that out.

9 And that is, those functions that are
10 needed to protect whatever barriers a designer is
11 choosing to accomplish those functions. By and large,
12 that's going to be the fuel, some reactor system.
13 Whether it be the fuel encased in the cladding or some
14 kind of pressure boundary. And then in some cases, an
15 additional structure as a last barrier.

16 But for MHTGR it was identified, and we
17 gave the example during the Subcommittee meeting, that
18 you had heat generation or reactivity, heat removal.
19 This is decay heat removal systems, emergency systems.
20 And then for that time frame, when MHTGR was being
21 considered, they identified chemical interactions as
22 a different function.

23 But within our system, if those are the
24 required safety functions, then Part 53 would then
25 also say, within Subpart C, that we'll get to, you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 have to identify the design features that are going to
2 accomplish those functions and then you identify
3 additional engineering parameters to show that they
4 can support that.

5 And if you go back and look at the MHTGR,
6 and then to some degree, how that was carried through
7 next generation nuclear plant, you can see how this
8 has fed into the approach that we're proposing for
9 Part 53.

10 So, as the ACRS mentioned in your letter
11 on SECY-19-0117, that methodology and the methodology
12 that you're seeing in Part 53, is really an evolution
13 over the last 30 years. And so, some of what we're
14 going to do today is a little bit of history to kind
15 of fill in where we're getting this.

16 So, if you go to Slide 11, this is
17 basically the same slide again. The top of this slide
18 is right out of MHTGR and NGNP documents that show how
19 you go down and determine those, what are your
20 required safety functions.

21 And then I just added on to that figure
22 for Part 53 space. In Subpart C you would do the
23 design features and the functional design criteria in
24 order to fill out the detail on how you were doing
25 something like removing decay heat.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, if we go to Slide 11. I mean 12.
2 Thank you. One of the things that we talked about,
3 and think is true, is that if you look at the general
4 design criteria and the exercise that was done in the
5 late '60s to develop the general design criteria for
6 light water reactors, and then even more recently
7 three or four, well, from three years ago with the
8 issuance of Reg Guide 1.232 on the advance reactor
9 design criteria, the same exercise that we just
10 described in going from safety functions to design
11 features to functional design criteria, was largely
12 what was done for the, to develop the specific
13 requirements for light water reactors that's reflected
14 in the GDC.

15 And so, if you look at the safety
16 functions in the left in the first column, you'll see
17 reactivity control, fluid systems for heat removal and
18 containment systems. Those align pretty closely to
19 the fundamental safety functions of reactivity heat
20 removal and containment.

21 Or if you're familiar with another one,
22 the three C's, control, cool and contain. So those
23 principles were laid out in the GDC.

24 And then for light water technologies,
25 they basically filled in some specifics that became

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the individual GDC. So, we think it's a exercise that
2 is similar.

3 In order to support Part 53, which is
4 intended to be a technology inclusive approach, what
5 we're building into Part 53 is a requirement to go
6 through this methodology. And every designer or
7 applicant ultimately would have to do this in order to
8 come up with how they're going to perform the
9 functions and what design features they're going to
10 rely on to do that.

11 So, it is, to some degree, what we're
12 proposing to do on Part 53, and when we get to the
13 actual language in Subpart B, is to replace a fairly
14 perspective list of technical requirements with a
15 methodology to accomplish the same thing.

16 And when we were talking to the Committee
17 during the review of the reg guide and the SECY paper
18 on the licensing modernization project, we had the
19 same discussion of looking at these as a methodology
20 and a requirement to go through this exercise, versus
21 having a prescriptive list because the regulator, or
22 someone else, had already done it.

23 So, a useful exercise, if you have time,
24 is to really look, for example, at the reg guide on
25 the advance reactor design criteria, Reg Guide 1.232,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and look specifically at the MHTGR. One of the
2 technologies that's addressed in the advance reactor
3 design criteria is the MHTGR.

4 I point out that it's particularly
5 interesting because the MHTGR was really, from a
6 design and licensing process, the genesis of much of
7 what we're talking about, in terms of licensing
8 modernization, and even moving forward into Part 53.
9 And so, those folks that were involved in that, at the
10 time of the NGNP, were looking at the ARDC and
11 translating and doing this exercise.

12 And so you'll see, through the MHTGR ARDC,
13 some degree of how this plays out. And it somewhat
14 proves the point, at least to me, that the methodology
15 can get you to basically the same place.

16 If we now can go to 13. It just finishes
17 out the rest of the GDC, in terms of the other safety
18 functions. Fluid systems or cooling and containment.

19 And then, we can now start to get into,
20 okay, we have one more slide and then we'll get into
21 the Subpart B actual language.

22 So the next slide, Slide 14, again, just
23 tries to do some comparison of what people are more
24 familiar with, which is the light water or Part 50
25 construct. And some of the changes or alternatives

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that are being looked at in Part 53.

2 So, we talked earlier, the safety criteria
3 are basically the same. We're using the same
4 reference values. The 25 rem at the exclusionary
5 boundary. We're using the same QHOs.

6 Albeit, the QHOs don't show up
7 specifically in Part 50, but as we've talked about,
8 they are used in Part 52. Specifically under Chapter
9 19 of the SRP. I think Marty will talk about, more
10 about that when he goes through some of the PRA
11 discussions.

12 Within the design and analysis area, the
13 design basis events are similar. But under Part 50,
14 given the way that Part 50 was developed, it's more
15 prescriptive. It's more conservative.

16 It includes, for example, and we're going
17 to have specific slides on the single failure
18 criterion, so I have it highlighted, but I didn't want
19 to spend much time on this slide.

20 Under Part 53 it's more, it still includes
21 a deterministic DBA in terms of a test of safety
22 related equipment. It still performs that function of
23 having a deterministic DBA.

24 It's probably a little more, it's a little
25 less conservative under Part 53. And the reason for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that is the next bullet. Is that, under Part 50,
2 beyond design basis events were kind of ad hoc under
3 Part 50.

4 And under Part 53 you have a whole
5 category, a new category of events, in which you're
6 doing a methodical assessment. And coming up with
7 design and programs and operator actions needed to
8 address the events down in that category. We will
9 also talk about that when Marty does the PRA
10 discussion.

11 The special treatment for non-safety
12 related, but safety significant SSCs.

13 MEMBER BLEY: Bill?

14 MR. RECKLEY: Yes, Dennis.

15 MEMBER BLEY: I want to stop you just a
16 second. I agree with what you said up there but if
17 one looks at your 53.450, Paragraph F, analysis of
18 design basis accidents, it uses the words conservative
19 and the other typical words. But it doesn't really
20 define what they mean.

21 See, what they mean right now is defined
22 from the SRP in Chapter 15, and you don't have any
23 definition here. Which means some people are kind of
24 feeling empty that there is no requirement.

25 MR. RECKLEY: Yes. And that might be a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 great point to clarify or enroll language or guidance
2 provide.

3 The reason I say it's somewhat less
4 conservative is that the event that's being analyzed
5 under Part 50, and in particular, for example,
6 treating the double ended guillotine break. The
7 frequency of that particular event, if you looked at
8 it from a PRA standpoint, might move it under Part 53
9 down to a beyond design basis event.

10 And it would still need to be addressed
11 but it might now show up as the design basis accident
12 as it was, for good reason, for the light water
13 reactors when it was developed using the process
14 developed for Part 50. The evolution of Part 50.

15 So, in terms of like the thermal
16 hydraulics, and some of the conservatisms that are
17 built in to making sure that if you're using a
18 particular correlation or something like that, then
19 that would be, that's, when we say a conservative
20 analysis under, in our Part 53, Section 450, that's
21 what we were referring to when we say conservative.

22 You know, you'd have to make sure that the
23 actual modeling including the appropriate
24 conservatisms in the DBA. Some of this we'll get into
25 as we discussed the specifics, I think.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 But again, the reason I highlighted single
2 failure, that came up during the Subcommittee meeting,
3 but we have a couple of slides specifically on that.
4 And also looking at the combinations of failures
5 within the PRA, and the two topics are related, as
6 we'll see as we get into the discussion.

7 So, Slide 15. So now we're going to get
8 into the specific language. On Slide 15, this is the
9 language that we established, that the objectives are
10 to limit the possibility of an immediate threat to
11 public health and safety, and then appropriate
12 measures considering risks.

13 There was a discussion during the
14 Subcommittee meeting on whether we would need to
15 define those terms more.

16 And I just wanted to point out, and have
17 highlighted here, that from our perspective, though
18 the meaning of those terms, if you just read them as
19 they're written, might lead to questions. But the
20 last sentence there is meant to clarify what we mean
21 by that. And these safety objectives shall be carried
22 out by meeting the safety criteria identified in the
23 subpart.

24 So to translate that, what do we mean by
25 an immediate threat to public health and safety, is an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 event that would lead to 25 rem over two hours at the
2 exclusionary boundary or over the duration of the
3 event at the low population zone boundary. So that's
4 what we're equating to be an immediate threat to
5 public health and safety.

6 And then as we get to the second tier,
7 what do we mean by appropriate, considering potential
8 risk to public health, that's the QHOs. So, we do
9 think that sentence, hopefully, puts in context what
10 we mean by the high level objectives.

11 If we go to 16, we go into start talking
12 about the first tier. And the language, as I just
13 said, was that the dose, largely from a, well, it's
14 two parts.

15 Part A is normal operations. And we
16 include, within the first tier safety criteria, the
17 100 millirem from Part 20. That's the annual dose
18 from normal effluence.

19 And then more focus is on the unplanned
20 events. And again, we use the same reference values.
21 And as we'll talk about under, as we go down, this
22 analysis is a DBA type analysis, only relying on
23 safety related equipment. And it will show that the
24 dose at the EAB, or low population zone boundary, is
25 less than 25 rem over the duration of two hours or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 over the whole course of the event.

2 So if we go then to Slide 17, this is
3 somewhat repetitious of what I just said. Twenty-five
4 rems, same reference values we've historically, only
5 relied on safety related equipment demonstrated by a
6 deterministic type DBA.

7 It also is the vehicle for which we ensure
8 an appropriate protection against external hazards.
9 Again, that's largely consistent with how it's done
10 now where the safety related equipment is protected
11 against design basis seismic events or floods or other
12 hazards.

13 And then one last point is, we're going to
14 carry this through, as I mentioned, through the whole
15 rest of the subparts. And it shows up again, for
16 example, under what is the equipment that would be
17 handled and controlled, tightly, through technical
18 specifications. It would be the equipment needed to
19 satisfy this first tier.

20 So the desire there would be to be always
21 able to say that the plant is meeting that first level
22 goal of not presenting an immediate threat to public
23 health and safety.

24 And then as we get into the second tier,
25 you'll see a parallel where we try to take a risk-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 informed approach. And also carry it through the
2 design, the construction and operations where we
3 basically have the same table for non-safety related
4 but safety significant equipment, and the need to
5 define special treatment for all of those things
6 throughout the lifetime.

7 So, if we go onto Slide 18.

8 MEMBER HALNON: Excuse me, Bill?

9 MR. RECKLEY: Yes.

10 MEMBER HALNON: Bill, this is Greg Halnon
11 and I just wanted to comment on the immediate aspect
12 of this. And we don't have to have a lengthy
13 discussion, but by putting the term immediate in the
14 rule itself, it gives it a very temple emphasis as
15 opposed to the way you're describing it, at least in
16 my mind, is more emphasis on consequence opposed to
17 the tempo aspect of it. So keep that in mind.

18 And when I read it I see a tempo, urgent
19 tempo aspect to it. And the way you described it, at
20 least in my mind is, more of a consequence or an
21 ultimate consequence of an event that could be very
22 long as opposed to intermediate thing. So, anyway,
23 that's my opinion there.

24 MR. RECKLEY: Yes. And we'll look at the
25 language to see if the word immediate, and where we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 got the word immediate threat to public health and
2 safety is actually from the case law on technical
3 specification and what is the appropriate content to
4 tech specs.

5 And knowing that we wanted to carry that
6 threat all the way through, and just looking at how
7 things had been characterized, tech specs, and again,
8 since it's been what we've regulated, large light
9 water reactors, it was put in the terms of an
10 immediate threat to public health and safety.

11 And so, maybe we can look at that. We'll
12 look at that language as we go through the future
13 iterations. I understand what you're saying though.

14 So, if we go then to Slide 18 it lays out
15 the second tier of criteria. And it's been much
16 discussion, but for normal operations, normal
17 effluence, we have kept that they should be kept as
18 low as reasonably achievable.

19 We're looking at future wording to tie it
20 into Part 20. And also into an appropriate
21 relationship with environmental protection agency
22 requirements under Title 40.

23 Under unplanned events, again, it's been
24 a lot of discussion, but the highlight texts is
25 basically the existing quantitative health objectives

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that the immediate health effects or prompt fatalities
2 would be less than five and ten million. And the risk
3 to, of latent health effects would be less than two
4 and one million years.

5 Again, based, that is the existing QHOs
6 just put out into words.

7 So, going on to Slide 19, just sensitive,
8 I received so much attention from stakeholders. We
9 have slides that we gave to the Subcommittee that
10 just, noting that many stakeholders did not believe
11 ALARA meant, a range of comments from ALARA shouldn't
12 apply to advance reactors down to, ALARA didn't need
13 to meet, in Part 53, because it was already addressed
14 in Part 20, to some proposing to keep it more or less
15 as we had proposed it.

16 Which is the same as it is provided in
17 Part 50. Specifically, although it's old, Appendix I
18 to Part 50.

19 So, our iteration has been, as we
20 discussed on the previous slide, to keep the ALARA
21 requirements in place. And looking forward, we did it
22 for occupational exposures, as well we for normal
23 effluence.

24 So if we go to Slide 20, the other area
25 that got a lot of discussions with stakeholders during

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the roll out of the preliminary language was on the
2 use of the QHOs. And again, a range of comments from,
3 don't include the QHOs, don't use the numerical
4 aspects of the QHOs and try to put it into more
5 general wording, to some who were in favor of
6 basically using them as we had proposed in the
7 preliminary language.

8 And our iteration has been to basically
9 keep them as we proposed in the first iteration. You
10 saw the language, we continued to refer to them as the
11 primary metric for unplanned events in the unlikely
12 and very unlikely event categories.

13 So, if we go then to Slide 21.

14 MEMBER DIMITRIJEVIC: Hi, this is Vesna
15 Dimitrijevic. I just want to make comment on your
16 previously slide. Where you said the QHO is a well-
17 established measuring using risk-informed, I would
18 challenge that because the QHO are not directly ever
19 used in the risk-informed, just substantive measures.

20 MR. RECKLEY: Well --

21 MEMBER DIMITRIJEVIC: You know, CDF. And
22 no one ever in the application looks back to QHOs. I
23 mean, they are originally used to deny those CDF, but
24 they're based on the couple very significant
25 assumptions which have never been checked.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So I would say the subsidy objectives are
2 well established, but not QHO. By any means.

3 MR. RECKLEY: Okay.

4 MEMBER DIMITRIJEVIC: They're based on the
5 conservatives and things like that. Like a
6 conservative change of like 30 percent to the aspect,
7 yes. Nobody ever goes back to QHOs.

8 MR. RECKLEY: And we'll have some slides
9 that Marty will talk about the QHOs and their
10 assessment. I will say more recently, before advance
11 reactors I worked in the area of the Fukushima
12 response, we used the QHOs.

13 When we were making determinations on
14 things like whether boiling water reactors should have
15 filters on the release, we were using the QHOs. When
16 we were looking at the assessment of whether we should
17 expedite the fuel, spent fuel transfer from poles to
18 casks, we used the QHOs.

19 So, yes, light water applicants have not
20 traditionally used the QHOs because, in large part,
21 surrogate measures have been developed. There have
22 been, in recent cases, the use of QHOs and decision
23 making.

24 But again, I don't want to get ahead of
25 ourselves, Marty is going to talk about that a little

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 bit. Or we have backup slides when Marty talks about
2 probabilistic risk assessments.

3 So, I understand what you're saying. Not
4 disagreeing that for light water reactors the use of
5 surrogates, such as CDF and large release frequencies
6 have been used instead of QHOs. Marty can better
7 address the derivation of those surrogates. So, we'll
8 get to that in a few, in a few minutes.

9 MEMBER DIMITRIJEVIC: All right.

10 MR. RECKLEY: So, Slide 21, goes to
11 somewhat of a caution, if you will, that one of the
12 reasons we need a metric, and it would have to be, as
13 all the aspects of Part 53 has to be technology
14 inclusive, but we have to have a fairly high level
15 metric, but well-defined metric, within the safety
16 criteria, is because we are proposing to use those
17 metrics, again, throughout on how you procure
18 equipment on which quality assurance requirements
19 would be applicable.

20 Down into operations of how would one
21 define what the reliability targets are for equipment,
22 and that comes from the probabilistic risk assessment.
23 And a metric for that analysis, which we're currently
24 proposing to use the QHOs.

25 So, in the absence of a well-defined

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 metric, you make things like requiring an applicant to
2 define reliability targets for equipment that much
3 harder, if you don't have a metric to use for that
4 purpose. So that's all I wanted to say on Slide 21.

5 If we go to Slide 22, we had some
6 discussion during the Subcommittee meeting on the
7 safety functions. Basically we lay it out that the
8 primary function is the retention of radionuclides.

9 And then a requirement for additional
10 safety functions to be identified, and again, the
11 previous slides I had gone through on how to go
12 through that exercise. And largely what was done in
13 the late 1960s to develop the GDC was similar.

14 We gave examples of heat removal, heat
15 generation and chemical interactions. The ACRS
16 Subcommittee mentioned they thought reactivity should
17 be mentioned, and we'll commit to including that.

18 There was, I think as some other members
19 mentioned, we thought that was somewhat addressed but
20 maybe less clearly by saying heat generation. We
21 don't mind including reactivity as a specific example.

22 The notion of requiring or identifying
23 those particular safety functions as requirements
24 versus a requirement to assess and identify them, our
25 concern is that, and it's highlighted down in the text

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 box, one of the things that an applicant will need to
2 do is identify safety functions for every major
3 inventory.

4 And for some technologies, the other
5 inventories, like waste gas, can be comparable in
6 challenge to the reactor system itself. And so, under
7 the way we have it worded, hopefully they would need
8 to identify safety functions for that waste gas
9 system.

10 And reactivity would not, or maybe even
11 heat generation would be not as important. But they
12 would have to identify, for that waste gas system,
13 what are the safety functions needed to retain the
14 radionuclides.

15 As the secondary concern, and we'll talk
16 about this tomorrow when we talk about fusion, we have
17 said to the Commission that we would try to keep Part
18 53 so technology inclusive that it might address
19 fusion facilities.

20 And obviously the high level safety
21 function, retention of radionuclides, would be
22 applicable to even a fusion facility whereas
23 reactivity, as an example, or even post-operation heat
24 generation is less a concern. I won't say it's not a
25 concern, but it's less a concern than it is for a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 fission system.

2 So, that is part of the rationale for the
3 setup as we have it, for not listing the specific
4 functions other than the retention of radionuclides.

5 MEMBER MARCH-LEUBA: Hey, Bill, what are
6 you talking about? This is Jose.

7 I'm reading this as a rule. And you just
8 need an example of something that you might want to
9 consider to do what?

10 I mean, you might just well describe the
11 RFB, but what does it do?

12 MR. RECKLEY: Well, what it does is if you
13 go back to that, again, the first principles slide.
14 Any designer will have to identify how they are
15 planning to retain the radionuclides.

16 As Charlie mentioned, they all, what they
17 all have in common is there's a hazard. And that's
18 the radionuclides.

19 MEMBER MARCH-LEUBA: Okay. But what
20 you're saying is, Paragraph 53 to 30B is irrelevant.
21 And it doesn't tell me anything.

22 You just have to do, it basically says the
23 famous joke, when in doubt, refer to Paragraph A. So
24 either say something or don't say something. But what
25 you're saying doesn't say anything.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I'll leave you with that concept. I mean,
2 rules have to be rules. I mean, they have to be the law
3 and have to be well-defined.

4 When I read them, I need to know how to
5 follow it. I don't know how to follow this.

6 MR. RECKLEY: Well it's, again, it's
7 intended to give the designer enough flexibility to
8 say, to retain radionuclides, what functions do I
9 need. And so --

10 MEMBER MARCH-LEUBA: And that is the
11 function of a regulatory guide, not of the rule.

12 MR. RECKLEY: And we would expect that
13 there will be guidance in this area. And one way,
14 well, there actually already is guidance in this area,
15 in terms of Reg Guide 1.233 on the LMP, goes through
16 an exercise of identifying those safety functions. Of
17 laying out what would be needed in order to satisfy
18 Paragraph A on the retention of radionuclides.

19 MEMBER MARCH-LEUBA: You know what, if I
20 ask you, how do I satisfy Paragraph B, what do I have
21 to do?

22 Paragraph B is something I must do because
23 it's in the rule. What do I have to do to satisfy it?

24 MR. RECKLEY: Well, when we get into
25 Subpart H, the content to applications, part of it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 will be to say, what functions have you identified in
2 order to satisfy 53.230. And that would be, for
3 example, somewhat paralleled with the requirement we
4 currently have for light water reactors to address the
5 GDC and for non-light water reactors to define their
6 principle design criteria.

7 Those same things, as we talked about
8 before are, the identification of the safety functions
9 is part of that exercise.

10 MEMBER MARCH-LEUBA: Yes, I think I made
11 my point clear in that --

12 MR. RECKLEY: Okay.

13 MEMBER MARCH-LEUBA: -- this babble makes
14 no sense whatsoever.

15 MEMBER REMPE: So, I guess I have a
16 different perception, but make sure I understand
17 things correctly, Bill.

18 To me, they are going to go through. And
19 if they have a unique non-LWR, they will look at
20 things that could lead to radioactive, to release of
21 radioactive materials. And if they, for some reason,
22 if they have a chemical interaction and you have an
23 air ingress or a water ingress in a gas reactor that
24 can lead to radioactive material release, then that is
25 a safety function that will be identified as an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 additional safety function that must be done.

2 And then I look at C, and even though some
3 things are primary and some things are additional, all
4 of those things have to be met. And so, the fact that
5 it's a primary or an additional one doesn't mean the
6 regulatory is going to say, oh, it's only an
7 additional one. It gets the same attention as a
8 primary.

9 Am I understanding the intent of what the
10 words are here, Bill?

11 MR. RECKLEY: Yes. I think you probably
12 worded it better than I did, so thank you.

13 And the reason that it's constructed the
14 way we constructed it was, because it's to be
15 technology inclusive, how you do B might differ.

16 And again, I don't like to use it too
17 much, but ultimately if Part 53 is used for fission
18 energy systems, it will have a different set of safety
19 functions than fission reactors. Some of them will be
20 similar, but they'll be different than fission
21 reactors have.

22 But even within different designs, the
23 importance of something like chemical interactions
24 might differ. And so, anyway, I understand what
25 people are saying, we'll just take that as an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 observation.

2 23. So licensing basis events are, again,
3 I don't think the concept of having them has been very
4 controversial. There has been some discussion on
5 where this should be within Part 53.

6 But in general, what we're trying to
7 emphasis is that any designer needs to look at a range
8 of unplanned events from anticipated operational
9 occurrences down to very unlikely sequences. And
10 within LMP, if you want to go over to that
11 terminology, from AAOs to design basis events and the
12 lowest frequency events down into beyond design basis
13 event category.

14 So, going on then to Slide 24.

15 MEMBER REMPE: Oh, one more thing, Bill.

16 MR. RECKLEY: Oh.

17 MEMBER REMPE: Actually, back to 22. The
18 other thing I guess one I would raise to maybe address
19 some questions would be that, if an applicant didn't
20 identify chemical interactions and the staff reviewed
21 it and said you need to look at this because you could
22 have had a release, they would have to add that safety
23 function as part of the review process for Part 53,
24 right?

25 MR. RECKLEY: We would certainly be

1 raising questions. And quite possibly, it could lead
2 to them adding that as a safety function.

3 MEMBER REMPE: Again --

4 MR. RECKLEY: Yes.

5 MEMBER REMPE: -- that's I think something
6 that's important that might help with some of the
7 confusion about this. But again, I came from a
8 history and a prior career with an advance reactor
9 component and that's what they were concerned about.

10 But anyway, go ahead. Thank you. I'm
11 sorry to interrupt again.

12 MR. RECKLEY: Oh, no problem. Thank you.

13 MEMBER BLEY: Bill?

14 MR. RECKLEY: Yes.

15 MEMBER BLEY: I'm going to interrupt.
16 We're about halfway through your slides and I think
17 the next five or six are kind of really important and
18 things we didn't talk about in depth at the last
19 meeting. So I'm going to declare a break right now
20 and then we'll come back and finish those.

21 So Part C will probably go a little faster
22 than those. So, at this time I'm going to declare a
23 break. And we will recess until a quarter till the
24 hour.

25 MR. RECKLEY: Okay, thank you.

1 MEMBER BLEY: We're in recess.

2 (Whereupon, the above-entitled matter went
3 off the record at 3:27 a.m. and resumed at 3:45 a.m.)

4 MEMBER BLEY: At this time we will
5 continue with Bill Reckley's presentation. Bill?

6 MR. RECKLEY: Thank you, Dennis. So, one
7 of the things we wanted to talk about is the licensing
8 basis events.

9 There was some discussion at the
10 subcommittee meeting and some distinctions of how it's
11 done under Part 53 and the basis that we're getting
12 out of the licensing modernization project and maybe
13 how it was done traditionally, so the next few slides
14 are kind of a summary or a revisiting of the LMP and
15 the discussions we had with the ACRS during the
16 development of Reg Guide 1.233, SECY paper 19-0117.

17 I don't know the protocol, Dennis, so I'll
18 just offer up that I know there's new members. I also
19 know this is one of those topics that if you're not
20 exercising it, it's hard to keep in the forefront of
21 your mind.

22 So, if for new members or as kind of a
23 refresher for anybody, if there's a mechanism for us
24 to give presentations or whatever informal processes,
25 we're certainly willing to do that if there's an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 interest, and we can set that up if Derek or somebody
2 wants to just give me a call.

3 We have existing presentations we're using
4 for staff and in interactions with other regulators
5 like CNSC for example, so we have all of that on hand.
6 It's not really a burden for us to do.

7 MEMBER BLEY: Thank you very much. I
8 think that's something -- we'll talk about it.

9 MR. RECKLEY: Okay.

10 MEMBER BLEY: It's something I think Paul
11 might want to take advantage of, so go ahead, and this
12 is one more of those areas where the real language
13 just says we'll select them from this group, but it
14 doesn't really go into what was in your SECY, what's
15 in the LMP on exactly how you do that.

16 MR. RECKLEY: Right, so, but before, if we
17 go on then to slide 24, before getting into the LMP,
18 we just might want to revisit some of the ways it's
19 been done in the past.

20 And so I know it's a busy slide and most
21 of you are probably aware of the traditional
22 approaches. I just copied this out of the standard
23 ANS 51.1, the 1983 version.

24 Actually, for most operating reactors, it
25 was the previous version, the one that's kind of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 highlighted that talks about condition two, three, and
2 four events, basically the anticipated operational
3 occurrences and design basis accidents. This is also
4 discussed a little further in chapter, or, yeah,
5 chapter 15 of the standard review plan under section
6 15.0.

7 But basically it just lays out, and it's
8 similar for boiling water reactors and pressurized
9 water reactors, and kind of follows roughly a process
10 hazards kind of approach.

11 Consider what could make temperatures go
12 up and down. Consider what might make flow rates go
13 up or down. Consider what might make reactivity go up
14 or down, what might disturb the power distribution
15 within the core, what might lead to losses of
16 inventory.

17 And laid out basically in the earlier
18 versions was largely based on engineering judgment to
19 define the categories in terms of anticipated events
20 or events that were not considered likely to happen or
21 conditioned for the design basis accident conditions.

22 The 1983, by the development of the 1983
23 standard, you can actually see that frequencies were
24 being considered more specifically in both the
25 categorization and also the little box is basically a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 frequency consequence curve.

2 So, by the 1980s, the earlier versions
3 were starting to introduce or including more of a
4 frequency component. Now, very -- I don't think any
5 reactor was actually referencing the '83 standard. By
6 that time, we weren't licensing plants anymore.

7 So, that kind of just lays out the
8 background for the light water reactors. If we go
9 onto slide 25, I'll go through a few slides that
10 basically gives a similar process as it was developed
11 under LMP, one difference being instead of using the
12 -- it may be process hazard oriented terminology of
13 consider what can make flow rates go up and down.

14 It basically is actually looking at event
15 sequences from the PRA and looking at a particular
16 component and failing it one way or another. In the
17 end, it's similar.

18 So, depending on how you want to approach
19 it, you can either highlight the differences or you
20 can actually highlight the similarities between even
21 the historical approach and the LMP.

22 MEMBER BLEY: Bill?

23 MR. RECKLEY: Yes, Dennis?

24 MEMBER BLEY: I actually had two things.

25 The first is I agree with what you just said, but the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 underlying PRA --

2 (Telephonic interference.)

3 MEMBER REMPE: Dennis, I think we lost
4 you.

5 MR. RECKLEY: Okay.

6 CHAIR SUNSERI: Yeah, Dennis, this is
7 Matt. If you -- we can't hear you if you're talking.

8 MR. RECKLEY: Okay, what I might do, and
9 Dennis has had some problems, I know, from the
10 subcommittee meeting, so maybe I'll go on, and then
11 when he comes back, we can pick up. Is that okay?

12 (Simultaneous speaking.)

13 CHAIR SUNSERI: He's asked me to carry on
14 if he --

15 MR. RECKLEY: Okay.

16 CHAIR SUNSERI: -- drops off, so go ahead,
17 Bill, carry on.

18 MR. RECKLEY: Okay, and we can revisit
19 when he reconnects with the point that Dr. Bley was
20 going to make.

21 So, basically for the LMP, the event
22 selection is again taking the event sequences from the
23 results of the probabilistic risk assessment and
24 plotting them in terms of frequency and consequence
25 onto this figure, and then as we get into more of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 discussion, ultimately looking to the margins that
2 exist between those events and the target figure,
3 which is the figure in blue.

4 And if we go down to slide 26, this is a
5 slide -- again, I'm using the MHTGR, trying to use it
6 so we can maintain some consistency between what we're
7 talking about, but this is one of the tabletop
8 exercises done for the LMP.

9 It was actually done for X-energy XE-100
10 design, but where they were at this time. This was
11 four years ago. They were looking and largely
12 borrowed by the MHTGR PRA and event assessments, and
13 you can see in purple all of the event sequences that
14 they had identified in the various categories.

15 And then as we get into more of the
16 discussion, actually the red dots, if you can see them
17 in the design basis event region, are event sequences
18 that contribute to the identification of a design
19 basis accident, and we'll get into that discussion
20 when we talk about the DBEs.

21 So, it does just show the number of events
22 and the number of sequences that are being looked at
23 from the probabilistic risk assessments, and actually
24 even this, the number, if you plotted all of the
25 sequences that were actually run, there would even be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 more dots on here.

2 They do group them into what's called
3 event families based on similarities of how the
4 progression and the end state of the transient, so
5 this is actually a plot of families, not necessarily
6 individual sequences.

7 But, so if we go on then to slide 27, this
8 just lays out again the categories of events.
9 Anticipated operational occurrences are basically
10 those that go down to a frequency per plant year of
11 ten to the minus two, where a plant year is any number
12 of modules that might be affected, any number of
13 inventories that might be affected within a plant.

14 DBEs are between ten to the minus two and
15 ten to the minus four, and beyond design basis events
16 below ten to the minus four down to five times ten to
17 the minus seven, and then importantly, the methodology
18 includes the assessment of uncertainties and the
19 requirement to really look at that, and if the 95th or
20 the fifth percentile in an uncertainty assessment puts
21 you across the band, then you look at it in both
22 categories.

23 So, the other thing that I'll just point
24 out is, and this, we've introduced some confusion. In
25 an attempt to not use exactly the terminology that's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 used in the LMP or to give the impression that we were
2 requiring they use LMP, we're introducing different
3 terms, but the terms have the same meaning, like
4 instead of beyond design basis events, you might have
5 noticed we call them very unlikely events, so, but
6 within the overall construct, they're the same.

7 One last point on this, and I know I'm
8 going pretty quickly through what can take many
9 minutes to discuss, the other thing that's looked at
10 under this is an assessment when you're looking at all
11 of these event sequences against the cumulative risk
12 metric, and again, that is proposed to be the QHOs in
13 our particular example.

14 So, the other aspect, if we go to slide 28
15 --

16 MEMBER MARCH-LEUBA: Wait a minute, Bill,
17 go back, go back. I wanted to make a comment on the
18 record. How did you, I mean, how do you address in
19 this methodology the known unknowns, which is what
20 they call the completeness of the PRA? How do you
21 know you selected all of the events at the front of
22 that, not just the ones you thought about, but all of
23 them?

24 MR. RECKLEY: Well, I think I'll let Marty
25 get into that discussion a little more, but it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 basically goes through the methodologies that you use
2 to make sure you address everything that can break.

3 MEMBER MARCH-LEUBA: No, that goes against
4 the scientific method. You cannot prove a negative.
5 You cannot say I -- you can say of everything I
6 looked, this is how it turns out to be, but there
7 might be something else I didn't understand.

8 And with light water, large light water
9 reactors, we have 60 years of experience. Basically,
10 almost everything that could happen has already
11 happened.

12 With these large reactors, we don't have
13 any experience and we have designers that want to
14 expedite things. They don't, you know, have as much
15 money. They cannot spend 20 years designing a
16 reactor. They have to do it in two.

17 The completeness of the set of events is
18 crucial. It's crucial, and as I keep telling you, I
19 mean, this is not a hypothetical, okay? You can
20 forget the most limiting events simply because it
21 doesn't fit in what happened for the last 60 years on
22 light water reactors.

23 And I don't see any emphasis on the rule
24 or in your thinking on the review of the staff to
25 understand how complete is that set of events.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. RECKLEY: Okay, let's --

2 MEMBER MARCH-LEUBA: And that's a clear --
3 I mean, you say you're premising the whole Part 53 on
4 the fact that I can calculate the risk, and that's a
5 non-scientific statement, period, over and out.

6 MR. RECKLEY: Okay.

7 CHAIR SUNSERI: Bill, this is Matt. I
8 just want to let you know Dennis is back on, so.

9 MR. RECKLEY: Okay, let's revisit that
10 point when we get to the PRA discussion, and I think
11 Marty will, I think either in his slides or in the
12 backup slides, go through the methodologies, but let
13 me defer that. And Dennis, if you had a point before
14 you dropped off?

15 MEMBER BLEY: It's an important point Jose
16 raises, but it's not a point about PRA. It's about
17 safety analysis. It would apply whether we were doing
18 PRA or the other kinds of events, and the things that
19 tend to dominate risks aren't things that we would
20 have seen in 60 years.

21 They are things that -- we haven't seen
22 everything. We're going to see some more things. And
23 so I'll be happy when Marty gets to this and talks
24 about it, but it's not strictly a PRA issue at all.

25 MR. RECKLEY: Okay, so, yeah, we'll

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 revisit this. Let me go on then to slide 29, 28,
2 thank you.

3 So, one of the things that comes out of
4 the process as we talked about are what are the
5 required safety functions, things like heat removal
6 and reactivity, and for those, those are the functions
7 that have the potential to make you exceed the
8 frequency consequence targets, and in particular in
9 our example for the first tier safety criteria, the
10 potential to exceed the 25 rem reference values.

11 That is what then goes into the
12 determination of safety-related equipment because for
13 every required safety function, you're required to
14 have safety-related equipment in order to do what's on
15 the next slide, the design basis accident, and
16 demonstrate that using only safety-related equipment,
17 you don't exceed the referenced values.

18 So, if we go onto slide 29, again, just
19 coming back to the MHTGR example, they've done this
20 exercise. They've identified the required safety
21 functions, and then you go down into slide 30.

22 They would use only safety-related
23 equipment to perform those functions in the DBA. So,
24 they're going to have a safety-related reactivity
25 control system, a safety-related heat removal system.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Many of the non-light water reactors are using reactor
2 cavity cooling or reactor vessel direct cooling
3 systems.

4 But in any case, you have a safety-related
5 system for those required safety functions of needing
6 to bring down the heat generation through reactivity
7 control and to remove that heat through a decay heat
8 removal system, so the DBAs are derived from the PRA
9 sequences and then are looked at again only using
10 safety-related equipment.

11 So, this is the LMP approach. It's also
12 the approach that's reflected in Part 53 to have both
13 a PRA, or as we'll talk about, another systematic
14 assessment, and to keep a fairly deterministic DBA,
15 traditional safety-related equipment as a kind of a
16 backstop for the plants.

17 So, if we go down then to slide 31, the
18 other couple sections that remained in Subpart B, the
19 safety criteria, is the defense in depth 53 250.
20 Again, we didn't make any major changes in the second
21 iteration.

22 One change we did make was to emphasize
23 that it's an engineered design feature, trying to give
24 some room. If there's actually an inherent
25 characteristic that's being credited, that would be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 given special consideration, but no single engineered
2 design feature could be relied on to meet the safety
3 criteria in 53 220(b), which again is meeting the
4 QHOs.

5 MEMBER BLEY: Bill?

6 MR. RECKLEY: Yes?

7 MEMBER BLEY: That's a nice distinction,
8 but it implies if you have an inherent feature, you'd
9 be happy with a single one, and depending on what you
10 -- they can be degraded as well, so it seems odd to
11 suggest engineered design features to me.

12 MR. RECKLEY: And we're going to have to
13 define some of these terms. Engineered design feature
14 would include a passive system, so those can be
15 degraded. What we're tend --

16 I mean, we're still developing this and
17 engaging stakeholders on the terminology, but when we
18 use the word inherent, it is something that doesn't
19 require something even like natural circulation. So,
20 it's not --

21 MEMBER BLEY: Even if it's coming from the
22 physics, which I think is what you're saying.

23 MR. RECKLEY: Right.

24 MEMBER BLEY: You really got to be careful
25 and make sure, one, you know all of the physics that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 might apply, and two, that nothing outside can
2 interfere with it, so.

3 MR. RECKLEY: I 100 percent agree and
4 that's -- and we're not trying to say it would be
5 easy. So, if you have an inherent feature, you're
6 right.

7 What we mean by that is it's the physics,
8 but the physics has to be maintained over the life of
9 the facility, so that means the physics couldn't be
10 changed by irradiation or other environmental factors.
11 It means the inherent feature is present within the
12 bounds of what the plant's going to be operating
13 under.

14 So, no easy task to show that the inherent
15 feature can be relied on. They're going to have to do
16 the science, the testing, and all of that to
17 demonstrate that that inherent feature could be relied
18 on, so.

19 MEMBER BLEY: Then you have plenty of
20 external things like fires, severe earthquakes.

21 MR. RECKLEY: Right, so --

22 (Simultaneous speaking.)

23 MEMBER BLEY: -- all of those things.

24 MR. RECKLEY: We agree 100 percent. We
25 were just trying to give some room that if there is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 such an engineered, I mean, if there is such an
2 inherent feature and it can be proven, then that would
3 be a basis to at least evaluate not requiring
4 additional defense in depth measures, but no easy
5 task. I'd agree with you there.

6 MEMBER PETTI: Bill?

7 MR. RECKLEY: Mm-hmm?

8 MEMBER PETTI: Does this mean as written
9 that if one wanted redundancy and backup, you could
10 have one engineered system and one inherent system?

11 MR. RECKLEY: That would be one way to
12 address the potential uncertainties with the inherent
13 characteristic that Dennis just mentioned, yeah.

14 MEMBER PETTI: Right, I can see some
15 cases, some inherent functions where you can back it
16 up. I can see others that it's harder to back up, for
17 instance, molten salt. The fission product retention
18 in that salt, I don't know you'd get an engineered
19 system there.

20 I can -- probably an engineered system to
21 make sure the temperature doesn't get outside some
22 bound that would invalidate its ability to hold
23 fission products or something, but okay, thanks.

24 MEMBER KIRCHNER: Bill, this is Walt.

25 Along Dennis and Dave's line of thinking, why do you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 have to modify it with engineered? Why not just no
2 single design feature, whether it's inherent, or
3 passive, or engineered, or -- it's a design feature,
4 something maybe as simple as a negative temperature
5 coefficient or neutron leakage for reactivity control.

6 But again, as you pointed out and Dennis
7 did in his examples, those things can be affected
8 throughout the life of the plant because of upset
9 conditions and so on and so forth.

10 You know, like a fast reactor that depends
11 on leakage, well, you might not have that performance
12 characteristic under all conditions, et cetera. Why
13 not just leave it at single design feature and not
14 have to split hairs over whether it's engineered,
15 passive, or inherent?

16 MR. RECKLEY: We were -- I mean, one of
17 the reasons is you have to go back and see how this is
18 actually being used to assess individual event
19 sequences, right, individual events.

20 And so whereas what we're talking about up
21 to this point, I tend to agree with everyone that when
22 you're talking at an overall plant, that is actually
23 the way it would most likely play out, but when you're
24 looking at an event, at a particular event, we're just
25 saying if it could be proven that that event could be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 addressed by an inherent feature, we were
2 acknowledging it's a challenge, but we were trying to
3 say that that sequence then would not need to be
4 backed up with an additional design feature, or may
5 not have to be.

6 So, again, it was one of the comments that
7 we had gotten. Some of the designers had felt
8 strongly they could justify the inherent features, and
9 so as a compromise, this is what we're proposing, but
10 I guess that's all the explanation I can give.

11 MS. VALLIERE: Hey, Bill? I might add
12 just to jog the members' memories that when we
13 presented on key guidance documents that need to be
14 developed to support Part 53, you'll find I think in
15 that list that guidance on inherent characteristics
16 was one of the items identified as needing guidance to
17 support Part 53.

18 MR. RECKLEY: Thank you, Nan. Okay, so if
19 we can go onto slide 32, the last section within
20 Subpart B on the overall objectives and safety
21 criteria is the need to protect plant workers. We
22 largely do this by referencing back to Part 20, and I
23 don't think there was much controversy to that, at
24 least in the discussions with the subcommittee.

25 Going on then to the next section and the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 next subpart under design and analysis -- well, maybe
2 I'll stop there and say is there any questions or
3 discussion on Subpart B?

4 MEMBER BLEY: Bill?

5 MR. RECKLEY: Yes?

6 MEMBER BLEY: I was trying to make a point
7 before I lost the internet.

8 MR. RECKLEY: Yes.

9 MEMBER BLEY: I don't know if you heard
10 me.

11 MR. RECKLEY: Only the very first
12 fragments, so, yes, if you could just repeat the two
13 points?

14 MEMBER BLEY: There were two things I
15 wanted to mention. With respect to your slide number
16 24, which is kind of nice, but the first note is by
17 the time you have this kind of layout, you'd have 30
18 years' experience working almost exclusively with
19 expert judgment to dream about what are the things
20 that could go wrong and how do we consider them, so
21 this was a real evolution by the time you got here.

22 And the other, I think I was just talking
23 about whether you're doing this traditional approach
24 to define your errors and design basis accidents that
25 you're going to analyze in the traditional way or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 whether you're looking for initiating events in some
2 areas in the PRA, it's the same process.

3 You've got to find them before you know
4 what they are and that's a place where this time it
5 looks pretty coherent, but that was after 20 to 30
6 years of trying to describe what these things ought to
7 be and it was unique to LWRs.

8 So, this idea that you need a way to look
9 for these events, especially for new technologies
10 where we haven't been working on them for decades,
11 that's where the guidance for people is very sparse.
12 There isn't --

13 (Telephonic interference.)

14 MEMBER BLEY: Please continue with your
15 next set of slides.

16 MR. RECKLEY: Okay, thank you, Dennis, and
17 I'll also mention that, you know, one of the ones with
18 the least experience is molten salts, and there are a
19 couple of reports out of Oak Ridge going through an
20 exercise similar to ANS-53.1.

21 There's also a good EPRI report that was
22 supported in part by DOE that talks about how to do a
23 process hazard analysis for molten salt systems, which
24 are similar.

25 Yeah, we don't have much experience maybe

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 with molten salt reactors, but chemical systems have
2 been used in process hazards analysis for a long time,
3 so they use that exercise.

4 And then the EPRI report talks about, as
5 Marty will go into the PRA discussion, also how to
6 inform or to use the process hazards as a starting
7 point for what ultimately would go into the PRA, but
8 we'll talk about that a little more under Subpart C
9 under the analysis.

10 So, yeah, if we go onto slide 34, again,
11 the layout of Subpart C follows the chevrons we talked
12 about earlier, the design criteria, the safety
13 functions in Subpart B.

14 Then they progress down into Subpart C
15 where the first section is on design features, and
16 then the second section, second and third sections are
17 how do you define the functional design criteria to
18 meet the first tier.

19 That's the safety-related design basis
20 accident tier, and then the second tier, which is the
21 more risk-informed approach coming out of the PRA, the
22 beyond design basis events and so forth, and then how
23 you get down into some additional design requirements
24 we'll talk about, and then really we want to spend
25 some time talking about the role of the PRA under the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 analysis section.

2 So, going through the first couple of
3 sections, 35, I'll turn it over to Marty. One of the
4 things that we wanted to talk about because it had
5 come up in the subcommittee meeting was single failure
6 versus the PRA probabilistic and reliability approach,
7 so, Marty?

8 MR. STUTZKE: Yeah, good afternoon. I'm
9 Marty Stutzke, the senior technical advisor for
10 probabilistic risk assessment in the division of
11 advanced reactors and non-power production and
12 utilization facilities.

13 And as Bill had said before, we wanted to
14 talk about the fact that Part 53 would allow the
15 single failure criteria to be replaced with a
16 reliability criteria.

17 This had been mentioned in Reg Guide 1.233
18 as approved by the SRM, the SECY-190117, to allow us
19 to do this, as well as using probabilistic evaluation
20 to select events, some things like that.

21 A little bit prior to that in a different
22 context was the staff had approached the Commission in
23 SECY-19036 about the NuScale ECCF systems,
24 specifically the inadvertent actuation block valves,
25 and whether single failure criteria should apply to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 those valves specifically, and the Commission came
2 back and told us to apply risk-informed principles
3 when you don't need the strict deterministic criteria
4 such as the single failure criteria.

5 MEMBER BLEY: Marty?

6 MR. STUTZKE: Yes?

7 MEMBER BLEY: This may be more for Bill.
8 When you're all talking about the single failure
9 criteria as applied to a system, and a big system that
10 has a safety function, under the single failure
11 criteria, it has to be able to withstand any single
12 failure without a loss of function.

13 There's another aspect of single failure
14 that Bill was talking about earlier, and that is when
15 you do the equivalent of the Chapter 15 analysis
16 deterministically with only safety grade equipment
17 operating, you assume for each system the most
18 challenging single failure.

19 That is still part of Part 53 as I
20 understand Bill's earlier explanation. Is that
21 correct, Bill?

22 MR. RECKLEY: Actually not. The defense
23 in depth measures that we talked about would require
24 that you have additional measures, but the difference
25 between what we're proposing and the traditional

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 single failure criteria is that we wouldn't require
2 for the DBA a specific additional single failure that
3 has led traditionally to two trains.

4 MEMBER MARCH-LEUBA: It would be perfectly
5 okay with you to have a single safety protection
6 system, a one channel protection system because you
7 would have to assume a single failure?

8 MR. RECKLEY: One train, yeah, one train.

9 MEMBER MARCH-LEUBA: So, your I&C will not
10 only not have diversity, it won't even have
11 redundancy?

12 MR. RECKLEY: For the assessment of the
13 DBA. The diversity --

14 (Simultaneous speaking.)

15 MR. RECKLEY: For the diversity, and the
16 redundancy, and so forth comes largely in repeating
17 that in a non-safety related system most likely for
18 the other event sequences.

19 MEMBER MARCH-LEUBA: So, you will have one
20 safety grade I&C channel and say three non-safety
21 grade channels, trains? That would be perfectly okay?

22 MR. RECKLEY: I'll be honest. I haven't
23 seen the application of this down to the I&C channel.
24 I'm mechanical oriented, so --

25 MEMBER MARCH-LEUBA: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. RECKLEY: -- I've seen it on the
2 mechanical --

3 MEMBER MARCH-LEUBA: You're a mechanical
4 guy. Would it be okay to have one single safety
5 relief valve to protect for the SME safety code?

6 MR. RECKLEY: For the DBA, yeah.

7 MEMBER MARCH-LEUBA: Yeah, so only one
8 safety relief valve will be okay for you --

9 MR. RECKLEY: But keep in mind --

10 MEMBER MARCH-LEUBA: -- to protect this
11 against other pressure?

12 MR. RECKLEY: For the DBA. Because you
13 have to analyze the other events and meet the defense
14 in depth requirement, you will have more than one.

15 (Simultaneous speaking.)

16 MEMBER MARCH-LEUBA: But it will not be
17 safety related.

18 MR. RECKLEY: It may not be safety
19 related.

20 MEMBER MARCH-LEUBA: So, only one safety-
21 related SRV, only one safety-related protection
22 channel, only one control, okay, that's fantastic,
23 man. You're making my day.

24 MR. RECKLEY: Keep in mind that you're
25 talking about what is needed to protect against an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 individual event sequence, not what would be found
2 acceptable for the overall plant design, because you
3 need to bring in the other event categories, and the
4 defense in depth requirement, and other --

5 MEMBER MARCH-LEUBA: The only event
6 categories, the ones that don't have AOOs don't give
7 you safety-related components. Are you saying that
8 we're going to create non-safety grade, some
9 additional control protection system channels and
10 trains, non-safety grade SRVs we're going to give them
11 credit for? They're not in tech specs and do not
12 exist, but we grade them? Okay, guys, you know how I
13 feel about this thing. This is lunacy.

14 MR. RECKLEY: Okay --

15 MEMBER BLEY: Bill? This is -- yeah, when
16 you do the DBA analysis, which Part 53 calls
17 deterministic, that's fine and conservative, but you
18 assume everything's working. You're not doing
19 reliability accounting for the chance of failures.
20 You're assuming everything works, so it's a different
21 kind of analysis that we did before.

22 Now, I will agree with you if you've done
23 the PRA right, you've looked at the overall risk and
24 the chance that things fail, but if you do that and
25 you come up with those licensing basis events which

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 are out of the PRA, those are pretty reasonable, but
2 then when you say I'm going to define a DBA as one of
3 those and I'm going to analyze it in the traditional
4 deterministic conservative way, you're not doing that.

5 Now, there are good arguments about why
6 you might not want to define DBAs, just stay with the
7 overall PRA, but I don't see what you gain at all by
8 defining DBAs and then applying thermal hydraulics to
9 it. I don't get it.

10 MR. RECKLEY: The notion is that you'll
11 have, at least for the required safety functions,
12 you'll have at least one safety-related way to meet
13 that function. So, in reality, you have multiple, but
14 at least one of those paths will include only safety-
15 related equipment, so.

16 MEMBER BLEY: But if we go back to
17 thinking about an LWR, when we have, say, three pumps
18 of safety injection and you go buy one that's safety
19 grade and two that aren't, you're probably going to
20 buy the same pumps. I'm not sure what we're picking
21 up here.

22 MEMBER REMPE: Well, would we say the
23 maintenance might be less for the non-safety grade
24 ones?

25 MEMBER BLEY: It might be nonexistent.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER REMPE: Right, so --

2 MEMBER BLEY: And it can't be, and you
3 can't just have one because when you do that PRA with
4 its embedded systems analysis, you cannot get
5 sufficient enough reliability out of the system if you
6 don't have maintenance and if you don't have
7 redundancy in the systems.

8 You can't approach anything like returns
9 of reliability we need in our systems to protect the
10 design. I guess where I'm -- it sounds like the only
11 thing doing this defining of the DBA that does
12 anything is that the main one of them is safety grade.
13 They're all going to have to be under tech specs or
14 you can't get the maintenance contributions on
15 reliability well enough.

16 MR. RECKLEY: And we'll get there when you
17 see the operating controls we set. There will be
18 reliability programs for -- let's take your example
19 and there's three ways to remove heat.

20 Yes, the exercise is one of those ways, if
21 it's serving a required safety function, it will be
22 safety related. They will all have, if they're risk
23 significant, they'll all have reliability controls on
24 them.

25 What you'll see under proposed Subpart F

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is the safety related would have the control under
2 tech specs and the other two would have their controls
3 under a reliability assurance program, not in tech
4 specs, but in another required by regulation program,
5 which is the reliability assurance program, so.

6 MEMBER PETTI: So, Bill, does that -- I
7 mean, I'm trying to understand does that change
8 anything really on the ground that there's
9 requirements, but they're coming through two different
10 pathways if you will in terms of what you do with the
11 systems on the ground?

12 MR. RECKLEY: The thought is there would
13 not be that much difference on the ground. From a
14 regulatory perspective, the tech specs will have the
15 traditional action statements and so forth, whereas
16 the others would come more under a licensee-defined
17 program, so a little more flexibility in the non-
18 safety related, non-tech spec.

19 In terms of the actual equipment like
20 you're suggesting, probably not that much difference,
21 but in the regulatory treatment, some difference.

22 MEMBER PETTI: Okay.

23 MR. RECKLEY: So, I'm sorry about --

24 MEMBER REMPE: When I think about like
25 crud that was deposited on the vessel head nozzles,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 how often they have to be inspected could change,
2 which could affect the performance, right?

3 And so I'm trying to think of examples
4 with real operating plants where you had to do stuff
5 and there was an inspector who was verifying it was
6 done. I mean, yeah, it would save a lot of money for
7 the licensee, but I'm wondering does that mean we're
8 really depending on one?

9 MR. RECKLEY: Yes, some of this, I think,
10 and I hate to say it, but I think it will be more
11 clear when we look at the operations requirements, and
12 that will be next month, so.

13 MEMBER KIRCHNER: Bill, this is Walt. I
14 guess I'm -- going back to my colleague Jose's
15 comments, let's just pick something, a reactor
16 protection system.

17 To only have one channel, to me, violates
18 the whole philosophy of defense in depth, one safety-
19 grade channel for detection of, let's say, over power,
20 you know, high flux calibrated in terms of power, so
21 a power trip.

22 MR. RECKLEY: And if we could, Walt, just
23 because I'm not as familiar with the I&C side and the
24 fact that when you get into I&C, even in the safety-
25 related functions, you've going to have multiple

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 channels.

2 Those channels might actually all be
3 safety-related channels because they're looking at
4 different quadrants in the core. They're looking at
5 different loops in the coolant system and so forth.

6 So, I prefer not to focus in on an I&C
7 channel, but if we look at, let's say, a heat removal
8 system and take reactor cavity cooling as the safety-
9 related system, all we're saying is there wouldn't be
10 necessarily two trains of reactor cavity cooling, but
11 reactor cavity cooling is not the only heat removal
12 system you have.

13 In fact, it might be the fourth or fifth
14 heat removal system that you have, but it might turn
15 out to be the safety-related system you have for heat
16 removal.

17 MEMBER KIRCHNER: Well, let's take it on
18 the mechanical side, just kind of rhetorically, your
19 nice chart of the layered fission product or
20 radionuclide barriers.

21 So, and maybe the first one is the
22 equivalent of the, of a fuel form, or the first one is
23 for a liquid fueled system is probably that primary
24 envelope.

25 And if you lose that first, you know, that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 first line of defense, one would think that you would
2 need a safety grade second line of defense or, yeah,
3 safety related, I'm sorry, equipment, you know,
4 qualified to be in concert with your defense-in-depth
5 overlying not philosophy now but objectives in terms
6 of --

7 MR. RECKLEY: Right.

8 MEMBER KIRCHNER: -- system performance.

9 MR. RECKLEY: And I think we're probably
10 in agreement other than the safety classification of
11 your backup.

12 The fact is you would be required to have
13 a backup. But the backup, depending on the assessment
14 that you're doing, the backup would very likely be a
15 non-safety related backup.

16 And that's not dramatically different than
17 what we accepted on some of the passive light water
18 reactor designs. But it -- there still would be a
19 backup. There still is defense-in-depth. You're not
20 totally relying on one layer as you're suggesting.

21 It's just that, because of the way we've
22 categorized the events, the design-basis accident,
23 you're going to credit the safety related one. You're
24 going to ignore the non-safety related ones that are
25 actually providing that backup.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And that way you're assured, again, that
2 you have at least one safety related way to carry
3 that, to make sure that you don't exceed the 25 rem
4 first tier safety criteria.

5 (Simultaneous speaking.)

6 MEMBER KIRCHNER: I understand what you're
7 saying. I just, you know, I've said this too many
8 times in the past. But I'll say it one more time.

9 I kind of look at this and say, well, does
10 this provide an equivalent level of protection in the
11 public's eye, I mean, because that's, you know, if
12 that defense-in-depth, the second barrier now, is not
13 safety related, do you convince the public that you've
14 provided an adequate, a comparable level of safety to
15 the existing fleet. And I don't know.

16 It strikes me that the public, looking at
17 this not knowing the nuances of an in-depth PRA, et
18 cetera, et cetera, might not be convinced.

19 MEMBER HALNON: Bill, do you ever see a
20 situation where the backup would be non-safety related
21 but important enough to be tested by a tech spec
22 surveillance?

23 MR. RECKLEY: We're still developing the
24 requirements under Subpart F. That question comes
25 down really to the fourth criteria and under 50.36 for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 including limiting condition for operation and a tech
2 spec surveillance for risk significant SSCs.

3 And since it's out, I'll tell you, our
4 first draft, our first iteration of the language says
5 that that's addressed through the reliability
6 assurance programs for the non-safety related
7 equipment and not included in tech specs. That's our
8 first iteration.

9 MEMBER KIRCHNER: But what happens, Bill,
10 when the PRA results are used such that that second
11 backstop or second line of defense after the safety
12 related equipment has been assumed to fail or does
13 fail and it's not on the D-RAP?

14 And I don't want to go into actual
15 details, but when we have instances where in the
16 recent review the two obvious systems to recover or
17 provide that backup didn't make the D-RAP list.

18 MR. RECKLEY: Well, again, well, the
19 assumption -- and I'll let Marty get back into the
20 slides here. But the -- if it's shown to be either
21 risk significant because of the PRA results or it's
22 required to meet the defense-in-depth measure, under
23 what we would propose under Part 53, it would be in
24 the equivalent of D-RAP. That's one of the criteria
25 for being there.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER KIRCHNER: But let me pursue it a
2 little further then. So, okay, we obviate the need
3 for single failure criteria. We do define -- this
4 morning we heard about fire safety. I'll use their
5 terminology, a success path to fall below, in that DBA
6 analysis, fall below the dose, the safety criteria as
7 expressed in terms of dose at the exclusionary
8 boundary or LPZ.

9 Wouldn't, in that case, wouldn't that
10 second line of defense then have to be covered by the
11 D-RAP, or as Greg was saying, Greg triggered me on
12 this, that, wouldn't then that have to be somehow in
13 the tech specs at least for the DBAs?

14 MR. RECKLEY: Again, and we're jumping
15 ahead a month to look at what's in tech specs. But,
16 yeah, if it's required to address the DBA under the
17 Part 53 proposal we just released, then it's required
18 to be in tech specs.

19 MEMBER KIRCHNER: Okay. All right. Thank
20 you.

21 CHAIR SUNSERI: Hey, Bill, this is Matt.
22 Vesna has her hand up. You might want to call on her.

23 MR. RECKLEY: Please, Vesna.

24 MEMBER DIMITRIJEVIC: Yes, hi. So my
25 question is to Marty. Marty, are we discussing,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 because now I'm confused with all of this.

2 Are we discussing here, so action of the
3 licensing basis events and application to Chapter 15,
4 or we are discussing safety classification, because I
5 have a question for later on safety classification,
6 but suddenly we are discussing safety classification
7 here. And I didn't see too much about safety
8 classification in your documents.

9 So are we discussing here safety
10 classification of SSCs, or we are discussing selection
11 of licensing basis events? Those are two separated
12 things.

13 I mean, you say in selection of licensing
14 basis events, credit only safety equipment. But where
15 is the safety classification and how it's determined
16 that's not discussed.

17 MR. RECKLEY: Yeah, no, I might have gone
18 through the slides quickly. If you can flip back up
19 a couple to -- and the topics you mentioned are all
20 interrelated.

21 If you go back to 27, so this is the
22 selection of the licensing basis events by looking at
23 the PRA sequences and putting them in these categories
24 --

25 MEMBER DIMITRIJEVIC: Yeah.

1 MR. RECKLEY: -- based on the frequency.
2 Then if you go to the next slide 28, you're looking at
3 those and saying, out of those event sequences, if I
4 take a piece of a -- what are the required safety
5 functions?

6 So, if I don't have any system to remove
7 heat, what would happen to the event sequence that I
8 just plotted in the design-basis event category?

9 Let's say I have three ways to remove
10 heat. And that's -- so that puts me in the design-
11 basis event category, because probably at least two of
12 the three is going to work on any given sequence. But
13 if I take away all heat removal, what happens?

14 And that's what that arrow is showing. If
15 I take away all heat removal, then I'm likely in this
16 example to exceed the 25 rem number. I'm going to
17 exceed that frequency consequence target figure.

18 That means that's a required safety
19 function, because without it I won't pass the
20 criteria, the first tier criteria.

21 So now that goes into safety
22 classification. Given I have identified that as a
23 required safety function, I need at least one system
24 to perform, one safety related system to satisfy that
25 function, to perform that function.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So one of, in the example, one of the
2 three heat removal systems is going to get picked as
3 a safety related system.

4 MEMBER DIMITRIJEVIC: Okay. So let's
5 start with this selection. This selection of event
6 sequences where they actually, the end state is not
7 determined yet. So it could be an initiating event,
8 everything successful, for example. That could be one
9 of the sequences, you know.

10 So let's say this sequence, if you want to
11 determine this lease in this category but you're only
12 crediting safety equipment, so we have here a question
13 of the chicken and egg.

14 I mean, how do you select sequences if you
15 don't know what the safety equipment or, I mean, you
16 know, you can see how this is all -- and somebody was
17 proposing that maybe we go as an example to this, I
18 think it was Bill, to this licensing basis event
19 selection, you know.

20 But we can actually do this as a tabletop
21 to see how that will work, because obviously these
22 things are so interconnected. It's not clear at all
23 how that will work in practice.

24 MR. RECKLEY: Right. And --

25 MEMBER DIMITRIJEVIC: It's not clear to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 me.

2 MR. RECKLEY: Yeah, and there's been
3 various tabletops done. And so we could revisit that,
4 as I mentioned to Dennis, through the LMP briefing or
5 whatever.

6 MEMBER DIMITRIJEVIC: I mean, examples in
7 that Lorad (phonetic), you know, which has examples
8 for PWR and PWR, the 1860, in those examples it's
9 already known, because they rely on the existing light
10 water reactor.

11 Like, for example, if you just look at
12 heat removal, the main feedwater, and feed and bleed,
13 they're non-safety functions. But here when you are
14 playing with, and then they're only looking in, you
15 know, absolutely feedwater removal drains.

16 But if you are looking in the new designs
17 and you don't really know what is happening, then you
18 don't know how to select those sequences in the basis.
19 So this is a -- you know, like looking at examples
20 will help a lot in these cases.

21 MR. RECKLEY: Okay. So, Marty --

22 MEMBER PETTI: So, Bill, just, let me make
23 sure I understand, because this is kind of moved
24 around.

25 Let me take an example that I know and you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 know, MHTGR, the regular cooling system was one way to
2 remove heat. It's clearly safety related. Reactor
3 cavity cooling system was a passive system. And it
4 was also safety related.

5 But there was a third cooling system that
6 many people don't know about called the shutdown
7 cooling system. It was not safety related. And so it
8 backs up, if you will, the passive system.

9 And it was decided by the designer. The
10 designer could have decided the shutdown system could
11 be the safety system and the RCCS, reactor cavity
12 system, could have been non-safety. But they made the
13 decision to go the other way.

14 So there were three ways to remove heat,
15 two, you know, one engineered and safety, one passive
16 and safety, and one engineered but non-safety. And
17 that would be consistent with how you described, you
18 know, single failure of a system.

19 MR. RECKLEY: Right, right.

20 MEMBER PETTI: Okay.

21 MEMBER KIRCHNER: But in your case, which
22 I know well, Dave, there were two safety grade systems
23 for the function. And as you said, they made the
24 decision.

25 It was a tradeoff between, you know, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 cavity, passive system versus the active shutdown
2 system that would get them down, you know, to low
3 enough temperatures for refueling. But there were two
4 safety related systems that could take the heat out of
5 a core.

6 MEMBER PETTI: Right. Yes, yes. But I
7 think that, the defense-in-depth requirement says no
8 single individual system. That's what the words say.
9 So this idea of having only one system would fail,
10 right --

11 MEMBER KIRCHNER: No, I --

12 MEMBER PETTI: -- from that requirement --

13 MEMBER KIRCHNER: -- Bill earlier
14 correctly that second or third system might not be
15 safety related.

16 MR. RECKLEY: Right. And you also, even
17 had to be careful in the example, because the pressure
18 boundary might have been safety related for another
19 purpose other than heat removal. So --

20 MEMBER MARCH-LEUBA: Yeah, on all the
21 defense-in-depth you're hanging your fruit on, your
22 hat on, it is so full of examples and such as and
23 maybe you can use margin and maybe you can use hand
24 waving. It's not clear that defense-in-depth says
25 anything honestly.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 If you want to take credit for defense-in-
2 depth for your backup, your safety grade systems, you
3 have to tighten up the language and make sure that
4 defense-in-depth truly exists, because right now you
5 have so many qualifiers and examples and how you can
6 do this, how you could do that, that I don't have any
7 good feeling that it exists. Thank you for listening
8 to my complaints.

9 MR. RECKLEY: Okay. Back to 35, Marty.

10 MR. STUTZKE: Yeah, on the last row, I
11 would just point out that this notion of replacing the
12 single failure criteria with the reliability criterion
13 has been around about 18 years. And the Commission
14 approved it back in 2003.

15 Slide 36, please, a little history on
16 single failure criteria I thought that would provide
17 some perspective.

18 Back in 1965, the Atomic Energy Commission
19 convened a regulatory review panel to look at ways to
20 review policies and practices for licensing with an
21 eye towards expediting the licensing process.

22 And the panel came back. And one of the
23 recommendations was they felt there was an absence of
24 definitive requirements and criteria. And so to that
25 end, the Atomic Energy Commission proposed the general

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 design criteria in late 1965. They weren't finalized
2 until 1971.

3 But later on in '77, as the slide points
4 out, the Commission asked the staff to critique the
5 use of the single failure criteria. And the staff
6 said, yeah, it seems to be working, however, it's just
7 one of multiple fuels that are applied in system
8 design and analysis with the not comment, the single
9 failure criteria in and of itself is not sufficient.

10 They also pointed out the single failure
11 criteria was developed without testaments of
12 probability, some components or system failures.

13 Most importantly, they picked up on the
14 insights from WASH-1400, the original nuclear plant
15 PRA, and said things such as systems interactions,
16 what we would now call dependent failure analysis,
17 multiple human errors, tests and maintenance, all of
18 these things have an influence on reliability. And at
19 the time, they're not considered within the scope of
20 the single failure criteria, so we have to use
21 additional methods.

22 And one thing that I found very
23 interesting, almost prophetic, it says, gee, the use
24 of probabilistic methods such as the reactor safety
25 study, could be, areas could be increased and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 ultimately supplant the single failure criteria.

2 So, when you think about it, that was
3 some-40, well over 40 years ago. Okay.

4 MEMBER BLEY: I'd like to fill a little
5 bit more in on your history there, Marty. Back when
6 they did the reactor safety study, most folks here
7 weren't -- you know, they hired a bunch of guys from
8 Boeing to come over and bring folks and analysis with
9 them.

10 And those guys have (audio interference).
11 But then when we analyze these systems, you're going
12 to find that even more single point failures than we
13 would have ever guessed and reliability is much lower
14 than we expected.

15 That turned out not to be true. And it
16 turned out not to be true because of these single
17 failure criteria and the way the staff at that time,
18 you know, I've brought in some system analyses to talk
19 with the old generation of staff on what, dependent
20 failures.

21 They did track down some of these repeated
22 interrelated, interacting system failures and really
23 developed a deep questioning to look for single
24 failures. And that served very well.

25 You know, the folks found very few of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 those failure in likely failures in systems. So it
2 has worked well. But it turns out that it missed some
3 of the more important things that were identified as
4 important in the study.

5 Anyway, I'm sorry, Marty. Go ahead.

6 MR. STUTZKE: No, you said it very well.
7 That was all that I was going to comment on this
8 slide. So slide 37, I think this one is yours, Bill.

9 MR. RECKLEY: Okay. One of the other
10 questions that came up during the subcommittee was
11 codes and standards and the phrase generally accepted
12 codes and standards.

13 So, since that time, we have released some
14 definitions. And one of the definitions we released
15 was of consensus codes and standards, which I won't
16 read here.

17 But basically it is our general
18 understanding. It's coming out of a standards
19 development organization and run through the normal,
20 you know, processes of ASME, ANS, ANSI, so forth.

21 So the, in terms of the discussion box
22 down below, we wanted to continue to encourage and
23 actually are required to encourage the use of
24 consensus codes and standards. So that's one of the
25 reasons we put the language in, to satisfy the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 National Technology Transfer and Advancement Act.

2 We do, however, recognize that there's a
3 lot of possible technologies in play and a lot of
4 different potential standards and somewhat of an
5 interest to also look at other standards approaches
6 like the International Standards Organization, or ISO,
7 and their standards in some areas for some components,
8 as well as the possibility of looking at other
9 international standards, if it happens to be a vendor
10 or a designer that's looking let's say to deploy in
11 Europe first, or some other area where another set of
12 standards other than, for example, ASME or IEEE might
13 be the ones generally used.

14 So, given the whole host of potential
15 standards, that was another reason we stuck with
16 wanting to encourage the use of consensus codes and
17 standards but not incorporate into the rules specific
18 codes and standards like the boiler and pressure
19 vessel code that we have for light water reactors.

20 We would look to, I think as we discussed
21 during the subcommittee meeting, look at guidance
22 documents, the submittal of proposals from either
23 SDOs, which we currently do, or the individual
24 designers or others and to try to pick that up in
25 guidance.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And a recent example of that, for example,
2 is the Division 5 of ASME for high temperature
3 materials that we're looking to pick up in a Reg Guide
4 but not necessarily incorporate into 50.55(a).

5 And the last bullet there, one of the
6 reasons for that is that the incorporation of those
7 consensus codes and standards into the regulations has
8 raised other issues, including the need to do
9 rulemakings when they come up with new versions of the
10 codes. And that would be a little easier to handle in
11 guidance updates versus rulemakings.

12 So that was the slide on consensus codes
13 and standards and why you're not seeing ASME or IEEE
14 or ANS standards incorporated into Part 53, at least
15 where we are with the preliminary language.

16 So, if we go on into 38 --

17 MEMBER HALNON: Okay. Bill, just --

18 MR. RECKLEY: Yeah.

19 MEMBER HALNON: -- this is Greg. Just one
20 point on the consensus standards, in the guidance, you
21 know, I think it's a good idea, because it is poised
22 to get it into the rule and it takes a long time.

23 But do you foresee possibly taking any
24 kind of major exceptions to portions of the code? I
25 mean, that concerns me a little bit where the Reg

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Guides come out and they'll have exceptions and/or,
2 you know, a differing thought process on a certain
3 endorsement. And you say we'll endorse, you know,
4 nine-tenths of it but not this last tenth of it. And
5 that could circumvent the use of it, the way it was
6 intended to be used.

7 MR. RECKLEY: It can. We always reserve
8 the right to do what you're saying, to put in
9 exceptions or clarifications.

10 Generally, we're able to avoid that in
11 many cases, and keeping in mind that often NRC people
12 are on the consensus code and standards, so we can at
13 least recognize what's coming and sometimes even
14 influence what's in the standard itself.

15 But, so hopefully -- I agree with you.
16 Hopefully, we could avoid that. And we traditionally
17 have avoided it in large part. But we do need to
18 maintain the ability in the development of a Reg Guide
19 to take exceptions to anything in a consensus code and
20 standard.

21 MEMBER HALNON: Okay. I guess it can be
22 important to point out that all that would go through
23 public comment, in addition to probably ACRS review as
24 well for --

25 MR. RECKLEY: Right, right. Yeah.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER HALNON: Yeah. So, okay. Thanks.

2 MR. RECKLEY: Yes. All right. Okay. 38,
3 on the PRA, again, the requirement is being maintained
4 in our second iteration of the language to require PRA
5 to be done. And the use of the PRA as is highlighted
6 there is to at least support the assessment against
7 the second tier safety criteria of meeting the QHOs.

8 And with that, I'll turn it over. I think
9 the next slide --

10 MEMBER BLEY: Bill, I wanted to go back to
11 the point Greg made. I wanted to support the staff in
12 this area, because I have not seen a case that I was
13 involved in where the NRC was considering adopting a
14 consensus code or standard in which the NRC didn't
15 have one or more people on the committee that was
16 developing the standard.

17 So they were very knowledgeable about how
18 it was developed and what the intent was. So I don't
19 think there's much chance that you, you know, lose the
20 intent.

21 Usually, the clarifications and exceptions
22 are cases where the standard wasn't strict enough for
23 what NRC thought was the appropriate --

24 MR. RECKLEY: Okay. Thank you, Dennis.
25 I do want to caveat that when you serve on a standards

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 committee you're not representing the NRC. I mean,
2 there's the practical thing that you work for the NRC
3 and you're volunteering to be on a standard. But you
4 don't represent the NRC. I think most people know
5 that. I just think it's worth --

6 MEMBER BLEY: That's a good point. So,
7 when you come back to the NRC, you can represent --

8 MR. RECKLEY: Yes. You don't forget what
9 you just sat through. That's exactly right. That's
10 the point.

11 So, with this, I think one of the things
12 that came out of this subcommittee was a need for a
13 bit more discussion on PRA. So I'm going to hand it
14 back over to Marty for slide 39.

15 MR. STUTZKE: Okay. This slide looks at
16 past and present uses of PRA. These are listed in
17 Standard Review Plan, Chapter 19, which typically
18 applies to LWRs. But in general, these uses would
19 also apply to non-LWRs.

20 So the first one, it's about identifying
21 severe accident vulnerabilities. That one comes from
22 the advanced reactor policy statement, which in turn
23 references the severe accident policy statement.

24 The second one is the demonstration that
25 the plant needs to commission safety goals. This

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 bullet pointed out our second tier criteria would
2 embed the QHOs directly into the rule language. This
3 one comes, again, from the Commission's advanced
4 reactor policy statement.

5 A third one here is use of the PRA to
6 support environmental reviews, specifically the
7 evaluation of SAMDAs, severe accident mitigation
8 design alternatives.

9 Now, to be clear, Part 51 does not require
10 the use of a PRA, but this is the way that it's been
11 done in the past. And I refer you to Regulatory Guide
12 4.2 in general on the preparation of environmental
13 reports and this new interim staff guidance 29, which
14 talks about environmental reviews and SAMDAs with
15 respect to micro-reactors.

16 But we point out in order to implement the
17 methods in these things you require a full level 3
18 PRA. Because it's a consequence, the idea is to
19 compute consequences of accidents, monetize them, and
20 then compare to the cost of implementing the
21 corrective action. So, in that respect, it's similar
22 to a --

23 (Off mic comments.)

24 MR. STUTZKE: I would also point out that
25 all the plants that have been certified designs and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 combined licenses all have level 3 PRAs in order to
2 meet this environmental review and the use of SAMDAs.

3 So, in the fourth bullet, if you're going
4 to implement the LMP guidance in NEI 18-04 you're
5 using the PRA to select and classify SSCs, and inform
6 defense-in-depth evaluations.

7 Let's go to slide 40.

8 (Off mic comments.)

9 MR. STUTZKE: Request people to mute their
10 microphones, please.

11 Okay. On slide 40, for applications that
12 are not based on the LMP, a PRA could be used to
13 support the Ritnis (phonetic), the identification of
14 systems incorporated within the program, et cetera.
15 The results and insights to the PRA are used to
16 support ITAACs, tech specs, COL action items, and
17 things like this.

18 Of course, the PRA may be used also to
19 support other concurrent voluntary risk informed
20 applications that may be included within a license
21 application, for example, risk informed in-service
22 inspection, risk informed tech specs. All of these
23 things could be in there.

24 And lastly, the staff uses the results of
25 the PRA to inform the scope of the review. This was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 an action that came from former Chairman Jaczko and
2 Commissioner Apostolakis. And it's known as the
3 enhanced safety focus review approach that's explained
4 better in, again, in the SRP like this.

5 But the idea is to focus the staff's
6 review on what's important and do a smaller amount of
7 review for things that the PRA says are not important.

8 Last and not least, the results of the PRA
9 are used to support reactor oversight programs.

10 So, continuing with slide 41 --

11 MEMBER KIRCHNER: Could you go back to 39,
12 Marty? This is Walt Kirchner.

13 MR. STUTZKE: Yes, of course.

14 MEMBER KIRCHNER: You know, I just -- this
15 is just an observation from a non-practitioner of PRA
16 but one who appreciates it.

17 I think the most important use of a PRA is
18 to gain insights and inform the design. And that
19 rarely ever gets listed.

20 It seems like the PRA is being used more
21 to determine regulatory compliance, to exclude things
22 from being on a D-RAP list, to, et cetera, et cetera,
23 which are all I think useful and important things.
24 But the most fundamental thing in my mind for the PRA
25 is to use the insights you gain to improve the design.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And I just make that as a comment, that I
2 would hope that, to the extent that the rule is
3 requiring the PRA and such, that that is embedded in
4 the, one of the purposes, rather than I think there's
5 a tendency to, from my observing things on the
6 committee over the last five years, to focus on the
7 numbers and then use those numbers to exclude things
8 from regulatory treatment or, et cetera, et cetera.

9 And that's all justifiable. There's
10 economic reasons behind that.

11 But, again, I feel the most valuable part
12 of a PRA will be at the design phase to help inform
13 the design. And that rarely is cited.

14 MEMBER BLEY: I should, I really disagree
15 with your last statement. I agree with,
16 indefensible. But at least 4 of the design certs
17 we've done in the last 15 years made heavy use of
18 their PRA in the design process. In fact, it's what
19 led them to the new designs they proposed and got in.

20 (Simultaneous speaking.)

21 MEMBER KIRCHNER: I stand corrected.

22 MR. STUTZKE: Absolutely. So we expect in
23 the, is that the Commission argues in its advanced
24 reactor policy statement that it's clear the
25 Commission's intent was for designers to use the PRA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 as part --

2 MEMBER KIRCHNER: That's where I agree.
3 That's I guess what I was getting at. And I stand
4 corrected by Dennis.

5 But, yeah, when I think of the 2008
6 advanced reactor policy statement, it's just some of
7 those concepts, if they were -- I think many of them,
8 of those are embedded already in your language that
9 you've been developing.

10 But that one just doesn't stand out to me.
11 Maybe I'm missing it somewhere or maybe, as Dennis
12 says, it's just done and that's it. But --

13 MR. STUTZKE: We'll take it under
14 advisement.

15 Okay. Another thing that I wanted to
16 discuss here is, in the letter the ACRS wrote on our
17 Part 53 white paper back in September of last year,
18 2020, you all used the phrase it's important to be, to
19 search for events without preconceived expectations.

20 And I know the topic had come up before
21 about how do you know that you're complete. So I
22 wanted to provide you with some language or some
23 thoughts that come out of the non-light water reactor
24 PRA standard, the various requirements on how the
25 initiating events are selected and how one confirms or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 attempts to show that they're complete like this.

2 So there are requirements to identify
3 initiating events, which are defined as challenges to
4 plant operations, and mitigate those challenges such
5 that you prevent a radioactive release.

6 That's put in there to account for things
7 like you may have, for example, a loss of feedwater,
8 followed by failure to scram. So the feedwater event
9 would become the initiating event, and the scram
10 failure and ATLAS sequence is treated elsewhere in the
11 PRA.

12 The second requirements are using a
13 structured systematic process. And it specifically
14 lists things like master logic diagrams, heat balance
15 fault trees, a process hazard analysis, failure modes
16 and effects analysis.

17 The process hazards analysis, the PHA, has
18 been a subject of study by the Electric Power and
19 Research Institute and its contractor, Vanderbilt
20 University. And they have actually applied it to the
21 old molten salt reactor experiment design to use it as
22 kind of -- I think of it as the prelude to the PRA, so
23 a very good process. They've issued reports on this.
24 So the guidance is there.

25 I should back up a minute and remind you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that the PRA standard specifies what to do. But it
2 doesn't tell you how to do it. Rather, it makes
3 references to other techniques that could be used like
4 this.

5 So, down to the third bullet, analyzing
6 operating procedures and practices to see where humans
7 could become involved and inadvertently trip the plant
8 off the line.

9 The fourth bullet is still in the
10 standard, review existing list of known initiators
11 specific to type. Obviously, that bullet by itself is
12 not sufficient.

13 One could come and say, take a list of LWR
14 initiators and say, gee, I'm designing a molten salt
15 reactor, so that one doesn't apply, that one doesn't
16 apply. And you don't -- ultimately you end up with
17 very few initiators.

18 So it's the totality of all these
19 requirements on this slide and the next one is what
20 provides the confidence.

21 That being said, conferring or referring
22 to known list of initiating events is an appropriate
23 way to do it.

24 MEMBER BLEY: Marty?

25 MR. STUTZKE: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: Comments. This is very
2 good. To my knowledge, the non-light water reactor
3 care is standard.

4 Has it been adopted as yet?

5 MR. STUTZKE: We are in the process of
6 endorsing that in a regulatory guide that will look
7 very similar to Reg Guide 1.200.

8 MEMBER BLEY: Yeah. And we'll see that
9 sometime. But, it isn't there yet.

10 MR. STUTZKE: Right.

11 MEMBER BLEY: The take we were trying to
12 make is that, of course, you should look at existing
13 lists, your last four.

14 But, really, that should be the last thing
15 you do. That should be a check on was there anything
16 in your other processes that you found out earlier?

17 If you're stuck with that list, it gets
18 harder and harder to really dig in for these other
19 approaches to try to make sure you're complete.

20 Anyway, but personally, I agree it belongs
21 on the list. But, I think it belongs at the end after
22 you've done the creative work of working hard for --
23 and using the things that might be hiding in your
24 design.

25 And I'll be glad when this standard is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 out. But, this is the first time to my knowledge.
2 It's not the first time people have done this, it's
3 the first time to my knowledge it's been on any kind
4 of documents.

5 MR. STUTZKE: Yeah. That standard we
6 intend to go to start the Reg Guide publication
7 process towards the end of June or early July.

8 I know we have a meeting set up with one
9 of the subcommittees of ACRS to talk about it. But,
10 we hope to issue that standard by December, or endorse
11 that standard by December of this year.

12 MEMBER BLEY: That's good news.

13 MR. STUTZKE: On your last comment about
14 you were referring to the known initiators. But
15 personally, I've always looked at that.

16 That's like when you do, you know, a
17 calculus problem in school, and you know the answer is
18 in the back of the book.

19 So, you do all of the creative work up
20 front, and then you look in the back of the book and
21 see if you got it right. Something extra that maybe
22 you should have thought about.

23 MEMBER BLEY: Well, it certainly is. But,
24 I'll give you one, an anecdote, and this comes from a
25 lot of research in the area of expert elicitation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And there's been a number of studies where
2 they looked at the problem of anchoring, which is the
3 problem if you start with the last bullet. And with
4 a couple of the studies, they got people together and
5 they said, you know, just to help you out, we're going
6 to make up a first starting point.

7 And then you think about what could make
8 it more like or less likely. You know, you work from
9 that point.

10 But, now it's just made up. And if you
11 start with that, it's amazing how close you stay to it
12 by the time you've done the process.

13 You really don't want to bias yourself to
14 some anchor point where you've been searching broadly.

15 MR. STUTZKE: All right.

16 MEMBER BIER: Dennis, this is Vicki. If
17 I can just expand on that.

18 There was one study that specifically did
19 this for fault trees. Where they had like auto
20 mechanics or something.

21 And some of them looked at a complete
22 fault tree for why a car might fail to start. And
23 some of them looked at a fault tree when the cap
24 causes were missing.

25 And both trees were rated as being equally

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 completed. So.

2 MEMBER BLEY: That's their problem. Okay,
3 thanks.

4 MR. STUTZKE: Okay. Let's go to slide 42,
5 please. Okay. So, in addition to the previous slide,
6 the list continues.

7 It says, you know, don't forget about the
8 external hazards. Including combinations of hazards
9 like seismically induced fires.

10 Looking at operating experience from
11 similar plants if it's available. Basically a
12 systematic evaluation down to the subsystem of the
13 train level.

14 Including all of the supporting systems.
15 So, you really understand the dependencies that the
16 gear system has with other systems, and things like
17 that.

18 Including initiating events that may have
19 involved multiple failures if they arise from a common
20 cause. That picks up things like earthquakes, these
21 big ones like this.

22 Interviewing plant designers and operators
23 after you've done your homework above like this. And
24 last but not least, don't forget to consider
25 initiating events that might impact multiple sources

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of radioactive material.

2 The non-LWR PRA standard would consider
3 that you could have multiple reactors onsite, plus
4 non-reactor radiological sources.

5 So, spent fuel or off cast systems, things
6 like that. And they would all be included in the
7 scope of the PRA.

8 So, okay. Moving to slide 43. Another
9 question that we commonly have to address is, what
10 about the lack of operating experience?

11 So what I've tried to list here in the
12 lefthand column here, are all the, for lack of a
13 better word, the numbers that go into the PRA
14 calculation. The initiator frequencies, the component
15 failure rates, and so forth, is listed here.

16 And thinking about it, a great many of
17 them can be estimated using existing nuclear or non-
18 nuclear information. We point out that a great deal
19 of the zeta that went into the original WASH-1400
20 study was from non-nuclear sources like this.

21 And they can be formally combined using
22 Razian statistical methods, which allow you to mix
23 limited sets of operating experience with subjective
24 judgments.

25 Last but not least, is the list of formal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 expert elicitation on this. I would point out, these
2 are currently done for large light water reactor PRAs
3 as well.

4 That's where we get numbers like the
5 frequency of large break LOCAs, is through an
6 elicitation process.

7 Common cause failures, we have good
8 models, such as the Alpha Factor model that's been
9 used like this. We have very good generic information
10 that's been developed over a number of years.

11 One of the things that I would point out,
12 what is interesting about the generic common cause
13 failure data is it's stability in the sense that
14 numbers don't change among systems too much, or
15 components too awfully much.

16 So, it's reasonably robust. Yes, Dr.
17 Bier?

18 MEMBER BIER: (No response)

19 MR. STUTZKE: Is there a question from
20 Vicki?

21 MEMBER BIER: Yes. I had to unmute.
22 Sorry. I just wanted to chime in again on the topic
23 of expert elicitation.

24 And, I think this is again for background.
25 Is something that needs to be -- that needs to be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 incorporated in this document.

2 But, over time there is a lot of evidence
3 that not all experts are equally good at putting what
4 they know into probabilistic terms.

5 So, at some future time, the Committee or
6 the Agency may want to look into updating the guidance
7 on expert elicitation. But, I don't think that needs
8 to be part of this process today. Thanks.

9 MR. STUTZKE: Yes, thank you. It reminds
10 me of an interaction I had once with former Commission
11 Apostolakis.

12 He told me, when he estimated numbers for
13 use in a PRA, he was providing his expert opinion. On
14 the other hand, if I estimated the same number, I was
15 just guessing.

16 So, you're right. Different experts have
17 different qualifications. And I would agree, we need
18 to revisit our guidance on how to conduct expert
19 elicitation.

20 Jumping down to the bottom of the list
21 there, human error probabilities, hazard frequencies,
22 external hazard fragilities, none of those require
23 design specific operating experience.

24 They come from knowledge of the design,
25 the review of the procedures. We have acceptable

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 methods for performing those sorts of analyses.

2 Any other questions on this slide? Vicki?

3 MEMBER BIER: (No response)

4 MR. STUTZKE: Okay. Well, let's go onto
5 slide 44 then. But, I would also emphasize the PRA
6 provides a framework for assessing the uncertainties
7 normally lumped into the parametric uncertainties, the
8 modeling uncertainties, and the completeness
9 uncertainties, like this.

10 We would certainly expect that people
11 don't just estimate the uncertainty and all the
12 parameters. Do a Monte Carlo propagation up to the
13 final risk metrics and call it a day.

14 They're actually obliged to understand
15 what factors, which basic events, human error, et
16 cetera, et cetera, are driving the uncertainty in the
17 overall results. So, kind of a decomposition.

18 But, that's the process that helps you put
19 the uncertainty into perspective. As you can see,
20 things that might be uncertain or questionable, let's
21 say, because of a lack of operating experience.

22 For example, the turbine trip rate, or an
23 uncomplicated scram rate. Things that we would
24 normally estimate using a lot of statistical data, but
25 we would lack, because the plan hasn't been built.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Those sorts of events don't tend to be
2 risk significant. And therefore, they won't overall
3 have too great an impact on the final risk calculation
4 or the uncertainty in that risk calculation.

5 Okay. Comments on that?

6 MEMBER DIMITRIJEVIC: Yes, Monty, I have.
7 Okay. I really appreciate, you know, how you well
8 summarize the usefulness of the PRA. That was really
9 good.

10 But, the new list of all the PRA
11 applications, the only one with actually level three
12 results were necessary for any of the report, and some
13 -- and most of the design certification which have
14 been submitted now, are not required to have a level
15 three PRA.

16 So, now when we came to the -- to this
17 slide of uncertainties, you also nicely summarize the
18 positivity. Because one of the main issues with using
19 PRA is associated with uncertainties.

20 So, we don't even have a good way to
21 address every item that was in the PRA. Which
22 completely addressed modeling uncertainties or
23 completeness uncertainties.

24 And those uncertainties are still open.
25 Now, when we open these to the level three PRA, would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you agree with me the uncertainties multiply like, you
2 know, half the times responded with level one PRA.

3 And doing the level three, especially when
4 you don't have a location, increases uncertainties
5 associated with the results significantly.

6 And this is my main objection. Is why do
7 we want to introduce these QHOs when we actually
8 really, you know, the drop are uncertain?

9 MR. STUTZKE: Well, I would respond, you
10 know, we've done -- the staff has done extensive
11 looking and the state of the art reactor consequence
12 analysis, the SOARCA Project.

13 Which included a full propagation of
14 uncertainty all the way through the MELCOR and the MAX
15 codes. And the uncertainties were perhaps not as big
16 as one would expect.

17 All right. The other thing is that the
18 Commission's safety role policy statement, while it
19 was being developed, considered how to decide whether
20 somebody had met the goal.

21 And after a lot of discussion, they
22 concluded the best way was to compare the mean of the
23 uncertainty distribution to the care chart as well as,
24 you know, then later consider the uncertainties as
25 I've described here on slide 44.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, from that perspective, you know, the
2 issue was debated a while back. And reasonably result
3 --

4 (Off record sound interruption)

5 MEMBER BLEY: Okay. If the members on the
6 public on the line can mute your phones.

7 (Off record sound interruption)

8 MEMBER BLEY: Quynh, if you can help us
9 out.

10 MR. NGUYEN: The members on the public
11 line with a radio or music, could you please turn it
12 off?

13 MEMBER BLEY: Thank you. Marty, can you
14 hear me now?

15 MR. STUTZKE: (No response)

16 MEMBER BLEY: Or did Marty drop off?

17 MR. STUTZKE: I am here Dennis.

18 MEMBER BLEY: Oh good. Okay. I want to
19 take you back to your slide 41. You've got me
20 curious, and I started digging around.

21 I really like this. But, I'm remembering
22 back some time in the last year or so, maybe it was
23 two, because I think we were in person back then in
24 Rockville.

25 But, we had a meeting with the staff and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 with representatives of the committee developing this
2 non-light water reactor PRA standard. And we
3 challenged them that there was no guidance here like
4 in other places, on how to structure this search.

5 And I think we said a structured
6 systematic process. And what date is the version on
7 the standard that you have?

8 Because I've got the one we reviewed back
9 then, with a 2020 date on it. And I can't find any of
10 this in there.

11 And the representatives from there said
12 that if you think about it, that they couldn't speak
13 for the committee. So, maybe it's just recently been
14 developed.

15 But, the bottom line is, I'm glad to see
16 it's going to be here. But, I don't think it was
17 there a year and a half ago or so, whenever we had
18 that meeting.

19 But, I'm pleased it's here, so.

20 MR. STUTZKE: Yeah. I don't know about
21 that. The final version of the standard that was
22 issued in February 2021.

23 MEMBER BLEY: Well, that's really great.
24 And they sent me a bunch of papers that are right in
25 line with this, as to how they've used it in other

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 analyses.

2 And they put it in here. So, I'm glad to
3 see. I guess it's under initiating events?

4 MR. STUTZKE: Right.

5 MEMBER BLEY: We'll have to get their
6 version.

7 MR. STUTZKE: Yes.

8 MEMBER BLEY: But, use this -- is this
9 their interpretation?

10 MR. STUTZKE: Yes. This is a compilation
11 of the various supporting requirements.

12 MEMBER BLEY: Okay. Derek, we'd like to
13 get that. We're out of date. Thank you.

14 MR. WIDMAYER: I heard you.

15 MR. STUTZKE: Well, with that, I'll turn
16 it back over to Bill. I do have some backup slides on
17 PRA and risk metrics if you would like me to discuss
18 any of them.

19 The origin of the QHOs, the risk
20 surrogates, things like that.

21 MEMBER BLEY: All right. I think some of
22 us would be interested. But, unless other members
23 really want to see it, I don't think we'll go to that
24 today. I don't think it's terribly relevant.

25 Bill mentioned that you have some prepared

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 presentations on some of the materials that you guys
2 have talked about today. And I just wondered, is all
3 of that something you could bring and present?

4 Or is some of this available in some kind
5 of self study modules at the Commission?

6 MR. RECKLEY: It is. It's publically
7 available. Most of it, I don't know how it could be
8 -- I don't know if it would be effective in self study
9 mode.

10 MEMBER BLEY: Okay.

11 MR. RECKLEY: We can -- we can provide it
12 to you, and you can maybe help us assess --

13 MEMBER BLEY: If you can get that to
14 Derek, I'll take a look. And then we can upload it to
15 the rest of the members and see if anybody wants this
16 in study mode.

17 MR. RECKLEY: Okay. We will provide that.

18 MEMBER BLEY: Thank you.

19 MEMBER KIRCHNER: Dennis, this is Walt.
20 Let me ask you a question.

21 Based on what Marty's just presented, does
22 this address what you've often stated, starting with
23 a blank sheet of paper, and doing a completed search
24 -- well, not a complete search, but a well-informed
25 search or initiating events, and defining design basis

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 events?

2 MEMBER BLEY: Yes, it does. Although on
3 the slide, it wasn't quite expressed that way. And I
4 don't know what it says in the standard. But, we
5 better look at that sometime soon.

6 But, if you remember, we had that meeting
7 on the standard. They were going to come back at some
8 point.

9 And we talked about this issue. And the
10 representative that was there, I used to work with,
11 sent us about 20 papers dealing with these issues.

12 And they're the same kinds of things I was
13 putting together in that White Paper we covered. So,
14 maybe it will save me some effort and not going to
15 read it.

16 But yes, it's supposedly reentered if it's
17 not the same.

18 MR. RECKLEY: Okay. We have a few more
19 slides to finish up. But, I guess before getting into
20 that, I'll apologize on the single failure
21 discussions.

22 It's the danger of trying to do by
23 examples. But, I'll also look to see if there's some
24 clarification.

25 And I know, for example, I was only

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 involved on the periphery, but the design review guide
2 that the ACRS did look at, it talks about INC, and
3 whether INC is developed under an LNP approach, or the
4 more traditional single failure.

5 I think both of those avenues are
6 addressed within that design review guide again, that
7 the ACRS has looked at.

8 So, I'll gather up some examples of that
9 as well. And then maybe even some past examples.

10 MEMBER BLEY: Was that -- was that the
11 read list of Chapter 70 SRP? Or --

12 MR. RECKLEY: Yes.

13 MEMBER BLEY: Okay.

14 MR. RECKLEY: Yes, that. So, finishing up
15 on the last few slides under design and analysis. We
16 did revise the guidance from the first time that ACRS
17 looked at it.

18 This is consistent with what we brought to
19 the subcommittee. And for the purposes of design and
20 licensing basis event selection, safety class and
21 SSCs, that other engineering approaches could be used
22 for that.

23 That was -- this change was a result, or
24 resulted from public stakeholders who wanted to make
25 sure we weren't foreclosing on other generally

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 accepted ways, be they reflected in other guidance
2 documents, IAEA approaches, and so forth.

3 So, we did change this. I think it really
4 doesn't change much in the way of the overall
5 requirements or approach. Go to slide 46.

6 We did go through some iterations on some
7 of the specific sections. If you want to go to 47,
8 that's one example.

9 And again, we brought this before the
10 subcommittee. I'm not sure it was -- felt at that
11 time it warranted a lot of discussion.

12 But, we did expand and tried to clarify
13 that the -- that an applicant would need to look at
14 the whole range of licensing basis events from AAOs
15 down to very unlikely events.

16 Go onto 48. This is the DBA. And there
17 was some discussion of this at the subcommittee
18 meeting.

19 We did add a specific sentence that said
20 for the DBAs they needed to be analyzed from
21 initiation to a safe stable end state. And again, as
22 we've talked several times, assuming only safety
23 related SSCs and safety-related human actions would be
24 credited in that assessment of the DBA.

25 Any further, or any thought given after

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the subcommittee meeting as to whether this kind of
2 scratched that itch that I think was identified in the
3 first iteration?

4 (No response)

5 MR. RECKLEY: Okay. Seeing no hands, 49,
6 slide 49. Just kind of wanted to emphasize that we
7 did maintain a fairly traditional safety
8 classification scheme of having safety related, non-
9 safety related but safety significant, which for those
10 more familiar with LNP, those would be non-safety
11 related with special treatment, and non-safety
12 significant SSCs.

13 And you can draw parallels between that
14 and some of the other approaches like regulatory
15 treatment of non-safety systems. Or the primary, the
16 three prim -- three of the four risk categories in
17 50.69.

18 And even to some degree, some
19 similarities, when you start to look at IAEA, specific
20 safety requirements and the introduction of design
21 extension conditions.

22 So, if there's no questions on safety
23 classification, we can go to slide 50.

24 MEMBER KIRCHNER: Is there a --

25 MR. RECKLEY: Go ahead.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER KIRCHNER: Bill, this is Walt
2 again. Is there any need to make it clear somehow
3 that like if you're invoking the LNP approach, the PRA
4 and all the rest that, I -- you said it, and I can't
5 remember it.

6 They don't -- the middle category, they
7 call it non-safety related but risk significant? Or
8 -- I can't remember.

9 MR. RECKLEY: Yeah. Under LNP or in NEI
10 1804, it's called non-safety related with special
11 treatment.

12 MEMBER KIRCHNER: Special treatment.
13 Sorry, I misspoke.

14 MR. RECKLEY: And it really is equivalent
15 to what we're calling non-safety related but safety
16 significant.

17 In that what we -- what we'll ultimately
18 say is needed for any SSC that's designated as non-
19 safety related but safety significant, is the
20 definition of what is needed in terms of special
21 treatment.

22 Be it hardware requirements like the
23 environment it needs to withstand, be it relia --
24 almost certainly a reliability assurance program and
25 measure to carry through in operations.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And maybe even programmatic requirements
2 in terms of inspections, procedures to operate the
3 equipment. Whatever special treatment is needed in
4 order to ensure that that SSC --

5 MEMBER KIRCHNER: Right.

6 MR. RECKLEY: Would have the capabilities,
7 the reliabilities, the availabilities that are assumed
8 in the assessments.

9 So --

10 MEMBER KIRCHNER: Okay. And so, the --
11 obviously then, these will make your definition table
12 some place.

13 MR. RECKLEY: Yes.

14 MEMBER KIRCHNER: And then we won't have
15 to deal with the many other terms. At least in terms
16 of 53, at least.

17 And we would -- we would just have these
18 three. We wouldn't have the two by two box. We
19 wouldn't have other -- other terminology then in 53.
20 We would be self-consistent.

21 MR. RECKLEY: Yes. That's the goal.

22 MEMBER KIRCHNER: Good. Good.

23 MR. RECKLEY: Yeah. And there were
24 certain terms that we avoided on purpose, just to not
25 carry forth the confusion for another 50 years.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, with that, I think we can -- if
2 there's no more questions on that. Analytical margins
3 for operating flexibilities, we've talked about this
4 a fair amount.

5 And we've really not changed the language
6 very much. Or at all really. This is the provision,
7 this is the section that would define how the analysis
8 needs to be carried through and maintained to support
9 something like the calculation that you could have a
10 smaller emergency planning zone, or you could justify
11 an alternative to the population density criteria in
12 the siting reg guide.

13 Any other operational flexibilities that
14 we're going to start to get into in Subpart F, this
15 provision is allowing the margins to be traded off.

16 And then establishing the requirements to
17 make sure that all the assumptions and analysis that
18 went into justify trading off the margins, are
19 maintained over the life of the plan.

20 So, we can go onto 51, I think. There
21 were really no changes or much of a discussion with
22 external stakeholders or with the ACRS subcommittee on
23 the need to have quality assurance for the design
24 process, and the need to set up interfaces between the
25 design process and things like construction, fairly

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 obvious, operations, and so forth.

2 So, I don't -- I won't spend much more
3 time on that. Slide 52 goes to non-radiological
4 hazards. And we talked about this with the
5 subcommittee.

6 We're just -- we are still looking at this
7 and looking at other examples like fuel cycle
8 facilities, to see how we should bring in the non-
9 radiological hazards into Part 53.

10 We'll acknowledge that it warrants, I
11 don't know, reviewing that topic. And we're currently
12 doing that. And we will come back to the ACRS on our
13 resolution of that.

14 And with that, I think that's the last
15 slide. Yes.

16 MEMBER BLEY: Okay. Bill?

17 MR. STUTZKE: Yes, Dennis?

18 MEMBER BLEY: I might go back to Marty if
19 he's still with us. Marty, could you pull up your
20 slide 64 and then 65?

21 MR. STUTZKE: Yes.

22 MEMBER BLEY: My first question is just
23 personal curiosity on 64. The surrogates here, the
24 QHOs, my memory is that this stuff was put together by
25 Trevor Bott (phonetic) and maybe John Lanoff

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 (phonetic), but both may have been by going to
2 existing PRAs and kind of summarizing this.

3 Do you remember if that's how that came
4 about?

5 MR. STUTZKE: Yes. That is.

6 MEMBER BLEY: And then --

7 (Simultaneous speaking)

8 MR. STUTZKE: And when a --

9 MEMBER BLEY: Go ahead.

10 MR. STUTZKE: Yeah, that's how it was
11 done. I mean, they actually described it pretty well
12 in the Appendix D of the technology neutral framework,
13 NUREG-1860.

14 MEMBER BLEY: That's why I remember it.
15 Thank you.

16 MR. STUTZKE: Yes.

17 MEMBER BLEY: Go onto 65. There's some
18 real key stuff in this slide. Maybe you can talk us
19 through this one.

20 And you know, we've -- we thought some
21 about some difficulties. Now Bill's assured us, and
22 we've found they're not too difficult directly of
23 having the QHOs.

24 But, there are arguments about why it
25 might be better if you use other integral risk

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 measures to test the overall risk for a new plant.

2 And that you've cited something up here
3 that was also in Appendix in 1860. But, I think in
4 the body of 1860 they went with the QHOs as an
5 integral risk measure.

6 But in the Appendix they used various
7 other approaches. If you could talk us through that,
8 I think that would be helpful.

9 MR. STUTZKE: Yeah. It's an historic
10 issue as you said, Dennis. They ended up using the
11 QHOs in the main body.

12 And there is this extended discussion
13 about the use of complementary accumulative
14 distribution functions, CCDFs, in there. I've cited
15 the main ACRS letter where they debated, you know, the
16 members at that time about the pros and cons of using
17 the method.

18 The staff deferred action on it. One,
19 because the project was coming to an end. And they
20 wanted to get 1860 published.

21 The more technical reason is they were
22 worried about anchoring the CCDF to the QHOs. So, the
23 area under the CCDF is the main risk, right. The
24 expected value of risk.

25 So, you start that way, and the question

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is then, how do you draw the line? You know, the
2 limit line that the CCDF would represent.

3 And they never got to that point during
4 the development of NUREG-1860. But rather, it was
5 intended to be deferred until they could pilot 1860
6 either on the, I think the pebble bed design.

7 MEMBER BLEY: Yeah. It was the pebble
8 bed. And they backed out.

9 MR. STUTZKE: Yeah. They backed out and
10 it never got done. It was never picked up.

11 MEMBER BLEY: So, have you given any
12 thought to relative merits of sticking with the QHOs?
13 Or using something like a CCDF limit curve?

14 MR. STUTZKE: Yeah. I thought about it
15 occasionally. About how would I come up with the, you
16 know, the shape of the CCDF curve. And make certain
17 it goes through appropriate anchor points and things
18 like that.

19 But, that's about as far as I've gotten.
20 I'm not ready to say, you know, one way is better than
21 the other.

22 MEMBER BLEY: Of course Rich Denning and
23 Vinod Mubayi, and Vinod was probably the primary
24 author of that Appendix, wrote a letter to the staff
25 on this very issue.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. STUTZKE: Yes.

2 MEMBER BLEY: I saw a copy of the letter.
3 Is there a response to the letter? Yes, there is.
4 And it's in -- you got it there. That's the end on
5 that one.

6 MR. STUTZKE: Yes.

7 MEMBER BLEY: Could you tell us how the
8 staff responded?

9 MR. STUTZKE: Bill, you want to jump in
10 since I didn't write this response?

11 MR. RECKLEY: Our response was basically
12 to acknowledge that what Dr. Denning and -- had
13 proposed was a workable approach.

14 However, we also thought that the LNP,
15 looking at the individual events, and comparing it to
16 the frequency consequence, when combined with looking
17 at the cumulative risk through looking at the QHOs and
18 the other cumulative measure that LNP had provided,
19 that it was also an acceptable approach.

20 And since for the purpose of writing the
21 regulatory guide, we were being asked to endorse NEI's
22 1804, that -- that as Marty said, we weren't saying
23 one was necessarily preferable over another. Both
24 could work.

25 And so that was the response.

1 MEMBER BLEY: Thank you. We may come back
2 to this some more later. Okay. So, I just wanted to
3 pick up those two.

4 I don't have anything else. Do any other
5 members have questions or comments you'd like to make
6 before we move to public comments?

7 MEMBER DIMITRIJEVIC: Well Dennis, I heard
8 two interesting things today. And I was wondering if,
9 are those two informations publically available?

10 And can we see some of that? Like for
11 example, there was a, I think Bill said there was a --
12 they've used the QHOs on some of them for Fukushima.

13 So, that would be something that would be
14 interesting to see. And also, Marty said that the
15 level three is out, which they've done.

16 I'm not sure I support that right at this
17 moment with the associate uncertainties, show the
18 uncertainties are not so high on level three results.

19 And I -- if that's a public available
20 book, I would love to see that.

21 MEMBER BLEY: All right. If the staff
22 could deliver any of that to Derek, that would be
23 helpful. My memory is that back when we reviewed the
24 Fukushima items on the failure to vent for all
25 reactors, that was part of the analysis, was that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 But Bill, I'm not positive of that.

2 MR. RECKLEY: Yeah.

3 MEMBER BLEY: So were --

4 MEMBER RECKLEY: Yes, you did. And it was
5 subsequently published in a NUREG. And so we'll give
6 you that reference.

7 MEMBER BLEY: Okay. I think that would be
8 helpful. And that would be great for that.

9 MR. RECKLEY: Yes.

10 MEMBER BLEY: Okay. Thank you. And
11 Derek, you're on the line. I remember we got the
12 comments from Rich and Vinod.

13 Did we also get the staff response? Or
14 can you get that for us?

15 MR. WIDMAYER: I think I got it. But,
16 I'll check and make sure.

17 MEMBER BLEY: Okay. Thank you.

18 MR. WIDMAYER: Yeah.

19 MEMBER BLEY: Anyone else?

20 (No response)

21 MEMBER BLEY: At this time I'd like to
22 open the public line. Oh, no, I'm sorry. My day has
23 gone blank.

24 But, at this time I'm going to invite
25 Cyril Draffin from the USNIC to speak. They requested

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 time with the meeting to make some comments.

2 And if you are available, please begin.

3 MR. DRAFFIN: I am. Thank you very much.

4 I am Cyril Draffin, the Senior Fellow for Advanced
5 Nuclear at the U.S. Nuclear Industry Council. And
6 today's remarks augment the comments we provided at
7 the April 22 subcommittee meeting.

8 First, it may be premature for the ARC to
9 make a definitive comment. The NRC has stressed that
10 Part 53 permitting language will remain open to change
11 until all parts of Part 53 have been provided and
12 stakeholder comments have been received.

13 Therefore, it may have a negative impact
14 for ACRS to submit a definitive interim letter to
15 support the current Subpart B and C drafts of the
16 rule. Recognize that only a current portion of the
17 Part 53 language is available and the current language
18 is likely to change.

19 Second, the U.S. Nuclear Industry Council
20 does not agree with the second iteration of Subparts
21 B and C. There are many areas where the preliminary
22 language in Subparts B and C are increasing regulatory
23 burden over Parts 50 and 52.

24 And the NRC has basically made no major
25 changes to address the industry concerns about those

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 two Subparts.

2 Also, there is a -- the NRC staff had
3 promised that Subpart F would enable a significant
4 reduction in operational burden as compared to Parts
5 50 and 52.

6 And therefore, that justified the
7 increased burden in Subparts B and C to obtain those
8 operational duties, the operational burden.

9 But, now having seen Subpart F, it's not
10 clear what the benefits are. The preliminary language
11 seems to result in increased burden, doesn't -- still
12 limits flexibility, and doesn't really enhance the
13 safety.

14 So, we're hoping that the NRC will be
15 receptive to incorporating some of industry's
16 stakeholders' inputs in the coming months.

17 The only apparent benefit of Part 53 so
18 far, is that there's no need to seek exemptions to
19 large LWR specific requirements.

20 Then a few points that we've covered
21 before, which I think are still relevant, particularly
22 for people that weren't on the subcommittee meeting.

23 For the adequate protection standard, we
24 disagree with the second revision to the strategic
25 objectives that drop the formal reference to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reasonable assurance of adequate protection standard.

2 We think that it, adequate protection to
3 public health and safety is important. And changing
4 the objectives primarily to justify the preliminary
5 language seems questionable.

6 For the tiers, we still think the tiered
7 category one and two are confusing, with opportunities
8 for unintended consequences. The second rendition of
9 the SOARCA objectives drops the language in the Atomic
10 Energy Act, and so the same 51 and 52 seem less
11 relevant.

12 And we might consider a simple tier unless
13 the operational language shows real benefits, and
14 particularly for all the criteria discussed earlier
15 that have to be met.

16 We continue to believe Part 53 should be
17 technology inclusive to allow both risk based and
18 deterministic methods. And that it should not be
19 limited to just applications using the PRA tool,
20 although it's a very valuable tool

21 And with this second iteration, it's still
22 too restrictive in requiring a PRA. As discussed
23 earlier, we think PRA should be applicable for a range
24 of licensing path and technologies.

25 And that risk insights are what are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 important for design, not the specific numerical
2 results. We don't believe that PRA should be elevated
3 to a compliance tool as part of the application,
4 especially for a construction permit.

5 It's not clear that any approach used by
6 Oklo or NuScale would comport with a prescriptive use
7 of the PRA as a compliance tool.

8 And if it is included, as it is not, in
9 Part 53 as a requirement, then exemptions will be
10 required for some of the technologies, which seems a
11 little inconsistent with the original goals and
12 objectives of Part 53.

13 Now, the timing for a phased or simplified
14 approach has merit. And I think that there's some
15 flexibility on how that's done. It merits further
16 discussion.

17 For ALARA, many stakeholders, as mentioned
18 this morning, believe that ALARA is an important
19 concept and certainly a good practice that we expect
20 to continue.

21 But, we do not believe ALARA should be
22 included in Part 53 formal regulation in part because
23 of the subjectivity and complexity of ALARA in the
24 design phase. New operation should be like protection
25 of plant workers and should not be included in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 safety criteria.

2 And for defense in depth, it's important
3 as a design philosophy and supporting an adequate
4 safety case. But, the defense in depth details should
5 be in guidance and not added to the regulations.

6 We believe that Part 53 can have
7 predictability as well as flexibility. We think it
8 really can have specific performance criteria that
9 must be demonstrated, and flexibility to allow them to
10 be made and not just relying upon LNP as the process.

11 And finally, we do support the consensus
12 codes and standards, which are being adopted by NRC.
13 So, those are some comments for you to consider as you
14 draft your interim letter.

15 Thank you for the opportunity.

16 MEMBER BLEY: Mr. Draffin, thank you very
17 much. You will be on the transcript. And you will
18 have access to that.

19 But, if you prefer to also send your
20 comments in writing, both they -- I shouldn't say it
21 won't be garbled, but once in a while, transcripts
22 don't read exactly like you thought you said them.

23 So, if you wanted to do it in writing too,
24 that's fine. Just give them to Derek.

25 MR. DRAFFIN: Well, thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: So, Thomas or Makeeka, can
2 we get the public line open?

3 MR. DASHIELL: The public line is open for
4 comments.

5 MEMBER BLEY: Thank you very much. If
6 there's anyone who would like to make a comment,
7 please identify yourself and make your comments.

8 (No response)

9 MEMBER BLEY: All right. Okay, I think we
10 can close the public line at this point.

11 For the members, we had a very long
12 session last week of deliberations. And as a result
13 of that, I really thank everyone for all the ideas and
14 written suggestions and the discussion.

15 But, it helped a lot. As I began to
16 organize my notes from it, that session, the pieces
17 started to come together.

18 And I think they're -- they're still
19 pretty much holding out that there might be some areas
20 we'll have to dig into. As I drafted a letter, I
21 tried to include areas where I had a sense we had
22 agreement.

23 And for other areas, rather than
24 reconcile, I tried to integrate that, or put together
25 the areas of concern. I couldn't address every issue

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that everyone raised. We don't need that in this
2 letter.

3 Added comments may be necessary or are
4 certainly welcomed. But that's kind of irrelevant.
5 You can write them anyway. But any area where one or
6 two people feel very strongly about, maybe it's
7 important.

8 At this time, I think we'll call this
9 meeting to an end. But, we'll move into a letter
10 writing session if that's okay, Matt.

11 But we will go off the record. But, I'll
12 let you do that since this is a full committee
13 meeting.

14 CHAIR SUNSERI: Thank you, Dennis. So,
15 could we take like a ten minute break though before we
16 go into reading the letter?

17 Would that be okay to everyone?

18 MEMBER BLEY: Yeah. I was going to
19 suggest that. And I think we'll try to finish in 15
20 or 20 minutes after.

21 I don't know, if we really get into
22 discussion, it could take a long time. But, I'd like
23 everybody to hear where it stands now and be able to
24 read it later.

25 I think Derek will verify this. I think

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 he's got it up on the website. But, I'm not quite
2 sure.

3 CHAIR SUNSERI: Okay. Very good. Then
4 we'll take a 15 minute break here. We'll recess until
5 6:15. Is it 6:15, is that right? Yeah.

6 Oh, it's 6:00. Okay. All right. We'll
7 recess until 6:15. And then we'll pick it up and read
8 through the letter and finish today at the conclusion
9 of that activity.

10 All right. So, we are recessed.

11 (Whereupon, the above-entitled matter went
12 off the record at 6:00 p.m.)

13

14

15

16

17

18

19

20

21

22

23

24

25



Advisory Committee on Reactor Safeguards (ACRS)

10 CFR Part 53
“Licensing and Regulation of
Advanced Nuclear Reactors”

May 5, 2021

Agenda

- Opening Remarks
- Overall Structure (Framework)
- Subpart B – Technology-Inclusive Safety Requirements
- Subpart C – Design and Analysis Requirements
- Discussion

Background

- Nuclear Energy Innovation and Modernization Act (NEIMA; Public Law 115-439) signed into law in January 2019 requires the NRC to complete a rulemaking to establish a technology-inclusive, regulatory framework for optional use for commercial advanced nuclear reactors no later than December 2027
 - (1) **ADVANCED NUCLEAR REACTOR**—The term “advanced nuclear reactor” means a nuclear fission or fusion reactor, including a prototype plant... with significant improvements compared to commercial nuclear reactors under construction as of the date of enactment of this Act, ...

NRC Staff Plan to Develop Part 53

Subpart B

Subpart C

Subpart D

Subpart E


Subpart F

Subpart G

← Project Life Cycle →

Requirements Definition

- Safety Objectives
- Safety Criteria
- Safety Functions



Other

Subpart A
General Provisions

Subpart J
Admin & Reporting

Plant/Site (Design, Construction, Configuration Control)

Analyses (Prevention, Mitigation, Compare to Criteria)

Plant Documents (Systems, Procedures, etc.)

LB Documents (Applications, SAR, TS, etc.)

Clarify Controls and Distinctions Between

Subparts H & I

Part 53 Contents

(A)	General Provisions (<i>including definitions</i>)
(B)	Safety Criteria (<i>two tiers/categories, as low as reasonably achievable (ALARA), defense in depth (DiD)</i>)
(C)	Design and Analysis (<i>design criteria, role of probabilistic risk assessment (PRA)</i>)
(D)	Siting (<i>external hazards, population</i>)
(E)	Construction and Manufacturing (<i>factory fueling</i>)
(F)	Operations (<i>structures, systems and components (SSCs), staffing, programs</i>)
(G)	Decommissioning
(H)	Licensing (<i>siting, design, licenses</i>)
(I)	Maintaining Licensing Basis
(J)	Administrative and Reporting

Subpart B

Technology-Inclusive Safety

Requirements


Preliminary Language

Rulemaking Plan (SECY-20-0032)

The staff plans to build upon ongoing activities such as those described in SECY-19-0117, “Technology-Inclusive, Risk-Informed, and Performance-Based Methodology to Inform the Licensing Basis and Content of Applications for Licenses, Certifications, and Approvals for Non-Light-Water Reactors,” dated December 2, 2019 (ADAMS Accession No. ML18311A264), to develop the associated performance criteria. ... The methodology described in SECY-19-0117, ... includes identifying the potential benefits provided by design features and programmatic controls in terms of the margins between estimated doses and the reference values in NRC regulations and the margins between estimated health effects and the NRC’s safety goals. SECY-18-0096, “Functional Containment Performance Criteria for Non-Light-Water-Reactors,” dated September 28, 2018 (ADAMS Accession No. ML18115A157), and SECY-18-0103, “Proposed Rule: Emergency Preparedness for Small Modular Reactors and Other New Technologies (RIN 3150-AJ68; NRC-2015-0225,” dated October 12, 2018 (ADAMS Accession No. ML18134A076), provide examples of how those margins are used within performance criteria for potential operational flexibilities.

First Principles


Recent NRC activities related to advanced reactors (e.g., functional containment performance criteria, possible changes to emergency planning & security, and DG-1353) recognize the limitations of existing LWR-related guidance, which requires a return to first principles such as fundamental safety functions supporting the retention of radionuclides





See: **SECY-18-0096**, “Functional Containment Performance Criteria for Non-Light-Water-Reactors,” INL/EXT-20-58717, “Technology-Inclusive Determination of Mechanistic Source Terms for Offsite Dose-Related Assessments for Advanced Nuclear Reactor Facilities,” and **SECY-19-0117**, “Technology-Inclusive, Risk-Informed, and Performance-Based Methodology..”

Subpart B – Safety Criteria


- Safety Objectives
- First Tier Safety Criteria
 - Immediate threat to public health and safety
- Second Tier Safety Criteria
 - Appropriate to address potential risks to public health and safety
- Safety Functions
- Licensing Basis Events (LBEs)
- Defense in Depth
- Protection of Plant Workers



Technology-Inclusive Methodology



Modular High-Temperature Gas-Cooled Reactor (MHTGR) Example (Safety Functions)



Addressing Functions & Design Criteria

(B) Safety Functions

(C) Design Features

(C) Functional Design Criteria

10 CFR 50, Appendix A
General Design Criteria

I. Overall Requirements:

II. Protection by Multiple Fission Product Barriers:

III. Protection and Reactivity Control Systems:

Quality Standards and Records	1
Design Bases for Protection Against Natural Phenomena	2
Fire Protection	3
Environmental and Dynamic Effects Design Bases	4
Sharing of Structures, Systems, and Components	5
Reactor Design	10
Reactor inherent Protection	11
Suppression of Reactor Power Oscillations	12
Instrumentation and Control	13
Reactor Coolant Pressure Boundary	14
Reactor Coolant System Design	15
Containment Design	16
Electric Power Systems	17
Inspection and Testing of Electric Power Systems	18
Control Room	19
Protection System Functions	20
Protection System Reliability and Testability	21
Protection System Independence	22
Protection System Failure Modes	23
Separation of Protection and Control Systems	24
Protection System Requirements for Reactivity Control Malfunctions	25
Reactivity Control System Redundancy and Capability	26
Combined Reactivity Control Systems Capability	27
Reactivity Limits	28
Protection Against Anticipated Operational Occurrences	29

Addressing Functions & Design Criteria

(B) Safety Functions

(C) Design Features

(C) Functional Design Criteria

IV. Fluid Systems:

V. Reactor Containment:

VI. Fuel and Radioactivity Control:

Quality of Reactor Coolant Pressure Boundary	30
Fracture Prevention of Reactor Coolant Pressure Boundary	31
Inspection of Reactor Coolant Pressure Boundary	32
Reactor Coolant Makeup	33
Residual Heat Removal	34
Emergency Core Cooling	35
Inspection of Emergency Core Cooling System	36
Testing of Emergency Core Cooling System	37
Containment Heat Removal	38
Inspection of Containment Heat Removal System	39
Testing of Containment Heat Removal System	40
Containment Atmosphere Cleanup	41
Inspection of Containment Atmosphere Cleanup Systems	42
Testing of Containment Atmosphere Cleanup Systems	43
Cooling Water	44
Inspection of Cooling Water System	45
Testing of Cooling Water System	46
Containment Design Basis	50
Fracture Prevention of Containment Pressure Boundary	51
Capability for Containment Leakage Rate Testing	52
Provisions for Containment Testing and Inspection	53
Systems Penetrating Containment	54
Reactor Coolant Pressure Boundary Penetrating Containment	55
Primary Containment Isolation	56
Closed Systems Isolation Valves	57
Control of Releases of Radioactive Materials to the Environment	60
Fuel Storage and Handling and Radioactivity Control	61
Prevention of Criticality in Fuel Storage and Handling	62
Monitoring Fuel and Waste Storage	63
Monitoring Radioactivity Releases	64

Part 50 and Part 53 Comparing Licensing Frameworks

- Safety criteria
 - Same safety criteria in Parts 50 and 53
 - Quantitative health objectives (QHOs) used in guidance under Part 50
- Design and Analyses
 - Design Basis Accidents (DBAs)
 - Part 50: Assessed using prescriptive, highly conservative analyses
 - Including single failure criterion (SFC)
 - Part 53: Assessed methodically considering event frequencies and assuming only safety-related SSCs are available
 - Beyond Design Basis Events (BDBEs)
 - Part 50: Identified & assessed by largely ad-hoc, prescriptive approach with uncertainties addressed through conservatism
 - Part 53: Derived methodically using event frequencies with explicit consideration for uncertainties
 - Including combinations of various equipment failures
- Special Treatment for Non-Safety-Related but Risk-Significant SSCs
 - Part 50: Ad-hoc (e.g., § 50.69 programs, Reliability Assurance Programs (RAP))
 - Part 53: Systematic approach to control frequencies and consequences of the LBEs in relation to safety criteria

Second Iteration – Objectives

§ 53.200 Safety Objectives.

Each advanced nuclear plant must be designed, constructed, operated, and decommissioned to limit the possibility of an immediate threat to the public health and safety. In addition, each advanced nuclear plant must take such additional measures as may be appropriate when considering potential risks to public health and safety. These safety objectives shall be carried out by meeting the safety criteria identified in this subpart.

- Discussion
 - Generally aligns with requirements for content of technical specifications and regulatory treatment of non-safety systems
 - Addresses concerns related to tying tiers to authorities provided in the Atomic Energy Act (e.g., adequate protection and minimize danger to life or property)

Second Iteration – First Tier

§ 53.210 First Tier Safety Criteria.

- (a) Public dose does not exceed Part 20 limit (0.1 rem) from normal plant operation
- (b) Provide design features and programmatic controls such that events with frequencies greater than once per 10,000 years meet the following
 - (1) 2-hour dose below 25 rem at EAB
 - (2) Duration dose below 25 rem at LPZ boundary

- Discussion
 - Maintains technical criteria from first iteration
 - Generally aligns with requirements for content of technical specifications and regulatory treatment of non-safety systems
 - Deleted paragraph (c) since the first tier criteria are no longer tied to adequate protection standard
 - Added existing footnote on 25 roentgen equivalent man (rem) as reference value
 - General note that staff assessing terminology (tiers)

Additional Discussion – First Tier

- Possible Applications of First Tier Safety Criteria
 - Minimally acceptable level of safety
 - Met by satisfying the safety functions needed for dose < 25 rem
 - Provides basis for safety classification of safety-related SSCs
 - Demonstration of meeting the first tier safety criteria supported by analyses of DBA
 - Provides basis for identifying SSCs needing protection against external events up to the design basis external hazard levels
 - Provides basis for identifying appropriate content of technical specifications (TS)
 - Reserved for the most significant safety requirements
 - Necessary to obviate the possibility of an abnormal situation or event giving rise to an immediate threat to the public health and safety
 - May provide basis for staffing and operator licensing decisions
 - Greatest level of detail for information in licensing documents

Second Iteration – Second Tier

- Second Tier Safety Criteria

FIRST ITERATION/SECOND ITERATION

§ 53.220 Second Tier Safety Criteria.

(a) *Normal operations*. Design features and programmatic controls must be provided for each advanced nuclear plant to ensure the estimated total effective dose equivalent to individual members of the public from effluents resulting from normal plant operation are **as low as is reasonably achievable** taking into account the state of technology, the economics of improvements in relation to the state of technology, operating experience, and the benefits to the public health and safety. Design features and programmatic controls must be established such that [to be reworded for consistency with 10 CFR part 20 and 40 CFR part 190].

(b) *Unplanned events*. Design features and programmatic controls must be provided to:

- (1) Ensure plant SSCs, personnel, and programs provide the necessary capabilities and maintain the necessary reliability to address licensing basis events in accordance with § 53.240 and provide measures for defense-in-depth in accordance with § 53.250; and
- (2) **Maintain overall cumulative plant risk from licensing basis events such that the risk to an average individual within the vicinity of the plant receiving a radiation dose with the potential for immediate health effects remains below five in 10 million years, and the risk to such an individual receiving a radiation dose with the potential to cause latent health effects remains below two in one million years.**

Feedback – 2nd Tier, ALARA

- ALARA
 - Proposal by some stakeholders to eliminate all ALARA requirements under Part 53.
- NRC Iteration: Maintained requirements for normal operations and occupational exposures to be ALARA

Note that concerns related to ALARA and NRC reviews of design-related applications are also being addressed through the Advanced Reactor Content of Application Project with current drafts of Chapter 9 released to support stakeholder interactions:

“... in lieu of providing detailed system descriptions and analysis of estimated effluent releases as required by 10 CFR 50.34, 50.34a, 52.47, and 52.79, an application may demonstrate compliance with the applicable regulations by describing a radiation protection program and an effluent release monitoring program that will ensure that effluent release limits will be met during normal operations for the life of the plant. Information related to physical systems can be limited to general descriptions of layout and technologies used to limit the release of the various inventories of radioactive materials within the plant.”

Feedback – 2nd Tier, QHOs

- QHOs
 - Proposal by some stakeholders to maintain QHOs as policy but exclude from rule
 - Some concern over use of QHOs related to inclusion of requirement to perform PRA
 - Proposal by some stakeholders to use a metric other than QHOs as second tier
 - Range of stakeholder views, from use of QHOs to use of cost-benefit assessment for second tier, which in NRC practice includes assessment against QHOs
- NRC Iteration: Maintained QHOs within the second tier safety criteria
 - The QHOs are a well-established measure used in NRC risk-informed decision making and are a logical performance metric to support the risk management approaches to operations that will be reflected in Subpart F, “Operations.”
 - Note that using less defined criteria for the second tier would decrease the predictability of the regulations in terms of the desired graded approach (e.g., differentiation between SSCs that are safety related and non-safety related with special treatment)

Additional Discussion – Second Tier

- Possible Applications of Second Tier Safety Criteria
 - With first tier, ensures appropriate level of safety for long-term, risk-informed operations
 - Met by satisfying the safety functions for meeting QHOs
 - Demonstration of meeting the second tier safety criteria supported by systematic analyses (i.e., PRA)
 - Provides basis for identifying additional risk-informed requirements
 - Provides basis for identifying appropriate special treatment for non-safety related SSCs (e.g., functional design requirements & reliability)
 - Provides basis for enabling risk management approach to operations
 - May provide basis for staffing and operator licensing decisions
 - Enables appropriate level of detail in licensing basis documentation based on a risk-informed, function-oriented and performance-based approach

Second Iteration – Safety Functions

§ 53.230 Safety Functions

(a) The primary safety function is limiting the release of radioactive materials from the facility and must be maintained during routine operation and for licensing basis events over the life of the plant.

(b) Additional safety functions supporting the retention of radioactive materials during routine operation and licensing basis events—such as controlling [reactivity], heat generation, heat removal, and chemical interactions--must be defined.

(c) The primary and additional safety functions are required to meet the first and second tier safety criteria and are fulfilled by the design features and programmatic controls specified throughout this part.

- Discussion (Safety Functions)
 - Maintains mention of fundamental safety functions as examples to maintain technology-inclusive framework (with potential use for multiple inventories of radionuclides within plants and possibly technologies such as fusion energy systems)
 - Reinforces general hierarchy of safety criteria, safety function, design feature, and functional design criteria.

Second Iteration – LBEs

§ 53.240 Licensing Basis Events

Licensing basis events must be identified for each advanced nuclear plant and analyzed in accordance with § 53.450 to support assessments of the safety requirements in this subpart B. The licensing basis events must address combinations of malfunctions of plant SSCs, human errors, and the effects of external hazards **ranging from anticipated operational occurrences to very unlikely event sequences with estimated frequencies well below the frequency of events expected to occur in the life of the advanced nuclear plant.** The evaluation of licensing basis events must be used to confirm the adequacy of design features and programmatic controls needed to satisfy first and second tier safety criteria of this subpart and to establish related functional requirements for plant SSCs, personnel, and programs.

- Discussion (LBEs)
 - Changes to clarify the range of scenarios to be addressed by LBEs

Licensing Basis Events – Light-Water Reactor (LWR) Summary

a. Consider events that can result in the basic parameter changes listed below and identify potential limiting events:

- Increase of core reactivity,
- Changes of reactor coolant flow,
- Changes of reactor coolant pressure,
- Changes of reactor coolant temperature,
- Changes of reactor coolant inventory,
- Changes in energy supplies to the plant,
- Changes in coolant supplies to the plant,
- Changes in the nuclear safety-related equipment status,
- Changes in core power distribution,
- Changes in radioactive releases, or
- Changes of any other variable that has a limiting value.

EVENT FREQUENCY RANGE (per reactor-year)	PLANT CONDITIONS CATEGORIES	OTHER CATEGORIZATION SCHEMES					
		NRC			ANS		
		10 CFR	RG 1.48 ASME Code*	RG 1.70 Rev. 2	51.1 (N18.2)	52.1 (N212)	53.1 (N213)
Planned Operations	PC-1	Normal	Normal	Normal	Condition I	Normal PPC	Plant Condition A
10 ⁻¹	PC-2	Anticipated Operational Occurrences	Upset	Moderate Frequency	Condition II	Frequent PPC	Plant Condition B
	PC-3			Infrequent Incidents	Condition III		
10 ⁻²	PC-4	Accidents	Emergency	Limiting Faults	Condition IV	Infrequent PPC	Plant Condition C
10 ⁻³							
10 ⁻⁴	PC-5	Faulted	Limiting Faults	Limiting Faults	Condition IV	Limiting PPC	Plant Condition D
10 ⁻⁵							
10 ⁻⁶							
	Not sidered						

Table 3-1

Offsite Radiological Dose Criteria for Plant Conditions

* 1977 version of the ASME Code.

Best-Estimate Frequency of Occurrence (F) Per Reactor Year	Plant Condition (PC)	Offsite Radiological Dose Criterion
Normal Operations	PC-1	10 CFR 50, App. I ^(a) [18]
F ≥ 10 ⁻¹	PC-2	10 CFR 50, App. I ^(a) [18]
10 ⁻¹ > F ≥ 10 ⁻²	PC-3	10% 10 CFR 100 ^(b) [2]
10 ⁻² > F ≥ 10 ⁻⁴	PC-4	25% 10 CFR 100 ^(b) [2]
10 ⁻⁴ > F ≥ 10 ⁻⁶	PC-5	100% 10 CFR 100 ^(b) [2]

Fig. B-1
Event Categorization

ANSI/ANS-51.1-1983; nuclear safety criteria for the design of stationary pressurized water reactor plants (withdrawn 1989)

Licensing Modernization Project (LMP): Event Selection & Analysis

- Introduction of an actual frequency-consequence curve as part of the regulatory process (vs. general relationship of decreased consequences expected for more frequent events)





Figure 3-1. Frequency-Consequence Target

Tabletop Exercise (MHTGR; Xe-100)

XE-100 LMP DEMONSTRATION HIGHLIGHTS



- Example of LMP application at early state of design.
- Limited scope high level PRA developed during preconceptual design to guide conceptual design.
- Completed preliminary selection of LBEs and RSFs with examples identified for SR SSCs.



Internal Initiating Events	
Turbine Trip (TT)	
Reactor Trip (RT)	
Circulator Trip (CT)	
Loss of Primary Flow (LF)	
Control Rod Withdrawal (CR)	
Loss of Offsite Power (LO)	
Steam Generator Feedwater Pump Trip (FW)	
Small Helium Depressurization (SD)	
Medium Helium Depressurization (MD)	
Large Helium Depressurization (LD)	
Steam Generator Tube Rupture (SG)	

LMP: Event Selection & Analysis

Anticipated Operational Occurrences (AOOs)

[Part 53 – AOOs]

Anticipated **event sequences** expected to occur one or more times during the life of a nuclear power plant, which may include one or more reactor modules. **Event sequences with mean frequencies of 1×10^{-2} /plant-year and greater are classified as AOOs. AOOs take into account the expected response of all SSCs within the plant, regardless of safety classification.**

DBEs

[Part 53 – Unlikely events]

Infrequent **event sequences** that are not expected to occur in the life of a nuclear power plant, which may include one or more reactor modules, but are less likely than AOOs. **Event sequences with mean frequencies of 1×10^{-4} /plant-year to 1×10^{-2} /plant-year are classified as DBEs. DBEs take into account the expected response of all SSCs within the plant regardless of safety classification.**

BDBEs

[Part 53 – Very unlikely events]

Rare **event sequences** that are not expected to occur in the life of a nuclear power plant, which may include one or more reactor modules, but are less likely than a DBE. **Event sequences with mean frequencies of 5×10^{-7} /plant-year to 1×10^{-4} /plant-year are classified as BDBEs. BDBEs take into account the expected response of all SSCs within the plant regardless of safety classification.**





Figure 3-1. Frequency-Consequence Target

LMP: Required Safety Functions

Required Safety Function (RSF): A PRA Safety Function that is required to be fulfilled to maintain the consequence of one or more DBEs or the frequency of one or more high-consequence BDBEs inside the F-C Target




Provides connection to Safety-Related Classification

Note – in Part 53, RSFs would translate to those functions needed to address first tier safety criteria

Figure 3-1. Frequency-Consequence Target

RSF Example

- MHTGR RSFs



Design Basis Accidents

DBAs

[Part 53 – DBAs]

Postulated event sequences that are used to set design criteria and performance objectives for the design of Safety Related SSCs. DBAs are derived from DBEs based on the capabilities and reliabilities of Safety-Related SSCs needed to mitigate and prevent event sequences, respectively. **DBAs are derived from the DBEs by prescriptively assuming that only Safety Related SSCs are available to mitigate postulated event sequence consequences to within the 10 CFR 50.34 dose limits.**




Figure 3-1. Frequency-Consequence Target

Second Iteration – DiD

§ 53.250 Defense in Depth

Measures must be taken for each advanced nuclear plant to ensure appropriate defense in depth is provided to compensate for uncertainties such that there is high confidence that the safety criteria in this subpart are met over the life of the plant. The uncertainties to be considered include those related to the state of knowledge and modeling capabilities, the ability of barriers to limit the release of radioactive materials from the facility during routine operation and for licensing basis events, and those related to the reliability and performance of plant SSCs, personnel, and programmatic controls. No single **engineered design feature, human action, or programmatic control**, no matter how robust, should be exclusively relied upon to meet the safety criteria of § 53.220(b) or the safety functions defined in accordance with § 53.230.

- Discussion (DiD)
 - Maintains defense in depth within Subpart B because of historical and continued importance of its role in addressing risk
 - Parts 50/52 do not include a similar section because the defense-in-depth philosophy is incorporated into prescriptive technical requirements for light-water reactors
 - Possibility that this section could be addressed within Subpart C can be considered as part of the later review of the technical requirements
 - Reflects possible crediting of inherent characteristics within the design and analysis for advanced reactors and the reduced uncertainties associated with such characteristics

Second Iteration – Protection of Plant Workers

§ 53.260 Protection of Plant Workers

(a) Design features and programmatic controls must exist for each advanced nuclear plant to ensure that radiological dose to plant workers does not exceed the occupational dose limits provided in subpart C to 10 CFR part 20.

(b) **As required by Subpart B to 10 CFR part 20, design features and programmatic controls** must, to the extent practical, be based upon sound radiation protection principles to achieve occupational doses that are as low as is reasonably achievable.

- Discussion (Protection of Plant Workers)
 - Maintains the protection of plant workers within Subpart B to capture occupational exposures within the high-level safety requirements
 - Changed to refer to part 20, as suggested by stakeholders

Note that ALARA is not only a long-standing requirement by Atomic Energy Commission/NRC (including maintaining in Part 20 rulemaking) but also is addressed in U.S. Environmental Protection Agency [Federal Guidance for Radiation Protection](#)


Subpart C

Design and Analysis

Preliminary Language

Subpart C – Design and Analysis

- Design Features
- Functional Design Criteria for First Tier Safety Criteria
 - Comparable to Principal Design Criteria for Safety-Related SSCs
- Functional Design Criteria for Second Tier Safety Criteria
 - Provides Design Criteria for Safety Significant Non-Safety-Related SSCs
- Functional Design Criteria for Protection of Plant Workers
- Design Requirements
- Analysis Requirements
 - Role of PRA
- Safety Categorization and Special Treatment
- Application of Analytical Safety Margins to Operational Flexibilities
- Design Control Quality Assurance
- Design and Analyses Interfaces



Design-Related Discussions SFC vs Reliability Criterion

Part 53	PRA Required; Reliability Assurance through TS/RAP Subpart F
RG 1.233 (Licensing Modernization) (SECY-19-0117)	The staff finds that the NEI 18-04 methodology, including assessments of event sequences and DiD, obviates the need to use the single-failure criterion (SFC) as it is applied to the deterministic evaluations of AOOs and DBAs for LWRs.
SRM-SECY-19-0036 (Application of the Single Failure Criterion to NuScale IAB Valves)	The staff should apply risk-informed principles when strict, prescriptive application of deterministic criteria such as the SFC is unnecessary to provide for reasonable assurance of adequate protection of public health and safety.
SECY-03-0047 (Policy Issues Related to Licensing Non-Light-Water Reactor (NLWR) Designs) SRM dated 6/26/2003	The SFC would be replaced with a reliability criterion and the event scenarios identified in the PRA would be examined against this criterion. Note that Issue 4 in SECY-03-0047 also described probabilistic event selection and safety classification

The SFC

- The SFC has the direct objective of promoting reliability through the enforced provision of redundancy in those systems which must perform a safety-related function
- In SECY 77-439 (ML060260236), the staff critiqued the SFC at the request of the Commission:
 - The SFC has served well in its use as a licensing review tool to assure reliable systems as one element of the defense in depth approach to reactor safety.
 - The SFC is just one of several tools applied in systems design and analysis to promote reliability of the systems which are needed in a nuclear power plant for safe shutdown and cooling, and for mitigation of the consequences of postulated accidents. It is not sufficient by itself.
 - The SFC was developed without the benefit of numerical assessments on the probabilities of component or system failure.
 - The Reactor Safety Study (WASH-1400, the first nuclear plant PRA) also pointed out that factors such as systems interactions, multiple human errors, and maintenance and testing requirements also have an influence on reliability. Such factors fall outside the scope of the SFC, and supplementary methods must be utilized in their study.
 - It is expected that probabilistic methods of the type used in the Reactor Safety Study will gradually come into increasing use and supplement the SFC.
- See also the discussions in SECY-03-0047, SECY-05-0138, SECY-19-0036, SECY-19-0117 and related SRMs

Codes and Standards

§ 53.440 Design Requirements.

(a) The design features required to meet the first and second tier safety criteria defined in §§ 53.210 and 53.220 shall be designed using generally accepted consensus codes and standards wherever applicable.

Preliminary Definition (Subpart A): Consensus code or standard means any technical standard (1) developed or adopted by a voluntary consensus standard body under procedures that assure that persons having interests within the scope of the standard that are affected by the provisions of the standard have reached substantial agreement on its adoption, (2) formulated in a manner that afforded an opportunity for diverse views to be considered, and (3) designated by the standards body as such a standard for the safe design, manufacture, construction, or operation of nuclear power plants.

- Discussion (Codes and Standards)
 - Preliminary language encourages use of consensus codes and standards as required by the National Technology Transfer and Advancement Act.
 - Recognizes variety of technologies and designs as well as stated desire of some stakeholders to adopt standards outside of typical LWR standards development organizations (e.g., ISO or other international standards).
 - Considering using NRC endorsement of guidance documents versus incorporation of standards into the regulations.
 - Capture of acceptable standards in guidance increases efficiency by avoiding routine rulemakings related to the revision of incorporated standards in the regulations.

Second Iteration – Analysis (PRA)

§ 53.450 Analysis Requirements

(a) *Requirement to have a probabilistic risk assessment.* A probabilistic risk assessment (PRA) of each advanced nuclear plant [reminder – plant definition to include multi-module and multi-source] must be performed to identify potential failures, degradation mechanisms, susceptibility to internal and external hazards, and other contributing factors to unplanned events that might challenge the safety functions identified in § 53.230 **and to support demonstrating that each advanced nuclear plant meets the second tier safety criteria of § 53.220(b).**

- Discussion (PRA)
 - Maintains requirement in Part 53 for PRA consistent with evolution of risk-informed approaches but provide alternatives to PRA for design and analysis processes (paragraph (b)) and to support the licensing and regulatory programs being developed in subsequent subparts
 - Staff is engaged in ongoing discussions on how to ensure the level of effort required for a PRA is commensurate with the complexity of the subject reactor design while also ensuring possible deployment of advanced reactors poses no undue risk to public health and safety.

Past and Present Uses of the PRA

- Identify severe accident vulnerabilities and to provide insights which support the conclusion that the plant design, construction, and operation provides reasonable assurance no undue risk to public health and safety.
- Demonstrate that the plant meets the Commission's safety goals.
- Support the environmental review required by 10 CFR Part 51, specifically, the evaluation of severe accident mitigation design alternatives:
 - RG 4.2, "Preparation of Environmental Reports for Nuclear Power Stations," Rev. 3, September 2018
 - COL-ISG-029, "Environmental Considerations Associated with Micro-reactors," October 28, 2020
- For applications based on the LMP guidance, the PRA is used to select licensing basis events, classify SSCs, and to inform the DiD evaluation.

Past and Present Uses of the PRA (Cont'd)

- For applications not based on the LMP guidance, the PRA may be used to support the process used to demonstrate whether the regulatory treatment of non-safety systems (RTNSS) is sufficient and, if appropriate, identify the SSCs included in RTNSS.
- The results and insights of the PRA are used to identify and support the development of specifications and performance objectives for the plant design, construction, inspection, and operation, such as:
 - Inspection, testing, analysis, acceptance criteria,
 - TS, and
 - Combined operating license action items and interface requirements.
- The PRA may be used to support various voluntary risk-informed applications (e.g., risk-informed inservice inspection) that may be included in the licensing application.
- The PRA may be used to inform the scope of staff's review; see SRM-COMGBJ-10-0004/COMGEA-10-0001 (ML102510405).
- The results and insights of the PRA are used to support the reactor oversight program.

Searching for Initiating Events (Adapted from the NLWR PRA Standard)

- Identify initiating events that:
 - Challenge normal plant operation (when plant is at-power) or the ability to sustain safe shutdown or low-power conditions (when not at-power), and
 - Require successful mitigation to prevent a release of radioactive material.
- Use a structured, systematic process that accounts for plant- or design-specific features, such as:
 - Master logic diagrams
 - Heat balance fault trees
 - Process hazards analysis
 - Failure modes and effects analysis
- Analyze operating procedures and practices.
- Review existing lists of known initiators applicable to the specific reactor type and design.

Searching for Initiating Events (Cont'd) (Adapted from the NLWR PRA Standard)

- Consider external hazards (e.g., seismic), including initiating events caused by a combination of hazards (e.g., seismically induced fires).
- Review operating experience, including similar plants.
- Perform a systematic evaluation of each system down to the subsystem or train level and including support systems in each modeled plant operating state.
- Include initiating events resulting from multiple failures if the equipment failures result from a common cause.
- Interview resources knowledgeable in plant design or operation.
- Include initiators that impact two or more sources of radioactive material

Addressing Lack of Operating Experience

Type of Data/Information	Methods
Internal initiating event frequencies	<ul style="list-style-type: none"> • Many can be estimating using LWR or relevant non-nuclear information • Bayesian estimation methods • Formal expert elicitation
Component failure rates	
Common-cause failures (CCFs)	<ul style="list-style-type: none"> • Use existing CCF models (e.g., alpha factors) • Use existing generic information derived from LWR experience
Test/maintenance availabilities	<ul style="list-style-type: none"> • Use component failure rates • Controlled by technical specifications (surveillance test intervals and allowed outage times)
Human error probabilities	<ul style="list-style-type: none"> • Does not require design-specific operating experience • Use existing methods
External hazard frequencies	
External hazard fragilities	

Addressing Lack of Operating Experience (Cont'd)

- PRA provides a framework for assessing uncertainties:
 - Parametric uncertainties
 - Modeling uncertainties
 - Completeness uncertainties
- PRA helps to put uncertainties into perspective.
 - Which events contribute to the overall uncertainty?
 - Are these events also risk significant?

Second Iteration – Analysis (Use of PRA)

§ 53.450 Analysis Requirements

(b) Requirement to use PRA, other generally accepted risk-informed approach for systematically evaluating engineered systems, or combination thereof to:

- **Determine LBEs**
 - **Support safety classification of SSCs**
 - **Evaluate defense in depth**
-
- Discussion (Use of PRA)
 - Change intended to support alternative approaches to a PRA
 - Worded in terms of “generally accepted” to support possible standards or other guidance documents
 - The use of guidance, Part 53 rule language, or revisions to Part 50 are being explored as possible ways to accommodate deterministic approaches for performing design and analysis

Second Iteration – Analysis Requirements (c – g)

§ 53.450 Analysis Requirements

- (c) Maintenance and upgrade of analyses**
- (d) Qualification of analytical codes**
- (e) Analyses of LBEs (added)**
- (f) Analysis of DBAs**
- (g) Other required analyses**

- Discussion (Analysis Requirements)
 - Clarification of maintenance and upgrading of analyses (referring to codes and standards)
 - Maintain placeholder for other required analyses to address fire protection, aircraft impact, and specific beyond design basis accidents.

Second Iteration – Analysis Requirements (c – g)

§ 53.450(e) Analyses of licensing basis events [New sub-paragraph]

(e) *Analyses of licensing basis events.* Analyses must be performed for licensing basis events ranging from anticipated operational occurrences to very unlikely event sequences with estimated frequencies well below the frequency of events expected to occur in the life of the advanced nuclear plant. The licensing basis events must be identified using insights from a PRA, other generally accepted risk-informed approach for systematically evaluating engineered systems, or combination thereof to systematically identify and analyze equipment failures and human errors. The analyses must address event sequences from initiation to a defined end state and demonstrate that the functional design criteria required by § 53.420 provide sufficient barriers to the unplanned release of radionuclides to satisfy the second tier safety criteria of § 53.220(b) and provide defense in depth as required by § 53.250.

- Discussion (Analyses of LBEs)
 - Section added to clarify requirements for LBEs, including analysis from initiation to a defined end state
 - Staff considering further clarification for anticipated operational occurrences in terms of acceptance criteria beyond QHOs and defense in depth

Second Iteration – Analysis Requirements (c – g)

§ 53.450 (f) Analysis of design basis accidents

(f) *Analysis of design basis accidents.* The analysis of licensing basis events required by § 53.240 and § 53.450(e) must include analysis of a set of design basis accidents that address possible challenges to the safety functions identified in accordance with § 53.230. Design basis accidents must be selected from those unanticipated event sequences with an upper bound frequency of less than one in 10,000 years as identified using insights from a PRA, other generally accepted risk-informed approach for systematically evaluating engineered systems, or combination thereof to systematically identify and analyze equipment failures and human errors. The events selected as design basis accidents should be those that, if not terminated, have the potential for exceeding the safety criteria in § 53.210(b). **The design-basis accidents selected must be analyzed using deterministic methods that address event sequences from initiation to a safe stable end state and assume only the safety-related SSCs identified in § 53.460 and human actions addressed by § 53.8xx (reference to concept of operations sections of Subpart F) are available to perform the safety functions identified in accordance with § 53.230.** The analysis must conservatively demonstrate compliance with the safety criteria in § 53.210(b).

- Discussion (DBAs)
 - Revised to clarify that analysis is to address sequences from initiation to a safe stable end state.

Second Iteration – Safety Classification

§ 53.460 Safety Categorization and Special Treatment

(a) SSCs and human actions must be classified according to their safety significance. **The categories must include “Safety Related” (SR), “Non-Safety Related but Safety Significant” (NSRSS), and “Non-Safety Significant” (NSS), as defined in subpart A of this part.**

- Discussion
 - Editorial changes to remove material duplicating preliminary rule language in other sections
 - Maintaining for now the specific categories of safety related, non-safety related but safety significant, and non-safety significant

Second Iteration – Analytical Margins and Operating Flexibilities

§ 53.470 Application of Safety Margins to Operational Flexibilities

(No Change) Where an applicant or licensee so chooses, design criteria more restrictive than those defined in § 53.220(b) may be adopted to support operational flexibilities (e.g., emergency planning requirements under Subpart F of this part). In such cases, applicants and licensees must ensure that the functional design criteria of § 53.420(b), the analysis requirements of § 53.450, and identification of special treatment of SSCs and human actions under § 53.460 reflect and support the use of alternative design criteria to obtain additional analytical safety margins. Licensees must ensure that measures taken to provide the analytical margins supporting operational flexibilities are incorporated into design features and programmatic controls and are maintained within programs required in other Subparts.

- Discussion
 - No change; Released related requirements in Subpart F to support public meeting on May 6th

Feedback – Design Control Quality Assurance and Design Interfaces

First Iteration

§ 53.480 Design Control Quality Assurance

§ 53.490 Design Interfaces

- Questions/comments on quality assurance and design interfaces
 - Many stakeholders reserving comments pending release of other subparts
- Discussion
 - No change; Released related requirements in Subpart F to support public meeting on May 6th

Feedback – Non-Radiological Hazards

- Non-Radiological Hazards
 - Some ACRS members noted inclusion of non-radiological hazards should be considered in Part 53, such as chemical releases.
 - Staff has this issue under consideration and recognizes existing frameworks for addressing this multi-jurisdictional topic
 - Does ACRS have feedback on this topic that could inform the Staff's ongoing considerations?

Final Discussion and Questions



Acronyms and Abbreviations

ACRS	Advisory Committee on Reactor Safeguards	DiD	Defense in depth
ADAMS	Agencywide Document Access Management System	EAB	Exclusion area boundary
AEA	Atomic Energy Act	EP	Emergency planning
ALARA	As low as reasonably achievable	EPA	U.S. Environmental Protection Agency
ANS	American Nuclear Society	F-C	Frequency consequence
AOO	Anticipated operational occurrence	FMEA	Failure modes and effects analysis
ASME	American Society of Mechanical Engineers	FW	Steam generator feedwater pump trip
BDBEs	Beyond design basis events	HPB	Helium pressure boundary
CCF	Common cause failure	IAB	Intake air bypass
CFR	Code of Federal Regulations	ISO	International Standards Organization
CR	Control rod withdrawal	ITAAC	Inspection, test, analyses, acceptance criteria
CT	Circulator trip	LBEs	Licensing basis events
DBAs	Design basis accidents	LD	Large helium depressurization
DG	Draft guidance	LF	Loss of primary flow

Acronyms and Abbreviations

LMP	Licensing modernization project
LO	Loss of offsite power
LPZ	Low-population zone
LWR	Light-water reactor
MD	Medium helium depressurization
MHTGR	Modular high-temperature gas-cooled reactor
NEI	Nuclear Energy Institute
NEIMA	Nuclear Energy Innovation and Modernization Act
NLWR	Non-light-water reactor
NRC	U.S. Nuclear Regulatory Commission
NSRSS	Non-safety related but safety significant
NSS	Non-safety significant
PAG	Protective action guide

PC	Plant condition
PPC	Porcelain polycarbonate
PRA	Probabilistic risk assessment
QHO	Quantitative health objective
RAP	Reliability assurance program
Rem	Roentgen equivalent man
ROP	Reactor oversight program
RSF	Required safety function
RT	Reactor trip
RTNSS	Regulatory treatment of non-safety systems
SAR	Safety analysis report
SD	Small helium depressurization
SDO	Standard development organization
SFC	Single-failure criterion

Acronyms and Abbreviations


SG	Steam generator rupture
SR	Safety related
SSCs	Structures, systems, components
TS	Technical specifications
TT	Turbine trip

BACKUP SLIDES


Part 53 Rulemaking Schedule

Milestone Schedule	
Major Rulemaking Activities/Milestones	Schedule
Public Outreach, ACRS Interactions and Generation of Proposed Rule Package	Present to April 2022 (11 months)
Submit Draft Proposed Rule Package to Commission	May 2022
Publish Proposed Rule and Draft Key Guidance	October 2022
Public Comment Period – 60 days	November and December 2022
Public Outreach and Generation of Final Rule Package	January 2023 to February 2024 (14 months)
Submit Draft Final Rule Package to Commission	March 2024
Office of Management and Budget and Office of the Federal Register Processing	July 2024 to September 2024
Publish Final Rule and Key Guidance	October 2024

Integrated Approach



Presenting PRA Results



Cumulative Risk Metrics

- QHOs in the Commission's Safety Goal Policy Statement
 - The risk to an average individual in the vicinity of a nuclear power plant [1 mile] of prompt fatalities that might result from reactor accidents should not exceed 0.1% of the sum of prompt fatality risk resulting from other accidents to which members of the U.S. population are generally exposed [5E-7/y].
 - The risk to the population in the area near a nuclear power plant [10 miles] that might result from nuclear power plant operation should not exceed 0.1% of the sum of cancer fatality risks resulting from all other causes [2E-6/y].
 - Compare mean risks to QHOs, and consider the uncertainties
 - Basis: NUREG-0880, "Safety Goals for Nuclear Power Plant Operation," Rev. 1, ML071770230, May 1983.
- LMP: The total mean frequency of exceeding a site boundary dose of 100 mrem < 1/plant-year (based on 10 CFR 20).

Large Release Frequency (LRF)

- In its safety goal policy statement, the Commission proposed a general performance guideline for further staff examination:
 - The overall mean frequency of a large release of radioactive materials to the environment from a reactor accident should be less than 1 in 1,000,000 per year of reactor operation
 - Rationale as explained by Forrest Remick (former Director of Office of Policy Evaluation, former ACRS member, and former Commissioner) in a memorandum dated 3/2/1993 (ML051660709) to James Taylor (former EDO):
 - The proposed SGPS included a goal for core-damage frequency (CDF) $< 1E-4/y$
 - The ACRS wanted to include a goal for conditional containment failure probability (CCFP) < 0.1
 - The LRF goal was developed to break the deadlock between the staff and ACRS
 - $(1E-4/y \text{ CDF}) \times (0.1 \text{ vessel breach probability}) \times (0.1 \text{ CCFP}) = 1E-6 \text{ LRF}$
- In SRM-SECY-89-102 (ML051660712), the Commission made clear that LRF applies to all reactor designs (LWRs and NLWRs).
- As discussed in SECY-93-138, the staff abandoned efforts to anchor LRF to the QHOs (LRF is more conservative).
- There is no NRC definition for LRF; Part 52 applicants have been allowed to propose various definitions.

Large Release vs. Large Early Release

- JCNRM definition of large release (approved 4/2/2021): The release of airborne fission products to the environment such that there are significant off-site impacts. Large release and significant off-site impacts may be defined in terms of quantities of fission products released to the environment, status of fission product barriers and scrubbing, or dose levels at specific distances from the release, depending on the specific analysis objectives and regulatory requirements.
- RG 1.200 implied definition of large early release: A rapid, unmitigated release of airborne fission products from the containment to the environment occurring before the effective implementation of offsite emergency response and protective actions such that there is the potential for early health effects. (Such accidents generally include unscrubbed releases associated with early containment failure shortly after vessel breach, containment bypass events, and loss of containment isolation.)

Core-Damage Frequency (CDF) and Large Early Release Frequency (LERF)

- For large LWRs:

$LERF < 10^{-5}/y$	\Rightarrow	<i>individual prompt fatality risk</i>	$< 5 \times 10^{-7}/y$
$CDF < 10^{-4}$	\Rightarrow	<i>individual latent cancer fatality risk</i>	$< 2 \times 10^{-6}/y$

- Used when developing RG 1.174 (late 1990s)
- Technical basis documented in NUREG-1860, Appendix D (based on NUREG-1150 results)
- In SRM-SECY-12-0081, the Commission approved the staff's recommendation that new reactors transition from LRF to LERF at or before initial fuel load.

CCDF Representation of Risk

- Used in traditional PRAs (e.g., WASH-1400, NUREG-1150)
- Considered during development of NUREG-1860, “Feasibility Study for a Risk-Informed and Performance-Based Regulatory Structure for Future Plant Licensing”
 - Deferred - how to establish the acceptance criterion?
 - Discussed in ACRS letter dated September 26, 2007
- Public comment on DG-1353 [RG 1.233] by former ACRS Member Rich Denning and Vinod Mubayi (one of the authors of NUREG-1860) recommended the development of a CCDF criterion in lieu of the frequency-consequence target:
 - Comment: ML19158A457
 - Staff response: ML20091L696
 - Discussed at ACRS Future Plant Design Subcommittee meeting held July 20, 2020

Frequency-Consequence Plot

- Uses include:
 - MHTGR pre-application (1989)
 - NUREG-1860 (2007)
 - NGNP Licensing Strategy (2008)
 - NEI 18-04 (2019)
- In NEI 18-04:
 - The F-C Target is used as a tool to identify risk-significant event sequence families and SSCs
 - **The F-C Target is not an acceptance criterion!**