

CALCULATION CHANGE NOTICE

CCN NO. XX-E-013 - 004 - CN007
Base Calc No. Rev No. Sequence No.

of load tap changer feature of new transformer included with clarification it is not PFSSD. XX-E-013-004-CN007 supersedes XX-E-013-004-CN005 in its entirety.

CALCULATION DATABASE INPUT

CCN NO. XX-E-013 - 004 - CN007
 Base Calc No. Rev No. Sequence No.

Link new systems to the calculation/CCN in EIS.

Systems Affected: NB, MA

Develop relationships between interdependent calculations in EIS.

Additional Calculations Providing Input to this calculation:

None

Additional Calculations Impacted by this calculation:

None

Develop relationships between the calculation/CCN and controlled reference documents in EIS.

Additional Controlled Documents Inputs to this calculation:

None

Additional Controlled Documents Impacted by this calculation:

None

The reference documents listed below are those that cannot be linked to the calculation/CCN and shall be entered in the INDUSTRY REFERENCE field in EIS, e.g., ASME Codes, ANSI Standards, letters, etc.

Additional Other Reference Documents:

CP 020021, Enercon Calc. WCN-025-CALC-010 R/1

Link new components to the calculation/CCN in EIS.

Additional Components:





None

REFER TO DESKTOP GUIDE FOR PROCESSING CALCULATIONS IN EIS

ATTACHMENT 1

CCN NO. XX-E-013 - 004 - CN007
Base Calc No. Rev No. Sequence No

Vendor calculation WCN-025-CALC-010, Rev 1

| | | | | |
|--|---|---|-------------------------------------|---------------------------------------|
|  | CALCULATION COVER SHEET | | CALC NO. WCN-025-CALC-010 | |
| | | | REV. 1 | |
| | | | PAGE NO. 1 of 8 | |
| Title: | UPDATE TO WCNOG CALCULATION XX-E-013, PFSSD ANALYSIS | | Client: WCNOG | |
| | | | Project Identifier: WCN-025 | |
| Item | Cover Sheet Items | Yes | No | |
| 1 | Does this calculation contain any open assumptions, including preliminary information, that require confirmation? (If YES , identify the assumptions.) | <input type="checkbox"/> | <input checked="" type="checkbox"/> | |
| 2 | Does this calculation serve as an "Alternate Calculation"? (If YES , identify the design verified calculation.) Design Verified Calculation No. _____ | <input type="checkbox"/> | <input checked="" type="checkbox"/> | |
| 3 | Does this calculation supersede an existing Calculation? (If YES , identify the design verified calculation.) Superseded Calculation No. WCN-025-CALC-010 Rev. 0 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| Scope of Revision: Revised Section 1.0, 3.0, and 5.0 and Appendix A for DCP 20021 Rev. 1 | | | | |
| Revision Impact on Results: This calculation documents the changes for the replacement of transformer XNB01. | | | | |
| Study Calculation <input type="checkbox"/> Final Calculation <input checked="" type="checkbox"/> | | | | |
| Safety-Related <input type="checkbox"/> Non-Safety-Related <input checked="" type="checkbox"/> | | | | |
| <i>(Print Name and Sign)</i> | | | | |
| Originator: Alex Wurtz | |  Alex Wurtz | | Date: See Electronic Signature |
| Design Verifier¹ (Reviewer if NSR): Stacey Graybeal | |  Digitally signed by Stacey Graybeal DN: cn=Stacey Graybeal, c=US, email=stgraybeal@enercon.com Date: 2020.05.06 16:09:59 -05'00' | | Date: See Electronic Signature |
| Approver: Austin Tran | |  Digitally signed by Austin Tran DN: cn=Austin Tran, ou=Enercon Services, Inc., email=atran@enercon.com, c=US Date: 2020.05.12 14:21:57 -05'00' | | Date: See Electronic Signature |

Note 1: For non-safety-related calculation, design verification can be sul



Digitally signed by Austin Tran
 DN: cn=Austin Tran, ou=Enercon Services, Inc., email=atran@enercon.com, c=US
 Date: 2020.05.12 14:22:48 -05'00'



**CALCULATION
REVISION STATUS SHEET**

CALC NO. WCN-025-CALC-010

REV. 1

PAGE NO. 2 of 8

CALCULATION REVISION STATUS

| <u>REVISION</u> | <u>DATE</u> | <u>DESCRIPTION</u> |
|-----------------|-------------|--|
| 0 | 09/20/2018 | Initial Issue |
| 1 | 04/16/2020 | Revised section 1.0, 3.0, and 5.0 and Appendix A |

PAGE REVISION STATUS

| <u>PAGE NO.</u> | <u>REVISION</u> | <u>PAGE NO.</u> | <u>REVISION</u> |
|-----------------|-----------------|-----------------|-----------------|
| 3,7,8 | 0 | | |
| 1,2,4-5 | 1 | | |


APPENDIX/ATTACHMENT REVISION STATUS

| <u>APPENDIX NO.</u> | <u>NO. OF PAGES</u> | <u>REVISION NO.</u> | <u>ATTACHMENT NO.</u> | <u>NO. OF PAGES</u> | <u>REVISION NO.</u> |
|---------------------|---------------------|---------------------|-----------------------|---------------------|---------------------|
| A | 4 | 1 | | | |

| | | |
|---|--------------------------|---|
|  | TABLE OF CONTENTS | CALC NO. WCN-025-CALC-010 |
| | | REV. 1 |
| | | PAGE NO. 3 of 8 |

| Section | Page No. |
|---|-----------------|
| 1.0 Purpose and Scope | 4 |
| 2.0 Summary of Results and Conclusions | 4 |
| 3.0 References | 5 |
| 4.0 Assumptions | 5 |
| 5.0 Design Inputs | 5 |
| 6.0 Methodology | 7 |
| 7.0 Calculations | 8 |
| 8.0 Computer Software | 8 |

| List of Appendices | # of Pages |
|--------------------------------|-------------------|
| A - Markup Updates to XX-E-013 | 4 |

| | | |
|---|---|----------------------------------|
|  | UPDATE TO WCNOG CALCULATION XX-E-013, PFSSD ANALYSIS | CALC NO. WCN-025-CALC-010 |
| | | REV. 1 |
| | | PAGE NO. 4 of 8 |


1.0 Purpose and Scope

Wolf Creek is performing a systematic replacement of their large oil-filled transformers to address aging concerns and to implement design improvements in support of long-term station operation. ESF Transformer XNB02 is to be replaced prior to the replacement of ESF transformer XNB01.

DCP 020021 is replacing XNB01 and the new transformer will have a Load Tap Changer (LTC) to control the voltage supplied to 4.16kV bus NB01 even if the 13.8 kV input voltage level changes. The DCP is also replacing/deleting relays in the MA104F panel and the relays are addressed by XX-E-013. The purpose of this calculation is to document the impact on Wolf Creek calculation XX-E-013 due to these changes. This calculation is non-safety related per the ENERCON requirements. The Wolf Creek update will be considered “special scope” per the site requirements.

2.0 Summary of Results and Conclusions

Wolf Creek calculation XX-E-013 does not have any computations. It is a document used to identify the components required to support the Post Fire Safe Shutdown (PFSSD) functions. Based on the results of this calculation the addition of the LTC controls will not impact the PFSSD function of XNB01. Two differential current relays (287/T1 Phase B and Phase C) are removed from the calculation (287/T1 Phase A is replaced with one new relay 287/T1 (A,B,C) to monitor all three phases). Also, components 263-1/T1, 263X-1/T1, 263-2/T1 and 263X-2/T1 are removed from the calculation. New fault pressure trip relays 263FP K4A and 263FP K4B are added because they provide a trip input for breaker NB00112 (XNB01 input breaker to NB01). Cable 15NBK16AA supplies 125VDC to the sudden pressure monitor that contains the two relays at XNB01. Failure of this cable does not cause the relays to change state and cause a loss of power to XNB01. Therefore, cable 15NBK16AA is not a PSFFD related cable. Drawing E-1F9425 impacted by this change and will be revised by DCP 020021 via WIP-E-1F9425-002-A-1. The proposed changes to XX-E-013 as a result of DCP 020021 are acceptable.

| | | |
|---|---|----------------------------------|
|  | UPDATE TO WCNOG CALCULATION XX-E-013, PFSSD ANALYSIS | CALC NO. WCN-025-CALC-010 |
| | | REV. 1 |
| | | PAGE NO. 5 of 8 |

3.0 References

- 3.1 Wolf Creek Calculation XX-E-013, PFSSD Analysis, Rev. 4
- 3.2 E-074-00007, Outline (Trans-Sealed), Rev. W09
- 3.3 DCP 020021, XNB01 Replacement, Rev. 0
- 3.4 E-1F9425, Post Fire Safe Shutdown Logic Diagram Support Function – Electrical, NB001 Off-Site Power Availability, Rev. 2
- 3.5 E-1F9910, Post Fire Safe Shutdown Fire Area Analysis, Rev. 15
- 3.6 E-022-00029, Relay Panels and Fabrication Details, (related to MA104F), Rev. W12
- 3.7 E-022-00043, Transformer Feeder Wiring (related to XNB01), Rev. W09
- 3.8 E-15000, Electrical Cable and Raceway List, Rev. 67
- 3.9 E-1R4431, Raceway Plan Turbine Building Area-3 EL. 2033'-0", Rev. 2
- 3.10 E-1R4331, Raceway Plan Turbine Building Area-3 EL. 2000'-0", Rev. 1
- 3.11 E-1R4321, Raceway Plan Turbine Building Area-2 EL. 2000'-0", Rev. 2
- 3.12 E-1R4322, Exposed Conduit Turbine Building Area-2 EL. 2000'-0", Rev. 5
- 3.13 E-13NB10, Schematic Diagram 13.8kv XNB01 Breaker Rev. 3
- 3.14 E-13NB16, ESF Transformers Auxiliary Power and Control Schematic Diagram, Rev. 1


4.0 Assumptions

There are no assumptions used in the calculation.

5.0 Design Inputs


Reviews of existing change notices against XX-E-013 were performed to determine if any of the documents impact the changes being performed by DCP 020021. Results are as follows:

- XX-E-013-004-CN001 – VOID
- XX-E-013-004-CN002 – FINAL – DCP 14209 removes the HMCP breakers from MCC cubicles NG03DBF6 and NG04DBF6, which were

| | | |
|---|--|---|
|  | UPDATE TO WCNO CALCULATION XX-E-013, PFSSD ANALYSIS | CALC NO. WCN-025-CALC-010 |
| | | REV. 1 |
| | | PAGE NO. 6 of 8 |


added as PFSSD components in CCN XX-E-013-002-CN014 per DCP 13800. These breaker cubicles provide power and control functions for Train A and B emergency diesel generator room supply fan motors DCGM01A and DCGM01B, respectively. Due to breaker coordination issues, DCP 14209 will modify the power supply to supply 480 VAC power to the diesel generator room supply fan motors DCGM01A and DCGM01B directly from new load center breakers NG0308 and NG0408, respectively. Breakers NG0308 and NG0408 will supply power to the fan control functions within NG03DBF6 and NG04DBF6, respectively. Therefore, MCC cubicles NG03DBF6 and NG04DBF6 will remain as PFSSD components. The changes per this update do not impact the evaluation performed by this calculation.

- XX-E-013-004-CN003 – COMMITTED – Change Package 14658 is replacing cable from EDGs speed signal generators to the EDGs speed switches. Appendices 1, 2 and 3 are updated to reflect these changes. The changes per this update do not impact the evaluation performed by this calculation.
- XX-E-013-004-CN004 – FINAL - CP 15070 is changing the 120VAC source from system NG to NN for the control room a/c unit inlet and exhaust dampers GKHZ0029A/B (Train A) & GKHZ0040A/B (Train B). The changes per this update do not impact the evaluation performed by this calculation.
- XX-E-013-004-CN005 – COMMITTED – CP 20021 is replacing XNB01 and the change impacts the PFSSD components for XNB01. This revision (revision 1) of this calculation will be accepted by Wolf Creek as a new CCN that supersedes XX-E-013-004-CN005
- XX-E-013-004-CN006 – COMMITTED – CP 12513 is replacing XNB02 and the change impacts the PFSSD components for XNB02. The changes per this update do not impact the evaluation performed by this calculation.

| | | |
|---|--|---|
|  | UPDATE TO WCNO CALCULATION XX-E-013, PFSSD ANALYSIS | CALC NO. WCN-025-CALC-010 |
| | | REV. 1 |
| | | PAGE NO. 7 of 8 |

6.0 Methodology

This calculation is a tabulation of cables and components that are required to support the PFSSD power sources and functions. XNB01 is a power source that is required to support the PFSSD functions. The impact of the LTC controls on the PFSSD power supply function was reviewed and determined to not impact the PFSSD power supply function of XNB01. PFSSD components associated with XNB01 are listed in calculation XX-E-013. Some of the components are being removed by DCP 020021. The calculation was reviewed and components 287/T1(B) and 287/T1(C) are removed from the plant and will be removed from the calculation. Relay 287/T1(A) is changed to 287/T1(A,B,C) because the new digital relay monitors all three phases. Fault pressure monitors 263-1/T1 and 263-2/T1 are being removed from the plant and will be removed from the calculation. Auxiliary relays 263X-1/T1 and 263X-2/T1 are being disconnected/“abandoned-in-place” and will be removed from the calculation. A new sudden pressure monitor at XNB01 contains trip relays that are used to trip the NB00112 breaker on a fault pressure signal, 263FP relays K4A and K4B. These relays will be added to the calculation. The changes to the relays also impact drawing E-1F9425. This drawing update will be addressed in DCP 020021 via WIP-E-1F9425-002-A-1. PK4115 via cable 15NBK16AA supplies 125VDC to the sudden pressure monitor. Failure of this power source or cable does not cause the relays to change state and loss of XNB01. Therefore, PK4115 and cable 15NBK16AA are not required for PFSSD.

| | | |
|---|--|---|
|  | UPDATE TO WCNO CALCULATION XX-E-013, PFSSD ANALYSIS | CALC NO. WCN-025-CALC-010 |
| | | REV. 1 |
| | | PAGE NO. 8 of 8 |

7.0 Calculations

N/A

8.0 Computer Software

NONE

APPENDIX A – Markups to Calculation XX-E-013 Rev. 4 (4 pages)

APPENDIX 4
PFSSD RELAY LIST

(Sorted by Relay Location / Relay ID)

| Relay ID | S/G | Relay Name | Room | Fire Area | Relay Location | SSD Fun | Sprtd Fun | Hot Sdbly | Cold Shdwn | Normal Shdwn | Alt Shdwn | Schematic / One Line | Other Drawing | Power Feeder Breaker | Notes | Logic Diagram (E-1F) | R E V |
|-----------|-----|---------------------------------------|-------|-----------|----------------|---------|-----------|-----------|------------|--------------|-----------|----------------------|----------------------------|----------------------|-------|----------------------|-------|
| TSR | 4 | Test Start Relay | 5201 | D-2 | KJ122 | S | R, M, H | X | X | X | X | E-13KJ03A | M-018-00105 M-018-00106 | NK5414 | --- | 9411B 9412B | 0 |
| 286/T1 | 6 | Lockout Relay | 4401W | TURB | MA104F | S | R, M, H | X | X | X | --- | --- | --- | PK6204 PK6106 | --- | 9426 | 0 |
| 486/T1 | 5 | Lockout Relay | 4401W | TURB | MA104F | S | R, M, H | X | X | X | --- | --- | --- | PK6204 PK6106 | --- | 9426 | 0 |
| 151N/T1 | 5 | Ground Over Current Relay | 4401W | TURB | MA104F | S | R, M, H | X | X | X | --- | --- | --- | PK6108 | --- | 9425 | 0 |
| 263X-1/T1 | 5 | Fault Pressure Switch Relay | 4401W | TURB | MA104F | S | R, M, H | X | X | X | --- | --- | --- | PK6108 | --- | 9425 | 0 |
| 263X-2/T1 | 5 | Fault Pressure Switch Relay | 4401W | TURB | MA104F | S | R, M, H | X | X | X | --- | --- | --- | PK6108 | --- | 9425 | 0 |
| 287/T1(A) | 6 | Phase A Differential Current Relay | 4401W | TURB | MA104F | S | R, M, H | X | X | X | --- | --- | --- | PK6108 | --- | 9425 | 0 |
| 287/T1(B) | 6 | Phase B Differential Current Relay | 4401W | TURB | MA104F | S | R, M, H | X | X | X | --- | --- | --- | PK6108 | --- | 9425 | 0 |
| 287/T1(C) | 6 | Phase C Differential Current Relay | 4401W | TURB | MA104F | S | R, M, H | X | X | X | --- | --- | --- | PK6108 | --- | 9425 | 0 |
| 94-1/T | 6 | Switchyard Trip Relay | 4401W | TURB | MA104F | S | R, M, H | X | X | X | --- | --- | --- | PK6108 | --- | 9425 | 0 |
| 127-1/DG | 1 | NB01 Undervoltage Relay | 3301 | C-9 | NB0101 | S | R, M, H | X | X | X | --- | --- | --- | NB0101 | --- | 9411A 9412A | 0 |
| 152 STA | 1 | AC Circuit Breaker Stationary Contact | 3301 | C-9 | NB0104 | S | R, M, H | X | X | X | --- | --- | --- | NK4101 | --- | 9401A 9401B | 0 |
| 152 STA | 1 | 287/T1 (A, B, C) Contact | 3301 | C-9 | NB0104 | S | R, M, H | X | X | X | --- | --- | --- | NK4101 | --- | 9401A 9401B | 0 |
| 186/M | 1 | Lockout Relay | 3301 | C-9 | NB0107 | S | R, M, H | X | X | X | --- | --- | --- | NK4101 | --- | 9401A | 0 |
| 152 STA | 1 | AC Circuit Breaker Stationary Contact | 3301 | C-9 | NB0108 | S | R, M, H | X | X | X | --- | --- | --- | NK4101 | --- | 9401A 9401B | 0 |
| 186/M | 1 | Lockout Relay | 3301 | C-9 | NB0108 | S | R, M, H | X | X | X | --- | --- | --- | NK4101 | --- | 9401A | 0 |
| 125/F | 1 | Synchronizing Check Relay | 3301 | C-9 | NB0109 | S | R, M, H | X | X | X | --- | --- | --- | NK4101 | --- | 9425 | 0 |
| 152 STA | 1 | AC Circuit Breaker Stationary Contact | 3301 | C-9 | NB0109 | S | R, M, H | X | X | X | --- | --- | --- | NK4101 | --- | 9423 | 0 |
| 186/F | 1 | Lockout Relay | 3301 | C-9 | NB0109 | S | R, M, H | X | X | X | --- | --- | --- | NK4101 | --- | 9423 9425 | 0 |
| 286-2/T2 | 1 | Lockout Relay | 3301 | C-9 | NB0109 | S | R, M, H | X | X | X | --- | --- | --- | NK4101 | --- | 9425 | 0 |

These two relays are removed from the plant.

These two relays are no longer inservice and can be removed.

Phase A, B, C Differential Current Relay

APPENDIX 4
PFSSD RELAY LIST

(Sorted by Relay Location / Relay ID)

| Relay ID | S/G | Relay Name | Room | Fire Area | Relay Location | SSD Fun | Sprtd Fun | Hot Sdbly | Cold Shdwn | Normal Shdwn | Alt Shdwn | Schematic / One Line | Other Drawing | Power Feeder Breaker | Notes | Logic Diagram (E-F) | R E V |
|----------|-----|---|------|-----------|----------------|---------|-----------|-----------|------------|--------------|-----------|-------------------------------------|----------------------------|--|---|---------------------|-------|
| K526 | 4 | Safety Injection Master Relay | 3605 | C-27 | SB032D | S | R, M, H | X | X | X | --- | --- | M-767-00374 M-767-00350 | NK4416 NN0412 | --- | 9432 | 0 |
| K713 | 4 | Pressurizer High Pressure Relay | 3601 | C-27 | SB032D | M | --- | X | X | X | --- | E-13BB40 E-13SB05 | M-767-00186 M-767-00189 | NK4421 NN0412 NK4416 | BBFCV0456A opens if K713 is energized. XX-E-013-002-CN002 | 9301 | 3 |
| K726 | 4 | Low-Low T _{AVG} or ABHS0064 in 'OFF/RESET' Relay | 3605 | C-27 | SB032D | R, H | --- | X | --- | X | --- | E-13AB08 | M-767-00188 | NK4416 NN0412 | --- | 9103 | 0 |
| K727 | 4 | Low-Low T _{AVG} or ABHS0064 in 'OFF/RESET' Relay | 3605 | C-27 | SB032D | R, H | --- | X | --- | X | --- | E-13AB11A E-13AB11B E-13AB11C | M-767-00188 | NK4416 NN0412 | --- | 9103 | 0 |
| K728 | 4 | Low-Low T _{AVG} or ABHS0064 in 'OFF/RESET' Relay | 3605 | C-27 | SB032D | R, H | --- | X | --- | X | --- | E-13AB11C | M-767-00188 | NK4416 NN0412 | --- | 9103 | 0 |
| K734 | 4 | High-1 RCS Pressure Relay | 3605 | C-27 | SB032D | H | --- | --- | X | --- | --- | E-13BB12A E-13BB12B | M-767-00186 M-767-00189 | NG02B0F2 NG02B0F3 NN0412 NK4416 | --- | 9205 | 0 |
| K740 | 4 | Safety Injection Signal Relay | 3605 | C-27 | SB032D | H | --- | --- | X | --- | --- | E-13EJ06B E-13SB05 | M-767-00189 | NG02BEF2 NN0412 NK4416 | --- | 9205 | 0 |
| K741 | 4 | RWST Low-Low 1 Level Relay | 3605 | C-27 | SB032D | H | --- | --- | X | --- | --- | E-13EJ06B E-13SB05 | M-767-00189 | NG02BEF2 NN0412 NK4416 | --- | 9205 | 0 |
| K811 | 4 | Block Test Relay | 3605 | C-27 | SB033A | M | --- | X | X | X | --- | E-13BB40 | --- | NK4421 | --- | 9301 | 0 |
| 263-1/T1 | 5 | Fault Pressure Switch Relay | Yard | --- | XNB01 | S | R, M, H | X | X | X | --- | E-13NB10 | --- | PK6108 | --- | 9425 | 0 |
| 263-2/T1 | 5 | Fault Pressure Switch Relay | Yard | --- | XNB01 | S | R, M, H | X | X | X | --- | E-13NB10 | --- | PK6108 | --- | 9425 | 0 |
| 263-1/T2 | 6 | Fault Pressure Switch Relay | Yard | --- | XNB02 | S | R, M, H | X | X | X | --- | E-13NB11 E-13PA14 | --- | PK6204 | --- | 9426 | 0 |
| 263-2/T2 | 6 | Fault Pressure Switch Relay | Yard | --- | XNB02 | S | R, M, H | X | X | X | --- | E-13NB11 E-13PA14 | --- | PK6204 | --- | 9426 | 0 |

PK4115


PK4115


E-13NB16


263FP (K4B)


263FP (K4A)


PK4115 is connected to cable 15NBK16AA. This supplies power to the monitor that houses relays at XNB01. PK4115 and associated cable 15NBK16AA are not required for PFSSD. Loss of power or cable failure will not cause a loss of XNB01.


| | | | | |
|---|---|---|-------------------------------------|-------------------------------------|
|  | CALCULATION PREPARATION CHECKLIST | CALC NO. WCN-025-CALC-010 | | |
| | | REV. 1 | | |
| CHECKLIST ITEMS¹ | | YES | NO | N/A |
| GENERAL REQUIREMENTS | | | | |
| 1. | If the calculation is being performed to a client procedure, is the procedure being used the latest revision? This calculation is not being performed per a client procedure. | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 2. | Are the proper forms being used and are they the latest revision? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 3. | Have the appropriate client review forms/checklists been completed? This calculation is not being performed per a client procedure. | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 4. | Are all pages properly identified with a calculation number, calculation revision and page number consistent with the requirements of the client's procedure? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 5. | Is all information legible and reproducible? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 6. | Is the calculation presented in a logical and orderly manner? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 7. | Is there an existing calculation that should be revised or voided? This is a revision | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 8. | Is it possible to alter an existing calculation instead of preparing a new calculation for this situation? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 9. | If an existing calculation is being used for design inputs, are the key design inputs, assumptions and engineering judgments used in that calculation valid and do they apply to the calculation revision being performed. | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 10. | Is the format of the calculation consistent with applicable procedures and expectations? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 11. | Were design input/output documents properly updated to reference this calculation? This calculation will be made into a calculation change notice by Wolf Creek. DCP 020021 will update any required documents associated with this calculation. | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 12. | Can the calculation logic, methodology and presentation be properly understood without referring back to the originator for clarification? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| OBJECTIVE AND SCOPE | | | | |
| 13. | Does the calculation provide a clear concise statement of the problem and objective of the calculation? This revision does not impact these items | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |


| | | | | |
|---|---|----------------------------------|--------------------------|-------------------------------------|
|  | CALCULATION PREPARATION CHECKLIST | CALC NO. WCN-025-CALC-010 | | |
| | | REV. 1 | | |
| CHECKLIST ITEMS¹ | | YES | NO | N/A |
| 14. | Does the calculation provide a clear statement of quality classification? This revision does not impact this item | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 15. | Is the reason for performing and the end use of the calculation understood? This revision does not impact this item | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 16. | Does the calculation provide the basis for information found in the plant's license basis? This revision does not impact this item | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 17. | If so, is this documented in the calculation? This revision does not impact this item | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 18. | Does the calculation provide the basis for information found in the plant's design basis documentation? This revision does not impact this item | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 19. | If so, is this documented in the calculation? This revision does not impact this item | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 20. | This revision does not impact this item | | | |
| 21. | Does the calculation otherwise support information found in the plant's design basis documentation? This revision does not impact this item | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 22. | If so, is this documented in the calculation? This revision does not impact this item | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 23. | Has the appropriate design or license basis documentation been revised, or has the change notice or change request documents being prepared for submittal? This revision does not impact this item | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| DESIGN INPUTS | | | | |

| | | | | |
|---|--|-------------------------------------|--------------------------|-------------------------------------|
|  | CALCULATION PREPARATION CHECKLIST | CALC NO. WCN-025-CALC-010 | | |
| | | REV. 1 | | |
| CHECKLIST ITEMS¹ | | YES | NO | N/A |
| 24. | Are design inputs clearly identified? This revision does not impact this item | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 25. | Are design inputs retrievable or have they been added as attachments? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 26. | If Attachments are used as design inputs or assumptions are the Attachments traceable and verifiable? This revision does not impact this item | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 27. | Are design inputs clearly distinguished from assumptions? This revision does not impact this item | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 28. | Does the calculation rely on Attachments for design inputs or assumptions? If yes, are the attachments properly referenced in the calculation? This revision does not impact this item | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 29. | Are input sources (including industry codes and standards) appropriately selected and are they consistent with the quality classification and objective of the calculation? This revision does not impact this item | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 30. | Are input sources (including industry codes and standards) consistent with the plant's design and license basis? This revision does not impact this item | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 31. | If applicable, do design inputs adequately address actual plant conditions? This revision does not impact this item | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 32. | Are input values reasonable and correctly applied? This revision does not impact this item | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 33. | Are design input sources approved? This revision does not impact this item | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |

| | | | | |
|---|--|----------------------------------|-------------------------------------|-------------------------------------|
|  | CALCULATION PREPARATION CHECKLIST | CALC NO. WCN-025-CALC-010 | | |
| | | REV. 1 | | |
| CHECKLIST ITEMS¹ | | YES | NO | N/A |
| 34. Does the calculation reference the latest revision of the design input source? This revision does not impact this item | | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 35. Were all applicable plant operating modes considered? This revision does not impact this item | | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| ASSUMPTIONS | | | | |
| 36. Are assumptions reasonable/appropriate to the objective? This revision does not impact this item. | | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 37. Is adequate justification/basis for all assumptions provided? This revision does not impact this item | | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 38. Are any engineering judgments used? | | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 39. Are engineering judgments clearly identified as such? This revision does not impact this item | | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 40. If engineering judgments are utilized as design inputs, are they reasonable and can they be quantified or substantiated by reference to site or industry standards, engineering principles, physical laws or other appropriate criteria? This revision does not impact this item | | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| METHODOLOGY | | | | |
| 41. Is the methodology used in the calculation described or implied in the plant's licensing basis? This revision does not impact this item | | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 42. If the methodology used differs from that described in the plant's licensing basis, has the appropriate license document change notice been initiated? This revision does not impact this item | | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |

| | | | | |
|---|--|----------------------------------|--------------------------|-------------------------------------|
|  | CALCULATION PREPARATION CHECKLIST | CALC NO. WCN-025-CALC-010 | | |
| | | REV. 1 | | |
| CHECKLIST ITEMS¹ | | YES | NO | N/A |
| 43. Is the methodology used consistent with the stated objective? This revision does not impact this item | | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 44. Is the methodology used appropriate when considering the quality classification of the calculation and intended use of the results? This revision does not impact this item | | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| BODY OF CALCULATION | | | | |
| 45. Are equations used in the calculation consistent with recognized engineering practice and the plant's design and license basis? This calculation does not use any equations. | | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 46. Is there reasonable justification provided for the use of equations not in common use? | | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 47. Are the mathematical operations performed properly and documented in a logical fashion?. | | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 48. Is the math performed correctly? | | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 49. Have adjustment factors, uncertainties and empirical correlations used in the analysis been correctly applied?. | | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 50. Has proper consideration been given to results that may be overly sensitive to very small changes in input? This revision does not impact this item | | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| SOFTWARE/COMPUTER CODES | | | | |
| 51. Are computer codes or software languages used in the preparation of the calculation? No computer codes are used in this calculation update. | | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 52. Have the requirements of CSP 3.09 for use of computer codes or software languages, including verification of accuracy and applicability been met? | | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 53. Are the codes properly identified along with source vendor, organization, and revision level? | | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 54. Is the computer code applicable for the analysis being performed? | | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |

| | | | | |
|---|---|-------------------------------------|--------------------------|-------------------------------------|
|  | CALCULATION PREPARATION CHECKLIST | CALC NO. WCN-025-CALC-010 | | |
| | | REV. 1 | | |
| CHECKLIST ITEMS¹ | | YES | NO | N/A |
| 55. | If applicable, does the computer model adequately consider actual plant conditions? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 56. | Are the inputs to the computer code clearly identified and consistent with the inputs and assumptions documented in the calculation? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 57. | Is the computer output clearly identified? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 58. | Does the computer output clearly identify the appropriate units? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 59. | Are the computer outputs reasonable when compared to the inputs and what was expected? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 60. | Was the computer output reviewed for ERROR or WARNING messages that could invalidate the results? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| RESULTS AND CONCLUSIONS | | | | |
| 61. | Is adequate acceptance criteria specified? This revision does not impact this item | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 62. | Are the stated acceptance criteria consistent with the purpose of the calculation, and intended use? This document does not use acceptance criteria. | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 63. | Are the stated acceptance criteria consistent with the plant's design basis, applicable licensing commitments and industry codes, and standards? This document does not use acceptance criteria. | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 64. | Do the calculation results and conclusions meet the stated acceptance criteria? This document does not use acceptance criteria. | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 65. | Are the results represented in the proper units with an appropriate tolerance, if applicable? This document does not use any units. | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 66. | Are the calculation results and conclusions reasonable when considered against the stated inputs and objectives? | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| 67. | Is sufficient conservatism applied to the outputs and conclusions? Conservatism is not required for this document. | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |

| | | | | |
|---|--|----------------------------------|-------------------------------------|-------------------------------------|
|  | CALCULATION PREPARATION CHECKLIST | CALC NO. WCN-025-CALC-010 | | |
| | | REV. 1 | | |
| CHECKLIST ITEMS¹ | | YES | NO | N/A |
| 68. | Do the calculation results and conclusions affect any other calculations? This output of this calculation does not impact any other calculations. | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 69. | If so, have the affected calculations been revised? This output of this calculation does not impact any other calculations. | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 70. | Does the calculation contain any conceptual, unconfirmed or open assumptions requiring later confirmation? No assumptions are used in the calculation update. | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 71. | If so, are they properly identified? No assumptions are used in the calculation update. | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| DESIGN REVIEW | | | | |
| 72. | Have alternate calculation methods been used to verify calculation results? No alternate calculations are used to support this document update. | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |

Note:

- Where required, provide clarification/justification for answers to the questions in the space provided below each question. An explanation is required for any questions answered as "No" or "N/A".

Originator: Alex Wurtz

Print Name and Sign

Alex Wurtz

Digitally signed by Alex Wurtz
DN: cn=Alex Wurtz, c=US,
email=awurtz@enercon.com
Date: 2020.05.06 15:22:28 -
05'00'

**SEE ELECTRONIC
SIGNATURE**



Date

| | | | |
|---------------|---|-----------------|------------------------|
| WCNOC | OWNER'S ACCEPTANCE REVIEW CHECKLIST FOR EXTERNAL CALCULATIONS AND SPECIFICATIONS | | PAGE 1 OF 5 |
| | Title: Post Fire Safe Shutdown (PFSSD) Analysis | | |
| | Wolf Creek document #: XX-E-013-004-CN007 | Revision #: N/A | |
| ECDE: Enercon | | | |

| | |
|---|---------------|
| INITIATING DOCUMENT and revision: (e.g., PO, CR, SWO) | CP 020021 R/1 |
|---|---------------|

CHANGE TYPE: **Calculation** **Specification**

SAFETY CLASS: **SR** **SS** **NSR**

| | | | |
|---------------------------|--|-------|------------|
| WCNOC Reviewer signature: | <small>DigsigVer 5, 0.45</small>  | Date: | 05/19/2020 |
| WCNOC Approver: | <small>DigsigVer 5, 0.45</small>  | Date: | 5/20/2020 |

| Prepared By: | Init / Date |
|--------------------|----------------|
| William M. Wilkins | WMW 05/19/2020 |
| | |
| | |
| | |
| | |

| | | | |
|---------------|---|-----------------|------------------------|
| WCNOC | OWNER'S ACCEPTANCE REVIEW CHECKLIST FOR EXTERNAL CALCULATIONS AND SPECIFICATIONS | | PAGE 2 OF 5 |
| | Title: Post Fire Safe Shutdown (PFSSD) Analysis | | |
| | Wolf Creek document #: XX-E-013-004- CN007 | Revision #: N/A | |
| ECDE: Enercon | | | |

| No. | Question | Instructions and Guidance | YES | NO | N/A |
|-----|---|---|-----|----|-----|
| 1 | Do assumptions have sufficient documented rationale? | <p>All Assumptions should be stated in clear terms with enough justification to confirm that the assumption is conservative:</p> <p>For example, 1) the exact value of a particular parameter may not be known or that parameter may be known to vary over the range of conditions covered by the Calculation. It is appropriate to represent or bound the parameter with an assumed value. 2) The predicted performance of a specific piece of equipment in lieu of actual test data. It is appropriate to use the documented opinion/position of a recognized expert on that equipment to represent predicted equipment performance.</p> <p>Consideration should also be given as to any qualification testing that may be needed to validate the Assumptions. Ask yourself, would you provide more justification if you were performing this analysis? If yes, the rationale is likely incomplete.</p> | | | X |
| 2 | Are assumptions compatible with the way the plant is operated and with the licensing basis? | <p>Ensure the documentation for source and rationale for the assumption supports the way the plant is currently or will be operated post change and they are not in conflict with any design parameters. If the Analysis purpose is to establish a new licensing basis, this question can be answered yes, if the assumption supports that new basis.</p> | | | X |

| | | | |
|---------------|---|-----------------|------------------------|
| WCNOC | OWNER'S ACCEPTANCE REVIEW CHECKLIST FOR EXTERNAL CALCULATIONS AND SPECIFICATIONS | | PAGE 3 OF 5 |
| | Title: Post Fire Safe Shutdown (PFSSD) Analysis | | |
| | Wolf Creek document #: XX-E-013-004-CN007 | Revision #: N/A | |
| ECDE: Enercon | | | |

| No. | Question | Instructions and Guidance | YES | NO | N/A |
|-----|---|---|-----|----|-----|
| 3 | Do all unverified assumptions have a tracking and closure mechanism in place? | If there are unverified assumptions without a tracking mechanism indicated, then create the tracking item either through an ATI or a work order attached to the implementing WO. Due dates for these actions need to support verification prior to the analysis becoming operational or the resultant plant change being op authorized. | | | X |
| 4 | Do the design inputs have sufficient rationale? | The origin of the input, or the source should be identified and be readily retrievable within WCNOC's documentation system. If not, then the source should be attached to the analysis. Ask yourself, would you provide more justification if you were performing this analysis? If yes, the rationale is likely incomplete. | X | | |
| 5 | Are design inputs correct and reasonable with critical parameters identified, if appropriate? | The expectation is that an WCNOC Engineer should be able to clearly understand which input parameters are critical to the outcome of the analysis. That is, what is the impact of a change in the parameter to the results of the analysis? If the impact is large, then that parameter is critical. | X | | |
| 6 | Are design inputs compatible with the way the plant is operated and with the licensing basis? | Ensure the documentation for source and rationale for the inputs supports the way the plant is currently or will be operated post change and they are not in conflict with any design parameters. | X | | |
| 7 | Are Engineering Judgments clearly documented and justified? | Ask yourself, would you provide more justification if you were performing this analysis? If yes, the rationale is likely incomplete. | | | X |

| | | | |
|---------------|---|-----------------|------------------------|
| WCNOC | OWNER'S ACCEPTANCE REVIEW CHECKLIST FOR EXTERNAL CALCULATIONS AND SPECIFICATIONS | | PAGE 4 OF 5 |
| | Title: Post Fire Safe Shutdown (PFSSD) Analysis | | |
| | Wolf Creek document #: XX-E-013-004-CN007 | Revision #: N/A | |
| ECDE: Enercon | | | |

| No. | Question | Instructions and Guidance | YES | NO | N/A |
|-----|--|--|-----|----|-----|
| 8 | Are Engineering Judgments compatible with the way the plant is operated and with the licensing basis? | Ensure the justification for the engineering judgment supports the way the plant is currently or will be operated post change and is not in conflict with any design parameters. If the Analysis purpose is to establish a new licensing basis, then this question can be answered yes, if the judgment supports that new basis. | | | X |
| 9 | Do the results and conclusions satisfy the purpose and objective of the Design Analysis? | Why was the analysis being performed? Does the stated purpose match the expectation from WCNOC on the proposed application of the results? If yes, then the analysis meets the needs of the contract. | X | | |
| 10 | Are the results and conclusions compatible with the way the plant is operated and with the licensing basis? | Make sure that the results support the USAR defined system design and operating conditions, or they support a proposed change to those conditions. If the analysis supports a change, are all of the other changing documents included on the cover sheet as impacted documents? | X | | |
| 11 | Have any limitations on the use of the results been identified and transmitted to the appropriate organizations? | Does the analysis support a temporary condition or procedure change? Make sure that any other documents needing to be updated are included and clearly delineated in the design analysis. Make sure that the cover sheet includes the other documents where the results of this analysis provide the input. | | | X |
| 12 | Have margin impacts been identified and documented appropriately for any negative impacts. | Make sure that the impacts to margin are clearly shown within the body of the analysis. If the analysis results in reduced margins ensure that this has been appropriately dispositioned in the EC being used to issue the analysis. | | | X |

| | | | |
|---------------|---|-----------------|------------------------|
| WCNOC | OWNER'S ACCEPTANCE REVIEW CHECKLIST FOR EXTERNAL CALCULATIONS AND SPECIFICATIONS | | PAGE 5 OF 5 |
| | Title: Post Fire Safe Shutdown (PFSSD) Analysis | | |
| | Wolf Creek document #: XX-E-013-004-CN007 | Revision #: N/A | |
| ECDE: Enercon | | | |

| No. | Question | Instructions and Guidance | YES | NO | N/A |
|-----|---|--|-----|----|-----|
| 13 | Does the Design Analysis include the applicable design basis documentation? | Are there sufficient documents included to support the sources of input, and other reference material that is not readily retrievable in WCNOC controlled Documents? | | | X |
| 14 | Have all affected design analyses been documented on the Affected Documents List (ADL) for the associated Configuration Change? | Determine if sufficient searches have been performed to identify any related analyses that need to be revised along with the base analysis. It may be necessary to perform some basic searches to validate this. | | | X |
| 15 | Do the sources of inputs and analysis methodology used meet committed technical and regulatory requirements? | Compare any referenced codes and standards to the current design basis and ensure that any differences are reconciled. If the input sources or analysis methodology are based on an out-of-date methodology or code, additional reconciliation may be required if the site has since committed to a more recent code | | | X |
| 16 | Have vendor supporting technical documents and references (including GE DRFs) been reviewed when necessary? | Based on the risk assessment performed during the pre-job brief for the analysis, ensure that sufficient reviews of any supporting documents not provided with the final analysis are performed. | | | X |
| 17 | If the design includes digital assets, does it adequately address digital and cyber security requirements? | Ensure the design addresses and meets digital and cyber security requirements. Refer to AP 15D-008 and contact the Cyber Security Group to perform additional reviews prior to approval. The CSAT is required to review modifications impacting Cyber Security. | X | | |