

From: Venkataraman, Booma
Sent: Tuesday, June 15, 2021 1:20 PM
To: Sally.Mergen@wisconsin.gov; Pamela.Cook@wisconsin.gov
Cc: Venkataraman, Booma
Subject: Point Beach Nuclear Plant, Units 1 and 2: Issuance of Amendment Re: Technical Specification Changes to Implement New Surveillance Methods for Transient Heat Flux Hot Channel Factor (EPID L-2020-LLA-0170)

Expires: Monday, August 9, 2021 12:00 AM

Hello,
The NRC staff is preparing to issue the following license amendment regarding the Point Beach Nuclear Plant, Units 1 and 2. A brief description of the license amendment request (LAR) is provided below. Additional information can be found in the licensee's submittal dated August 13, 2020, available in ADAMS Accession No. ML20216A243.

Please let me know if you have any comments or questions regarding this licensing action by June 21, 2021.

My current projection for issuance of the amendment is July 5, 2021.

POINT BEACH NUCLEAR PLANT, UNITS 1 and 2 – ISSUANCE OF AMENDMENT NOS. 269 AND 271 RE: TECHNICAL SPECIFICATION CHANGES TO IMPLEMENT NEW SURVEILLANCE METHODS FOR TRANSIENT HEAT FLUX HOT CHANNEL FACTOR (EPID L-2020-LLA-0170)

Brief Description:

The amendments would modify the TSs for Point Beach to implement new surveillance methods for nuclear transient heat flux hot channel factor, F_Q . The new surveillance methods are applicable to plants using either relaxed axial offset control (RAOC) or constant axial offset control (CAOC) surveillance formulations, as described in the NRC-approved topical report WCAP-17661-P-A, "Improved RAOC and CAOC F_Q Surveillance Technical Specifications" (ADAMS Accession No. ML19225C138). The NRC issued a proposed finding that the amendment involves no significant hazards consideration in the Federal Register on September 22, 2020 (85 FR 59562). The NRC has not received any public comments or requests for hearing on this LAR, thus far.

Sincerely, Booma
Booma Venkataraman
Project Manager, NRR/DORL/LPL3
Office of Nuclear Reactor Regulation
Booma.Venkataraman@nrc.gov
[301.415.2934](tel:301.415.2934)

Hearing Identifier: NRR_DRMA
Email Number: 1242

Mail Envelope Properties (BY5PR09MB52816431D19E14D12B67BA6386309)

Subject: Point Beach Nuclear Plant, Units 1 and 2: Issuance of Amendment Re: Technical Specification Changes to Implement New Surveillance Methods for Transient Heat Flux Hot Channel Factor (EPID L-2020-LLA-0170)

Sent Date: 6/15/2021 1:20:10 PM

Received Date: 6/15/2021 1:20:00 PM

From: Venkataraman, Booma

Created By: Booma.Venkataraman@nrc.gov

Recipients:

"Venkataraman, Booma" <Booma.Venkataraman@nrc.gov>

Tracking Status: None

"Sally.Mergen@wisconsin.gov" <Sally.Mergen@wisconsin.gov>

Tracking Status: None

"Pamela.Cook@wisconsin.gov" <Pamela.Cook@wisconsin.gov>

Tracking Status: None

Post Office: BY5PR09MB5281.namprd09.prod.outlook.com

Files	Size	Date & Time
MESSAGE	1707	6/15/2021 1:20:00 PM

Options

Priority: Normal

Return Notification: No

Reply Requested: No

Sensitivity: Normal

Expiration Date: 8/9/2021