

JUL 06 2021

Docket No.: 52-025

ND-20-1190
10 CFR 52.99(c)(1)U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555-0001Southern Nuclear Operating Company
Vogtle Electric Generating Plant Unit 3
ITAAC Closure Notification on Completion of ITAAC 2.2.01.01 [Index Number 90]

Ladies and Gentlemen:

In accordance with 10 CFR 52.99(c)(1), the purpose of this letter is to notify the Nuclear Regulatory Commission (NRC) of the completion of Vogtle Electric Generating Plant (VEGP) Unit 3 Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC) Item 2.2.01.01 [Index Number 90]. This ITAAC verified that the functional arrangement of the Containment System (CNS) and associated systems is as described in the Design Description of Combined License (COL) Appendix C, Section 2.2.1. The closure process for this ITAAC is based on the guidance described in NEI 08-01, "Industry Guideline for the ITAAC Closure Process under 10 CFR Part 52", which is endorsed by the NRC in Regulatory Guide 1.215.

This letter contains no new NRC regulatory commitments. Southern Nuclear Operating Company (SNC) requests NRC staff confirmation of this determination and publication of the required notice in the Federal Register per 10 CFR 52.99.

If there are any questions, please contact Kelli A. Roberts at 706-848-6991.

Respectfully submitted,

Michael J. Yox
Regulatory Affairs Director Vogtle 3 & 4Enclosure: Vogtle Electric Generating Plant (VEGP) Unit 3 Completion of ITAAC 2.2.01.01
[Index Number 90]

MJY/RMS/sfr

To:

Southern Nuclear Operating Company/ Georgia Power Company

Mr. Peter P. Sena III
Mr. D. L. McKinney
Mr. M. D. Meier
Mr. G. Chick
Mr. S. Stimac
Mr. P. Martino
Mr. M. J. Yox
Mr. A. S. Parton
Ms. K. A. Roberts
Mr. C. T. Defnall
Mr. C. E. Morrow
Mr. J. M. Fisher
Mr. R. L. Beilke
Mr. S. Leighty
Ms. A. C. Chamberlain
Mr. J. C. Haswell
Document Services RTYPE: VND.LI.L06
File AR.01.02.06

cc:

Nuclear Regulatory Commission

Ms. M. Bailey
Mr. M. King
Mr. G. Bowman
Ms. A. Veil
Mr. C. P. Patel
Mr. G. J. Khouri
Mr. C. J. Even
Mr. B. J. Kemker
Ms. N. C. Coovert
Mr. C. Welch
Mr. J. Gaslevic
Mr. O. Lopez-Santiago
Mr. G. Armstrong
Mr. M. Webb
Mr. T. Fredette
Mr. C. Santos
Mr. B. Davis
Mr. J. Vasquez
Mr. J. Eargle
Mr. E. Davidson
Mr. T. Fanelli
Ms. K. McCurry
Mr. J. Parent
Mr. B. Griman

Oglethorpe Power Corporation

Mr. R. B. Brinkman
Mr. E. Rasmussen

Municipal Electric Authority of Georgia

Mr. J. E. Fuller
Mr. S. M. Jackson

Dalton Utilities

Mr. T. Bundros

Westinghouse Electric Company, LLC

Dr. L. Oriani
Mr. D. C. Durham
Mr. M. M. Corletti
Mr. Z. S. Harper
Mr. J. L. Coward

Other

Mr. S. W. Kline, *Bechtel Power Corporation*
Ms. L. Matis, *Tetra Tech NUS, Inc.*
Dr. W. R. Jacobs, Jr., Ph.D., *GDS Associates, Inc.*
Mr. S. Roetger, *Georgia Public Service Commission*
Mr. R. L. Trokey, *Georgia Public Service Commission*
Mr. K. C. Greene, *Troutman Sanders*
Mr. S. Blanton, *Balch Bingham*

U.S. Nuclear Regulatory Commission
ND-20-1190 Enclosure
Page 1 of 3

**Southern Nuclear Operating Company
ND-20-1190
Enclosure**

**Vogtle Electric Generating Plant (VEGP) Unit 3
Completion of ITAAC 2.2.01.01 [Index Number 90]**

ITAAC Statement

Design Commitment:

1. The functional arrangement of the CNS and associated systems is as described in the Design Description of this Section 2.2.1.

Inspections, Tests, Analyses:

Inspection of the as-built system will be performed.

Acceptance Criteria:

The as-built CNS conforms with the functional arrangement as described in the Design Description of this Section 2.2.1.

ITAAC Determination Basis

An inspection of the as-built containment system (CNS) and associated systems was conducted after completion of construction to confirm that the functional arrangement of the CNS and associated systems is as described in the Design Description of Combined License (COL) Appendix C, Section 2.2.1. This inspection encompassed the structures, systems, and components (SSCs) identified in the COL Appendix C, Section 2.2.1 Design Description, including those in Table 2.2.1-4 and Figure 2.2.1-1.

The inspection (walkdown) was completed in accordance with ND-RA-001-012, Functional and Physical Arrangement Scoping Process (Reference 1), which required the preparation of a detailed inspection plan. This inspection plan included the use of detailed drawings such as Piping and Instrumentation Drawings (P&IDs) or Single Line Elementary Drawings to perform visual observations and compared the as-built system to the Design Description.

The inspection results were documented in the Unit 3 Principal Closure Document (Reference 2) as well as the Unit 3 ITAAC 2.2.01.01 Completion Package (Reference 3) and verified that the SSCs are physically arranged and located to perform the functions described in the Design Description and referenced table and figure. The inspection results confirmed that the as-built CNS and associated systems conform with the functional arrangement as described in the COL Appendix C, Section 2.2.1, Design Description.

The Unit 3 Principal Closure Document (Reference 2) is available for NRC inspection as well as is the Unit 3 ITAAC 2.2.01.01 Completion Package.

ITAAC Finding Review

In accordance with plant procedures for ITAAC completion, Southern Nuclear Operating Company (SNC) performed a review of all findings pertaining to the subject ITAAC and associated corrective actions. This review found that there are no relevant ITAAC findings associated with this ITAAC. The ITAAC completion review is documented in the ITAAC Completion Package for ITAAC 2.2.01.01 (Reference 3) and is available for NRC review.

ITAAC Completion Statement

Based on the above information, SNC hereby notifies the NRC that ITAAC 2.2.01.01 was performed for VEGP Unit 3 and that the prescribed acceptance criteria were met.

Systems, structures, and components verified as part of this ITAAC are being maintained in their as-designed, ITAAC compliant condition in accordance with approved plant programs and procedures.

References (available for NRC inspection)

1. ND-RA-001-012, Version 6.0, "Functional and Physical Arrangement Scoping Process"
2. SV3-CNS-ITR-800090, Revision 1, "Unit 3 CNS Functional Arrangement Inspection: ITAAC 2.2.01.01 NRC Index Number 90"
3. 2.2.01.01-U3-CP-Rev0, ITAAC Completion Package