

Hoc, HOO X

From: Tracy Bolt <TBolt@ParagonES.com>
Sent: Monday, June 28, 2021 14:59
To: Hoc, HOO X
Subject: [External_Sender] P21-06102021 Notification
Attachments: VC Summer 10CFR part 21 formal notification P21-06102021, R0 6-28-2021.pdf

10CFR Part 21 Notification: P21-06102021, Rev. 0

Ref. P21-06102021-IN, Rev. 0 ([ML21174A009](#))

Subject: Deviation Identified in the Bolting Utilized to Maintain Seismic Qualification

Pursuant to 10CFR 21.21 (b) Paragon Energy Solutions, LLC is providing written notification of the identification of a deviation. On 6/24/2021, Paragon has determined that we do not have the capability to perform the evaluation to determine if the deviation, if left uncorrected, could create a substantial safety hazard. VC Summer has been notified within five working days of this determination so that they can evaluate the deviation or failure to comply, pursuant to § 21.21(a).

Regards,

Tracy Bolt

Chief Nuclear Officer, CNO

(940)468-9151 (C) 817-284-0077 (O) 817-686-1418 (D) | www.ParagonES.com



The information in the subject deviation report is not confidential, you have the authority to strike out the words "is confidential".

Confidentiality Note: The information contained in this message (and attachments) ~~is confidential~~ and may be legally privileged. The message is intended solely for the addressee(s). If you are not the intended recipient, you are hereby notified that any use, dissemination, or reproduction is strictly prohibited and may be unlawful. If you are not the intended recipient please contact the sender by return e-mail and destroy all copies of the original message and attachments.



Date: 6/28/2021

To: Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555
Fax Number (301)816-5151

10CFR Part 21 Notification: P21-06102021, Rev. 0

Ref. P21-06102021-IN, Rev. 0 ([ML21174A009](#))

Subject: Deviation Identified in the Bolting Utilized to Maintain Seismic Qualification

Pursuant to 10CFR 21.21 (b) Paragon Energy Solutions, LLC is providing written notification of the identification of a deviation. On 6/24/2021, Paragon has determined that we do not have the capability to perform the evaluation to determine if the deviation, if left uncorrected, could create a substantial safety hazard. VC Summer has been notified within five working days of this determination so that they can evaluate the deviation or failure to comply, pursuant to § 21.21(a).

Condition that requires evaluation:

NLI 280-ton Custom Chillers, Serial Numbers XHX-0001A / XHX-0001B / XHX-0001C.
The Chillers were originally supplied by NLI to VC Summer station under PO: NU-02SR726683 in 2010.
Ref. P21-06102021-IN, Rev. 0 ([ML21174A009](#))

Name and address of the individual or individuals informing the Commission.

Tracy Bolt, Chief Nuclear Officer
Paragon Energy Solutions, LLC
7410 Pebble Drive
Ft. Worth, TX 76118

Please contact me with any questions or comments.

Sincerely,

Tracy Bolt
Chief Nuclear Officer
Paragon Energy Solutions
817-284-0077
tbolt@paragones.com