

3.7 PLANT SYSTEMS

3.7.8 Auxiliary Saltwater (ASW) System

LCO 3.7.8 Two ASW trains shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|---|--|
| A. One ASW train inoperable. | <p>A.1 -----NOTE----- Enter applicable Conditions and Required Actions of LCO 3.4.6, "RCS Loops - MODE 4," for residual heat removal loops made inoperable by ASW. ----- Restore ASW train to OPERABLE status</p> | <p>-----NOTE----- A Completion Time of 144 hours is applicable for ASW pump 1-1 on a one-time basis, for Unit 1 cycle 23. ----- 72 hours</p> |
| B. Required Action and associated Completion Time of Condition A not met. | <p>B.1 Be in MODE 3. <u>AND</u> B.2 -----NOTE----- LCO 3.0.4.a is not applicable when entering MODE 4. ----- Be in MODE 4.</p> | <p>6 hours 12 hours</p> |